

Bob/CLVIA

Memorandum

RECEIVED
JUN 14 1993

PLS. MAKE SURE **UNOCAL 76**

THIS GETS ON THE COMPUTER DATABASE
ALSO, COPY LUIS ON THIS TO ENSURE
OUR PERMITS REFLECT THE DISPENSER CHANGE.

San Ramon, California
June 9, 1993

BEA

To: E. R. Brown
From: A. L. Quijalvo

RECEIVED
2:25 pm, Apr 21, 2009
Alameda County
Environmental Health

Service Station # 0746
40th / Broadway
Oakland, California
Dispenser replacement

The dispenser replacement project at subject location was started on May 3, 1993, and was completed on May 14, 1993.

The project included the following changes to the facility:

- removal of existing mechanical dispensers.
- installation of four used wayne quads and two used wayne duals.
- installation of a used wayne console.
- installation of a 3M-D20 intercom system.
- installation of a Shure pass thru tray.

R.A. MATSON
JUN 16 1993

Store #:	250746
Report Type Code:	CAP
Description:	CHANGES
Date:	6/9/93

Box 9494

cc: Ken Barton III
Bea Best
Karl Dixon

Service Station # 0746

Address: 40th / BROADWAY, OAKLAND

TANK #	CAPACITY (gal.)	CONTENTS (circle one)								TYPE MONITORING (circle one)					FILL BOX	OVERFILL* PROTECTION		TAGS PROD. CAP.	
		87	89	92	D2	E	O	W	I	A	W	T	U	Y		N	Y	N	Y
TANK 1	12,000	87	89	92	D2	E	O	W	I	A	W	T	U	Y	N	Y	N	Y	N
TANK 2	12,000	87	89	92	D2	E	O	W	I	A	W	T	U	Y	N	Y	N	Y	N
TANK 3		87	89	92	D2	E	O	W	I	A	W	T	U	Y	N	Y	N	Y	N
TANK 4		87	89	92	D2	E	O	W	I	A	W	T	U	Y	N	Y	N	Y	N
TANK 5		87	89	92	D2	E	O	W	I	A	W	T	U	Y	N	Y	N	Y	N
TANK 6		87	89	92	D2	E	O	W	I	A	W	T	U	Y	N	Y	N	Y	N
TANK 7		87	89	92	D2	E	O	W	I	A	W	T	U	Y	N	Y	N	Y	N

Revised: 8/4/92

* High-level alarm or overfill prevention valve

Date of Survey: _____

- E = Empty
- O = Other
- W = Waste-Oil
- I = Inv. Reconcil.
- A = Annular Probe
- W = Vadose/GW Well
- T = Tank Level Mon.
- U = Unknown

COMMENTS (Include observations about the tank slab, permits, tank charts, dealer training/knowledge, etc.):

UST Permit #: _____

Issued by: _____

Issue Date: _____

Exp. Date: _____

ELECTRONIC MONITORING	TANKS	LINES
Monitoring System Brand(s):	_____	_____
Monitoring System Model(s):	_____	_____

site survey conducted by:
A. L. QUIALVO
 JUN 29 1993

Service Station # _____

	CONTENTS (circle one)	LINE TYPE	TYPE MONITORING (circle one)	SECONDARY CONTAINMENT
LINE 1	87 89 92 D2 W E O	P G	L P A U	Y-Pipe Y-Trench N U
LINE 2	87 89 92 D2 W E O	P G	L P A U	Y-Pipe Y-Trench N U
LINE 3	87 89 92 D2 W E O	P G	L P A U	Y-Pipe Y-Trench N U
LINE 4	87 89 92 D2 W E O	P G	L P A U	Y-Pipe Y-Trench N U
LINE 5	87 89 92 D2 W E O	P G	L P A U	Y-Pipe Y-Trench N U
LINE 6	87 89 92 D2 W E O	P G	L P A U	Y-Pipe Y-Trench N U
LINE 7	87 89 92 D2 W E O	P G	L P A U	Y-Pipe Y-Trench N U

Revised: 8/4/92

W = Waste-Oil
E = Empty
O = Other

P = Pressure
G = Gravity

L = Mechanical
Leak Detector
P = Pressure Line
Sensor
A = Annular Probe
U = Unknown

Y = Yes
N = No
U = Unknown

COMMENTS (Include observations about presence or lack of turbine and fill manways, condition of trenches, fuel dispensing problems, etc.):

Service Station # _____

	MAKE	MODEL NO.	NO. OF NOZZLES	PRODUCT (circle which apply)	FACING STREET NAME	WHICH ISLAND?	SHEAR VALVE
DISPENSER 1	WAYNE	DLI-379	4	87 (89) (92) D2 E O	40 th	(I) M O	(S) R
DISPENSER 2	- " -	- " -	4	(87) (89) 92 D2 E O	- " -	(I) M O	(S) R
DISPENSER 3	- " -	- " -	4	(87) (89) 92 D2 E O	- " -	I M (O)	(S) R
DISPENSER 4	- " -	- " -	4	(87) 89 (92) D2 E O	- " -	I M (O)	(S) R
DISPENSER 5	- " -	DLI-377	2	(87) 89 92 D2 E O	- " -	(I) M O	(S) R
DISPENSER 6	- " -	- " -	2	87 89 (92) D2 E O	- " -	(I) M O	(S) R
DISPENSER 7				87 89 92 D2 E O		I M O	S R
DISPENSER 8				87 89 92 D2 E O		I M O	S R
DISPENSER 9				87 89 92 D2 E O		I M O	S R
DISPENSER 10				87 89 92 D2 E O		I M O	S R
DISPENSER 11				87 89 92 D2 E O		I M O	S R
DISPENSER 12				87 89 92 D2 E O		I M O	S R
DISPENSER 13				87 89 92 D2 E O		I M O	S R
DISPENSER 14				87 89 92 D2 E O		I M O	S R
DISPENSER 15				87 89 92 D2 E O		I M O	S R
DISPENSER 16				87 89 92 D2 E O		I M O	S R

Revised: 8/4/92

DISPENSER CODES:

I = Inside Island
M = Middle Island *
O = Outside Island

S = Secure -- OK
R = Repair Necessary (Called into Maintenance Dispatch)

* Note: If only one island, designate as M.

STATION OBSERVATIONS: Is station operating with Phase II VR?: YES NO

If so, which type of Phase II equipment is being used? (circle one):

Balance**Hassleman****Hastech****Healy****Other**

Which type of Phase I equipment is being used? (circle one):

None**Coaxial (single drop)****Two point (dual drop)**

Does number of nozzles present at station correspond exactly to number of nozzles noted on air quality permit to operate for station?:

 YES NO (explain in comments)

COMMENTS (Include observations about the condition of hose retractors, presence of console connections, presence or lack of secondary containment for glycol and solvent drums, etc.):

Air Quality

Permit #:

ATC:

GDF 618

Issued by:

BARDMD

Issue Date: _____

Exp. Date: _____

LUBE-BAY CLARIFIER

Does station possess a clarifier?:

 Yes No

Date of last pump-out: _____

Clarifier condition (circle one):

Clean

Fair

Poor

Sealed



BAY AREA AIR QUALITY MANAGEMENT DISTRICT

ALAMEDA COUNTY
Edward R. Campbell
Loni Hancock
Greg Harper
Frank H. Ogawa

March 15, 1993

CONTRA COSTA COUNTY
Paul L. Cooper
Sunne Wright McPeak
Tom Powers

Unocal 76
Attn: Tony Quijalvo
P.O. Box 5155
San Ramon, CA 94583

MARIN COUNTY
Al Aramburu

NAPA COUNTY
Paul Battisti
(Secretary)

Application Number: 23076
BAAQMD GDF Number: 618
Equipment Location:
Unocal 76
3943 Broadway
Oakland, CA 94611

SAN FRANCISCO COUNTY
Roberta Achtenberg
Harry G. Britt

SAN MATEO COUNTY
Anna Eshoo
(Chairperson)
Janet Fogarty

Dear Mr. Quijalvo:

SANTA CLARA COUNTY
Marge Bruno
Rod Diridon
Joe Head
Dianne McKenna

This is your Authority to Construct the following:

Dispenser Replacement - Dispenser and Nozzle Addition

SOLANO COUNTY
Osby Davis

Resulting in:

Two(2) 12,000 Gallon Gasoline Tank with 20 Gasoline Dispensing Nozzles.

SONOMA COUNTY
Jim Harberson
Patricia Hilligoss
(Vice-Chairperson)

Vapor Recovery Equipment

Phase I Two-Point System, pursuant to California Air Resources Board (CARB) Executive Order(s) G-70-97A.

Phase II Balance System pursuant to CARB Executive Order G-70-49AA using OPW 11VF or equivalent CARB certified nozzles.

Please notify us by letter about three days before you are ready to operate so that we may observe your equipment in operation before we issue a Permit to Operate. This Authority to Construct authorizes operation during the start-up period from the first date of operation until the Permit to Operate is issued, up to a maximum of 60 days. Operation of equipment beyond the start-up period without a Permit to Operate may result in enforcement action.

This Authority to Construct (and the Permit to Operate, when issued, is subject to the following conditions:

- 1. The Phase I equipment shall be installed in accordance with California Air Resources Board (CARB) Executive Order G-70-97A. The nominal inside diameter of the vapor side of the two-point system shall be no less than four(4) inches anywhere between the storage tank and the vapor poppet.**

2. All vapor recovery system components shall be installed in accordance with CARB Executive Order G-70-52-AM and CARB Executive Order G-70-49AA.
3. Vapor Recovery nozzles which contain a built-in vapor check valve may not be used in conjunction with any remote vapor check valve.

Vapor Recovery nozzles which do not contain a built-in check valve must be used in conjunction with a remote vapor check valve.
4. Vapors from the blended product shall be returned via vapor recovery piping to each tank from which the blend stock is drawn. The vapor recovery piping shall be manifolded at the tanks or at the dispenser.
5. Each grade of gasoline shall have separate 2" diameter (minimum) vapor recovery piping and shall slope back to the tank a minimum of 1/8" per linear foot (minimum).
6. Within ten(10) days of start-up, a Leak Test on all new and/or modified nozzle systems shall be performed in accordance with the District's Manual of Procedures Source Test Procedure ST-30. If the tank size is 500 gallons or less, the test shall be performed on an empty tank.
7. Within ten(10) days of start-up a Dynamic Back Pressure Test on all and/or modified nozzle systems shall be performed in accordance with the District's Source Test Procedure ST-27. The test shall be conducted at nitrogen flowrates of 20, 60, and 100 CFH. If a remote vapor check valve is used, the test shall be conducted using Alternate Method II or III.
8. Submit all test results on the District reporting form for the applicable test procedure within twenty(20) days of start-up.
9. Pursuant to BAAQMD Toxic Section policy, this facility's annual throughput shall not exceed 1.3 million gallons in any consecutive 12 month period.

In the absence of specific permit conditions to the contrary, the throughputs, fuel and material consumptions capacities, and hours of operation described in your permit application will be considered maximum allowable limits. A new permit will be required before any increase in these parameters, or change in raw material handled, may be made.

Application No.: 23076
BAAQMD GDF No.: 618
Page -3-

Please include your application number with any correspondence with the District. If you have any questions on this matter, please call Irma C. Salinas of Permit Services at (415)749-5110.

Very truly yours,

Milton Feldstein
Air Pollution Control Officer

by 
Permit Services Division

SAO/ICS/bak

SEND TO: Area Inspector _____

VIA: (1) Jack Bean, Inspection Mgr.
 (2) _____ Supervising Inspector

Readings		
TO	BY	DATE
Supv.		
Copy to Luns, Permits		
File		

EQUIPMENT START - UP FOR PERMIT TO OPERATE Gasoline Dispensing Facility

GDF No. _____ Authority to Construct# _____ Date: _____

Company _____	
Equipment Address _____	
City, Zip _____	
Contact/Title _____	Telephone # () _____
Project Description: _____	
EQUIPMENT DESCRIPTION:- See Attached A/C ()	
Phase I _____	
Phase II _____	

- Please conduct compliance inspection () Phase I () Phase II
- Is the installation complete? () Yes () NO
- Is the installation in accordance with the above A/C description? () Yes () NO
- Was facility operating? () Yes () NO
- Are all components CARB certified? () Yes () NO () N/A
- Please perform back pressure test! ___ Yes ___ NO
- If applicable, is back pressure acceptable? () Yes () NO () N/A
- Distance of submerged fill pipe from bottom of tank:
 ___ inches; ___ inches; ___ inches; ___ inches; ___ inches; ___ inches.

COMMENT _____

Inspection conducted by: _____ I# _____ Date: _____

ATTACH PHASE II VAPOR RECOVERY INSPECTION SHEET
 and return to Luns, Permit Operations, BEFORE _____

SUMMARY OF SOURCE TEST RESULTS

Test Run # _____

Run A: _____

Run B: _____

Run C: _____

SOURCE INFORMATION		FACILITY PARAMETERS
Firm Name and Address	Firm Representative and Title	PHASE II SYSTEM TYPE (Check One) Balance _____ Hirt _____ Red Jacket _____ Hasstech _____ Healy _____ Manifolded?(Y or N) _____
	Phone No.	
Permit Conditions	Source: Vapor Recovery System Plant No. _____ Permit No. <u>23076</u> Operates _____ hr/day & 365 days/yr	

Operating Parameters:

Tank #	Capacity	Gallons Present
1	_____	_____
2	_____	_____
3	_____	_____

Applicable Regulations:	VN Recommended:
-------------------------	-----------------

Source Test Results and Comments:

Tank #:	1	2	3
Product Grade:	_____	_____	_____
Actual Tank Capacity, gallons	_____	_____	_____
Gasoline Volume, gallons	_____	_____	_____
Ullage, gallons	_____	_____	_____
Initial Pressure, inches H ₂ O	_____	_____	_____
Pressure After 1 Minute, inches H ₂ O	_____	_____	_____
Pressure After 2 Minutes, inches H ₂ O	_____	_____	_____
Pressure After 3 Minutes, inches H ₂ O	_____	_____	_____
Pressure After 4 Minutes, inches H ₂ O	_____	_____	_____
Final Pressure After 5 Minutes, inches H ₂ O	_____	_____	_____

NO COMMERCIAL USE OF THESE RESULTS IS AUTHORIZED

Test Conducted by	Test Date	Date of Test
-------------------	-----------	--------------

*Ad File
Ad # 1283.01*

May 10, 1993

Bay Area Air Quality Management District
939 Ellis Street
San Francisco, California 94109

Reference: Unocal Service Station
3943 Broadway
Oakland, California
Application #23076

Gentlemen:

Enclosed please find a copy of the dynamic back pressure and the leak tests performed at the above referenced location, upon completion of the dispenser change.

Please feel free to contact me should you have any questions or comments.

Very truly yours,

Dennis Gan

DG/dc

cc: Tony Quijalvo - Unocal Corporation

SUMMARY OF SOURCE TEST RESULTS

Test Date: AM
 Run A: AM
 Run B: AM
 Run C: _____

SOURCE INFORMATION		FACILITY PARAMETERS
Firm Name and Address <i>Unocal</i> <i>3943 Broadway</i> <i>Oakland</i>	Firm Representative and Title Phone No. Source: <i>Vapor Recovery System</i>	PHASE II SYSTEM TYPE (Check One) Balance <input checked="" type="checkbox"/> Hirt _____ Red Jacket _____ Hasstech _____ Healy _____ Manifolided?(Y or N)
Permit Conditions	Plant No. <i>23076</i> Operates <i>Monday & 365 days/yr</i>	

Operating Parameters:

Tank #	Capacity	Gallons Present
1	<u>12000</u>	<u>1694</u>
2	<u>12000</u>	<u>5494</u>
3		

Applicable Regulations: _____ Vn Recommended: _____

Source Test Results and Comments:

Tank #:	1	2	3	
Product Grade:	<u>92</u>	<u>87</u>		<i>Leak Ra</i> <i>Criteria</i> <i>9.8</i>
Actual Tank Capacity, gallons	<u>12120</u>	<u>12120</u>		
Gasoline Volume, gallons	<u>1694</u>	<u>5494</u>		
Ullage, gallons	<u>10426</u>	<u>6626</u>	<u>= 17052</u>	
Initial Pressure, inches H ₂ O	<u>10.0</u>	<u>10.0</u>		
Pressure After 1 Minute, inches H ₂ O	<u>10.0</u>	<u>10.0</u>		
Pressure After 2 Minutes, inches H ₂ O	<u>10.0</u>	<u>10.0</u>		
Pressure After 3 Minutes, inches H ₂ O	<u>9.9</u>	<u>9.9</u>		
Pressure After 4 Minutes, inches H ₂ O	<u>9.9</u>	<u>9.9</u>		
Final Pressure After 5 Minutes, inches H ₂ O	<u>9.8</u>	<u>9.8</u>		

NO COMMERCIAL USE OF THESE RESULTS IS AUTHORIZED

Test Conducted by <i>L.C. Moore</i>	Test Facility <i>Gettler Ryan Inc.</i>	Date of Test <i>5-7-93</i>
--	---	-------------------------------

SUMMARY OF SOURCE TEST RESULTS

BAAQMD APPLICATION NUMBER

00355

Firm Name and Address

Testing Company Name and Address

UNOCAL
3943 BROADWAY
OAKLAND, CA

GETTLER RYAN INC.
2150 W. WINTON
HAYWARD, CA. 94545

PUMP #	GASOLINE GRADE	NOZZLE MFG. & MODEL NUMBER	DYNAMIC BACK PRESSURE, INS. W.C.			COMMENTS
			20 CFH	60 CFH	100 CFH	
1	87	OPW 11-V mod F22	.04	.20	.42	
1	89	" "	.04	.19	.43	
2	87	OPW-111V	.05	.21	.50	
2	89	OPW 11-V F22	.04	.20	.43	
3	92	" " "	.04	.17	.40	
4	92	" " "	.05	.19	.41	
5	87	OPW 11V-F47	.05	.20	.40	
6	87	OPW 11V-F47	.05	.22	.50	
7	89	" " "	.05	.18	.40	
7	92	" " "	.04	.17	.38	
8	89	" " "	.04	.18	.39	
8	92	" " "	.04	.19	.42	
9	89	OPW 11 VF	.05	.20	.40	
9	87	OPW 11 VF	.03	.19	.41	
10	89	OPW 11 VF	.05	.22	.47	
10	87	OPW 11 VF	.05	.19	.39	
11	87	" " " VF	.07	.21	.41	
11	92	" " " "	.06	.20	.40	
12	87	" " " "	.07	.28	.48	
12	92	" " " "	.07	.22	.41	

Test Conducted By
Scott Mootz

Date
5-7-93

TO: Area Inspector _____

VIA: (1) Jack Bean, Inspection Mgr.

(2) _____ Supervising Inspector

TO	INT	DATE
Supv.		
Copy to LUNA Permits		
File		

EQUIPMENT START - UP FOR PERMIT TO OPERATE Gasoline Dispensing Facility

GDF No. _____ Authority to Construct# _____ Date: _____

Company _____

Equipment Address _____

City, Zip _____

Contact/Title _____ Telephone # () _____

Project Description: Dispenser change - Additional Nozzles 8 -

EQUIPMENT DESCRIPTION: See Attached A/C ()

Phase I _____

Phase II _____

- | | | |
|---|---|--|
| Please conduct compliance inspection | () Phase I | <input checked="" type="checkbox"/> Phase II |
| Is the installation complete? | <input checked="" type="checkbox"/> Yes | () NO |
| Is the installation in accordance with the above A/C description? | <input checked="" type="checkbox"/> Yes | () NO |
| Was facility operating? | () Yes | <input checked="" type="checkbox"/> NO |
| Are all components CARB certified? | <input checked="" type="checkbox"/> Yes | () NO () N/A |
| Please perform back pressure test! | <input checked="" type="checkbox"/> Yes | ___ NO |
| If applicable, is back pressure acceptable? | <input checked="" type="checkbox"/> Yes | () NO () N/A |
| Distance of submerged fill pipe from bottom of tank: | | |
| ___ inches; ___ inches; ___ inches; ___ inches; ___ inches; ___ inches. | | |

COMMENT _____

Inspection conducted by: A.C. Moore 1# _____ Date: 5-7-93

ATTACH PHASE II VAPOR RECOVERY INSPECTION SHEET
and return to LUNA, Permit Operations, BEFORE _____