

October 22, 1996 Project 310-058.5A

Ms. Susan Keach Oro Loma Sanitary District 2600 Grant Avenue San Lorenzo, California 94580

Re: Wastewater Discharge Permit 024 - September 1996 Sewer Report Unocal Service Station 5760
 376 Lewelling Boulevard at Usher Street
 San Lorenzo, California

Dear Ms. Keach:

On behalf of Unocal Corporation, Pacific Environmental Group, Inc. (PACIFIC) is operating a groundwater extraction (GWE) and treatment system at the site referenced above. This letter transmits treatment system operational data for the period from August 31 through September 30, 1996. The GWE system was temporarily deactivated on July 17, 1996 due to operational problems. Operational parameters are summarized in the table below.

Current System St	atus:	Non-Operatio	nal
Reporting Period:		8/31/96 - 9/30/	¹ 96
Period Temperatu	re:	₩A	800
Period pH reading		VA.	
Period Volume Di Total Discharged		gallons	
Average Flow Rate		194,654 gallon N/A	S
Analytical Reports		VA VA	
		vita vita in the second second	

The primary carbon vessel was changed-out on October 13, 1996 and the primary and secondary vessel positions were switched. The GWE system was re-started on October 15, 1996 following pre-soaking of the new carbon, and samples were collected;

results will be presented in next month's report. The GWE system was down throughout September, so no samples were taken.

Operational and analytical data are included in Tables 1 and 2. If you have any questions regarding this project or require further information, please do not hesitate to call.

Sincerely,

Pacific Environmental Group, Inc.

Suzanne McClurkin-Nelson

Staff Scientist

Attachments: Table 1 - Treatment System Metered Volume

Table 2 - Groundwater Treatment System Analytical Data

Ms. Tina Berry, Unocal Corporation

Mr. Richard Hiett, Regional Water Quality Control Board - S.F. Bay Region Leech, Alaraeda Courry Health Care Services

Table 1 Treatment System Metered Volume

Unocal Service Station 5760 376 Lewelling Boulevard at Usher Street San Lorenzo, California

			Flow	Cumulative	Average	Average
		Flow	Meter	System	Total	Total
		Meter	Net	Discharge	System	System
Date		Reading	Volume	To Date	Discharge	Discharge
Sampled		(gallons)	(gallons)	(galions)	(gpm)	(gpd)
10/18/95	а	76	0	0	N/A	N/A
10/30/95		4,040	3,964	3,964	0.2	330
11/30/95		7,751	3,711	7,675	0.1	120
12/27/95		15,031	7,280	14,955	0,2	270
01/22/96		19,350	4,319	19,274	0.1	166
02/13/96		28,980	9,630	28,904	0.3	438
03/11/96	b	82,320	53,340	82,244	1.4	1,976
04/05/96		82,660	340	82,584	0.01	14
05/15/96	¢	132,610	49,950	132,534	0.87	1,249
07/02/96	d	142,690	10,080	142,614	N/A	N/A
07/17/96	e,f	194,730	52,040	194,654	2.4	3,469

gpm = Gallons per minute

gpd = Gallons per day

N/A = Not applicable or not available

- a. GWE continuous system operation began on October 18, 1995.
- b. GWE system found down 3/11/96; carbon chageout performed 3/25/96.
- c. GWE system shut down in May for primary carbon replacement.
- d. System restarted July 2, 1996.
- e. System temporarily shut down to address operational problems.
- f. Carbon changeout to primary on 10/13/96; primary & secondary switched.

Table 2 **Groundwater Treatment System Analytical Data**

Unocal Service Station 5760 376 Lewelling Boulevard at Usher Street San Lorenzo, California

						Permit Compliance Parameters			
				Ethyl-	İ				
Date	TPPH	Benzene	Toluene	benzene	Xylenes	COD	TSS	pН	
Sampled	(µg/L)	(µg/L)	(µg/L)	(µg/L)	(µg/L)	(mg/L)	(mg/L)	(units)	
ıfluent Sampl	es								_
10/30/95	33,000	480	1,400	900	7,100	N/A	N/A	N/A	_
11/30/95	15,000	190	310	210	3,700	N/A	N/A	N/A	
12/27/95	1,100	16	23	<2.0	300	N/A	N/A	N/A	
02/13/96 b	32,000	460	1,100	1,500	7,700	N/A	N/A	N/A	
04/05/96	25,000	280	1,400	900	6,400	N/A	N/A	N/A	
05/15/96	22,000	240	1,200	850	4,700	N/A	N/A	N/A	
07/02/96	22,000	230	1,300	950	4,700	N/A	N/A	N/A	
ffluent Sampl	es								_
10/04/95	<50	<0.50	<0.50	<0.50	<0.50	<20	<1.0	8.89	
10/30/95	<50	<0.50	<0.50	<0.50	<0.50	NS	NS	NS	į
11/30/95	<50	<0.50	<0.50	<0.50	<0.50	NS	NS	NS	,
12/27/95	<50	<0.50	<0.50	<0.50	<0.50	NS	NS	7.05	,
02/13/96 b	<50	<0.50	<0.50	<0.50	<0.50	<20	9,0	6.83	,
04/05/96 c	83	< 0.50	0.80	<0.50	2.0	<20	11	6.83	,
05/15/96 c	<50	1.8	1.6	<0.50	5.8	<20	12	6.86	j
07/02/96 d	<50	<0.50	<0.50	<0.50	<0.50	15	2.0	7.09	

TPPH = Total purgeable petroleum hydrocarbons

COD TS\$

= Chemical oxygen demand = Total suspended solids

μg/L

= Micrograms per liter

mg/L

= Milligrams per liter

N/A

= Not applicable

NS

= Not sampled

- = Denotes any potential concentrations fell below the shown detection limit for the analysis.
- a. The pH reading was measured by field instruments, not by laboratory analysis.
- b. GWE system was found down 1/17/96 and two pumps were pulled for repair and replaced 2/13/96.
- c. Carbon replacement of primary on 3/25/96 (switched to secondary); new primary replaced in May.
- d. System restarted July 2, 1996; de-activated July 17 to schedule carbon replacement to current primary.