

Unocal Service Station 5430 1935 Washington Avenue at Castro Street San Leandro, California

County STID #: 1747 County: Alameda

BACKGROUND

Unocal files suggest that a product line leak occurred in June 1976, and that one of the original underground gasoline storage tanks failed a precision test in October 1981. In December 1981, the two original steel gasoline storage tanks were replaced with two fiberglass gasoline storage tanks. Groundwater Monitoring Wells U-1 through U-3 and Borings U-A through U-E were installed in August 1993. Perimeter Wells U-4 through U-7-were installed in June 1995 to, further delineate the extent of hydrocarbon impacted groundwater. Monthly groundwater monitoring and quarterly groundwater sampling of the wells was initiated in December 1993.

RECENT QUARTER ACTIVITIES

Quarterly groundwater monitoring and sampling were performed in December 1995. Alameda County Health Services submitted a letter requesting additional site assessment to further delineate hydrocarbon impacted groundwater in the southern portion of the site.

NEXT QUARTER ACTIVITIES

First quarter 1996 groundwater monitoring and sampling will be performed. Unocal will submit a site assessment work plan by January 20, 1996. Upon approval of the work plan by Alameda County, site assessment activities will be implemented.

CHARACTERIZATION/REMEDIAL STATUS	
Soil contamination delineated? None encountered.	
Dissolved groundwater delineated? No.	•
Free product delineated? Not applicable.	
Amount of groundwater contaminant recovered this quarter? None	•
Soil remediation in progress? Not Applicable.	
Anticipated start date? Not Applicable.	
Anticipated completion date? Not Applicable.	•
Dissolved/free product remediation in progress? No. 5430 SS	
Anticipated start? Unknown.	
Anticipated completion? Unknown.	3 🚄
CONSULTANT: Pacific Environmental Group, Inc. 2 3 "	·

RECEIVED

3:57 pm, May 27, 2009

Alameda County

Environmental Health