



GETTLER - RYAN INC.

File

SITE SAFETY PLAN, JOB 1155.01

GENERAL INFORMATION:

SITE: Company: Unocal Corporation #5366
 Location: 7573 Amador Valley Blvd/Village Parkway
 City: Dublin, California

PLAN PREPARED BY: Gettler-Ryan Inc. DATE: 2/12/96

OBJECTIVES: To provide a plan for the safe completion of the site work.

PROPOSED DATE OF SITE WORK: Upon receipt of permits

DOCUMENTATION/ SUMMARY: Hazardous material may be present, caution is advised. Site work includes removal of two gasoline underground storage tanks, one waste oil tank and demolition of all site improvements.

SITE/WASTE CHARACTERISTICS:

WASTE TYPE(S):	Liquid	Solid	Gas
CHARACTERISTIC(S):	Volatile	Flammable	Toxic

FACILITY DESCRIPTION: Service station with underground utilities.

STATUS: Closed

HAZARD EVALUATION

PARAMETER: TLV 300 ppm THC
 HEALTH: ingestion, inhalation, absorption
 LEL 10% Gastechtor max.

**SPECIAL PRECAUTIONS
AND COMMENTS:**

Correct safety procedures must be followed, per Gettler-Ryan Inc. Health and Safety Plan. UGST to be inerted per BAAQMD guidelines (Reg.8, Section 30) 30 lbs. of dry ice per 1000 gallon capacity to be placed in each tank prior to removal. Tank LEL and oxygen to be below 10% prior to removal.

SITE SAFETY WORKPLAN

**PERIMETER
ESTABLISHMENT:**

Use barricades to restrict access to tank removal areas. Site is fenced.

PERSONAL PROTECTION:

Level of Protection EPA Level D
Modifications: Rubber gloves
Surveillance Equipment and Material: Gastech

SITE ENTRY PROCEDURES:

None

**DECONTAMINATION
PROCEDURES:**

Personnel: Wash thoroughly with detergent solution and water.

Equipment: Steam clean if necessary

FIRST AID:

As applicable

WORK LIMITATIONS:

(Time of day, weather, heat/cold stress): None

**PROJECT-DERIVED
MATERIAL DISPOSAL:**

Tank lines to be manifested and hauled by Erickson. All materials removed from tank hole to be sampled, placed on visqueen on site and covered until classified for proper disposal. Tank rinsate to be hauled by Erickson. Demolition debris to be recycled as appropriate.

TEAM COMPOSITION:

Barry McCoy- Job Foreman
1 Operator and Crew from Excavator Co.
1 Field Technician from KEI

Verify 40 H+S Training or 8 hr refresher

EMERGENCY INFORMATION

LOCAL RESOURCES:

Ambulance/Hospital
Police/Sheriff/Hwy Patrol
Fire Department

Dial 911
Dial 911
Dial 911

SITE RESOURCES:

Water Supply
Telephone
Visqueen
Fire Extinguisher
First Aid Kit
Sorbant Pads

EMERGENCY CONTACT:

Gettler-Ryan Inc.
G/R Project Manager: Tim Dahl
G/R Safety Manager: Barry McCoy
Unocal Engineer: Frank Pinnell

(510) 551-7555
(510) 551-7555 x217
(510) 551-7555 x253
(510) 277-2327


EMERGENCY ROUTES:

Nearest emergency hospital is:

**VALLEY CARE MEDICAL CENTER
5555 W. Las Positas Boulevard
Pleasanton, CA 94588**

(510) 847-3000

MAP ATTACHED



Route to Hospital:
VALLEY CANYON MEDICAL CTR
555 W. LAS POSITAS BLVD
PLEASANTON
(510) 847-3000

FORCES

TRAINING AREA

FEDERAL
CORRECTIONAL
INSTITUTION

SANTA RITA

REHABILITATION CENTER

(CAMP PARKS)

680

Hospital

680

