

Livermore - Pleasanton



Fire Department

December 19, 2007

Satya Sinha
Chevron Environmental Management Company
6001 Bollinger Canyon Road
San Ramon, CA 94583

Subject: Tank Removal and Soil Sampling, Former Standard Oil Service Station #30-7233, 2259 First Street, Livermore CA

Mr. Satya Sinha,

We have received the Underground Storage Tank Removal and Compliance Sampling Report for the above site, prepared by Conestoga-Rovers and dated August 17, 2007.

On June 20, 2007, two, 750 gallon underground storage tanks, were removed from the sidewalk area in the southwest corner of the Mills Square Park. Samples collected during removal suggested that they could of last contained diesel fuel, used oil, and similar petroleum related materials. Samples collected adjacent to the tanks (previously), below the tanks (during removal activities), and from the tank backfill materials stockpiled on site, confirmed that a release had occurred.

Sample results found petroleum compounds including diesel range organics up to 2,800 mg/kg, Total Oil and Grease up to 11,000 mg/kg. Additionally, concentrations of BETX, oxygenate compounds and metals were found. On July 6, 2007, an Unauthorized Release Form was submitted to LPFD for these tank systems.


Based upon the sampling results from this and previous investigations please continue to work with Alameda County Health Care Services, Environmental Health Division (the lead agency). At this time, LPFD has no comments or requirements.

For additional information related to this case, please contact Mr. Jerry Wickham at:

Alameda County Health Care Services
1131 Harbor Bay Parkway
Alameda, CA 94502
510-567-6700

If you have any questions concerning this letter, please contact me directly at 925-454-2337. Thank you for your cooperation in this matter.

Sincerely,


John Rigter
Hazardous Materials Inspector
Livermore-Pleasanton Fire Department

Cc: Jerry Wickham, Alameda County Health Care Services
Chester Bennett, Chevron Products Company
Chris Davidson, City of Livermore Economic Development

RECEIVED

DEC 24 2007

ENVIRONMENTAL HEALTH SERVICES

3560 Nevada Street, Pleasanton, CA 94566

Administration & Suppression
(925) 454-2361
Fax 249-2397

Fire Prevention Bureau
(925) 454-2361
Fax 454-2367