

BAY Excavators Inc.

6111 PANAMA AVENUE RICHMOND, CALIFORNIA 94804-5799

Alameda County H.C.S.A.
Hazardous Materials Division
80 Swan Way - Room 200
Oakland, California 94621

October 2, 1989
Ref: Underground Tank
J.H. Fitzmaurice
2857 Hanna St.

Attention: Dennis Byrne

SAFETY PLAN FOR TANK REMOVAL

1. Underground alert for pipe location.
2. Pump products from tanks.
3. Inert tank with 15# per 1,000 with dry ice one hour prior to removal (minimum).
4. On site gas detector.
5. One fire extinguisher, rating 20 BC.
6. Cap and plug openings. One plug vented for transporting.
7. Remove vent and suction lines to structure or slab. Cap and plug old lines.
8. Tanks will be hauled as hazardous waste.
9. If site is contaminated, shore for safety and fence site of excavation for further study. "Field condition".
10. Experienced foreman and operators on equipment with 35 years in this type of work.
11. Available respirators.

Sincerely,


George Blair
President

GB:gb