

Sent via "Certified Mail" P1897817401

# UNDERGROUND STORAGE TANK UNAUTHORIZED RELEASE (LEAK) / CONTAMINATION SITE REPORT

<b>EMERGENCY</b> <input type="checkbox"/> YES <input type="checkbox"/> NO		<b>HAS STATE OFFICE OF EMERGENCY SERVICES REPORT BEEN FILED?</b> <input type="checkbox"/> YES <input type="checkbox"/> NO		<b>FOR LOCAL AGENCY USE ONLY</b> I HEREBY CERTIFY THAT I HAVE DISTRIBUTED THIS INFORMATION ACCORDING TO THE DISTRIBUTION SHOWN ON THE INSTRUCTION SHEET ON THE BACK PAGE OF THIS FORM. SIGNED: <i>[Signature]</i> DATE: <i>6/10/93</i>	
<b>REPORT DATE</b> 06/10/93		<b>CASE #</b> N/A			
<b>REPORTED BY</b>	<b>NAME OF INDIVIDUAL FILING REPORT</b> T. Briannon		<b>PHONE</b> (310) 407-2609		<b>SIGNATURE</b> <i>T. Briannon</i>
	<b>REPRESENTING</b> <input checked="" type="checkbox"/> OWNER/OPERATOR <input type="checkbox"/> REGIONAL BOARD <input type="checkbox"/> LOCAL AGENCY <input type="checkbox"/> OTHER		<b>COMPANY OR AGENCY NAME</b> ARCO Product Co.		
	<b>ADDRESS</b> P.O. Box 6038, Artesia, CA 90702-6038				
<b>RESPONSIBLE PARTY</b>	<b>NAME</b> ARCO Products Co.		<b>CONTACT PERSON</b> Courtland Holman		<b>PHONE</b> (310) 407-2610
	<b>ADDRESS</b> P.O. Box 6038, Artesia, CA 90702-6038				
<b>SITE LOCATION</b>	<b>FACILITY NAME (IF APPLICABLE)</b> # 374		<b>OPERATOR</b> John K. Chao		<b>PHONE</b> (510) 658-7508
	<b>ADDRESS</b> 6407 Telegraph Ave., Oakland, Alameda 94609				
	<b>CROSS STREET</b> Alcatraz		<b>CITY</b> Oakland		
<b>IMPLEMENTING AGENCIES</b>	<b>LOCAL AGENCY</b> Alameda Co Public Health		<b>CONTACT PERSON</b> Tim Spates		<b>PHONE</b> (510) 271-4320
	<b>REGIONAL BOARD</b> _____				
<b>SUBSTANCES INVOLVED</b>	(1) <b>NAME</b> no gasoline has entered the soil -				<b>QUANTITY LOST (GALLONS)</b> <input type="checkbox"/> UNKNOWN
	(2) <b>NAME</b> contained in secondary system				<input type="checkbox"/> UNKNOWN
<b>DISCOVERY/ABATEMENT</b>	<b>DATE DISCOVERED</b> 06/09/93		<b>HOW DISCOVERED</b> <input checked="" type="checkbox"/> TANK TEST <input type="checkbox"/> INVENTORY CONTROL <input type="checkbox"/> SUBSURFACE MONITORING <input type="checkbox"/> NUISANCE CONDITIONS		
	<b>DATE DISCHARGE BEGAN</b> 06/09/93		<input type="checkbox"/> TANK REMOVAL <input checked="" type="checkbox"/> OTHER Found gas in annular space		
	<b>HAS DISCHARGE BEEN STOPPED?</b> <input checked="" type="checkbox"/> YES <input type="checkbox"/> NO IF YES, DATE 06/09/93		<b>METHOD USED TO STOP DISCHARGE (CHECK ALL THAT APPLY)</b> <input type="checkbox"/> REMOVE CONTENTS <input type="checkbox"/> CLOSE TANK & REMOVE <input type="checkbox"/> REPAIR PIPING <input type="checkbox"/> REPAIR TANK <input type="checkbox"/> CLOSE TANK & FILL IN PLACE <input type="checkbox"/> CHANGE PROCEDURE <input type="checkbox"/> REPLACE TANK <input checked="" type="checkbox"/> OTHER Disabled space probe		
<b>SOURCE/CAUSE</b>	<b>SOURCE OF DISCHARGE</b> <input type="checkbox"/> TANK LEAK <input checked="" type="checkbox"/> UNKNOWN <input type="checkbox"/> PIPING LEAK <input type="checkbox"/> OTHER		<b>CAUSE(S)</b> <input type="checkbox"/> OVERFILL <input type="checkbox"/> CORROSION <input checked="" type="checkbox"/> RUPTURE/FAILURE <input type="checkbox"/> SPILL <input type="checkbox"/> OTHER		
	<b>CHECK ONE ONLY</b> <input type="checkbox"/> UNDETERMINED <input type="checkbox"/> SOIL ONLY <input type="checkbox"/> GROUNDWATER <input type="checkbox"/> DRINKING WATER - (CHECK ONLY IF WATER WELLS HAVE ACTUALLY BEEN AFFECTED)				
<b>CURRENT STATUS</b>	<b>CHECK ONE ONLY</b> <input checked="" type="checkbox"/> NO ACTION TAKEN <input type="checkbox"/> PRELIMINARY SITE ASSESSMENT WORKPLAN SUBMITTED <input type="checkbox"/> POLLUTION CHARACTERIZATION <input type="checkbox"/> LEAK BEING CONFIRMED <input type="checkbox"/> PRELIMINARY SITE ASSESSMENT UNDERWAY <input type="checkbox"/> POST CLEANUP MONITORING IN PROGRESS <input type="checkbox"/> REMEDIATION PLAN <input type="checkbox"/> CASE CLOSED (CLEANUP COMPLETED OR UNNECESSARY) <input type="checkbox"/> CLEANUP UNDERWAY				
	<b>CHECK APPROPRIATE ACTION(S) (SEE BACK FOR DETAILS)</b> <input type="checkbox"/> CAP SITE (CD) <input type="checkbox"/> EXCAVATE & DISPOSE (ED) <input type="checkbox"/> REMOVE FREE PRODUCT (FP) <input type="checkbox"/> ENHANCED BIO DEGRADATION (IT) <input type="checkbox"/> CONTAINMENT BARRIER (CB) <input type="checkbox"/> EXCAVATE & TREAT (ET) <input type="checkbox"/> PUMP & TREAT GROUNDWATER (GT) <input type="checkbox"/> REPLACE SUPPLY (RS) <input type="checkbox"/> VACUUM EXTRACT (VE) <input checked="" type="checkbox"/> NO ACTION REQUIRED (NA) <input type="checkbox"/> TREATMENT AT HOOKUP (HU) <input type="checkbox"/> VENT SOIL (VS) <input checked="" type="checkbox"/> OTHER (OT) Disabled monitor due to				
<b>REMEDIAL ACTION</b>	product in annular space creating a constant alarm. Monitor to be reactivated after repair.				
	cc. Kyle Chrishe - ARCO				