



RECEIVED

By dehloptoxic at 9:08 am, Sep 08, 2006

Aqua Science Engineers, Inc. 208 West El Pintado, Suite C, Danville, CA 94526
(925) 820-9391 - Fax (925) 837-4853 - www.aquascienceengineers.com

September 7, 2006

Mr. Jerry Wickham
Alameda County Health Care Services Agency
1131 Harbor Bay Parkway, Suite 250
Alameda, CA 94502-6577

SUBJECT: DIESEL LINE TESTING
Oakland Truck Stop
8255 San Leandro Street
Oakland, California

Dear Mr. Wickham:

Attached please find the line testing report for the leak test performed by Afforda-Test on August 31, 2006 at the above-referenced site. No leak was found in any of the lines. Should you have any questions or comments, please call us at (925) 820-9391.

Respectfully submitted,

AQUA SCIENCE ENGINEERS, INC.

A handwritten signature in black ink, appearing to read 'Robert E. Kitay', is written over a faint, larger version of the same signature.

Robert E. Kitay, P.G., R.E.A.
Senior Geologist

cc: Mr. Nissan Saidian

AFFORDA-TEST

416 2nd Street Galt CA 95632
(209) 744-0112 FAX (209) 744-0116

LINE & LEAK DETECTOR TEST REPORT

CONTRACTOR/ENGINEER

TEST DATE 8/31/06

SITE NAME OAKLAND TRUCK STOP


PHONE (510) 569-1624

ADDRESS 8255 SAN LEANDRO ST
OAKLAND, CA

- Repair/Construction
- Compliance
- Insurance
- Escrow

LOCATION SKETCH

Show North



Make & Type of Pump or Dispenser

RED JACK, FE PETRO

Cover Over Lines

CONCRETE, ASPHALT

Approx Burial Depth

4-5 ft

Weather

cold, breezy

Pressure Suction

SHOW STREETS, BLDGS, TANKS, ISLANDS, PIPING (IF KNOWN), PUMPS OR DISPENSERS

LEAK DETECTOR

FTA LEAK DETECTOR TEST INFORMATION

Calibrate
10 PSI

KEY	TYPES	No/Product	LD Key	Serial Number	Resiliency	Opening Time In Seconds	Test Leak Rate ML/Min	I Element Holding PSI	Metering PSI	Pass / Fail
A	LD 2000									
B	LD 2000 E									
C	FXI V									
D	FXI DV									
E	STPMLD									
F	STPMLD - D									
G	STPMLD - E									
H	STPMLD - D/E	Notes:								

CONTRACTOR CERTIFICATION

Technician: Zane A. Nimmo

ZAN

LINE TEST RESULTS

Tests were made on the line systems as noted in accordance with test procedures prescribed for as detailed on the test chart on Side 2 of this form with results as follows:

LINE IDENTIFICATION

NET VOLUME CHANGE PER HOUR

PETROTITE CERT#
CCA0202112304R
OTTL Lic#04-1676

Trainee:

DAVID WINKLER

EQUIPMENT: PETRO TITE LINE TESTER

<u>87 OCT</u>	<u>PASS</u> FAIL / INCONCLUSIVE	<u>±.0000</u>
<u>91 OCT</u>	<u>PASS</u> FAIL / INCONCLUSIVE	<u>-.0035</u>
<u>DIESEL</u>	<u>PASS</u> FAIL / INCONCLUSIVE	<u>-.0030</u>
	PASS / FAIL / INCONCLUSIVE	

