

JUN 25 2001

UNDERGROUND STORAGE TANK UNAUTHORIZED RELEASE (LEAK) / CONTAMINATION SITE REPORT

EMERGENCY YES NO
 HAS STATE OFFICE OF EMERGENCY SERVICES REPORT BEEN FILED? YES NO

FOR LOCAL AGENCY USE ONLY
 I HEREBY CERTIFY THAT I HAVE DISTRIBUTED THIS INFORMATION ACCORDING TO THE DISTRIBUTION SHOWN ON THE INSTRUCTION SHEET ON THE BACK PAGE OF THIS FORM.

REPORT DATE: 11/24/2001
 CASE #:

SIGNED: _____ DATE: _____

REPORTED BY: PRITPAUL S. SAPPAL (SID 799-9271)
 NAME OF INDIVIDUAL FILING REPORT: PRITPAUL S. SAPPAL
 PHONE: (510) 799-9271
 SIGNATURE: _____
 REPRESENTING: OWNER/OPERATOR REGIONAL BOARD LOCAL AGENCY OTHER
 COMPANY OR AGENCY NAME:
 ADDRESS: 272 CORAL DR. RODEO CITY CA 94572

RESPONSIBLE PARTY: PRITPAUL S. SAPPAL (UNKNOWN)
 NAME: PRITPAUL S. SAPPAL
 CONTACT PERSON: PRITPAUL S. SAPPAL
 PHONE: ()
 ADDRESS: 272 CORAL DR. RODEO CITY CA 94572

SITE LOCATION: ALASKA
 FACILITY NAME (IF APPLICABLE): ALASKA
 OPERATOR:
 PHONE: ()
 ADDRESS: 6211 SAN PABLO AVE CHARLTON ALABAMA 36608
 CROSS STREET: 62 St.

IMPLEMENTING AGENCIES: LOCAL AGENCY: _____ AGENCY NAME: _____ CONTACT PERSON: _____ PHONE: ()
 REGIONAL BOARD: _____ PHONE: ()

SUBSTANCES INVOLVED: (1) UNLEADED GASOLINE QUANTITY LOST (GALLONS) UNKNOWN
 (2) _____

DISCOVERY/ABATEMENT: DATE DISCOVERED: 11/01/2001 HOW DISCOVERED: INVENTORY CONTROL SUBSURFACE MONITORING NUISANCE CONDITIONS
 TANK TEST TANK REMOVAL OTHER: Routine Inspection
 DATE DISCHARGE BEGAN: 11/01/2001 UNKNOWN
 METHOD USED TO STOP DISCHARGE (CHECK ALL THAT APPLY):
 REMOVE CONTENTS CLOSE TANK & REMOVE REPAIR PIPING
 REPAIR TANK CLOSE TANK & FILL IN PLACE CHANGE PROCEDURE
 REPLACE TANK OTHER: Replaced gasket
 HAS DISCHARGE BEEN STOPPED? YES NO IF YES, DATE: 11/01/2001

SOURCE/CAUSE: SOURCE OF DISCHARGE: TANK LEAK UNKNOWN PIPING LEAK OTHER
 CAUSE(S): OVERFILL RUPTURE/FAILURE SPILL OTHER: Rubber gasket
 CORROSION UNKNOWN

CASE TYPE: CHECK ONE ONLY: UNDETERMINED SOIL ONLY GROUNDWATER DRINKING WATER (CHECK ONLY IF WATER WELLS HAVE ACTUALLY BEEN AFFECTED)

CURRENT STATUS: CHECK ONE ONLY: NO ACTION TAKEN PRELIMINARY SITE ASSESSMENT WORKPLAN SUBMITTED POLLUTION CHARACTERIZATION
 LEAK BEING CONFIRMED PRELIMINARY SITE ASSESSMENT UNDERWAY POST CLEANUP MONITORING IN PROGRESS
 REMEDIATION PLAN CASE CLOSED (CLEANUP COMPLETED OR UNNECESSARY) CLEANUP UNDERWAY

REMEDIAL ACTION: CHECK APPROPRIATE ACTION(S) (SEE BACK FOR DETAILS): EXCAVATE & DISPOSE (ED) REMOVE FREE PRODUCT (FP) ENHANCED BIO DEGRADATION (IT)
 CAP SITE (CD) EXCAVATE & TREAT (ET) PUMP & TREAT GROUNDWATER (GT) REPLACE SUPPLY (RS)
 CONTAINMENT BARRIER (CB) NO ACTION REQUIRED (NA) TREATMENT AT HOOKUP (HL) VENT SOIL (VS)
 VACUUM EXTRACT (VE) OTHER (OT) See comment

COMMENTS: Tank project engineering has been contacted to investigate and suggest remedial action if required.

Contract #22001 - Mark 1-800-523-8333 HSC 05 (8/94)