

PACIFIC
ENVIRONMENTAL
GROUP, INC.

August 25, 1993
Project 305-79.01

Mr. Robert Cave
Permit Services Division
Bay Area Air Quality Management District
939 Ellis Street
San Francisco, California 94109

93 AUG 27 AM 11:36

Re: BAAQMD Authority to Construct Number 10111
Shell Service Station
285 Hegenberger Road at Leet Drive
Oakland, California
WIC No 204-7620-1502

Dear Mr. Cave:

On behalf of Shell Oil Company, Pacific Environmental Group, Inc. (PACIFIC) is performing environmental services at the referenced site. This letter serves as a written notification of our intent to initiate operation of a soil vapor extraction (SVE) system on Monday, August 30, 1993. The SVE system will utilize internal combustion (A-1) for Precursor Organic Compound abatement. PACIFIC will monitor and sample the influent and effluent vapors for each of the first 3 days of operation, thereafter every 2 weeks, per permit requirements. Results of the first 3 days operations analysis shall be submitted in a report to be received by the Bay Area Air Quality Management District by September 29, 1992.

If you have any question or require addition information, please do not hesitate to call.

Sincerely,

Pacific Environmental Group, Inc.

Mark W. Boyd
Staff Engineer

cc: Mr. Dan Kirk, Shell Oil Company
Mr. Barney Chan, Alameda County Health Care Services Agency




BAY AREA AIR QUALITY MANAGEMENT DISTRICT

February 22, 1993

Pacific Environmental Group, Inc.
2025 Gateway Place, Suite 440
San Jose, CA 95110

Attention: Justin Hawkins

Application Number: 10111
Equipment Location:
285 Hagenberger Road
Oakland, CA 94621



Gentlemen:

This is your Authority to Construct the following:

S-1 Soil Vapor Extraction System consisting of a 250 max cfm positive displacement vacuum blower, and ancillary equipment, abated by A-1, A-2, or A-3 and A-4 arranged in series:

- A-1 VR Systems, Model V4, Internal Combustion Engine**
- A-2 Therm Tech, VAC 25, 250 scfm Catalytic Oxidation Unit**
- A-3 Westates, VSC 1200, 1,000 lb capacity Carbon Adsorption Vessel**
- A-4 Westates, VSC 1200, 1,000 lb capacity Carbon Adsorption Vessel**

SEE ATTACHED CONDITIONS #9018

Notification

Please notify the District by letter at least **three days** before the initial operation of the equipment is to take place so that we may observe the equipment in operation and verify conformance with the Authority to Construct. Operation includes any **start-up** of the source for testing or other purposes. Operation of equipment without prior written notification to the District or beyond the start-up period without a Permit to Operate may result in enforcement action.

Start-Up Period

After receipt of the start-up letter required above, this Authority to Construct authorizes operation during the start-up period from the date of initial operation noted in your start-up letter until the Permit to Operate is issued, up to a maximum of 60 days. **All conditions (specific or implied) of the Authority to Construct are in effect during the start-up period.**

Fees

District Regulation 3 requires a fee for each new Permit to Operate. You will be invoiced upon receipt of your start-up letter. No permits will be issued until all outstanding fees are paid.

Application Number: 10111

Page 2

Implied Conditions

In the absence of specific permit conditions to the contrary, the throughputs, fuel and material consumptions, capacities, and hours of operation described in your permit application will be considered maximum allowable limits. A new permit will be required before any increase in these parameters, or change in raw material handled, may be made.

Expiration

In accordance with Regulation 2-1-407, this Authority to Construct expires two years from the date of issuance unless substantial use of the authority has begun.

Correspondence

Please include your application number with any correspondence with the District regarding this matter. If you have any questions on this matter, please call **Robert E. Cave, Air Quality Engineer Assistant at (415) 749-5114.**

Very truly yours,

Milton Feldstein
Air Pollution Control Officer

by 
Permit Services Division

JAS:REC:me
attachment

COND# 9018 -----

1. Precursor Organic Compound (POC) emissions from Source S-1 shall be abated by either Abatement device A-1, I.C. Engine, or A-2, Catalytic Oxidizer, or A-3 & A-4, two 1,000 pound activated carbon vessels arranged in series, during all periods of operation.
2. The POC destruction efficiency of Abatement devices A-1, A-2, A-3, and A-4 shall be maintained at a minimum of 98.5% by weight for inlet concentrations greater than or equal to 3000 ppmv. For inlet concentrations below 3000 ppmv and greater than or equal to 1000 ppmv, a minimum destruction efficiency of 97% shall be maintained. For inlet concentrations below 1000 ppmv, a minimum destruction efficiency of 90% shall be maintained. The minimum destruction efficiency of 90% shall be waived if total emissions from the operation are less than 1 pound per day VOC and benzene emissions are less than 0.02 pounds per day.

3. A-1 shall be properly maintained and kept in good operating condition at all times. Influent flow shall not exceed 250 scfm. In no event shall benzene emissions to the atmosphere exceed 0.10 pounds per day.
4. To determine compliance with Conditions 2 and 3, the operator of this equipment shall:
 - a. Analyze inlet gas stream to determine the flow rate and concentration of total VOC's present for each of the first three days of operation. Thereafter, the inlet gas shall be analyzed to determine the flow rate and concentration of total VOC's once every two weeks.
 - b. Analyze exhaust gas to determine the concentration of benzene and total VOC's present for each of the first three days of operation. Thereafter, the exhaust gas shall be analyzed to determine the concentration of benzene once every two weeks.
 - c. Calculate the benzene emission rate in pounds per day based on the exhaust gas analysis and the operating exhaust flow rate. The soil vapor flow rate shall be decreased, if necessary, to demonstrate compliance with Conditions 2 and 3.
 - d. Submit to the District the test results and emission calculations for the first three days of operation within one month of start-up. All source test methods used shall be subject to the prior approval of the Source Test Section of the District Technical Division.
5. The operator of this source shall maintain the following information in a District-approved log for each month of operation of A-1:
 - a. days of operation
 - b. inlet and exhaust flow rate
 - c. inlet and exhaust sampling date
 - d. analysis results
 - e. calculated emissions of benzene in pounds per day.Such records shall be retained and made available for inspection by the District for two years following the date the data is recorded.

I.C.E.
System

6. Once influent concentrations fall below 3000 ppmv, the abatement device may be changed from A-1, I.C. Engine to A-2, Catalytic Oxidizer. Such changeover shall take place only after written notification of same has been received by the District. Operation of the source shall then be subject to the conditions which follow.
7. A-2 shall be properly maintained and kept in good operating condition at all times. Influent flow shall not exceed 250 scfm. In no event shall benzene emissions to the atmosphere exceed 0.10 pounds per day. At no time shall the minimum operating temperature of A-2 be less than 600 degrees Fahrenheit.
8. To determine compliance with Condition Number 7, A-2 shall be equipped with continuous measuring and temperature recording instrumentation consisting of at least 1 temperature probe in A-2 and at least one recording device, which will continuously record temperature.
9. The measuring and recording instrumentation to be installed and the specific placement within A-2 in condition number 8, is subject to the prior approval of the Source Test Section of the District Technical Division.
10. The temperature data collected from the temperature recorder shall be maintained in a file which shall be available for District inspection for a period of at least 2 years following the date on which such data are recorded.
11. Within ten days of abatement changeover from A-1 to A-2, the operator of this source, shall conduct an efficiency test to determine the weight percent reduction of Precursor Organic Compound (POC) emissions through A-2. As part of this test, the inlet and outlet exhaust to A-2 shall be analyzed to determine the Total Precursor Organic Compounds (POC's) and Benzene present and their respective concentrations. All test results shall be provided to the District within 30 days after testing has occurred. All source test methods used shall be subject to the prior approval of the Source Test Section of the District Technical Division.
12. The operator of this source shall maintain the following records for each day of operation of A-2:
 - a. Hours and time of operation.
 - b. Each emission test, analysis or monitoring results logged in for the day of operation they were taken.
 - c. Analysis results for any catalyst plugs removed from the bed to determine remaining life of the catalyst.

Such records shall be retained and made available for inspection by the District for two years following the date the data is recorded.

13. Once influent concentrations fall below 1000 ppmv, the abatement device may be changed from A-2, Catalytic Oxidizer to A-3 & A-4, carbon canisters arranged in series. Such changeover shall take place only after written notification of said abatement change has been received by the District. Operation of the source shall then be subject to the conditions which follow.

CAT-OK
system

CARBONS
system

CARBONS
(CONT)

14. The second to last carbon bed, A-3, shall be changed out with unspent carbon upon the detection of 10% of the inlet stream concentration to the carbon bed as measured by a flame-ionization detector (OVA-FID) or other method approved in writing by the APCO.
15. The last carbon bed, A-4 shall be changed out with unspent carbon upon detection of breakthrough or 10 ppmv (measured as C1) as measured with a flame-ionization detector (OVA-FID) or other method approved in writing by the APCO.
16. The limits set forth in Conditions # 14 and # 15 shall apply to non-methane hydrocarbon emissions. To determine the presence of methane in the exhaust stream, a reading shall be taken with and without a carbon filter tip fitted on the OVA-FID probe. Concentrations measured with the carbon filter tip in place shall be considered methane for the purpose of these permit conditions.
17. The operator of this source shall monitor with an OVA-FID or other method approved in writing by the APCO at the following locations:
 - a. At the exhaust of Source S-1; the inlet to carbon bed A-3.
 - b. At the exhaust of A-3; the inlet to carbon bed A-4.
 - c. At the outlet of carbon bed A-4; the carbon bed that is last in series prior to venting to the atmosphere.
18. These monitor readings shall be recorded in a monitoring log at the time they are taken. The monitoring results shall be used to estimate the frequency of carbon change out necessary to maintain compliance with conditions number 14 and 15.
19. To maintain compliance with conditions number 14 and 15, the monitoring shall be conducted on a daily basis. The operator of this source may propose for District review, based on actual measurements taken at the site during operation of the source, that the monitoring schedule be changed based on the decline in organic emissions and/or the demonstrated breakthrough rates of the carbon vessels. Written approval by the District must be received by the applicant prior to a change to the monitoring schedule.
20. The operator of this source shall maintain the following information in a District approved log for each month of operation of A-3, and A-4:
 - a. The hours of operation.
 - b. Each monitor reading or analysis result for the day of operation they are taken.
 - c. The number of carbon beds removed from service. Any exceedance of conditions number 14 and/or 15 shall be reported to the Permits Division with the log as well as the corrective action taken. In addition, an exceedance of conditions number 14 and/or 15 shall be submitted to the District Enforcement Section at the time it occurs. The submittal shall detail the corrective action taken and shall include the data showing the exceedance as well at the time of occurrence.
21. The operator shall maintain a file containing all


measurements, records and other data that are required to be collected pursuant to the various provisions of this conditional Authority to Construct/Permit to Operate. All measurements, records and data required to be maintained by the applicant shall be retained for at least two years following the date the data is recorded.

22. Upon final completion of the remediation project, the operator of Source S-1 shall notify the district within two weeks of decommissioning the operation.


CLOSURE

ATTACHMENT C
APPROVED BUILDING PLANS

FILE COPY



**Interim Remedial System
 Design Plans**
 Shell Service Station
 285 Hegenberger Road at Leet Drive
 Oakland, California
 WIC No 204-5508-5504
 Revision 1



**Interim Remedial System
Design Plans**

**Shell Service Station
285 Hegenberger Road at Leet Drive
Oakland, California
WIC No 204-5508-5504
Revision 1**

Port of Oakland

PLANNING DEPARTMENT
RECEIVED

Prepared for
Shell Oil Company

APR 05 1993

#3480

Port Permits Section

Prepared by

**Pacific Environmental Group, Inc.
2025 Gateway, Suite 440
San Jose, California 95110**

B9301239

Project 305-79.01



**PACIFIC
ENVIRONMENTAL
GROUP, INC.**

**FIRE EXTINGUISHERS AND
EXIT SIGNS AS REQUIRED
BY FIRE MARSHAL.**



FIGURES AND APPENDIX

FIGURES

- Figure 1 Site Location Map
- Figure 2 Site Plan
- Figure 3 SVE System Process Flow Diagram
- Figure 4 Soil Remediation System Compound
- Figure 5 SVE Piping Manifold Assembly
- Figure 6 Trailer Security Anchor Detail
- Figure 7 SVE/Sparge Well Head Plan View
- Figure 8 SVE/Sparge Well Head Profile View
- Figure 9 Common Utility Trench Diagram
- Figure 10 Electrical Single Line Diagram
- Figure 11 Treatment System Enclosure Profile
- Figure 12 System Enclosure Security Anchor Detail

APPENDIX

- Appendix A Manufacturer Specifications
- Appendix B Seismic Calculations

 PACIFIC ENVIRONMENTAL GROUP, INC.	SHELL SERVICE STATION 285 Hegenberger Road at Leet Drive Oakland, California		
	INTERIM REMEDIAL SYSTEM DESIGN PLANS		
	PROJECT: 305-79.01	DATE: 4-5-93	
REVISION	DESCRIPTION	DATE	APPROVED
0	ISSUED FOR PERMITS	3-30-93	
1	REVISION TO INCLUDE SEISMIC BRACING (FIGURES 11, 12 AND APPENDIX B)	4-5-93	

CONSTRUCTION NOTES

1.0 SCOPE

- 1.1 Current project is to install a soil remedial system at the referenced site (APN 42-4425-18-2). The remedial system will consist of the following elements: (1) five soil vapor extraction wells, (2) soil vapor extraction and treatment equipment, and (3) below grade conveyance piping to transport extracted soil vapor to the soil vapor extraction and treatment equipment compound.
- 1.2 Parties involved in this project: (1) Owner - Shell Oil Company, (2) Engineer - Pacific Environmental Group, Inc., and (3) Contractor.

2.0 GENERAL NOTES

- 2.1 All work shall be performed and completed in accordance with all Federal, State, and local building codes.
- 2.2 Engineer shall provide building, and air discharge permits. Contractor shall be responsible for obtaining all other permits.
- 2.3 Contractor shall be responsible for verifying all field dimensions with Engineer before beginning work. Any conflicts with details and notes shall be noted at this time.
- 2.4 Contractor shall arrange and schedule all inspections.
- 2.5 Contractor shall install equipment and appurtenances in accordance with respective manufacturers installation manuals.
- 2.6 Contractor shall submit a Site Safety Plan to Engineer 5 days prior to beginning work. Site Safety Plan shall be in accordance with U.S. Department of Labor, 29 CFR 1910.
- 2.7 New 120/240 volt, 100 amp, single phase, temporary electrical service shall be installed in accordance with Oakland and Pacific Gas and Electric (PG&E) standards and codes. New service shall be to an overhead service periscope attached to the

equipment compound wall. Contractor shall install temporary service in accordance with PG&E's minimum requirements (green book).

2.8 Concrete shall have maximum water:cement ratio (gallons:sack) of 5:1 and shall have a minimum compressive strength of 2,500 psi.


3.0 PIPING

3.1 All PVC pipe shall be solvent welded in accordance with Caltrans Section 20-2.15B(1) except where noted.

3.2 Above ground soil vapor conveyance pipe shall be attached to unistrut (or equivalent) at 6 foot spacing. Use unistrut P1119 pipe clamp (or equivalent). Conveyance pipe shall be strapped loosely to facilitate thermal expansion.

3.3 All utility pipe and conduit routed within treatment area shall be attached to unistrut (or equivalent) at 5 foot spacing.

3.4 Contractor shall paint all above ground utility pipe and conduit machine grey. Contractor shall clearly label pipe with flow direction.



LEET DRIVE

TRUCK STORAGE AREA

SOIL REMEDIATION SYSTEM COMPOUND (SEE DETAIL)

TEMPORARY POWER TO SERVICE PERISCOPE (100A, 240V, SINGLE PHASE)

ACCESS DOORS

STATION BUILDING

WASTE OIL TANK

UNDERGROUND FUEL STORAGE TANKS

SVVVVV

BELOW GRADE COMMON UTILITY TRENCH (SEE DETAIL)

CANOPY

PLANTER

MW-10

MW-1

VEW-5

MW-6

VEW-1

VEW-3

PLANTER

VEW-2

MW-7


PLANTER

MW-9

MW-4

PRODUCT ISLANDS

HEGENBERGER ROAD



LEGEND

- MW-7 GROUNDWATER MONITORING WELL LOCATION AND DESIGNATION
- VEW-1 EXISTING SOIL VAPOR EXTRACTION WELL LOCATION AND DESIGNATION
- VEW-2 PROPOSED SOIL VAPOR EXTRACTION WELL LOCATION AND DESIGNATION
- V-- 2" Sch 40 VAPOR CONVEYANCE PIPING
- S-- 4" Sch 40 SPARE CONDUIT

Actually 20' MIN OR 1" MIN


15' MIN

40' MIN

APPROVED
 CITY OF OAKLAND
 Inspectional Services Dept
 Building Inspection
 (Elec. & Mech. Not Check)
[Signature]




PACIFIC ENVIRONMENTAL GROUP, INC.



SHELL SERVICE STATION
285 Hegenberger Road at Leet Drive
Oakland, California

SITE PLAN

FIGURE: 2
PROJECT: 305-79.01




PACIFIC ENVIRONMENTAL GROUP, INC.

NO SCALE

SHELL SERVICE STATION
285 Hegenberger Road at Leet Drive
Oakland, California

SVE PROCESS FLOW DIAGRAM

FIGURE:
3
PROJECT:
305-79.01




PACIFIC ENVIRONMENTAL GROUP, INC.

SHELL SERVICE STATION
285 Hegenberger Road at Leet Drive
Oakland, California

SOIL REMEDIATION SYSTEM COMPOUND

FIGURE:
4

PROJECT:
305-79.01




PACIFIC
ENVIRONMENTAL
GROUP, INC.

SHELL SERVICE STATION
285 Hegenberger Road at Leet Drive
Oakland, California

SVE PIPING MANIFOLD ASSEMBLY

FIGURE:
5
PROJECT:
305-79.01



MJC

INSPECTED

OFFICE OF CALIFORNIA
 Operational Services Dept.
 Building Inspection
 (Elec. & Mech. Not Check)

NOT TO SCALE




PACIFIC ENVIRONMENTAL GROUP, INC.

SHELL SERVICE STATION
 285 Hegenberger Road at Leet Drive
 Oakland, California

TRAILER SECURITY ANCHOR

FIGURE:
 6
 PROJECT:
 305-79.01



NOT TO SCALE




PACIFIC ENVIRONMENTAL GROUP, INC.

SHELL SERVICE STATION
 285 Hegenberger Road at Leet Drive
 Oakland, California

SVE/SPARGE WELL HEAD PLAN VIEW

FIGURE:
7
 PROJECT:
 305-79.01



NOT TO SCALE




PACIFIC ENVIRONMENTAL GROUP, INC.

SHELL SERVICE STATION
285 Hegenberger Road at Leet Drive
Oakland, California

SVE/SPARGE WELL HEAD PROFILE VIEW

FIGURE:
8
PROJECT:
305-79.01



NOT TO SCALE




PACIFIC ENVIRONMENTAL GROUP, INC.

SHELL SERVICE STATION
285 Hegenberger Road at Leet Drive
Oakland, California

COMMON UTILITY TRENCH PROFILE

FIGURE:
9
PROJECT:
305-79.01



NOT TO SCALE




PACIFIC
ENVIRONMENTAL
GROUP, INC.

SHELL SERVICE STATION
285 Hegenberger Road at Leet Drive
Oakland, California

ELECTRICAL SINGLE LINE DIAGRAM

FIGURE:
10
PROJECT:
305-79.01



APPROVED
 CITY OF OAKLAND
 Inspection Services Dept
 Building Inspection
 (Elec. & Mech. Not Check)
 NHC

NOT TO SCALE




PACIFIC ENVIRONMENTAL GROUP, INC.

SHELL SERVICE STATION
 285 Hegenberger Road at Leet Drive
 Oakland, California

TREATMENT SYSTEM ENCLOSURE PROFILE

FIGURE:
11
 PROJECT:
 305-79.01



APPROVED
 CITY OF OAKLAND
 Inspection Services Dept.
 Building Inspection
 (Elec. & Mech. Not Check)
 MHW

NOT TO SCALE



PACIFIC
 ENVIRONMENTAL
 GROUP, INC.

SHELL SERVICE STATION
 285 Hegenberger Road at Leet Drive
 Oakland, California

SYSTEM ENCLOSURE SECURITY ANCHOR DETAIL

FIGURE:
 12
 PROJECT:
 305-79.01

APPENDIX A

MANUFACTURER SPECIFICATIONS

SPECIFICATIONS FOR K.B/H MMC-5A (100 scfm CatOx System)

CATALYTIC OXIDIZER WITH ELECTRIC PREHEATER

NOMINAL CAPACITY:	100 scfm
DAILY DESTRUCTION RATE of BTEX:	95 lbs
EQUIVALENT CONCENTRATION:	2500 ppm(v)
DIMENSIONS:	82" L x 24" W x 33" H
WEIGHT:	1,200 lbs
PREHEATER:	Electric; 9.0 kW, @ 240V
HEAT EXCHANGER EFFICIENCY:	45-50%
OPERATING TEMPERATURE:	800-950° F (typical)
MAXIMUM TEMPERATURE:	1,050° F
EFFLUENT TEMPERATURE:	450 -550° F (typical)
NMHC DESTRUCTION EFFICIENCY:	95-98%
BENZENE DESTRUCTION EFFICIENCY:	99% minimum
CATALYST VOLUME:	0.256 ft ³
GAS HOURLY SPACE VELOCITY:	23,400 HR ⁻¹

FEATURES:

- VACUUM INDICATOR
- INLET FILTER
- BLOWER DISCHARGE TEMPERATURE INDICATOR
- BLOWER INLET MUFFLER
- PROCESS GAS FLOW SENSOR & INDICATOR
- DILUTION AIR VALVE (MANUAL) with FILTER/MUFFLER
- FLOW CONTROL FROM 100 DOWN TO 30 SCFM USING RECIRCULATION LOOP OF VCU
- PROCESS GAS LOW PRESSURE LIMIT SWITCH
- STAINLESS STEEL HEAT EXCHANGER
- TIC WITH AUTOTUNE FOR CATALYST REACTOR TEMPERATURE CONTROL
- TEMPERATURE INDICATION AT CATALYST ENTRY, INTERSTAGE, AND EXIT
- 3 STAGE CATALYST BED
- AUTOMATIC QUENCH AIR VALVE
- HIGH AND LOW TEMPERATURE SHUTDOWN
- EXHAUST STACK 2" DIAMETER x 84" HIGH

STANDARD VACUUM BLOWER (VCU): SELECTED TO MEET CUSTOMER'S SITE REQUIREMENTS.

A typical package would consist of the following:

TYPE:	Rotary Positive Displacement or Regenerative
BRAND (Typical):	M-D Pneumatics 3206
VACUUM @ G.I.S.T. P.O.C.:	5" Hg @ 100 SCFM
DRIVE MOTOR:	5 hp TEFC, 230V, 1 or 3 phase
DIMENSIONS:	48" L x 25" W x 25" H
INLET MUFFLER	Included
WEIGHT:	450 lbs

OPTIONS:

- TRAILER MOUNTED*, BED SIZE 5' W x 10' L
- EXTRA HIGH EFFICIENCY CATALYST (FOR SPECIAL CASES)
- VAPOR-LIQUID SEPARATOR w/ EXPLOSION PROOF FLOAT SWITCH
- VACUUM RELIEF VALVE
- SOUND ENCLOSURE
- MULTIPOINT RECORDER
- COMMUNICATION PACKAGE, PC or FAX
- AUTOMATIC EXOTHERM CONTROL USING DILUTION AIR VALVE
- EXHAUST EXTENSION, 2.5" DIAMETER PIPE

* The MMC-5A system consists of a catalytic oxidizer (CatOx) and vacuum/compressor unit (VCU). The two major components have their own base supports, suitable for forklift, and can be configured to customer's preferred layout. A trailerized option is also available.



KING, BUCK & ASSOCIATES, INC.

For The Joint Venture King,Buck/Hasstech

*Specializing in the
energy and chemical processing
industries*

**SPECIFICATIONS FOR MMC-5A SERIAL #9020
PURCHASED BY PACIFIC ENVIRONMENTAL GROUP, SANTA CLARA, CA**

CATALYTIC OXIDIZER

NOMINAL CAPACITY:	25% LEL @100 scfm
DIMENSIONS:	82"L x 24"W x 33"H
WEIGHT:	1,200#
PREHEATER:	Electric; 7.5kw, 30A @ 240v
OPERATING TEMPERATURE:	800-950° F
MAXIMUM TEMPERATURE:	1,050° F
EFFLUENT TEMPERATURE:	450° F
DISCHARGE STACK:	2" Diameter, 120" High
TYPICAL DESTRUCTION EFFICIENCY:	95-98%
CATALYST VOLUME:	266 ft ³

BLOWER

TYPE:	Positive Displacement
BRAND:	M-D Pneumatics 3206
DRIVE MOTOR:	1 phase, 7.5hp TEFC (5.6kw, 40A)
DIMENSIONS:	48"L x 25"W x 25"H
WEIGHT:	450#

KING, BUCK/HASSTECH

MultiMode™ Combuster Component List

MMC-5A


VCU (Vacuum Compressor Unit) and Manifold

- Vacuum Compressor: Md Pneumatics, Model 3204 or equivalent**
- Electric drive motor, single- or 3-phase, hp depending on customer preference**
- Compressor inlet filter**
- Compressor discharge temperature indication**
- Dilution air valve**
- Dilution air Muffler/Filter**
- Automatic, programmable quench air valve**
- Recirculation valve (allows VCU discharge flow back to suction)**
- VCU discharge flow sensor**
- Flow indicator**

CatOx-100

- Catalytic Oxidizer, 100 scfm capacity**
- Electric preheater**
- 3-stage catalyst**
- Process flow pressure switch**
- High temperature limit switch**
- Temperature indication at catalyst entry, inner stage, and exit**
- Microprocessor controlled temperature control**

P & I D: MMC-5A




CUSTOMER MATCH LINE

LEGEND

EY	Electrical/shut down signal
TI	Temperature Indication
PI	Pressure Indication
PR	Pressure regulator
SV	Solenoid valve
PE	Pressure shutdown signal
TE	Temperature shutdown signal
VCU	Vacuum Compressor Unit
TIC	Temperature Indicating Controller

*vacuum
inst. diagram*

P & I D: MMC-5A	
KING.BUCK/HASSTECH	
P10021	4-16-90




- VCU: MD Pneumatics, Model 3206 81L3, Serial No. 11007G90
- Electric Drive Motor: Balcor, Catalog No. L3710T
- Dilution Air Filter/Muffler: Soberg, 2"
- VCU Inlet Filter: Soberg, 2" L-type
- Vapor/Liquid Separator: Anderson, Model LCR-200
- FIR: Dwyer DS-200 Flow Sensor + Dwyer Series 600 dP X-mitter + Yokogawa Square Root Extractor and 6-point Strip Chart Recorder
- TI: Taylor dial-type thermometer
- Quench Valve: ASCO, 1", Catalog No. R8215B50
- Equalizing Valve: ASCO, 1/4", Catalog No. 8262C54
- Vent Valve: ASCO, 1/4", Catalog No. 8262C54
- Fill Valve: ASCO, 3/4", Catalog No. 8041C3
- Drain Valve: ASCO, 3/4", Catalog No. 804C3

*See M10011.3 for control schematic

VCU Piping Manifold	
PACIFIC ENVIRONMENTAL GROUP	
KING.BUCK/HASSTECH	
MMC-5A, Serial No. 9020	
1120021	8-7-90

VCU MANIFOLD



① Discharge Silencer Discharge Silencer shipped with VCU for customer installation.

COMPONENTS

VCU: MD Pneumatics, Model 3206-81L3, Serial No. 11185L90 (2500 rpm)

Electric Drive Motor: Baldor Electric, Catalog No. L371OT, 7.5 hp/1Ø

Dilution Air Muffler/Filter: Solberg, 2"

VCU Inlet Filter: Solberg, 2" L-type

Inlet/Discharge Silencer: Burgess Manning, 2"


Flow Indication (FI): Dwyer DS-200 Flow Sensor + Dwyer Series 2000 Magnehelic dP gage

ΔPI: Dwyer Series 2000 Magnehelic dP gage

TI: Taylor, Dial-type Thermometer

VCU Piping Manifold	
PACIFIC ENVIRONMENTAL GROUP, INC.	
KING, BUCK/HASSTECH	
Serial No. 9033	
M20027	12-12-90

MMC-5A CATALYTIC OXIDIZER INTERNAL CONFIGURATION



CatOx Internal Configuration	
PACIFIC ENVIRONMENTAL GROUP	
KING, BUCK/HASSTECH	
MMC-5A, Serial No. 9020	
M40010	4-24-90

APPENDIX B
SEISMIC CALCULATIONS

SUMMARY OF FINDINGS

SHELL SERVICE STATION
285 HEGENBERGER ROAD
OAKLAND, CA.

I. FORCES ACTING ON RED HEAD™ DRAP IN WEDGE ANCHORS


- pg 2 DESIGN BASE SHEAR $V = 2,750$ lbs
- pg 5 STRUCTURAL PERIOD $T = 0.00296$ sec
- SINCE $T \ll 0.7$ sec
- pg 5 CONCENTRATED LOAD $F_c = 0$
AT TOP OF STRUCTURE
- pg 5 DISTRIBUTED LOAD $F_d = 2,750$ lbs
- pg 6 SEISMIC PULLOUT FORCE $F_p = 293$ lbs
PER SUPPORT
- pg 6 WEDGE ANCHOR PULLOUT $F_{wmp} = 4,038$ lbs
FORCE (PER MEG'R)

$$\frac{F_{wmp}}{F_p} = \text{FACTOR OF SAFETY} = 13.7$$

- pg 7 SEISMIC SHEAR FORCE $F_s = 1,375$ lbs
PER SUPPORT

- pg 7 WEDGE ANCHOR SHEAR $F_{was} = 5,175$ lbs
FORCE (PER MEG'R)

$$\frac{F_{was}}{F_s} = \text{SAFETY FACTOR} = 3.7 \Rightarrow \text{USE } \frac{1}{2} \text{ " } \phi \times 3 \frac{3}{4} \text{ " LONG RED HEAD™ DRAP IN WEDGE ANCHORS}$$



II. FORCES ACTING ON CABLE TIE DOWNS

- pg 7 BREAKING STRENGTH $F_{BS} = 2,363$ lbs
(PER MEG'R)

- pg 7 RESULTANT FORCE, EACH CORNER $F_r = 1,406$ lbs

$$\frac{F_{BS}}{F_r} = \text{SAFETY FACTOR} = 1.6 \Rightarrow \text{USE } \frac{1}{4} \text{ " } \phi \text{ STEEL } 1 \times 7 \text{ STRAND WIRE ROPE}$$



PACIFIC ENVIRONMENTAL
GROUP, INC.

1601 Civic Center Drive., Suite 202
Santa Clara, California 95050
(408) 984-6536

PROJECT _____ JOB NO. 305-79-01
PREPARED BY MICKAHEN/BOND DATE 4-2-92
CHECKED BY D. M. DATE 4-2-93
SCALE _____ SHEET 6 OF 16

SUMMARY OF FINDINGS (CONTINUED)

III. CONCRETE FOOTING SIZE REQUIREMENTS

pg 9	CONCRETE LOAD FOR 3'x2'x1' FOOTING	$W_c = 900 \text{ lbs}$
pg 9	PASSIVE LOAD	$P_p = 1,620 \text{ lbs}$
pg 9	FOOTING FRICTION	$F_b = 405 \text{ lbs}$
pg 9	WALL FRICTION	$F_s = 590 \text{ lbs}$
pg 10	OVERTURNING MOMENTS	$M_1 = 293 \text{ lbs}$
pg 10	RESISTING MOMENTS	$M_2 = 6,535 \text{ lbs}$

$$\frac{M_2}{M_1} = \text{SAFETY FACTOR} = 22.3 \Rightarrow \text{USE 3'x2'x1' FOOTING}$$



**PACIFIC ENVIRONMENTAL
GROUP, INC.**

1601 Civic Center Drive., Suite 202
Santa Clara, California 95050
(408) 984-6536

PROJECT _____ JOB NO. 305-79.01
PREPARED BY NICKANEN/ROHD DATE 4-2-93
CHECKED BY A. Man DATE 4-2-93
SCALE _____ SHEET 12 OF 11

EARTHQUAKE DESIGN

- FIND:**
- I. FORCES ACTING ON RED HEAD™ DROP IN WEDGE ANCHORS
 - II. FORCES ACTING ON CABLE TIE DOWNS
 - III. CONCRETE FOOTING SIZE REQUIREMENTS

GIVEN:

TREATMENT SYSTEM ENCLOSURE	→ 5000 lbs
(STEEL SHIPPING CONTAINER 20'x9'x8.5')	
KING-BUCK™ TRAILER MOUNTED CATEOX UNIT	→ 2500 lbs
55 GALLON WATER KNOCKOUT DRUM	→ 460 lbs
	7960 lbs
	W = 8000 lbs


ASSUMPTIONS: NON-BUILDING STRUCTURE - SEC 2338
 55 GALLON DRUM FULL (CONSERVATIVE, IT IS NEVER FULL)

I. FIND FORCES ACTING ON RED HEAD™ DROP IN WEDGE ANCHORS

STATIC FORCE PROCEDURE, EARTHQUAKE DESIGN (UBC-1991-CHAPTER 23)

SEC 2334.6
 BASE SHEAR

$$V = \frac{Z I C W}{R_w}$$



Z = SEISMIC ZONE, CA IS IN ZONE 4
 FIG NO 23-2 pg 194 UBC

$$Z = 0.4$$

I = IMPORTANCE FACTOR, HAZARDOUS FACILITY
 TABLE NO 23-4, pg 186 UBC

$$I = 1.25$$

R_w = NUMERICAL COEFFICIENT, USE ITEM 11
 TABLE NO 23-0, pg 192 UBC

$$R_w = 4$$

C = NUMERICAL COEFFICIENT,
 EQ 34-2, pg 162 UBC

$$C = \frac{1.25 S}{T^{2/3}}$$



PACIFIC ENVIRONMENTAL GROUP, INC.

1601 Civic Center Drive, Suite 202
 Santa Clara, California 95050
 (408) 984-6536

PROJECT _____ JOB NO. 305-79.01
 PREPARED BY MICKANEN/BOM DATE 4-2-93
 CHECKED BY [Signature] DATE 4-2-93
 SCALE _____ SHEET 1 of 10

$$C = 2.75$$

UBC 2334.6.1

"C NEED NOT EXCEED 2.75 AND MAY BE USED FOR MOM STRUCTURE....."

CHECK $\frac{C}{R_w} \geq .5$ (NONBUILDING STRUCTURE, AS OPPOSED TO $\frac{C}{R_w} \geq .075$)

$$\frac{C}{R_w} = \frac{2.75}{4} = .688 \text{ } \checkmark \text{ OKAY UBC 2334.6.1}$$

S = SITE COEFFICIENT FOR SOIL CHARACTERISTICS :
TABLE NO 23-J, PG 184 UBC

$$S = 1.5$$

"SITE GEOLOGY AND SOIL CHARACTERISTICS UNKNOWN, THEREFORE USE S=1.5....."

DESIGN BASE SHEAR :

$$V = \frac{Z I C}{R_w} W = \frac{(0.4)(1.25)(2.75)}{4} (8000 \text{ lbs}) = 2,750 \text{ lbs}$$

$$V = 2,750 \text{ lbs}$$

VERTICAL DISTRIBUTION OF LATERAL SEISMIC FORCE UBC 2334.6

$$V = F_z + \sum F_i \text{ (ONE LEVEL ONLY)}$$

$$V = F_z + F_1$$

WHERE IF $T \leq 0.7 \text{ SEC}$, THEN $F_z = 0$



PACIFIC ENVIRONMENTAL GROUP, INC.

1801 Civic Center Drive, Suite 202
Santa Clara, California 95050
(408) 984-8536

PROJECT _____ JOB NO. 305-79.01
PREPARED BY PAICKANEN/ROAD DATE 4-2-93
CHECKED BY M. M. DATE 4-2-93
SCALE _____ SHEET 2 OF 10

NEED TO FIND T, USE METHOD B, NATURAL PERIOD METHOD

$$f = \text{FREQUENCY} = \frac{1}{T}$$

$$\omega = \text{CIRCULAR FREQUENCY} \rightarrow \omega = \frac{2\pi}{T} \Rightarrow T = \frac{2\pi}{\omega}$$

FOR A SIMPLE MASS ON A SPRING, NATURAL FREQUENCY IS:

$$\omega = \sqrt{\frac{k g_c}{m}}$$

COMBINE

$$T = \frac{2\pi}{\sqrt{\frac{k g_c}{m}}} = 2\pi \sqrt{\frac{m}{k g_c}} \quad \text{WHERE } m = W$$


*

$$T = 2\pi \sqrt{\frac{W}{k g_c}}$$

* SEE SEISMIC DESIGN OF BUILDING STRUCTURES, 5TH ED.,
MICHAEL R. LINDBERG, P.E.

NEED TO FIND K, STIFFNESS COEFFICIENT

ASSUME HOOKE'S LAW APPLIES, BODY EXPERIENCES
PURE BENDING; NEUTRAL AXIS PASSES THRU
CENTROID. (TIMOSHENKO, MECH OF MATLS, 2ND ED, PG 213)



1" THICKNESS

8' = b

(NOTE: FOR SHIPPING CONTAINER, BOX
STRUCTURE OF 10 GAUGE STEEL, A
1" THICKNESS IS ASSUMED FOR
MODELING/SIMPLIFICATION PURPOSES)



PACIFIC ENVIRONMENTAL
GROUP, INC.

1601 Civic Center Drive, Suite 202
Santa Clara, California 95050
(408) 984-6536

PROJECT _____ JOB NO. 305-79.01
PREPARED BY MICKANEN/BOYD DATE 4-2-93
CHECKED BY A. White DATE 4-2-93
SCALE _____ SHEET 3 OF 10

K = STIFFNESS COEFF (CONT.)

$$K = \frac{1}{\left(\frac{x}{\text{TOTAL LOAD}}\right)} = \left(\frac{x}{wL}\right)^{-1}$$

$$x = \frac{5 w L^4}{384 E_s I}$$

(SIMPLE BEAM WITH DISTRIBUTED LOAD)


w = DISTRIBUTED LOAD

E_s = MODULUS OF ELASTICITY FOR STEEL
 28×10^6 psi

$$K = \left(\frac{5 w L^4}{384 E_s I}\right)^{-1} = \left(\frac{5 L^3}{384 E_s I}\right)^{-1} = \frac{384 E_s I}{5 L^3}$$

$$K = \frac{384 E_s I}{5 L^3}$$

NEED TO FIND I, AREA MOMENT OF INERTIA (ASSUMED 1" THICK WALLS)



I_i, b_i, h_i = INSIDE

I_o, b_o, h_o = OUTSIDE

$$b_i = 7.8333 \text{ ft}$$

$$h_i = 8.3333 \text{ ft}$$

$$b_o = 8 \text{ ft}$$

$$h_o = 8.5 \text{ ft}$$

$$I_i = \frac{h_i b_i^3}{12} = \frac{(8.3333)(7.8333)^3}{12} = 334 \text{ ft}^4$$

$$I_o = \frac{h_o b_o^3}{12} = \frac{(8.5)(8)^3}{12} = 363 \text{ ft}^4$$

$$I = I_o - I_i = 363 - 334 = 29 \text{ ft}^4 = I$$



PACIFIC ENVIRONMENTAL
 GROUP, INC.

1601 Civic Center Drive, Suite 202
 Santa Clara, California 95050
 (408) 984-8336

PROJECT _____ JOB NO. 305-79.01
 PREPARED BY MICKANEN/BOAD DATE 4-2-93
 CHECKED BY N. White DATE 4-2-93
 SCALE _____ SHEET 4 OF 10

$$K = \frac{384 E_c I}{5 L^3} = \frac{384 (28 \times 10^6 \frac{\text{lb}}{\text{in}}) (29 \text{ ft}^4)}{5 (20 \text{ ft})^3} \left[\frac{144 \text{ in}^2}{1 \text{ ft}^2} \right]$$

$$K = 1.12 \times 10^9 \frac{\text{lb}}{\text{ft}}$$

SOLVE FOR STRUCTURAL PERIOD:

$$T = 2\pi \sqrt{\frac{W}{K g_c}} = 2\pi \sqrt{\frac{8000 \text{ lb}}{(1.12 \times 10^9 \frac{\text{lb}}{\text{ft}}) (32.2 \frac{\text{ft}}{\text{sec}^2})}}$$

$$T = 0.00296 \text{ sec}$$

$$T = 0.00296 \text{ sec} \ll 0.7 \text{ sec} \text{ so } F_c = 0$$

$$F_c = 0$$


CONCENTRATED LOAD AT TOP OF STRUCTURE

DISTRIBUTED LOAD F_x OVER HEIGHT: $F_x = F_c$ (ONE STORY STRUCTURE)

$$F_1 = \frac{(V - F_c) w_i h_i}{w_i h_i} = V - F_c = V - 0$$

$$F_1 = V = 2,750 \text{ lbs.}$$

$$F_1 = 2,750 \text{ lbs}$$




PACIFIC ENVIRONMENTAL GROUP, INC.

1601 Civic Center Drive., Suite 202
Santa Clara, California 95050
(408) 984-6536

PROJECT _____ JOB NO. 305-74.01
PREPARED BY DICKINSON/BOND DATE 4-2-93
CHECKED BY H. Phib DATE 4-2-93
SCALE _____ SHEET 5 OF 10

FIND REACTIONS AT BASE DUE TO SEISMIC LOAD:



$$\sum M_B = F_1(4.25) - F_{AV}(20) = 0$$

$$F_{AV} = \frac{F_1(4.25)}{20} = \frac{2750(4.25)}{20} = 584.4 = 585 \text{ lbs}$$

$$\downarrow F_V = 0 \quad F_{AV} = F_{BV} = F_{\text{SUPPORT}} = 585 \text{ lbs}$$

∴ TOTAL PULL OUT FORCE DUE TO TWO SUPPORTS ON EACH END (4 TOTAL) USING AXIS OF SYMMETRY

$$F_{\text{PULLOUT}} = \frac{F_{\text{SUPPORT}}}{2} = \frac{585}{2} = 293 \text{ lbs}$$

SEISMIC PULLOUT FORCE PER SUPPORT

COMPARE PULLOUT FORCE DUE TO SEISMIC LOAD TO MANUFACTURER'S SPECIFICATIONS:

1/2" ϕ x 3 3/4" LONG RED HEAD™ DROP IN WEDGE ANCHOR:

ULTIMATE PULLOUT LOAD = 5384 lbs

SAFETY FACTOR (REDUCE BY 25%)

ULTIMATE PULLOUT LOAD SAFETY = 4038 lbs

$$4038 \text{ lbs} >> 293 \text{ lbs} \quad \therefore \text{OKAY}$$




PACIFIC ENVIRONMENTAL GROUP, INC.

1601 Civic Center Drive, Suite 202
Santa Clara, California 95050
(408) 984-6536

PROJECT _____ JOB NO. 305-79.01
 PREPARED BY MICKANEN/RAYD DATE 4-2-93
 CHECKED BY M. White DATE 4-2-93
 SCALE _____ SHEET 6 OF 10

COMPARE SHEAR FORCE DUE TO SEISMIC LOAD TO MANUFACTURER'S SPECIFICATIONS:



$$\leftarrow \sum F_H = F_{AH} + F_{BH} = 2750 \text{ lbs}$$

SYMMETRY $\Rightarrow F_{AH} = F_{BH}$

$$\therefore F_{AH} = F_{BH} = \frac{2750}{2} = 1375 \text{ lbs SEISMIC SHEAR FORCE PER SUPPORT}$$

$\frac{1}{2}$ " ϕ x $3\frac{3}{4}$ " LONG RED HEAD™ DROP IN WEDGE ANCHOR:

ULTIMATE SHEAR FORCE = 6,900

SAFETY FACTOR (REDUCE BY 25%)

ULTIMATE SHEAR FORCE = 5,175 lbs

$$5175 \text{ lbs} \gg 1375 \text{ lbs} \therefore \text{OKAY}$$

II. FIND FORCES ACTING ON CABLE TIE DOWNS

COMPARE TENSILE FORCES IN ANCHORING CABLE TO MANUFACTURER'S SPECIFICATIONS (2500 lb CARBOX UNIT INSIDE STEEL SHIPPING CONTAINER)

(4) $\frac{1}{4}$ " ϕ STEEL 1x7 STRAND WIRE ROPES


BREAKING STRENGTH = 3,150 lbs/each

SAFETY FACTOR (REDUCE BY 25%)

BREAKING STRENGTH = 2363 lbs/each

$$F = \sqrt{(1375)^2 + (293)^2} = 1406 \text{ lbs/each}$$

\therefore SINCE $1406 \text{ lbs} \ll 2363 \text{ lbs} \therefore \text{OKAY}$ SAFETY FACTOR = 2.24




PACIFIC ENVIRONMENTAL GROUP, INC.

1601 Civic Center Drive., Suite 202
Santa Clara, California 95050
(408) 984-6536

PROJECT _____ JOB NO. 305-79-01
PREPARED BY RICK WEN/BOYD DATE 4-2-93
CHECKED BY N. W. H. DATE 4-2-93
SCALE _____ SHEET 7 OF 10

III. CONCRETE FOOTING SIZE REQUIREMENTS

ASSUME FOOTING SIZE = 3' height x 2' width x 1' depth



$P_s =$ SEISMIC PULLOUT FORCE = 293 lbs (FROM PAGE 6)

$V_s =$ SEISMIC SHEAR FORCE = 1375 lbs (FROM PAGE 7)

$P_p =$ PASSIVE LOAD

$F_s =$ WALL FRICTION

$F_b =$ FOOTING FRICTION

$W_c =$ CONCRETE LOAD

ASSUME:

$\gamma_s = 120 \frac{lb}{ft^3}$ DENSITY OF SOIL

$\phi = 30^\circ$ ANGLE OF FRICTION

$\alpha = 0^\circ$ ANGLE BETWEEN BACKFILL SURFACE AND HORIZONTAL

$\gamma_c = 150 \frac{lb}{ft^3}$ DENSITY OF CONCRETE



PACIFIC ENVIRONMENTAL GROUP, INC.

1601 Civic Center Drive., Suite 202
Santa Clara, California 95050
(408) 994-6536

PROJECT _____ JOB NO. 305-79.01
PREPARED BY RICKANEN/ROYD DATE 4-2-93
CHECKED BY N.M.W. DATE 4-2-93
SCALE _____ SHEET 8 of 10

$W_c =$ CONCRETE LOAD:

$$W_c = \gamma_c h w d = (150 \frac{\text{lb}}{\text{ft}^3})(3 \text{ ft})(3 \text{ ft})(1 \text{ ft}) = 900 \text{ lbs}$$

$$W_c = 900 \text{ lbs}$$

$P_p =$ PASSIVE LOAD:

$$P_p = \frac{1}{2} \gamma_s h^2 K_p \cos^2 \alpha = \frac{1}{2} \gamma_s h^2 K_p$$

$$K_p = \frac{1 + \sin \phi}{1 - \sin \phi} = \frac{1 + \sin 30}{1 - \sin 30} = \frac{1.5}{.5} = 3$$

$$P_p = \frac{1}{2} (120 \frac{\text{lb}}{\text{ft}^3})(3 \text{ ft})^2 (3) = 1,620 \text{ lbs/ft}$$

$$P_p = (1,620 \frac{\text{lb}}{\text{ft}})(1 \text{ ft depth}) = 1,620 \text{ lbs}$$

$$P_p = 1,620 \text{ lbs}$$

$F_b =$ FOOTING FRICTION:

$$F_b = \mu R \text{ where } R = W_c \text{ and } \mu = 0.45 \text{ (FRICTION BETWEEN SOIL AND CONCRETE)}$$

$$F_b = (0.45)(900 \text{ lbs}) = 405 \text{ lbs}$$

$$F_b = 405 \text{ lbs}$$

$F_s =$ WALL FRICTION:

$$F_s = P_p \tan \delta \text{ where } \delta = \frac{2}{3} \phi = 20^\circ$$

$$F_s = (1,620 \text{ lbs})(\tan 20^\circ) = 590 \text{ lbs}$$

$$F_s = 590 \text{ lbs}$$



PACIFIC ENVIRONMENTAL GROUP, INC.

1601 Civic Center Drive, Suite 202
Santa Clara, California 95050
(408) 984-6536

PROJECT _____ JOB NO. 305-79.01
PREPARED BY MCKEANEN/BOYD DATE 4-2-93
CHECKED BY A. M. DATE 4-2-93
SCALE _____ SHEET 9 OF 10

MOMENTS ABOUT POINT "C" : (SEE SKETCH, PAGE 8)

LET M_1 = OVERTURNING MOMENTS \curvearrowright

LET M_2 = RESISTING MOMENTS \curvearrowleft

$$\curvearrowright M_1 = \sum fd = P_3 (1ft) = (293 \text{ lbs})(1ft) = 293 \text{ ft-lbs}$$

$$M_1 = 293 \text{ ft-lbs}$$

$$\curvearrowleft M_2 = \sum fd = W_1 (1ft) + F_6 (3ft) + F_5 (2ft) + P (2ft)$$

$$M_2 = 900(1) + 405(3) + 590(2) + 1120(2)$$

$$M_2 = 6535 \text{ ft-lbs}$$

$M_1 < M_2$: OKAY

$$\text{SAFETY FACTOR} = \frac{M_2}{M_1} = \frac{6535}{293} = \underline{\underline{22}} \quad \text{OKAY}$$

USE 3'X2'X1' CONCRETE FOOTING



PACIFIC ENVIRONMENTAL
GROUP, INC.



1601 Civic Center Drive., Suite 202
Santa Clara, California 95050
(408) 984-6536

PROJECT _____ JOB NO. 305-79.01
PREPARED BY MCKANEY/BOH DATE 4-2-93
CHECKED BY D. Whub DATE 4-2-93
SCALE _____ SHEET 10 OF 10

4th Ed.
Soil Engineering
Merlin G. Spencer
Richard L. Hardy

21.2. MOBILIZATION OF ACTIVE AND PASSIVE EARTH PRESSURES

The relationship between active and passive earth pressures can be demonstrated by a simple experiment with a model retaining wall in a box. The wall is hinged at the bottom and held by a spring scale at the top, so that by pulling on the scale the force on the wall may be varied and measured, Fig. 21.1. Dry sand is carefully poured into the space on one side of the wall, and the scale reading noted. The pulling force in the scale is then relaxed, and the force reduced until it finally reaches and holds a minimum value as the wall moves outward. The soil now is in the *active state*, and the force on the spring is indicative of the *active pressure* of soil on the wall. Then the spring is pulled until the force on the wall increases to a maximum value as the soil shears and the wall pushes it forward and upward. The wall movement now has




created a *passive resistance state* in the soil, and the maximum force on the spring is indicative of the *passive pressure* on the soil. This experiment and the results are shown in Fig. 21.1. Note that for either the active or passive states to develop, the wall must move. If the wall does not move, an intermediate stress state exists called *earth pressure at rest*. This pressure condition which develops with zero lateral strain was discussed in connection with consolidation of clays in Section 17.35.

For greatest economy, retaining walls are designed only sufficient strong to resist active pressure. They therefore must be allowed to move and should not be rigidly keyed in to adjacent buildings, and so forth, unless they are designed to resist the higher at-rest pressure. Vertical walls often built with a slight initial tilt or batter toward the soil so that subsequent movement under soil pressure will bring it to a vertical position. Otherwise the wall will develop a top-outward tilt which, while not necessarily dangerous, may give that impression to anybody standing in the shadow of the wall.

21.3. EXAMPLES OF PASSIVE EARTH PRESSURE

It may at first seem unlikely that a wall ever would be built to push into soil and mobilize passive earth pressures. A common example is illustrated in Fig. 21.2. Here the wall has been extended below grade sufficiently so that the active earth pressures developed on the high side of the wall are opposed by the much higher passive earth pressures on the low side, and the wall is stable. Pressures from passive wedges also play an important role in foundation bearing capacity (Fig. 22.11). Passive earth pressures thus are important and are useful. Passive pressures also are developed during earth moving by bulldozers or plows, and retaining wall theory is used in design of such equipment.



conjugate ratio becomes

$$K = \frac{1 - \sin \phi}{1 + \sin \phi} = \tan^2 \left(45^\circ - \frac{\phi}{2} \right) \quad (21.3)$$

in which ϕ is the angle of internal friction of soil.

In this form, K is often called Rankine's ratio of lateral pressure to vertical pressure. Also, it is sometimes called the hydrostatic pressure ratio. Equation 21.3 is derived from Mohr theory later in this chapter.

21.7. WALL FRICTION

According to the Rankine theory, the line of action of the resultant pressure on a retaining wall is parallel to the slope of the backfill surface. This means that the resultant is horizontal when the backfill is level; but it has a vertical component, and is therefore inclined with the horizontal, when the backfill is on a slope. Experimental evidence indicates that a vertical component is present even when the backfill surface is level, because of the tilt of the wall. That is, as shown in Fig. 21.2, tilting away from the active zone increases the available volume on that side so the soil tends to sag downward. This causes a downward shearing force on the wall. On the passive side the soil volume decreases and squeezes the soil upward, causing an upward shearing force. The limiting value of these shearing forces relates to the coefficient of friction between the soil and the wall:

$$V = F \tan \delta \quad (21.4)$$

in which

- V = vertical component of resultant pressure
- F = component of resultant pressure normal to back face of wall
- δ = angle of friction between soil and retaining wall

The angle δ can never be greater than the angle ϕ of internal friction of the soil. In practice δ is frequently assumed to be about two-thirds of ϕ .

It is to be noted that the vertical components of the resultant pressures usually decrease the calculated overturning moment on a retaining wall, as illustrated in Fig. 21.4. The upward rotation of the resultant force R results in a slight reduction of K . More important is the effect on moments, the overturning moment being reduced because F is less than P , and the resisting moment being added to by wall friction.

Example 21.1

In Fig. 21.4 the height of the wall is 6 m (20 ft). The backfill is level and the soil has a unit weight of 15 kN/m³ (90 lb/ft³). The wall is 2 m (6.6 ft) thick at the base and 0.5 m (1.6 ft) thick at the top. The soil surface is horizontal and the soil has a unit weight of 15 kN/m³ (90 lb/ft³). The wall is 2 m (6.6 ft) thick at the base and 0.5 m (1.6 ft) thick at the top.




Figure 21.4 Reduction of overturning moment by wall friction on a retaining wall.

SOLUTION. (a) Without wall friction:

$$P = \frac{1}{2} \gamma H^2 K = \frac{1}{2} (15)(6)^2 \left(\frac{1}{3} \right) = 90 \text{ N/m (6.17 lb/ft)}$$

$$M_A = P \times a = 90 \times 2 = 180 \text{ N} \cdot \text{m/m (40.5 ft} \cdot \text{lb/ft)}$$

(b) With wall friction, let $\delta = 20^\circ$, and estimate K from Equation 21.3.

$$P = \frac{1}{2} \gamma H^2 K = 90 \text{ N/m (6.17 lb/ft)}$$

$$M_A = F \times a - V \times b$$

$$= P \cos \delta \times a - P \sin \delta \times b$$

$$= 90 \cos 20^\circ \times 2 - 90 \sin 20^\circ \times 1$$

$$= 169 - 31 = 138 \text{ N} \cdot \text{m/m (31.1 ft} \cdot \text{lb/ft)}$$

In practice, wall friction is frequently neglected in design as an added factor of safety, or for high walls, the analysis of Coulomb is used.

21.8. PLANE OF FAILURE ACCORDING TO COULOMB THEORY

The Coulomb theory, which was proposed in 1773, is based upon the concept of a plane of failure extending diagonally upward and backward through the earth backfill, as shown in Fig. 21.5. The triangular mass of soil between this plane of failure and the back face of the retaining wall is sometimes referred to as the sliding wedge. It is reasoned that, if the retaining wall suddenly removed, the soil within the sliding wedge would slump downward. Therefore, an analysis of the forces acting on the sliding wedge at incip-

Special Soil Engineering
 Merlin G. Spangler
 Richard L. Handy

TABLE 21.5 Design Values of Unit Weight and Friction Angle for Soil Backfill

Backfill Material	Unit Weight γ kN/m ³ (lb/ft ³)	Internal Friction Angle ϕ (deg)
Soft plastic clay	16-19 (105-120)	0-10
Wet, fine silty sand	17-19 (110-120)	15-30
Dry sand	14-17 (90-110)	25-40
Gravel	19-21 (120-135)	30-40
Loose loam	12-14 (75-90)	30-45
Compact loam	14-16 (90-100)	30-45
Compact clay	14-17 (90-110)	25-45
Cinders	6 (40)	25-45
Compact sand-clay	18-20 (115-125)	40-50
Water	9.81 (62.4)	0

21.21. SUBMERGED BACKFILL VERSUS DRAINAGE

The lateral pressure produced by a saturated submerged soil is equal to the full hydrostatic pressure of the water in the soil pores plus the pressure exerted by the soil solids. The most convenient way to determine the lateral pressure due to a submerged backfill is to compute these two components separately and to add the results together. The hydrostatic pressure can be computed by applying Equation 21.9 and taking γ as 9.81 kN/m (62.4 lb/ft³) and K as 1.0 ($\phi = 0^\circ$). The pressure due to the soil solids also can be computed by applying Equation 21.9 and using the buoyant unit weight of the solid particles and a value of K corresponding to the friction angle ϕ of the soil in the saturated state. *Note that this is not the same as using the saturated unit weight of the soil and applying the same K to the soil and water collectively, which is incorrect and on the unsafe side.* Also, since water can sustain no shearing resistance, water pressure always acts normal to the wall surface, regardless of wall friction and the direction of the resultant soil pressure.

Most retaining walls are not designed to withstand full hydrostatic pressure plus the pressure from submerged soil, and therefore should be provided with adequate drainage facilities to ensure that the backfill soil will not become saturated. Weep holes 100 to 150 mm (4 to 6 in.) in diameter should be placed in the wall at intervals along its length and at the lowest elevation at which free outlet drainage can be maintained. If a vertical layer of crushed rock or coarse gravel about 200 to 300 mm (8 to 12 in.) thick is placed directly behind the wall, the effectiveness of the weep holes will be greatly enhanced. In case the backfill soil is fine-grained material, a graded filter should be placed between the soil and the rock in order to prevent clogging of the drainage system by migration of the soil fines into the coarse

the life of the structure, a longitudinal drain may be placed behind the wall at an elevation a little above that of the footing. A drain near the footing serves no useful purpose. Water collected by the footing drain is carried to outlets at the ends of the wall; or, in the case of a vertical wall, it may be discharged through headers extending through the wall at intervals of 50 to 100 m (150 to 300 ft). Seepage stresses act downward toward the footing and are usually small compared to precision of the analytical

21.22. EXPANSIVE CLAY

Often the fill behind retaining walls is not selected, and therefore sometimes involves expansive clay soils. If an expansive soil is placed behind a wall and the wall dries and later becomes wet and expands, the wall usually moves sufficiently to cause structural damage to the wall and adjacent structures. Since the soil shear strength is no longer acting to hold the soil back from the wall, but instead is pushing against the wall, the pressure condition applies. It therefore is usually impractical to design a wall to resist strain an expanding clay. If expansive clay must be used, a better solution is to ensure that it is fully expanded when it is being backfilled. This can be done by ensuring that the soil is fully expanded when it is being backfilled for saturated conditions and wetting during backfilling. Another method is to stabilize the clay with hydrated lime. Loose backfilling of the soil will not solve the problem, since the entire soil skeleton made up of individual clay clods will expand and exert pressure on the wall.

21.23. METHODS FOR DEVELOPING RESISTING MOMENTS

The several methods for developing resisting moments to resist the overturning of retaining walls are illustrated in Fig. 21.15. In the case of a gravity wall, Fig. 21.15(a), resisting moments are developed by the weight of the wall W times the horizontal distance x between its centroid and the point of overturning A , plus a soil weight W_s times its corresponding horizontal distance. Cantilever walls, Fig. 21.15(b), conserve concrete but require steel reinforcement, the main resisting moment coming from the weight of the wall. Crib or gabion walls are gravity structures which use soil weight to provide resistance. For mass walls, Figs. 21.15(c) and (d).

Floor-braced walls, Fig. 21.15(e), are common for base retaining walls. They usually give problems, particularly if backfilling is done before the wall is in place. Steel reinforcement is needed in the wall to prevent the wall from acting as a simple beam.

Although braced excavations, Figs. 21.15(f) and (g), are used for temporary support during construction, a much "cleaner" method is to use tiebacks which may be left in place to support the permanent structure, Figs. 21.15(h) and (i). The tiebacks are installed downward at about 45° to avoid encountering buried utilities

Riemann
Concrete
Design
Chu - kia Wang
Charles G. Salmon.




Figure 12.3.1 Forces on retaining wall.

where μ is the coefficient of friction between the soil and the footing. Table 12.3.1 gives the coefficients of friction as recommended by the 1958 AREA specification [4] and these may serve as a guide to typical values in lieu of more accurate ones.

Table 12.3.1 VALUES OF COEFFICIENT OF FRICTION BETWEEN SOIL AND CONCRETE, 1958 AREA SPECIFICATIONS

SOIL	μ
Coarse-grained soils (without silt)	0.55
Coarse-grained soils (with silt)	0.45
Silt	0.35
Sound rock (with rough surface)	0.60

The inclusion of some passive resistance P_p on the toe of the footing may or may not be justified. Certainly, to actually develop passive pressure in the soil in front of the wall, the concrete must have been placed with using forms for the toe and without disturbing the soil against which the concrete is placed.

Referring to Fig. 12.3.2, the ordinary passive resistance against the soil is

$$P_{p1} = \frac{1}{2} C_p w h^2 \quad (12.1)$$

... If when all reliable resistances have been included, the safety remains inadequate, a base key (Fig. 12.3.2) may be used. The base key, when placed in an unformed excavation against unconsolidated material, may be expected to develop an additional passive force against the possible failure plane from line 1 to line 2.




Figure 12.3.2 Passive resistance and effect of base key.

The base key develops the additional resistance

$$P_{p2} = \frac{1}{2} C_p w (h_2^2 - h_1^2)$$

... and also, an inert region, $bced$ of Fig. 12.3.2, is created which is a failure plane from bd to ce . Thus the frictional force developed against the failure plane is based on the angle α , the angle of internal friction of the soil, rather than the friction angle between soil and concrete. Normally, $\tan \alpha < \tan \phi$ for granular material, so that, by making the base key sufficiently deep to form an inert block, additional frictional resistance is developed.

Finally, the magnitude and distribution of the soil pressure must be considered. Usual practice is to require the resultant vertical force to be located inside the middle third of the footing for sand and gravel subbase and inside the middle half for rock subbase. In addition, the maximum soil pressure must not exceed the allowable value. Comments regarding allowable soil pressure as well as some typical safe bearing values are to be found in Chap. 20.

Referring to Fig. 12.3.3(a), when the entire footing is under uniform soil pressure, the basic equation for combined bending and axial compression in a 1-ft strip along the wall is

$$p = \frac{R}{L} \pm \frac{Re(L/2)}{L^3/12} = \frac{R}{L} \left(1 \pm \frac{6e}{L} \right)$$

... the limiting condition of zero stress at the heel, $e = L/6$, and Eq. (12.2) is valid for all positions of R within the middle third.

When the resultant R is outside the middle third [Fig. 12.3.3(b)], force equilibrium requires

$$R = \frac{1}{2} p_1 (3x_2)$$

4th Ed
Soil Engineering
Spangler & Handy




Figure 22.10 Mohr circles showing stress conditions in a $\phi = 0$ soil at failure—I: under a foundation; II: adjacent soil at the same level (see Fig. 22.9)

the minor principal stress for the square I in Fig. 22.9, and the major principal stress at failure becomes $q_0 = D\gamma + 4c$. Subtracting surcharge, the bearing capacity is therefore

$$q_0 = 4c = 2q_u \quad (22.10)$$

where q_0 is the bearing capacity and q_u is the unconfined compressive strength. This equation also is conservative for the same reasons as Equation 22.9, but supports the common use of unconfined compressive strength for bearing capacity of small structures on clay, the nominal factor of safety being 2.

A similar approach, subject to the same criticisms, may be used for soil with both cohesion and internal friction. These and other analytic methods are reviewed in a historic context by Jumikis (5).

22.10. TWO-DIMENSIONAL ANALYTICAL METHODS BASED ON OBSERVED SHEAR PLANES

Although the assumed geometry of shear in Fig. 22.9 somewhat resembles the observed failure in Fig. 22.2(b), there are some major discrepancies, and the Rankine or principal stress solutions therefore would not be realistic even if boundary friction were included. Where a potential bearing capacity failure involves shearing, the problem may be analyzed by using trial surfaces and one of the methods suggested for analysis of slope stability, such as the method of slices. However, this is laborious and not precise because

assumptions made in that analysis, although the method of slices is preferred over other methods for nonhomogeneous soil conditions.

One of the major contributions of Terzaghi was to adapt a theoretical solution by Prandtl to bearing capacity problems in soils. Prandtl was concerned with resistance of metal to a punch. He assumed zero friction between the metal and the punch, and that the metal is weightless. Terzaghi assumed essentially the same failure geometry, but added the effects of bearing friction and surcharge soil weight. An essential element of the Prandtl system is a central wedge of soil under the foundation, which moves vertically as the foundation settles and thus pushes the adjacent soil aside. Such wedges have been observed in model studies (see Fig. 22.2c), and are known to form during driving of pile, explaining why flat-ended pile drive about as easily as cone-ended ones.

The shape of the basal soil wedge has a considerable influence in the analysis, and is a subject for conjecture. Prandtl's wedge, Fig. 22.11(a), was drawn with a downward base angle $\psi = 45 + \phi/2$. This is consistent with a frictionless base, since the major principal stress then must be vertical, and the angle of shear lines with the major principal stress direction is $45 + \phi/2$. Terzaghi (15) proposed that since soil under load tends to bulge laterally due to Poisson's ratio, an inwardly directed horizontal friction should develop at the foundation base, Fig. 22.11(b). As a limiting case the wedge base angle ψ should equal ϕ . Meyerhof let the base angle vary, and found that the most critical condition should be reached when ψ is about 1.2ϕ (9), assuming that the base friction is mobilized. Other workers have questioned whether such flat wedges do occur, the steeper Prandtl geometry being apparent in scale models.


22.10.1. Bearing Capacity Equation. The format for bearing capacity equations is in terms of dimensionless bearing capacity factors designated N_γ , N_c , and N_q .

$$q_0 = \frac{\gamma B}{2} N_\gamma + c N_c + \gamma D N_q \quad (22.11)$$


width + cohesion + surcharge

where q_0 is the bearing capacity in force per unit area, γ is the soil unit weight, B the width of the foundation, c the soil cohesion, and D the depth of the foundation. All three "N" bearing capacity factors are functions of the internal friction angle ϕ and the assumed shape of the failure zone. A useful advantage of this equation is that it allows one to see separately the effects of foundation width, soil cohesion, and surcharge.


The bearing capacity factors depend only on the soil friction angle ϕ , and on the assumed geometry. The equations for N_c and N_q , Table 22.3, are analytical and exact and may be programmed, while the equations for N_γ are derived by curve-fitting to values determined by trial. Generally the Terzaghi factors are the most conservative, but have been shown to be accurate for cohesive soils (1). Factors based on both the Terzaghi and Prandtl geometries are presented in Table 22.3. Analogous factors were developed by



(a)



(b)



(c)

11 Idealized bearing capacity failure geometries drawn for $\phi = 20^\circ$. (a) with base angle $\psi = 45 + \phi/2$; (b) Terzaghi with rough base, $\psi = \phi$; (c) of with rough base, ψ varied for minimum bearing value.

on the basis of the geometry of Fig. 22.11(c), with shearing resistance the surcharge. While logical, the Meyerhof factors tend to be on side for larger embedment depths, probably because the shearing of the surcharge may not be mobilized. That is, any compression close to the foundation will tend to allow progressive failure. the

TABLE 22.3 Bearing Capacity Factors for Long Foundations*

ϕ	Terzaghi Rough Base			Prandtl-Reisner Smooth Base			$N_{\gamma, \sigma}$ (Eq. 22.12)
	N_{γ}^b	N_c^c	N_q^d	N_{γ}^e	N_c^f	N_q^g	
0	0.0	5.7	1.0	0.0	5.1	1.0	—
5	0.5	7.3	1.6	0.5	6.5	1.6	—
10	1.2	9.6	2.7	1.2	8.3	2.5	1.9 ± 0.8
15	2.5	13	4.4	2.6	11	3.9	3.4 ± 0.9
20	5.0	18	7.4	5.4	15	6.4	6.0 ± 1.1
25	9.7	25	13	11	21	11	11 ± 1
30	20	37	22	22	30	18	20 ± 2
35	42	58	41	48	46	33	41 ± 6
40	100	96	81	110	75	64	89 ± 20
45	300	170	170	270	130	130	—
LOCAL SHEAR							
0	0.0	5.7	1.0	0.0	5.1	1.0	—
5	0.3	6.7	1.4	0.3	6.0	1.3	—
10	0.7	8.0	1.9	0.7	7.0	1.8	1.3 ± 0.7
15	1.2	9.6	2.7	1.2	8.3	2.5	1.9 ± 0.8
20	2.0	12	3.8	2.1	10	3.4	2.8 ± 0.9
25	3.2	14	5.3	3.4	12	4.6	4.1 ± 1.0
30	5.0	18	7.4	5.4	15	6.4	6.0 ± 1.1

* $q_0 = \frac{\gamma B}{2} N_{\gamma} + c N_c + \gamma D N_q$.

^b After Bowles (1). Approximate equation fit by the authors: $N_{\gamma} = 1.1(N_q - 1) \tan 1.3\phi$.

^c $N_c = (N_q - 1) \cot \phi$ (exactly).

^d $N_q = \frac{c \tan \phi}{2 \cos^2 (45 + \phi/2)}$ (exactly).

^e Equation fit by Vesic (17): $N_{\gamma} = 2(N_q + 1) \tan \phi$.

^f $N_c = c \cot \phi \tan^2 (45 + \phi/2)$ (exactly).

^g $N_{\gamma, \sigma} = \frac{1}{2}(N_{\gamma} + N_q) \pm \text{standard deviation}$.

surpassed before the rest of the shear is mobilized. This has been verified by experiments by Vesic.

Example 22.3


A clay soil has $\phi = 10^\circ$, $c = 19.2 \text{ kPa}$ (400 lb/ft²), and $\gamma = 15.7 \text{ kN/m}^3$ (100 lb/ft³). Evaluate the relative influences of footing width and depth on total supporting capacity of a footing 1.22 m (4 ft) wide and 1.52 m (5 ft) deep.

SOLUTION. From Table 22.3 for a rough footing $N_{\gamma} = 1.2$, $N_c = 9.6$, and $N_q = 2.7$. Therefore according to Equation 22.11,

$$q_0 = \frac{15.7(1.22)}{2} (1.2) + (19.2)(9.6) + 15.7(1.52)(2.7) = 11.5 + 184 + 64.4 \text{ kPa} = 260 \text{ kPa} (5430 \text{ lb/ft}^2)$$

WEDGE AND MULTI-SET™ ANCHORS

HAND TOOLS



WEDGE ANCHORS

Zinc-plated carbon steel wedge anchors are available in anchor sizes 1/4" to 5/8" and hole diameters 3/8" to 1 1/2". Meet or exceed U.S. Government G.S.A. Specifications FF-S-325 Group II, Type 4, Class I. For fastening electrical, heating, ventilating, air conditioning, and plumbing systems to concrete, tilt-up construction, pipe hanging, in-plant machinery mountings, and storage racks. ITW Rammed/Red Head brand.

- Anchor size equals hole size
- One-piece wraparound stainless steel expander clip resists corrosion
- Provides 360° contact with concrete
- Comes complete with nuts and washers

Anchor Size	Drill Bit Size	Overall Length	Min. Thickness of Material to be Fastened	Thread Length	Min. Embedment in Concrete	Ultimate Pullout Lbs.	Ultimate Shear Lbs.	Red Head Model	Stock No.	List	Each Box	Anchor per Box	Ship. Wt.
1/4"	3/8"	1 1/2"	3/8"	3/4"	1 1/4"	1550	1225	WS-1416	3A442	\$33.11	100	100	2.2
	3/8"	2 1/4"	3/8"	3/4"	1 1/4"	2500	1910	WS-1422	3A443	40.82	50	50	2.9
	3/8"	3 1/4"	3/8"	3/4"	1 1/4"	3051	1891	WS-1433	3A444	48.12	33	33	3.5
3/8"	1/2"	1 1/2"	1/2"	1 1/4"	1 1/4"	2119	1625	WS-3822T	3A445	24.25	100	100	2.5
	1/2"	2 1/4"	1/2"	1 1/4"	1 1/4"	3675	2805	WS-3826T	3A446	33.85	50	50	3.1
	1/2"	3 1/4"	1/2"	1 1/4"	1 1/4"	4875	3805	WS-3830T	3A447	42.08	33	33	3.8
1/2"	5/8"	1 1/2"	1/2"	1 1/4"	1 1/4"	2319	1825	WS-3834T	3A448	26.10	100	100	2.8
	5/8"	2 1/4"	1/2"	1 1/4"	1 1/4"	3875	2905	WS-3838T	3A449	34.68	50	50	3.2
	5/8"	3 1/4"	1/2"	1 1/4"	1 1/4"	5075	3905	WS-3842T	3A450	43.20	33	33	3.6
3/4"	1"	1 1/2"	3/4"	1 1/4"	1 1/4"	3394	2600	WS-1230T	3A451	21.02	100	100	2.6
	1"	2 1/4"	3/4"	1 1/4"	1 1/4"	5233	4000	WS-1234T	3A452	27.32	50	50	3.0
	1"	3 1/4"	3/4"	1 1/4"	1 1/4"	7233	5449	WS-1238T	3A453	35.43	33	33	3.4
1"	1 1/8"	1 1/2"	3/4"	1 1/4"	1 1/4"	4000	3070	WS-1242T	3A454	24.21	100	100	2.7
	1 1/8"	2 1/4"	3/4"	1 1/4"	1 1/4"	6000	4500	WS-1246T	3A455	32.51	50	50	3.1
	1 1/8"	3 1/4"	3/4"	1 1/4"	1 1/4"	8000	5900	WS-1250T	3A456	40.81	33	33	3.5
1 1/8"	1 3/8"	1 1/2"	3/4"	1 1/4"	1 1/4"	5000	3770	WS-0834T	3A457	17.93	100	100	2.4
	1 3/8"	2 1/4"	3/4"	1 1/4"	1 1/4"	7500	5570	WS-0838T	3A458	23.31	50	50	2.8
	1 3/8"	3 1/4"	3/4"	1 1/4"	1 1/4"	10000	7449	WS-0842T	3A459	31.43	33	33	3.2
1 3/8"	1 3/8"	1 1/2"	3/4"	1 1/4"	1 1/4"	6000	4500	WS-0846T	3A460	24.21	100	100	2.7
	1 3/8"	2 1/4"	3/4"	1 1/4"	1 1/4"	9000	6750	WS-0850T	3A461	32.51	50	50	3.1
	1 3/8"	3 1/4"	3/4"	1 1/4"	1 1/4"	12000	8900	WS-0854T	3A462	40.81	33	33	3.5
1 1/2"	1 3/4"	1 1/2"	3/4"	1 1/4"	1 1/4"	8000	5900	WS-3446T	3A463	24.21	100	100	2.7
	1 3/4"	2 1/4"	3/4"	1 1/4"	1 1/4"	12000	8900	WS-3450T	3A464	32.51	50	50	3.1
	1 3/4"	3 1/4"	3/4"	1 1/4"	1 1/4"	16000	11800	WS-3454T	3A465	40.81	33	33	3.5
1 3/4"	1 3/4"	1 1/2"	3/4"	1 1/4"	1 1/4"	10000	7449	WS-3458T	3A466	27.32	100	100	3.0
	1 3/4"	2 1/4"	3/4"	1 1/4"	1 1/4"	15000	11200	WS-3462T	3A467	35.43	50	50	3.4
	1 3/4"	3 1/4"	3/4"	1 1/4"	1 1/4"	20000	15000	WS-3466T	3A468	43.54	33	33	3.8

*) Ultimate load capacity in 4000 PSI stone aggregate concrete. For load capacities in structural lightweight aggregate concrete refer to ICBO Report No. 1272. Safe working loads for single installations under static loading should not exceed 25% of the ultimate load capacity. (†) Indicates UL Listing. (‡) Indicates FM Listing. Do not use for continuous low temperature applications below 0°F (-17.8°C).

MULTI-SET™ ANCHORS



Carbon steel drop-in anchors for use in heavy-duty concrete materials, thin wall or prestressed concrete. Meet U.S. Government G.S.A. Specifications FF-S-325 Group VII, Type 1. For pipe hanging, mounting valves and pipes, machinery mountings, hanging shelves, and insulation. ITW Rammed/Red Head brand.

- Setting tool included with each box of anchors
- Precise hole depth not necessary
- Note clean-out not necessary

Anchor Size	Drill Bit Size	Thread Depth	Min. Embedment in Concrete	Ultimate Pullout Lbs.	Ultimate Shear Lbs.	Red Head Model	Stock No.	List	Each Box	Anchor per Box	Ship. Wt.
1/2"	3/8"	3/4"	1"	3,204	1,986	RM-14	3A492	\$38.17	\$35.55	100	2.8
3/8"	1/2"	1 1/4"	1 1/4"	6,350	3,908	RM-35T	3A493	28.27	28.21	50	3.1
1/2"	1/2"	1 1/4"	1 1/4"	8,544	6,002	RM-12T	3A494	47.01	44.89	33	3.5
3/4"	3/4"	1 1/4"	1 1/4"	12,218	10,380	RM-55T	3A495	41.83	41.04	25	4.0
1"	1"	1 1/4"	1 1/4"	17,255	13,962	RM-34T	3A496	60.97	68.52	15	4.8

*) Ultimate load capacity in 4310 PSI 1/2" crushed limestone aggregate concrete. For load capacities in structural lightweight aggregate concrete refer to ICBO Report No. 1272. Safe working loads for single installations under static loading should not exceed 25% of the ultimate load conditions. (†) Indicates UL Listing. (‡) Indicates FM Listing.

REPLACEMENT SETTING TOOLS FOR MULTI-SET™ ANCHORS

For Anchor No.	Red Head Model	Stock No.	List	Ship. Wt.	For Anchor No.	Red Head Model	Stock No.	List	Each Box	Ship. Wt.
3A492	RT-114	3A497	\$2.37	\$2.32	3A495	RT-158	3A501	\$5.64	\$5.52	6.8
3A493	RT-138	3A498	2.08	2.98	3A496	RT-134	3A502	8.31	8.12	11
3A494	RT-112	3A499	2.56	3.51						

Industrial and Automotive Air Tools

Complete line of Chicago Pneumatic, Dayton, Ingersoll Rand, Florida Pneumatic and Universal air tools handles industrial and automotive requirements. Line includes impact wrenches, air hammers, Sanders, screw drivers and drills.

SEE WARRANTY INFORMATION ON PAGE OPPOSITE INSIDE BACK COVER



Galvanized Wire Rope




Corrosion-resistant zinc coating on the wire gives added protection. Choose from a variety of galvanized rope constructions to meet application requirements such as guying, control and light hoisting. NOTE: All operating wire ropes should be lubricated.

Galvanized Steel Aircraft Cable

1x19 • Abrasion Resistance—Very Good
• Flexibility—Low

7x7 • Abrasion Resistance—Good
• Flexibility—Good

7x19 • Abrasion Resistance—Good
• Flexibility—Very Good



Nonflex 1x19—Single Strand*

Break. Strgth.	Cut Lengths	100-PL Lengths	300-PL Lengths
Dia. Lbs. No.	NET/FOOT No.	NET/LOTH. No.	NET/LOTH. No.
1/2" 185 3450T81	50.05	3450T81	84.00
3/4" 375 3450T82	50.05	3450T82	84.00
1/2" 500 3450T130	50.05	3450T130	7.00
3/4" 1,200 3450T140	12.00	3450T140	18.00
1/2" 2,100 3450T150	15.00	3450T150	11.00
3/4" 3,500 3450T160	18.00	3450T160	18.00
1/2" 4,700 3450T170	23.00	3450T170	23.00
3/4" 8,200 3450T180	38.00	3450T180	31.00

All wire ropes listed here have excellent strength. Corrosion resistance is very good. Breaking strength conforms to latest revision of Federal Specification MIL-RR-4100 except where indicated. 7x19 construction is available in two classes: 3458T series meets only the breaking strength requirements of Federal Specification MIL-RR-4100. The 3332T series is a full compliance category that meets all the requirements of Federal Specification MIL-RR-4100. To meet all requirements, this rope must pass through exceptional quality control testing plus offer a reduced stretch factor and increased fatigue resistance. All MIL-RR-4100 Federal Specification galvanized rope is lubricated prior to shipment.

Flexible 7x7—Strand Core*

Break. Strgth.	Cut Lengths	100-PL Lengths	300-PL Lengths
Dia. Lbs. No.	NET/FOOT No.	NET/LOTH. No.	NET/LOTH. No.
1/2" 480 3450T24	38.18	3450T24	518.00
3/4" 820 3450T28	32.34	3450T28	18.00
1/2" 1,700 3450T29	29.34	3450T29	24.00
3/4" 2,800 3450T29	38.34	3450T29	24.00
1/2" 3,700 3450T31	46.34	3450T31	40.00
3/4" 5,100 3450T32	47.34	3450T32	41.00

Extra Flex 7x19—Strand Core—Full Compliance

Break. Strgth.	Cut Lengths	100-PL Lengths	300-PL Lengths
Dia. Lbs. No.	NET/FOOT No.	NET/LOTH. No.	NET/LOTH. No.
1/2" 1,000 3332T81	50.36	3332T81	82.00
3/4" 2,000 3332T82	42.36	3332T82	34.00
1/2" 2,800 3332T83	48.36	3332T83	38.00
3/4" 4,200 3332T84	58.36	3332T84	48.00
1/2" 5,800 3332T85	66.36	3332T85	57.00
3/4" 7,000 3332T86	78.36	3332T86	68.00

- Galvanized and Type 304 stainless steel with vinyl or nylon coating conforms to applicable Federal Specification. Choose cut lengths, 50-foot coils or ADVANTAGES OF WIRE ROPE:
- (1) Increases cable life by protecting pulleys and drums from moisture.
 - (2) Protects pulleys and drums from moisture.
 - (3) Seals in lubricant and seals moisture.
 - (4) Protects hands, clothing, and any surface into contact with cable.
 - (5) Helps maintain full original capacity.
 - (6) Provides good handling surface.

7x7 STRAND

Break. Strgth.	Cut Lengths	100-PL Lengths	300-PL Lengths
Dia. Lbs. No.	NET/FOOT No.	NET/LOTH. No.	NET/LOTH. No.
1/2" 370 3450T11	37.00	3450T11	37.00
3/4" 480 3450T12	48.00	3450T12	48.00
1/2" 600 3450T13	60.00	3450T13	60.00
3/4" 820 3450T14	82.00	3450T14	82.00
1/2" 1,000 3450T15	100.00	3450T15	100.00
3/4" 1,200 3450T16	120.00	3450T16	120.00

STAINLESS STEEL

Break. Strgth.	Cut Lengths	100-PL Lengths	300-PL Lengths
Dia. Lbs. No.	NET/FOOT No.	NET/LOTH. No.	NET/LOTH. No.
1/2" 370 3450T17	37.00	3450T17	37.00
3/4" 480 3450T18	48.00	3450T18	48.00
1/2" 600 3450T19	60.00	3450T19	60.00
3/4" 820 3450T20	82.00	3450T20	82.00
1/2" 1,000 3450T21	100.00	3450T21	100.00
3/4" 1,200 3450T22	120.00	3450T22	120.00

Galvanized Steel 7-Wire Guy Strand



• Abrasion Resistance—Good
• Flexibility—Low

1x7—SINGLE STRAND—Also known as messenger strand. This moderate strength strand is recommended for guying, control and support purposes. It is also excellent for supporting telephones and electrical cables.

Break. Strgth.	Cut Lengths	100-PL Lengths	300-PL Lengths
Dia. Lbs. No.	NET/FOOT No.	NET/LOTH. No.	NET/LOTH. No.
1/2" 3,150 3448T84	50.18	3448T84	80.18
3/4" 5,350 3448T85	58.18	3448T85	88.18
1/2" 6,950 3448T86	66.18	3448T86	96.18
3/4" 12,100 3448T87	74.18	3448T87	104.18

Galvanized Iron Sash Cord




• Abrasion Resistance—Moderate
• Flexibility—Very Good

6x7—FIBER CORE—Use for connecting each to window weights and connecting sliding doors to counterweights. Galvanized sash cord is also ideal for operating freight elevator gates, shades, curtains, bells, whistles, and for any other application where an inexpensive metallic cord of relatively low strength is required. This cord is not pre-lubricated.

Break. Strgth.	Cut Lengths	100-PL Lengths	300-PL Lengths
Dia. Lbs. No.	NET/FOOT No.	NET/LOTH. No.	NET/LOTH. No.
1/2" 140 3448T14	50.31	3448T14	80.31
3/4" 315 3448T15	58.31	3448T15	88.31
1/2" 500 3448T16	66.31	3448T16	96.31
3/4" 840 3448T17	74.31	3448T17	104.31
1/2" 1,150 3448T18	82.31	3448T18	112.31
3/4" 1,840 3448T19	90.31	3448T19	120.31

Galvanized Improved Plow Steel Wire Rope




Fiber Core • Abrasion Resistance—Moderate
IWRC • Abrasion Resistance—Good

6x19—FIBER CORE OR IWRC—Use for rigging, guying and low ropes in applications where rope is not constantly bending over sheaves and around drums. Strength is about 10% less than a nongalvanized rope of the same grade and classification. Flexibility is very good. Breaking strength conforms to latest revision of applicable Federal Specification RR-W-410.

Break. Strgth.	Cut Lengths	100-PL Lengths	300-PL Lengths
Dia. Lbs. No.	NET/FOOT No.	NET/LOTH. No.	NET/LOTH. No.
1/2" 10,980 3454T13	51.38	3454T13	81.38
3/4" 19,200 3454T14	59.38	3454T14	89.38
1/2" 30,000 3454T15	67.38	3454T15	97.38
3/4" 20,600 3454T21	2.28	3454T21	3.28

Galva-Flex Wire Rope



Fiber Core • Abrasion Resistance—Low
IWRC • Abrasion Resistance—Moderate

6x37—FIBER CORE OR IWRC—The large number of small wires per strand provides excellent flexibility and high fatigue resistance. This improved plow steel wire rope is ideal for use on small drums and sheaves. To help avoid crushing, use well-designed sheaves and grooved drums. IWRC is less susceptible to crushing than fiber core. This wire rope is pre-lubricated.

Break. Strgth.	Cut Lengths	100-PL Lengths	300-PL Lengths
Dia. Lbs. No.	NET/FOOT No.	NET/LOTH. No.	NET/LOTH. No.
1/2" 4,940 3323T71	51.88	3323T71	81.88
3/4" 10,980 3323T72	59.88	3323T72	89.88
1/2" 19,280 3323T73	67.88	3323T73	97.88
3/4" 1,500 3323T21	2.11	3323T21	3.11
1/2" 31,800 3323T22	2.83	3323T22	3.83
3/4" 20,500 3323T23	3.60	3323T23	4.60

All descriptions of wire ropes are individual needs. To select the proper wire rope for your engineering practices.

are provided to help you choose the proper wire rope for your engineering practices.

McMASTER-CARR

All descriptions of wire ropes are individual needs. To select the proper wire rope for your engineering practices.