

8/31/94 meeting at DTSC 2023e

A & G Trucking 5600 Dulles road
2 UGT removal 1989 (1000 gal gasoline)

3 MWS

highest
↓ 450 ppb gas
100 ppb benzene

4/4/93
L & S

2700 ~~290~~ ppb diesel
2 sampling events 2/2/93
6/30/93

Station - site

12 UGTs removed 1989 diesel/gasoline fuel

2 UGTs installed
1 gasoline
1-10,000 gal diesel

1-MWS

Being evaluated if the tank case
can be recommended for closure

Soil contamination TOG
still remains on site etc
may do not appear to be
related to the former tank