

Mobil Oil Corporation

612 SOUTH FLOWER STREET
P.O. BOX 2122
LOS ANGELES, CALIFORNIA 90051

March 13, 1986

Alameda County
Div. of Environmental Health
• ATTN: Mr. T. M. Geron
470 - 27th St., Room 324
Oakland, CA 94612

19
UG TANKS

RE: MOBIL OIL CORPORATION
SER. STA. 10-LNO (724)
3315 HIGH STREET
OAKLAND, CALIFORNIA


Dear Mr. Geron:

As required under California's law for underground storage tanks, the following report is submitted for the above location.

As part of Mobil Oil's present tank testing program, this location had all systems tested on March 10, 1986. A failure occurred in the super unleaded system. Further isolation revealed the tank as the source. The tank has been made safe awaiting repairs/replacement. An audit of the operator's records is being completed.

Your office will be provided more information as it is obtained. If you have any questions, please contact my office at (213) 683-5520.

Sincerely,



R. J. Edwards
Region Environmental
Coordinator

CEG:ram
Attachment
(57670)-1

c.c.: Mr. L. Feldman
California Regional Water
Quality Control Board
1111 Jackson St., Room 6040
Oakland, CA 94607

RECEIVED
MAR 13 1986

**ENVIRONMENTAL HEALTH
ADMINISTRATION**

Mobil Oil Corporation

B3

812 SOUTH FLOWER STREET
P.O. BOX 2122
LOS ANGELES, CALIFORNIA 90051

March 13, 1986

Alameda County
Div. of Environmental Health
ATTN: Mr. T. M. Geron
470 - 27th St., Room 324
Oakland, CA 94612

RE: MOBIL OIL CORPORATION
SER. STA. 10-LNO (724)
3315 HIGH STREET
OAKLAND, CALIFORNIA


Dear Mr. Geron:

As required under California's law for underground storage tanks, the following report is submitted for the above location.

As part of Mobil Oil's present tank testing program, this location had all systems tested on March 10, 1986. A failure occurred in the super unleaded system. Further isolation revealed the tank as the source. The tank has been made safe awaiting repairs/replacement. An audit of the operator's records is being completed.

Your office will be provided more information as it is obtained. If you have any questions, please contact my office at (213) 683-5520.

Sincerely,


R. J. Edwards
Region Environmental
Coordinator

CEG:ram
Attachment
(57670)-1

c.c.: Mr. L. Feldman
California Regional Water
Quality Control Board
1111 Jackson St., Room 6040
Oakland, CA 94607

BSURFACE FUEL LEAK REPORTING FORM

TO: Toxics Cleanup Division
 RWQCB, Rm. 6040
 1111 Jackson St.
 Oakland, CA 94607

CASE NO. _____

REPORT DATE: 03/12/86 REPORTED BY: C. E. Galloway

FACILITY NAME: Mobil S/S 10-LNO (724) FACILITY ADDRESS: 3315 High Street
Oakland, CA

FACILITY CONTACT: Ron Park PHONE: (415) 536-7919

OWNER: Mobil Oil Corporation ADDRESS: 612 S. Flower Street
Los Angeles, CA 90017-2897

CONTACT: R. J. Edwards PHONE: (213) 683-6335

DATE DISCOVERED: 03/10/86 DATE STARTED: 03/10/86

HOW TANK ROUTINE
 DETECTED: REMOVAL _____ MONITORING _____ OTHER: Tank Testing

CHEMICALS: Super Unleaded MAX. CONCENTRATION: Unknown

EST. VOL. LOST: Unknown EST. METHOD: N/A

TANK AGE: 1971 TANK VOLUME: 6,000 gal. TANK MATERIAL: Steel

PRESSURE TEST: TANK X PIPING X LEAK STOPPED: Yes

CONTAMINATION DEFINED: SOIL Unknown FLOATING PRODUCT: Unknown

LOCAL WELLS SAMPLES: No

MONITORING WELL DATA: N/A PRODUCT PLUME CLEANUP: N/A

VAPOR CHECK (Y/N): N RESULTS: STORM DRAINS N/A SEWERS N/A
 UTILITY VAULTS N/A BLDGS N/A
 OTHER: N/A

OTHER AGENCIES NOTIFIED: Regional Water Board
Alameda County Environmental Health

STATUS AND PROPOSED ACTIVITIES: Systems have been isolated. Further investigation to
 be completed during repairs/replacement of tanks.