

# SEMCO

General Engineering Building Contractor  
License No. 449864 A, B, C-61  
Environmental Services Division  
Tank Destruction Certification

**RECEIVED**  
JAN 26 1989

**HAZARDOUS MATERIALS/  
WASTE PROGRAM**

This is to certify that SEMCO, Inc., has in accordance with applicable local, state, and federal rules and regulations decontaminated and properly disposed of the following storage tank(s):

**Excavation Location:**

US COAST GUARD

Island Support Center  
Alameda, CA 94501

**Tank Identification:**

Manifest #	87955637, 87955632, 87955631
Identification Number	_____
Size	(3) 2,000 Gallon Tanks
Construction	Steel
Product	(1) Diesel (2) Gasoline

**Transporter:**

SEMCO, INC.  
431 West Hatch Rd.  
Modesto, CA 95351

**Decontamination Process:** Decontaminated on site using "Triple Rinse Process". Residual to be disposed of as Class 1 hazardous waste. Clean tank delivered to SEMCO to be reduced to prepared scrap 18" x 36" for recycling via Modesto Junk.

I certify that this document and all attachments were prepared under my direction or supervision in accordance with a program designed to assure that qualified personnel properly decontaminated and disposed of the above noted tank(s). Based on my inquiry of the person or persons who managed the program, or those persons directly responsible for completion of the program assignments, the above information is true, accurate and complete to the best of my knowledge and belief.

[Signature]  
Signature

[Title]  
Title

[Date]  
Date

**SUPERIOR ANALYTICAL LABORATORY, INC.**

1385 FAIRFAX ST., STE D • SAN FRANCISCO, CA 94124 • PHONE (415) 647-2081

C E R T I F I C A T E   O F   A N A L Y S I S

LABORATORY NO.: 50531  
CLIENT: Hunter/Gregg  
JOB NO.: N/A

DATE SAMPLED: 12/29/88  
DATE ANALYZED: 1/4/89  
DATE REPORTED: 1/6/89


ANALYSIS FOR BENZENE, TOLUENE, ETHYL BENZENE & XYLENES  
by EPA SW-846 Methods 5030 and 8020

Sample Identification	Concentration (ug/kg)			
	Benzene	Toluene	Ethyl Benzene	Xylenes
1A 12/29 4:30	ND< 3	ND< 3	ND< 3	ND< 3
1B 12/29 4:35	ND< 3	ND< 3	ND< 3	ND< 3
2A 12/29 4:40	ND< 3	ND< 3	14.	57.
2B 12/29 4:49	ND< 3	ND< 3	4.5	ND< 3
3A 12/29 5:00	ND< 3	5.1	25.	10.
3B 12/29 5:15	ND< 3	ND< 3	6.4	8.
#4	ND< 60	2700.	5000.	24000.

ug/kg = part per billion (ppb)

QA/QC Summary: Matrix Spike, Matrix Spike Duplicate:  
Average Recovery: 102% , RPD: 3

Les Partridge, Ph.D.



Laboratory Manager

OUTSTANDING QUALITY AND SERVICE

**SUPERIOR ANALYTICAL LABORATORY, INC.**

1385 FAIRFAX ST., STE D • SAN FRANCISCO, CA 94124 • PHONE (415) 647-2081

**C E R T I F I C A T E   O F   A N A L Y S I S**

LABORATORY NO.: 50531  
CLIENT: Hunter/Gregg  
CLIENT ID: USCG-Alameda

DATE RECEIVED: 12/30/88  
DATE REPORTED: 1/6/89  
JOB NO.: -N/A

**ANALYSIS FOR TOTAL PETROLEUM HYDROCARBONS  
by Modified EPA SW-846 Method 8015**

Sample Identification	Concentration (mg/kg)	
	Gasoline Range	Diesel Range
1A 12/29 4:30	ND < 10	ND < 10
1B 12/29 4:35	ND < 10	ND < 10
2A 12/29 4:40	ND < 10	ND < 10
2B 12/29 4:49	ND < 10	ND < 10
3A 12/29 5:00	ND < 10	ND < 10
3B 12/29 5:15	ND < 10	ND < 10
#4	320.	260.


mg/kg = part per million (ppm)

Minimum Detection Limit for Gasoline and Diesel, 10 mg/kg.

QA/QC Summary:

Daily standards run at 200 mg/L; RPD Gasoline=10, Diesel=1.5  
MS/MSD: Average Diesel Recovery =93%; Duplicate RPD =7.

Les Partridge, Ph.D.

  
Laboratory Manager

**OUTSTANDING QUALITY AND SERVICE**

Please print or type. (Form designed for use on a 12-pitch typewriter).

### UNIFORM HAZARDOUS WASTE MANIFEST

1. Generator's US EPA ID No.

2. Page 1 of  
Main Document No.

Information in the shaded area is not required by Federal law

3. Generator's Name and Mailing Address

US Coast Guard Island Support Center

A. State Manifest Document Number  
87955631

4. Generator's Phone

415 437-5775 Alameda CA 94501

B. State Generator's ID  
CA7691039100317

5. Transporter 1 Company Name

Alford Petroleum

6. US EPA ID Number

CA0918161711128

C. State Transporter's ID  
903731

7. Transporter 2 Company Name

W-H Tank Lines

8. US EPA ID Number

CA1A004103710645

D. Transporter's Phone  
(209) 576-8500

E. State Transporter's ID  
(213) 427-3100

9. Designated Facility Name and Site Address

De Meno Kerdwan Low Alameda

10. US EPA ID Number

CA1T08001133152

G. State Facility's ID  
CA1T08001133152

H. Facility's Phone  
(213) 537-7100

11. US DOT Description (Including Proper Shipping Name, Hazard Class, and ID Number)

12. Containers

13. Total Quantity

14. Unit

15. Waste No.

a. Waste oil Combustible Liquid

NWS NA170

No

Type

Quantity

Unit

Waste No.

1

TT

21000

G

221

b.

c.

d.

J. Additional Descriptions for Materials Listed Above

About 95% water

K. Handling Codes for Wastes Listed Above

a.

b.

c.

d.

15. Special Handling Instructions and Additional Information

16. GENERATOR'S CERTIFICATION: I hereby declare that the contents of this consignment are fully and accurately described above by proper shipping name and are classified, packed, marked, and labeled, and are in all respects in proper condition for transport by highway according to applicable international and national government regulations.

If I am a large quantity generator, I certify that I have a program in place to reduce the volume and toxicity of waste generated to the degree I have determined to be economically practicable and that I have selected the practicable method of treatment, storage, or disposal currently available to me which minimizes the present and future threat to human health and the environment; OR, if I am a small quantity generator, I have made a good faith effort to minimize my waste generation and select the best waste management method that is available to me and that I can afford.

Printed/Typed Name

TIM MADDEN

Signature

*Tim Madden*

Month Day Year

11/22/95

17. Transporter 1 Acknowledgement of Receipt of Materials

Printed/Typed Name

Colin Kelley

Signature

*Colin Kelley*

Month Day Year

11/22/95

18. Transporter 2 Acknowledgement of Receipt of Materials

Printed/Typed Name

Signature

Month Day Year

19. Discrepancy Indication Space

20. Facility Owner or Operator Certification of receipt of hazardous materials covered by this manifest except as noted in Item 19

Printed/Typed Name

Signature

Month Day Year

IN CASE OF AN EMERGENCY OR SPILL, CALL THE NATIONAL RESPONSE CENTER 1-800-424-8802, WITHIN CALIFORNIA CALL 1-800-852-7550

GENERATOR

TRANSPORTER

FACILITY