

Jun 5, 91

**MODIFIED WORK PLAN FOR THE REMOVAL
OF UNDERGROUND STORAGE TANKS AND
INSTALLATION OF GROUNDWATER
MONITORING WELLS**

**PHASE I
SITE CHARACTERIZATION PROGRAM**

**HARRISON STREET GARAGE
1432 HARRISON STREET
OAKLAND, CALIFORNIA 94612**

Prepared by:

SCS Engineers
6761 Sierra Court, Suite D
Dublin, California 94568
415- 829-0661

June 5, 1991

File No. 0390044.02

SCS ENGINEERS

June 6, 1991
File No. 0390044.02

Mr. Paul Smith
Alameda County Health Care Services
Division of Hazardous Materials
Department of Environmental Health
80 Swan Way, Room 200
Oakland, California 94621

Subject: Modified Workplan for
Removal of Underground Storage Tanks
and Preliminary Site Investigation
Harrison Street Garage
1432 Harrison Street
Oakland, California 94612

Dear Mr. Smith:

On behalf of the property owners, SCS Engineers (SCS) is pleased to submit this modified work plan, including the appended Underground Tank Closure Plan, Health and Safety Plan, and other supporting documentation, for the 1) proposed removal of four abandoned underground storage tanks (USTs), three hydraulic lifts and associated facilities, and 2) initial installation of groundwater monitoring wells at the Harrison Street Garage, 1432 Harrison Street, Oakland California. The supporting documentation includes: copies of tank removal contractors' insurance certificates, plot plan, and a deposit check for \$1074 (as per 1991 Alameda County deposit fee schedule) to cover the cost of County review and administration.


Alameda County issued the original Cleanup Order to the property owners, Alvin Bacharach and Barbara Borsuk, on September 24, 1990. SCS Engineers submitted an initial work plan to the County on February 15, 1991. This modified work plan is being submitted pursuant to a letter dated April 24, 1991 from the owners Attorney to the

Mr. Paul Smith
June 6, 1991
Page Two


Alameda County District Attorney and subsequent discussions between Alameda County, SCS Engineers, and Attorneys representing the property owners and District Attorney's office, dated April 26, 1991, regarding the excavation and removal of the existing tanks and associated facilities prior to the implementation of a more detailed site characterization and assessment program involving the drilling and installation of soil borings and monitoring wells and collection of representative soil and groundwater samples. The tasks to be completed as part of this work plan constitute Phase I of the site characterization and assessment program for this site.

This work plan will be implemented immediately following the County's approval. If there are any questions, please contact either of the undersigned at (415) 829-0661.

Sincerely,



Nels R. Johnson, P.E.
Senior Project Engineer
SCS Engineers



John P. Cummings, Ph.D., R.E.A., R.E.P.
Office Director
SCS Engineers



Thomas D. Gilmore
Staff Geologist
SCS Engineers

NRJ/JPC/TDG:sar
Enclosures

CONTENTS

<u>Section</u>	<u>Page</u>
1 Project Description	1
2 Site Description and History	2
Results of Previous Investigations	2
Waste Oil Tanks	6
Gasoline Tanks	6
Hydraulic Lift Area	8
3 Project Organization and Functional Responsibilities	10
List of Project Personnel	10
SCS Engineers	10
Subcontractors	10
Contract Analytical Laboratory	10
SCS Engineers Organizational Structure	11
Functional Responsibilities	12
Project Director/Health and Safety Officer	12
Technical Advisor/Quality Assurance Officer	12
Project Manager	13
Field Manager	13
Field Geologists/Engineers	13
4 Field Activities	14
Introduction	14
Location of Underground Utilities	16
Collection of Samples from Wash Rack Sump and Basement	17
Collection Drain Areas	
Tank and Lift Removals	19
Collection of Soil Samples	19
Installation of Groundwater Monitoring Wells	20
Placement Rationale	21
Drilling and Installation of Wells	21
Well Construction	23
Well Development	25
Water-Level Measurement	26
Collection of Groundwater Samples	27
Sample Handling	29
5 Documentation of Chain of Custody	31

Cont'

6	Analytical Services and Quality Assurance Procedures	33
	Analytical Services	33
	Quality Assurance Procedures	33
	Field Quality Assurance	34
	Laboratory Quality Assurance	34

Appendices

- A Alameda County Underground Tank Closure Plan
- B Health and Safety Plan
- C Tank Removal Contractor's Workman's Compensation Insurance Certificates
- D SCS Forms

LIST OF FIGURES AND TABLES

<u>Figures</u>		<u>Page</u>
1.	Site vicinity map.	3
2.	Site plan, showing locations of proposed groundwater monitoring wells.	4
3.	Detailed site plan of Alice Street basement, showing locations of waste oil tanks and associated facilities.	7
4.	Detailed site plan showing locations of hydraulic lifts and suspected underground fluid reservoir.	9
5.	Unified Soil Classification System chart showing soil types and categories.	22
6.	Typical well construction details for the installation of groundwater monitoring wells.	24

<u>Tables</u>		
1.	Previous analytical test result, based on soil and groundwater samples collected and analyzed by Subsurface Consultants in October 1990.	5
2.	Summary of Laboratory Analyses to be performed on samples collected as part of this investigation.	18

SECTION 1
PROJECT DESCRIPTION

This modified work plan, including the appended Underground Tank Closure Plan and supporting documentation (Appendices A, B, and C), outlines the proposed field operations and associated analytical test services to be provided by SCS Engineers (SCS) for the proposed removal of abandoned underground storage tanks (USTs) and associated facilities, including hydraulic lifts, at the Harrison Street Garage, 1432 Harrison Street, Oakland, California. Alameda County issued the original Cleanup Order to the property owners on September 24, 1990. This modified work plan is being submitted pursuant to a recent agreement between Alameda County, SCS Engineers, and attorneys representing the property owners and District Attorney's office, dated April 26, 1991, to excavate and remove the existing tanks and associated facilities prior to the implementation of a more detailed site characterization and assessment program involving the drilling and installation of soil borings and monitoring wells and collection of representative soil and groundwater samples. The tasks to be completed as part of this work plan constitute Phase I of the site characterization and assessment program for this site. Following is a brief background and description of the site, including tank locations and conditions, investigative and remedial actions which have been performed to date, and current plans to remove the tanks, including sample collection procedures and proposed analytical tests to be conducted.

SECTION 2

SITE DESCRIPTION AND HISTORY

The subject site is located in downtown Oakland and is bordered by Harrison Street on the west and Alice Street on the east, between 14th and 15th Streets (Figure 1). Lake Merritt is located approximately one-quarter mile east of the subject site. Figure 2 presents a site plan that outlines the building perimeter, adjacent streets, and suspected locations of both on-site and off-site USTs.

A garage facility utilized for parking automobiles and light trucks currently exists on the site, and essentially consists of two directly adjoining buildings. The first is the principal entrance to the parking garage at 1432 Harrison Street. This single-story building contains a partial mezzanine and is constructed of timber and masonry. The second is a multi-story garage that is on the Alice Street portion of the property and is constructed of reinforced concrete. Historical aerial photographs date construction of the buildings back some forty to fifty years.

Results of Previous Investigations

Previous investigations by others indicate that the soil is contaminated beneath the site and that such contamination includes measurable quantities of gasoline, diesel fuel, Benzene, Toulene Ethylbenzene and Xylene (BTEX) constituents, and PCBs. The reported analytical results (Table 1) are based on analyses of selected soil samples collected during the drilling of 6 exploratory borings by Subsurface Consultants in October 1990. The Subsurface Consultants' report also indicates that subsurface materials consist primarily of dense, fine-grained sands containing varying amounts of clay and silt. Published geologic maps indicate that these sediments are part of the Merritt Sand Formation. Groundwater was encountered by Subsurface Consultants during the drilling at depths ranging from 23 to 25 feet below the Harrison Street grade. Information regarding groundwater flow direction is not available; however, it is presumed to flow eastward toward Lake Merritt.




FIGURE 1: Vicinity Map Showing the Location of Subject Site




FIGURE 2: Schematic of Site Showing Location of USTs and Proposed Monitoring Wells

TABLE 1. CONTAMINANT CONCENTRATIONS IN SOIL
(Results of Subsurface Consultants October 1990 Investigation)


Boring No. & Depth (ft)	TVH ¹ (ppm)	B ² (ppb)	T ³ (ppb)	X ⁴ (ppb)	X ⁵ (ppb)	TOG ⁶ (ppm)	TKH ⁷ (ppm)		OTHER
							Keros./Diesel	8010/Sol Pb/PCBs ---/(ppm)/(ppb)	
B1 @ 20	6,300	99,000	490,000	610,000	110,000	---	---/---	---/---/---	
B2 @ 18.5	9,300	98,000	900,000	1,100,000	190,000	---	---/---	---/0.21/---	
B3 (in sump)	---	---	---	---	---	---	---/---	---/---/---	
B4 @ 10	---	---	---	---	---	6,300	ND ⁹ /1,700	---/---/---	
B5 @ 22.5	110	24	210	1,300	69	---	---/---	---/---/---	
B6 @ 9	---	ND	ND	ND	ND	ND	98/ND	ND/0.06/9 (Arochlor 1260)	
B6 @ 9.5	---	---	---	---	---	ND	140/ND	---/---/---	

- 1 Total Volatile Hydrocarbons, mg/kg = ppm
- 2 Benzene, ug/kg = ppb
- 3 Toluene
- 4 Xylene
- 5 Ethylbenzene
- 6 Total Oil & Grease
- 7 Total Extractable Hydrocarbons (as kerosene and diesel)
- 8 --- = Not tested for
- 9 ND = Not detected

TABLE 1. CONTAMINANT CONCENTRATIONS IN SOIL (CONT'D)
 (Results of Subsurface Consultants October 1990 Investigation)

Boring No. & Depth (ft)	TVH ¹ (ppm)	B ² (ppb)	T ³ (ppb)	X ⁴ (ppb)	X ⁵ (ppb)	TOG ⁶ (ppm)	TKH ⁷ (ppm) Keros./Diesel	OTHER 8010/Sol Pb/PCBs ---/(ppm)/(ppb)
B7 @ 13	ND	ND	ND	ND	ND			
B7 @ 20	2,500	3,500	34,000	130,000	33,000	---	---/---	---/0.07/---
B8 @ 22.5	1,200	2,300	38,000	89,000	18,000	---	---/---	---/---/---

- 1 Total Volatile Hydrocarbons, mg/kg = ppm
- 2 Benzene, ug/kg = ppb
- 3 Toluene
- 4 Xylene
- 5 Ethylbenzene
- 6 Total Oil & Grease
- 7 Total Extractable Hydrocarbons (as kerosene and diesel)
- 8 --- = Not tested for
- 9 ND = Not detected



A L I C E S T R E E T

WASTE OIL TANKS

Kerosine 98ppm
TOG ND
PCB 9 ppb(Arochlor)260

WASHRACK SUMP

HYDRAULIC LIFT AREA

SUSPECTED FORMER TANK LOCATION

Diesel 1700 ppm
TOG 6300 ppm

Gasoline 110 ppm

Gasoline 1200 ppm

TEST BORING

1432
HARRISON
STREET

FUEL PUMPS


Gasoline 2500 ppm

HARRISON STREET

Gasoline 6300 ppm

Gasoline 9300 ppm

APPROXIMATE SCALE (feet)



SCS ENGINEERS

RESULTS FROM SUBSURFACE CONSULTANTS

Suspected sources of contamination may include either on-site and/or off-site USTs. The lateral and vertical extent of contamination has not yet been defined. A previous geophysical investigation by J. R. Associates completed in August 1990 disclosed the presence of several USTs and associated facilities within the boundaries of the subject site. A description of these tanks and a summary of investigative and remedial actions which have been performed to date are presented below.


Waste Oil Tanks

Two waste oil tanks are located beneath the basement floor of the multi-story parking structure along Alice Street. Figure 3 shows the tanks and associated piping and vent lines in the area. The date of installation of these tanks is unknown. No records have been located which have documented the volume or composition of these tanks. However, it is believed that each tank has an approximately 1000-gallon capacity and is of steel construction. On October 27, 1990, Falcon Energy drained the contents of both tanks by removing a combined total of 1300-gallons of waste oil from them.

Gasoline Tanks

Two gasoline tanks are located near the western property boundary beneath the Harrison Street sidewalk in front of the entrance to the garage. Permits issued to a former long-term tenant of the garage, Douglas Motor Services, show that these tanks each have 1000-gallon capacities, are of steel construction, and were installed in 1975 and 1982, respectively. On October 27, 1990, Falcon Energy removed most gasoline (total less than 200 gallons) from the tanks. The condition of these two tanks is unknown, although a sample collected from one was discolored by rust. The recovered gasoline and waste oil was accepted and utilized by a recycling contractor.

It should be noted that there is evidence of two other abandoned-in-place USTs a few feet west of the above-described gasoline tanks, beneath the Harrison Street sidewalk of the adjacent property. These tanks and property are owned and operated by other parties.



EXPLANATION:

----- Buried Line


SCS ENGINEERS

FIGURE 3: Detailed Site Plan of Alice Street Basement Garage, Showing Tank and Associated Piping Locations based on Geophysical Survey

Hydraulic Lift Area

The recent J. R. Associates geophysical investigation also identified a probable underground fluid reservoir located near the hydraulic lift area as well as three hydraulic lift rams inside the Harrison Street parking garage. Figure 4 shows the hydraulic lifts and associated piping in the area; the area of the Ground Penetrating Radar (GPR) anomaly marks the suspected location of the underground fluid reservoir.

There is no available record to indicate that integrity testing has ever been performed on any of the above-described tanks. The tanks are suspected to be the principal source(s) of the site's contamination. However, the total quantity of product(s) lost cannot be estimated at this time.



EXPLANATION:
 - - - - - Burled Line
 - - ? - - Possible Burled Line

FIGURE 4: Detailed Site Plan of Hydraulic Lift Area in upper Harrison Street Garage, Showing Lift and associated Piping and Suspected Underground Fluid Reservoir (GPR anomaly) areas

SECTION 3

PROJECT ORGANIZATION AND FUNCTIONAL RESPONSIBILITIES

LIST OF PROJECT PERSONNEL

SCS Engineers

Dr. John P. Cummings, Project Director and Health and Safety Officer
Mr. David E. Ross, P.E., Technical Advisor And Quality Assurance Officer
Mr. Nels R. Johnson, P.E., Project Manager
Mr. Jack N. Alt, Certified Engineering Geologist
Mr. J. Don McClenagan, Field Manager
Mr. Thomas D. Gilmore, Field Geologist
Ms. Adi Constantinescu, Field Geologist
Mr. Prabhu N. Ravandur, Field Engineer


Subcontractors

SCS Field Services
J R Associates
HEW Drilling Company
Hogate Exploration
Bay Area Exploration

Contract Analytical Laboratory

SCS Analytical Laboratory
2860 Walnut Avenue
Long Beach, California 90806

SCS ENGINEERS ORGANIZATIONAL STRUCTURE



FUNCTIONAL RESPONSIBILITIES

Project Director/Health and Safety Officer

The Project Director (PD) will be responsible for overall project management and supervision. In this capacity, he will also closely coordinate with USACE Project Managers in order to assure satisfactory, accurate, and timely completion of all field operations, interpretation of laboratory analytical results, establishment of and compliance with quality-assurance procedures, and other characterization activities as required. For this project, the PD also will serve as the Health and Safety Officer (HSO). In this capacity, his responsibilities will include development, implementation, and updating of the Health and Safety Plan, including assessing, and interpreting the results of site monitoring and evaluation of health hazards, with specific application to determination of appropriate corrective actions or changes in required Personal Protective Equipment (PPE) that may be mandated by changes in site working conditions or environment.

Technical Advisor/Quality Assurance Officer

The Technical Advisor (TA) will provide technical support and expertise to the project as required by specific site conditions or problems that may be encountered during the course of either field operations or interpretation of analytical results. Such conditions may include, but are not limited to, discovery of unusual and/or complex combinations of contaminants, characterization or assessment of complex or interactive contaminant plumes or migration patterns, or interpretation of ambiguous laboratory results. For this project, the TA also will serve as the Quality Assurance Officer (QAO). Because the TA/QAO is affiliated with the Long Beach Office of SCS Engineers, his QA responsibilities are separate and independent from the Dublin Office-based project management, although he will report directly to the Project Director. In this capacity, the QAO will assess, initiate, carry out, and review corrective actions required to maintain adequate quality-assurance procedures for the field collection and laboratory analysis of samples interpretation of results, and chemical characterization of the site.

Project Manager

The Project Manager (PM) will be responsible for the day-to-day management of all operations associated with the site characterization program. In this capacity, he will be responsible for conducting and coordinating smooth and timely completion of the field operations, ensuring adequacy and completeness of the sampling and monitoring program and resulting characterization, and resolving any unanticipated problems or difficulties that may occur during the daily operations. In addition, the PM will be responsible for maintaining compliance with the Health and Safety Plan and will audit site health and safety practices, decontamination, and environmental monitoring activities.

Field Manager

The Field Manager (FM) will be responsible for overseeing daily activities of the sampling and monitoring program. He will also monitor job progress and overall Health and Safety Plan compliance.

Field Geologists/Engineers

During drilling, well installation, water-level measurement, and sample collection activities, field geologists and/or engineers will identify sampling locations and depths, collect and preserve soil samples, log soil conditions, measure water depths, collect and preserve representative groundwater samples, complete Chain-of-Custody documentation, and ship samples to the laboratory.

SECTION 4

FIELD ACTIVITIES

INTRODUCTION

The planned field activities for this first phase of the contamination characterization program include removal and disposal of the USTs and hydraulic lifts, collection of soil samples from all excavated tank pits, collection of sludge and water samples from the wash rack sump area, basement collection drain and capped pipe in the basement, installation of a total of three groundwater monitoring wells, (one adjoining the gas UST, one adjoining the waste oil UST and one adjoining the hydraulic lifts), well development and collection of representative groundwater samples.

The field methodology and laboratory analytical procedures to be used in the collection, analysis, and interpretation of chemical data for this contamination characterization program are outlined and described below. The purpose of the planned operations is to: 1) remove probable sources of contamination presently on-site, 2) identify contaminants, 3) characterize the lateral and vertical extent of contamination, 4) identify concentration levels, and 5) identify the probable direction of movement (if any) of soil and /or groundwater contamination at the Harrison Street Garage.

Installation of groundwater monitoring wells will permit the collection and analysis of representative groundwater samples surrounding the tank and lift sites in order to define the nature, extent, and concentration of contamination and to discern the probable source and direction of movement of the contamination. Periodic measurement of groundwater levels in the wells will provide information concerning site-specific hydrologic conditions and temporal changes in water levels, which will in turn permit establishment of a groundwater gradient and probable direction of flow. Similarly, soil samples collected at the time of monitoring well installation and from additional, strategically located soil borings (to be drilled during a subsequent phase of site characterization) will permit characterization of the nature, probable source,

extent, and concentration levels of any potential soil contamination in the designated areas.

Completion of the above elements is expected to permit initial characterization and assessment of the nature and extent of any soil and/or groundwater contamination at the three individual sites being investigated. Interpretation and integration of analytical test results will permit: (1) qualitative and quantitative determination of whether chemical releases to the environment have occurred, (2) identification of probable sources and extent of contamination, (3) identification of chemical constituents and concentration levels of any contamination present, which will in turn indicate the appropriate method of disposal and/or remediation, and (4) determination of whether additional or more detailed characterization of any individual site may be either required or desirable.

All field operations will be conducted and analytical test results determined so as to fully comply with all applicable federal, state, and local regulations governing underground storage tanks. The results of this characterization investigation will provide the basis for addressing the next phase of cleanup operations. It should be noted here that soil and groundwater analyses in subsequent phases will be limited to those constituents detected in this phase of the workplan.

The sampling and analytical procedures presented in this plan will ensure that consistent and reproducible sampling methods are used; proper analytical methods are applied; analytical results are accurate, precise, and complete; and the overall objectives of the contamination characterization and monitoring program are achieved. These procedures will be performed in accordance with Title 23, Subchapter 15, Sections 2550 through 2559 of the California Code of Regulations. The Tri Regional Board Staff recommendations for Preliminary Evaluation and Investigation of USTs (10 August, 1990) has been used as a guideline for the development of these procedures.

The remainder of this work plan consists of sections that describe in detail the various elements of the Phase I Site Characterization Program, including: Tank and lift removal, installation of monitoring wells, procedures for soil sample collection, groundwater level measurement and groundwater sample collection. In addition, documentation of Chain-of-Custody, analytical services, and quality assurance procedures are described.

LOCATION OF UNDERGROUND UTILITIES

Prior to the beginning of any field drilling or tank removal operations, Underground Service Alert (U.S. Alert) will be contacted in order to locate any underground utilities present near the proposed investigative areas around each former tank site. In addition, a geophysical survey utilizing ground penetrating radar may also be conducted to locate the same. Such utilities will include, but may not be limited to:

- Water
- Storm and Sanitary Sewer
- Electric Power Lines
- Telephone
- Natural Gas and other High-pressure Fuel Lines
- Cable Television
- Other Facilities, such as Steam, Vacuum, or Compressed Air Lines
- Underground Storage Tanks and Associated Vent Lines or Dispenser Facilities

Precise field location of existing utility lines (or other unanticipated field conditions) may dictate the need to slightly modify proposed field locations of borings in order to avoid potential damage to the existing lines. SCS Engineers will contact the County for its approval of any such locational changes prior to the initiation of actual field work at those locations.

Identification of buried pipes or drain lines in the basement and their respective outlets or sewer hookups is of concern. It is not certain the destination of discharge for the drains in the basement. As built drawings for building and city public sewers will be researched. If adequate records are not available a pipe-locating service or

service or geophysical survey will be called upon to determine the destinations of discharge for the basement drain.

COLLECTION OF SAMPLES FROM WASH RACK SUMP AND COLLECTION DRAIN AREAS

Liquid and/or sludge samples will be collected for analysis from three possible contamination source areas, including 1) the wash rack sump area in the Harrison Street garage 2) the collection drain in the Alice Street Basement and 3) the capped pipe also in the Alice Street basement. Analysis of these samples will permit identification of the contents of these areas, which currently are unknown, and will provide the basis for further drilling and sampling during a subsequent phase of characterization.

Liquid and/or sludge samples, if available, will be collected from the wash rack sump and/or adjoining lift ram. A preliminary field reconnaissance indicated that no water was present in the sump area, although water was present in the adjoining lift ram. There is a sufficient amount of sludge or other solid residue present in the immediate sump area to collect a representative sample for analysis. Sludge will be collected using either a stainless steel or disposable plastic scoop and retained in a wide-mouth jar with a non-reactive screw-top. Representative water samples will be collected from the ram next to the sump using a disposable bailer. No water from the ram will be purged prior to sampling, as it is unknown how much product is available. The initial sample collected will be examined for the presence of floating, free product, which, if observed, will be measured and described, and any other distinguishing characteristics will be noted. A minimum of two 1-liter bottles and four 40-ml VOA vials will be collected. Samples will be sealed following collection, labeled, kept in cold storage (4⁰C), and transported with Chain-of-Custody documentation to a certified testing laboratory for analysis. The analyses to be performed are specified in Table 2.

TABLE 2

LABORATORY ANALYSIS SUMMARY
FOR COLLECTED SOIL AND WATER SAMPLES

<u>Location</u>	TPH-G ¹	TPH-D ²	BTEX ³	O.L. ⁴	O&G ⁵	ClH ⁶	PCB's ⁷	PPM ⁸
Gasoline Tanks	X	X	X	X	X	X	X	X
Hydraulic Lift		X	X		X			
Waste Oil Tanks (Basement)	X	X	X		X	X	X	X
Wash Rack Sump	X	X	X		X	X		
Collection Drain & Capped Pipe (Basement)	X	X	X		X	X		X

1. Total Petroleum Hydrocarbon as GAS (EPA 8015 Mod)
2. Total Petroleum Hydrocarbon as Diesel (EPA 8015 Mod)
3. Benzene, Toluene, Ethylbenzene, Xylene (EPA 8020)
4. Organic Lead (DOHS MIBK Method)
5. Oil & Grease (EPA 413.1)
6. Chlorinated Hydrocarbons (EPA 8120)
7. Polychlorinated Biphenyls (EPA 8080)
8. Priority Pollutant Metals

Liquid samples also will be collected from the basement collection drain and capped pipe. Based on preliminary field reconnaissance, both these sources appear to contain only liquids. If a disposable bailer cannot be inserted into either opening, or if insufficient material is available, a hand-operated siphon pump with removable hoses will be used for sample collection; clean hose lines will be installed in order to avoid cross-contamination of samples between the drain and pipe sources. A minimum of two 1-liter bottles and four 40-ml VOA vials will be collected from each source, provided sufficient material is available to sample.

TANK AND LIFT REMOVALS

The two gasoline USTs beneath the Harrison Street sidewalk, the two waste oil USTs in the Alice Street basement, and the three hydraulic lifts and possible associated hydraulic fluid reservoir, and any associated product piping or vent lines that are exposed all will be removed and disposed of by a State-licensed hazardous materials contractor, after first being properly cleaned, vented, degassed, and inerted. Manifests (to be appended to the tank removal report) will document proper treatment, storage, and disposal of all tanks, associated piping, and rinsate solutions.

It is anticipated that all excavation spoils will be retained on-site until disposition can be determined. The soil will be covered with visqueen material as required to keep contaminants contained. The open excavations will be barricaded until disposition of spoils can be determined (ie used as backfill or hauled off-site).

Collection of Soil Samples

Following excavation and removal of the tanks or lifts from each area, representative soil samples will be collected from each site and submitted to a State-certified analytical laboratory for testing. Two soil samples will be collected from beneath the ends of each tank or lift area. These samples shall be taken from native materials not to exceed 2 feet below the bottom of the tank/lift. Although groundwater is not expected to be encountered if it present in the excavation pit, the soil samples will be collected from the pit walls near the tank ends at the soil/groundwater interface. A water sample also will be collected from any excavation pit where it is present.

Soil samples will also be collected at an interval of 20 feet for associated product piping that is removed. These samples will be analyzed for the same constituents as the pertinent UST.

Additional soil samples will be collected from the excavation spoils piles. SCS Engineers expects to collect one sample, either discrete or a composite (at the direction of the County inspector) from each excavation. The two gasoline tanks and the two waste oil tanks should comprise one excavation each, and therefore, one sample each. It is currently unclear whether removal of the hydraulic lifts and associated reservoir will comprise one or more separate excavations; one to three soil samples will be collected from the hydraulic lift area excavation spoils pile(s). If composite samples are required, soil will be collected from portions of the pile as designated by the County inspector, mixed together in a clean bucket, and retained in brass sleeves.

Soil samples will be collected and retained in clean brass sleeves, the ends sealed with teflon tape, capped with plastic end caps, sealed tightly with tape, labeled, and kept in cold storage (4°C) for transport to a State-certified laboratory. During sampling, samples will be screened in the field using both visual inspection and a portable organic vapor meter.

INSTALLATION OF GROUNDWATER MONITORING WELLS

Following removal of the tanks and lifts, a total of 3 groundwater monitoring wells will be installed, one adjacent to gasoline UST, waste oil USTs and hydraulic lifts. Installation of the initial 3 wells is expected not only to permit determination of a verified downgradient groundwater flow direction and to measure water levels, but also to meet the "within 10 feet (of a former tank site)" requirement specified by the Tri-Regional Recommendations (revised August 10, 1990, Page 11). Figure 2 shows the proposed locations of the monitoring wells, each in the presumed downgradient (i.e., eastward) groundwater flow direction from the presumed source areas, which include: (1) the gasoline (2) waste oil tanks and (3) hydraulic lift areas. Each well also will

be used for sampling and monitoring during the next phase of the more detailed site characterization and assessment program.

Placement Rationale

The proposed wells are designed and will be sited so as to (1) permit computation of a verified downgradient groundwater flow direction, (2) measure water levels, and (3) optimally investigate the nature and levels of contamination both at known and suspected sources of contamination. A verified downgradient direction has not yet been established for this site; however, it is provisionally assumed to subparallel the local topographic slope. Consequently, and based on an assumed easterly direction of groundwater flow, contaminants which could move from their source are expected to migrate in a generally easterly direction toward Lake Merritt.

Drilling and Installation of Wells

The proposed groundwater monitoring wells will be installed using a hollow-stem auger drilling rig. Because of the height and clearance constraints imposed by the ceilings and access ways within the existing parking structure, a small skid-or trailer-mounted rig will be utilized inside the basement. The wells near the Harrison Street garage entrance and hydraulic lift areas will be installed using a conventional truck-mounted drilling rig.

The well installation will be coordinated by a field geologist, under the supervision of a State-registered Certified Engineering Geologist (CEG). The borings will be logged in the field by the field geologist, and soils encountered will be classified using the Unified Soil Classification System (Figure 5). Well logs for each boring showing lithologies encountered, depth to groundwater, and well construction details will be included in the final written report. A sample field boring log is shown in Appendix D.

The proposed borings will be approximately 6 inches in diameter. Borings will be drilled to a total depth of approximately 35 feet below the Harrison Street grade, or

UNIFIED SOIL CLASSIFICATION SYSTEM
















GENERAL SOIL CATEGORIES		SYMBOLS	TYPICAL SOIL TYPES	
COARSE GRAINED SOILS More than half is larger than No. 200 sieve	GRAVEL More than half coarse fraction is larger than No. 4 sieve size	GW	 Well Graded Gravel, Gravel-Sand Mixtures	
		GP	 Poorly Graded Gravel, Gravel-Sand Mixtures	
		Gravel with more than 12% fines	GM	 Silty Gravel, Poorly Graded Gravel-Sand-Silt Mixtures
			GC	 Clayey Gravel, Poorly Graded Gravel-Sand-Clay Mixtures
	SAND More than half coarse fraction is smaller than No. 4 sieve size	Clean sand with little or no fines	SW	 Well Graded Sand, Gravelly Sand
			SP	 Poorly Graded Sand, Gravelly Sand
		Sand with more than 12% fines	SM	 Silty Sand, Poorly Graded Sand-Silt Mixtures
			SC	 Clayey Sand, Poorly Graded Sand-Clay Mixtures
FINE GRAINED SOILS More than half is smaller than No. 200 sieve	SILT AND CLAY Liquid Limit Less than 50%	ML	 Inorganic Silt and Very Fine Sand, Rock Flour, Silty or Clayey Fine Sand, or Clayey Silt with Slight Plasticity	
		CL	 Inorganic Clay of Low to Medium Plasticity, Gravelly Clay, Sandy Clay, Silty Clay, Lean Clay	
		OL	 Organic Clay and Organic Silty Clay of Low Plasticity	
	SILT AND CLAY Liquid Limit Greater than 50%	MH	 Inorganic Silt, Micaceous or Diatomaceous Fine Sandy or Silty Soils, Elastic Silt	
		CH	 Inorganic Clay of High Plasticity, Fat Clay	
		OH	 Organic Clay of Medium to High Plasticity, Organic Silt	
HIGHLY ORGANIC SOILS		PT	 Peat and Other Highly Organic Soils	

FIGURE 5: Unified Soil Classification System Chart

at least 10 feet below the groundwater surface. A previous subsurface investigation conducted at this site in October 1990 by Subsurface Consultants, encountered groundwater at an average depth of 23 to 25 feet below the Harrison Street grade. The augers will be steam-cleaned on site at the completion of each boring. Waste water and sludge from the steam cleaning and excavation spoils from drilling will be collected and transferred to 55-gallon drums for temporary storage on-site. The waste water and spoils will be analyzed and the results will dictate the final disposition.

Soil samples will be collected from each boring at a minimum interval of every 5 feet, and at the soil/groundwater interface (if encountered), with a Modified California split-spoon sampler. Samples will be retained in brass sleeves, examined, sealed with teflon, capped with plastic end caps, tightly wrapped with tape, labeled, and kept in cold storage (4°C) for transport to a chemical testing laboratory certified by the California Department of Health Services. Samples submitted for analysis of heavy metal constituents will be retained in glass jars with non-reactive lids. Samples will be screened in the field using a photo-ionization detector type organic vapor meter (OVM). Protocol for sample labeling is as follows: All samples will include identification of project name or number, date and time of sampling, drill hole or

Well Construction

Typical well construction details for the installation of groundwater monitoring wells are shown in Figure 6. Each monitoring well will be constructed in the borehole using flush-mounted, threaded PVC well casing. As proposed, wells located inside the building will be two inches in diameter. Factory-slotted screen with 0.020-inch slots will be placed into the aquifer, with solid PVC pipe installed above. The perforated zone of the casing will be installed from about 5 feet above the groundwater surface to the total depth of the well, such that perforated casing extends at least 10 feet below the groundwater surface. A perforated zone of this nature should accommodate anticipated seasonal water-level fluctuations at the site. A flush-mounted, threaded end cap will be placed on the bottom of the perforated section. Couplings between




FIGURE 6: Typical Well Construction Details for the Installation of Groundwater Monitoring Wells

the casing sections will be flush-set, threaded pipe with no glued connections. All casings will be steam-cleaned prior to installation.

The well casing will be set inside the hollow augers prior to their removal in order to prevent caving of the hole prior to installation of the casing. The annular space surrounding the well screen will be filled with a filter pack, such as Monterey Sand No. 3, to a level at least 2 feet above the top of the screened interval and then capped with a bentonite seal approximately 3 feet thick. The sand will be poured slowly into the annular space between the PVC pipe and the augers. This procedure will be interrupted periodically in order to measure the depth to the top of the sand with a weighted tape. The remaining annular space above the bentonite seal will be monitoring well number, sample number, sample depth, and requested analyses.

filled with a cement/grout mixture to a level about 1 foot below grade. The top of the well will be cemented and set with a locking monument well cover. The concrete surface seal will be sloped away from the well casing at the ground surface in order to promote good drainage and prevent infiltration. The top or surface portion of the well casing will be fitted with a lockable, expandable rubber plug in order to reduce or minimize unwarranted intrusion into the casing.

A reference point on each monitoring well casing will be marked with an indelible marker and then surveyed by SCS Engineers in order to establish elevations that will be used for depth-to-water measurements and gradient calculations. The leveling survey will measure elevations to the nearest 0.01 foot and all elevations will be referred to an established benchmark or other fixed local control point of known elevation.

Well Development

Each monitoring well will be developed in order to increase its specific capacity, prevent sanding, maximize well life, and collect representative samples of the groundwater. Well development generally repairs any damage done to the native materials by the drilling operations, restores natural hydraulic properties to the

adjacent soils, and improves hydraulic properties near the borehole so that water flows more freely into the well.

The wells will be developed by removing or flushing the finer material from both the local native materials and the sand filter pack surrounding the wells. This procedure will consist first of bailing the well and then pumping or bailing the well until it produces clean water, i.e., water containing minimal amounts of suspended solids. All of the groundwater produced or removed during the well development operations will be stored temporarily on-site in approved 55-gallon drums, which will be labeled as to their contents. Subsequent testing of the purged groundwater will indicate its final disposition.

New disposable bailers will be used for all well purging and sampling activities. The use of dedicated bailers for each well will assure sample cleanliness and avoid potential for cross-contamination. Should any reusable equipment, such as pumps, be employed, all equipment will be decontaminated both prior to and subsequent to its use in each well. Decontamination will consist of steam cleaning and/or washing of equipment using trisodium phosphate soap, tap water rinse, and distilled water rinse.

Water Level Measurement

Prior to any groundwater sampling, static water-level measurements in each monitoring well will be taken using an electronic water-level indicator. Water-level measurements will be made by a field geologist or engineer and the readings will be measured to the nearest 0.01 foot from the marked reference point on the top of the well casing. The monitoring wells will be sampled for soluble constituents only after completion of the water-level measurements. Water levels will be converted to elevations with respect to mean sea level (MSL), or another fixed local control point, and a groundwater elevation contour map then will be constructed from the water level data.

Sealed wells should always be uncapped and left open for several minutes prior to water-level measurement in order to allow ambient groundwater levels to equilibrate. The water level will be measured by lowering the electrode and cable slowly into the well casing. The water level indicator will be turned on and the buzzer tested before lowering the cable into the well. Water levels will be reported in feet below a measured reference point, usually a mark on the top of the well casing. The point on the sounder cable where the water level indicator will register maximum deflection will be held against the reference point and marked. The distance from the mark to the nearest footage tab will be measured using a pocket tape calibrated in hundredths of feet. Water level measurements will be repeated two or more times in order to assure accuracy of the water level measurement.

All water levels will be recorded on prepared forms of the type shown in Appendix D. The recorded data will include the depth to water, in feet below the reference point, the time and date of the measurement, and the calculated water level, depth or elevation, with respect to a fixed control point. Water level measurements will be reported to the nearest 0.01 foot.

Notes of any activity or condition which may affect the water level measurements will be made during the water level measuring. Such activities may include changes in local atmospheric conditions, pumping from nearby wells, drilling and/or testing operations.

Collection of Groundwater Samples

The following sections contain a detailed description of the equipment, well purging and sampling techniques, and methods of sample handling to be utilized in the collection of representative groundwater samples for the water quality monitoring program.

The depth to static water level first will be measured and recorded, as described in the section "Groundwater Level Measurements," before purging and sampling of each

monitoring well begins. Next, a clear disposable bailer will be lowered into each well following water-level measurement, but prior to purging, in order to sample the upper surface of the groundwater. Any free product observed floating on the groundwater will be measured in the bailer, and its color, odor, turbidity, or other distinguishing characteristics will be noted and described.

Following free product sampling, each monitoring well will be purged of three to four well-volumes of water using disposable bailers or a submersible pump. Well purging permits a representative sample of groundwater to be obtained directly from the aquifer, rather than from water which had been standing in the well. Because the well casing diameter, total well depth, and groundwater level will be known or can be calculated for each well, an accurate estimate of well volume can be made in the field in order to estimate and measure the purge volume required to be evacuated from each well prior to sampling. If the well does not recharge fast enough to permit removing three well-casing volumes, the well will be pumped or bailed dry, and sampled as soon as sufficient recharge has occurred. Again, notations will be made as to any color, odor, turbidity, or other distinguishing characteristics in the water being purged from the well. Groundwater removed from wells prior to sample collection will be contained temporarily on-site in approved 55-gallon drums, which will be clearly labeled to identify contents as "Possibly Hazardous" and source. Subsequent testing results will dictate its final disposition.

After completion of the minimum bailing time required to adequately purge the well, the purging water level, well discharge rate, temperature, specific conductance, and pH again will be measured and recorded on the field data sheet. A typical data sheet is shown in Appendix D. The time when the purging began, the duration of purging, and the date of the sampling also will be noted on the data sheet. If a pump is used for purging of wells, it will be decontaminated both prior to and subsequent to its use in each monitoring well. Decontamination will consist of washing of equipment with trisodium phosphate soap, tap water rinse, and distilled water rinse.

Representative groundwater samples will be collected using a disposable acrylic bailer and contained in pre-cleaned 40 ml VOA vials with teflon-coated septa or 1-liter amber jars, depending on the analysis to be performed. The type of containers, preservation, and maximum holding times permitted prior to analysis for both soil and groundwater samples will conform to EPA standards. Samples will be acidified for preservation when required by EPA protocol. The general procedure for sample collection is as follows. Sample containers will not be pre-rinsed with sample, and will be filled slowly just to overflowing so that a convex meniscus remains over the opening of the container. Samples to be analyzed for volatiles will be collected first, allowing no head space and with as little disturbance of the water as possible. The container will then be carefully sealed with the teflon-lined cap. All efforts will be made to minimize volatilization of the samples, particularly by minimizing sample exposure to the atmosphere through collection as soon after completion of well purging or recharge as practicable and by ensuring that all air is expelled from sample containers. If air bubbles are present following sealing of sample containers, the sample should be poured out and resampled. Duplicate groundwater samples will be routinely collected.

Sealed sample containers then will be labeled with a sample tag, using similar protocol to that described above for soil samples. Labels will include: project name or number, date and time of sample collection, monitoring well number, sample number, name of person collecting the sample, and requested analyses.

Sample Handling

All samples for all analyses will be refrigerated from the time of field collection until the time the samples are analyzed in the laboratory. Samples obtained from sources or sample points known or suspected to contain high concentrations of volatile contaminants will be segregated from the other samples during handling and shipment. Samples containing high concentrations of volatile organic compounds will be shipped in separate containers to minimize potential cross contamination with other samples during shipping. Trip and field blanks (see Section 6) will be included with each

container of samples shipped to the laboratory. At the end of each field day, the samples will be carefully packaged to preclude damage or breakage and sealed with tape for secure transportation to the selected laboratory. All sample shipments will be sent via an overnight carrier such as Federal Express with the proper Chain-of-Custody forms clearly documenting the sample identification, time and date of collection, and analyses to be performed. An example of the Chain-of-Custody form is included in Appendix D. A more detailed description of Chain-of-Custody documentation is outlined in Section 5. Samples will be scheduled to arrive at the analytical lab within 24 hours after acquisition.

SECTION 5

DOCUMENTATION OF CHAIN OF CUSTODY

To ensure the integrity of samples from time of collection to reporting of analytical results, documentation of Chain-of-Custody is required. Custody documentation will permit tracing of the possession and handling of samples from the time of collection in the field through laboratory analysis and final disposition. The components of the custody procedure include: sample labels, field log, and Chain-of-Custody document containing analysis request. Sample field logs and Chain-of-Custody documents are included in Appendix D.

Sample labels will be attached to all sample containers in order to prevent misidentification of samples. Labels will be filled out and attached to sample containers at the time of sample collection. Protocol for sample labeling is discussed under the appropriate (i.e., soil or groundwater) sampling procedures outlined in Section 4, Field Activities.

Sample seals will be attached to the sample caps in order to detect possible contamination or unauthorized tampering of the samples during transfer. Gummed labels or tape are recommended. The seal will be attached in a manner that requires breaking of the seal in order to open the sample container.

A field sampling log will be maintained to record observations and information obtained during sampling. The field log will include:

- Location of sample point.
- Sample identification.
- Number and volume of samples taken.
- Description of sample point and sample methods.
- Date and time of collection.
- Field observations.
- Field measurements (e.g. pH, temperature, specific conductance).
- Names(s) and signature(s) of persons(s) collecting the sample.

The Chain-of-Custody document will accompany all samples delivered to the laboratory and will include sample identification, date sampled, and analyses requested. Any instructions for special handling, storage, or disposition of the samples also will be included on the request form.

The sample transmittal documents will include the shipping receipts to document sample transport, and sample Chain-of-Custody form. The acknowledgement of receipt will include date of sample receipt, identification of samples received, condition of samples as received, and signature of receiving laboratory representative on the same Chain-of-Custody form.

Copies of all documents relating to sample custody will be permanently retained by SCS Engineers and will be appended to written reports summarizing analytical test results.

SECTION 6

ANALYTICAL SERVICES AND QUALITY ASSURANCE PROCEDURES

ANALYTICAL SERVICES

A chemical testing laboratory certified by the State of California Department of Health Services will be retained to analyze all soil and water samples collected as part of the Site Characterization Program. The primary laboratory to be used is:

SCS Analytical Laboratory
2860 Walnut Avenue
Long Beach, California 90806

The minimum verification laboratory analyses to be performed on each sample will depend on the contaminants known or suspected to be present in each study area and will be in accordance with the "Tri-Regional Board Staff Recommendations for Preliminary Evaluation and Investigation of Underground Tank Sites". All sample analyses for organic compounds will be completed within 14 days of sample collection, or as otherwise required by EPA regulations. If contaminants other than those that are suspected to be present in any given study area or sample, then other EPA-designated analyses will also be performed, as required. Laboratory reports will include sample identification, date sampled, date received, date analyzed, and analytical results.

Internal laboratory QA/QC tests or assessments will be included with all reported test results. A written presentation and critical evaluation of laboratory quality assurance data will be included in site characterization program progress reports. For further explanation of the primary laboratory's QA/QC procedures, refer to the SCS Analytical Laboratory Quality Assurance Quality Control Manual. This manual is available upon request.

QUALITY ASSURANCE PROCEDURES

The quality assurance measures outlined below will be taken in order to ensure and

confirm the integrity and reliability of the analytical laboratory data generated during the Site Characterization Program.

Field Quality Assurance

As a part of the field quality assurance program of the contract, trip and field blanks will accompany all groundwater samples submitted for laboratory analyses. The trip blank will consist of a container of organic-free reagent water that is kept with the field sample containers from the time the samples are originally collected in the field until they are delivered to the laboratory. The purpose of trip blanks is to determine whether samples are being contaminated during transit or sample collection. Trip blanks pertain only to analyses for volatile organic compounds; therefore, the containers must contain no headspace. Only one trip blank is needed for one day's sampling and shall satisfy trip blank requirements for both soil and groundwater materials for that day if all volatile samples are shipped in the same cooler.

The field or rinsate blank will be collected at the sample site using ultrapure water which first has been poured directly into the acrylic bailer and then bottled under the same field conditions as the representative groundwater samples. Disposable bailers are expected to be the primary sampling tool, eliminating the need for equipment decontamination and potential cross-contamination of either field samples or sampling equipment. Should any other reusable sampling equipment be employed, the rinsate blank will consist of reagent water which has been collected from the final rinse of the sampling equipment following decontamination. This will permit detection of whether sampling equipment is causing cross-contamination of samples.

Laboratory Quality Assurance

Duplicate soil and groundwater samples will be simultaneously collected from each well using the same procedures as for collection of the original samples, as outlined in Section 4. The duplicate will be analyzed in the event that the original sample has been tampered with, broken, or otherwise rendered unusable. Duplicate samples also may be used for occasional internal QA/QC purposes in order to provide field

originated checks on the quality and accuracy of laboratory analytical procedures. For these purposes, the identity of the samples will be held blind to the analysts and laboratory personnel until the chemical analyses have been completed.

APPENDIX A
ALAMEDA COUNTY
UNDERGROUND TANK CLOSURE PLAN

ALAMEDA COUNTY HEALTH CARE SERVICES AGENCY
DEPARTMENT OF ENVIRONMENTAL HEALTH
HAZARDOUS MATERIALS DIVISION
80 SWAN WAY, ROOM 200
OAKLAND, CA 94621
PHONE NO. 415/271-4320

Project Specialist (print)

UNDERGROUND TANK CLOSURE PLAN

* * * Complete according to attached instructions * * *

1. Business Name All Right Parking
Business Owner Same
 2. Site Address 1432 Harrison Street
City Oakland Zip 94612 Phone _____
 3. Mailing Address _____
City _____ Zip _____ Phone _____
 4. Land Owner Alvin H. Bacharach, Barbara J. Borsuk
Address 383 Diablo Rd., Ste. 100 City, State Danville, CA Zip 94526
 5. Generator name under which tank will be manifested _____
Barbara J. Borsuk
- EPA I.D. No. under which tank will be manifested CAC 000598840

6. Contractor Falcon Energy Associates
 Address P.O. Box 1257
 City Stockton, 95201 Phone 209-463-7108
 License Type General Engineering ID# 584524
7. Consultant SCS Engineers
 Address 6761 Sierra Court, Suite "D"
 City Dublin, CA Phone 415-829-0661
8. Contact Person for Investigation
 Name Nels R. Johnson Title Senior Project Engineer
 Phone 415-829-0661
9. Number of tanks being closed under this plan 4
 Length of piping being removed under this plan Unknown
 Total number of tanks at facility 4
10. State Registered Hazardous Waste Transporters/Facilities (see instructions).

**** Underground tanks are hazardous waste and must be handled **
 as hazardous waste**

a) Product/Residual Sludge/Rinsate Transporter

Name Falcon Energy Associates EPA I.D. No. CAD 982526857
 Hauler License No. 2463 License Exp. Date June 1991
 Address P.O. Box 1257
 City Stockton, State CA Zip 95201-1257

b) Product/Residual Sludge/Rinsate Disposal Site

Name The Kiesel Company EPA I.D. No. MOT 300011160
 Address 4801 Fyler Avenue
 City St. Louis State MO Zip 63116

c) Tank and Piping Transporter

Name Falcon Energy Associates EPA I.D. No. CAD 982526857
Hauler License No. 2463 License Exp. Date June 1991
Address P.O. Box 1257
City Stockton, State CA Zip 95201-1257

d) Tank and Piping Disposal Site

Name Erickson Inc. EPA I.D. No. CAD 009466392
Address 255 Parr Boulevard
City Richmond, State CA Zip 94801

11. Experienced Sample Collector

Name Don Mc Clenagan
Company SCS Engineers
Address 6761 Sierra Court, Suite "D"
City Dublin, State CA Zip 94568 Phone 829-0661

12. Laboratory

Name SCS Analytical Laboratory
Address 2860 Walnut Avenue
City Long Beach, State CA Zip 90806
State Certification No. _____

13. Have tanks or pipes leaked in the past? Yes [] No []

If yes, describe. Unknown

14. Describe methods to be used for rendering tank inert

One hour prior to scheduled removal of tank, inert tank with dry ice at the rate of 20 lb per 1000 gal capacity with Fire/Health Inspector on-site, test tank with LEL/Oxygen meter.

Before tanks are pumped out and inerted, all associated piping must be flushed out into the tanks. All accessible associated piping must then be removed. Inaccessible piping must be plugged.

The Bay Area Air Quality Management District (771-6000), along with local Fire and Building Departments, must also be contacted for tank removal permits. Fire departments typically require the use of explosion proof combustible gas meters to verify tank inertness. It is the contractor's responsibility to bring a working combustible gas meter on site to verify tank inertness.

15. Tank History and Sampling Information

Gasoline Tanks

Tank		Material to be sampled (tank contents, soil, groundwater, etc.)	Location and Depth of Samples
Capacity	Use History (see instructions)		
1000 gal	Installed in 1975 contained gasoline last used - unknown	Soil/groundwater, if encountered	One at each end of tank from native materials at base of pit, not to exceed 2 ft below tank.
1000 gal	Installed in 1982 contained gasoline last used - unknown	Soil/groundwater, if encountered	One at each end of tank from native materials at base of pit, not to exceed 2 ft below tank.

One soil sample must be collected for every 20 feet of piping that is removed. A ground water sample must be collected should any ground water be present in the excavation.

Excavated/Stockpiled Soil	
Stockpiled Soil Volume (Estimated)	Sampling Plan
Unknown	See Modified Work Plan

Stockpiled soil must be placed on bermed plastic and must be completely covered by plastic sheeting.

16. Chemical methods and associated detection limits to be used for analyzing samples

The Tri-Regional Board recommended minimum verification analyses and practical quantitation reporting limits should be followed. See attached Table 2.

Gasoline Tanks

Contaminant Sought	EPA, DHS, or Other Sample Preparation Method Number	EPA, DHS, or Other Analysis Method Number	Method Detection Limit
TPH Gasoline		EPA 8015 G	Soil/Water 10 ppm/0.5 ppm
TPH Diesel		EPA 8015 D	10 ppm/0.05ppm
BTEX		EPA 8020	10 ppm/0.05 ppm
Oil and Grease		413.1	5 ppb/1 ppb
Total Lead		AA spectroscopy	0.2 ppm/5 ppb

17. Submit Site Health and Safety Plan (See Instructions)

14. Describe methods to be used for rendering tank inert

Before tanks are pumped out and inerted, all associated piping must be flushed out into the tanks. All accessible associated piping must then be removed. Inaccessible piping must be plugged.

The Bay Area Air Quality Management District (771-6000), along with local Fire and Building Departments, must also be contacted for tank removal permits. Fire departments typically require the use of explosion proof combustible gas meters to verify tank inertness. It is the contractor's responsibility to bring a working combustible gas meter on site to verify tank inertness.

15. Tank History and Sampling Information

Waste Oil Tanks

Tank		Material to be sampled (tank contents, soil, groundwater, etc.)	Location and Depth of Samples
Capacity	Use History (see instructions)		
Approximately 1000 gal	Installation: Unknown contained waste oil last used: Unknown	Soil/groundwater, if encountered	One at each end of tank from native materials at base of pit, not to exceed 2 ft below tank.
Approximately 1000 gal	Installation: Unknown contained waste oil last used: Unknown	Soil/groundwater, if encountered	One at each end of tank from native materials at base of pit, not to exceed 2 ft below tank.

One soil sample must be collected for every 20 feet of piping that is removed. A ground water sample must be collected should any ground water be present in the excavation.

Excavated/Stockpiled Soil	
Stockpiled Soil Volume (Estimated)	Sampling Plan
Unknown	See Modified WorkPlan

Stockpiled soil must be placed on bermed plastic and must be completely covered by plastic sheeting.

16. Chemical methods and associated detection limits to be used for analyzing samples

The Tri-Regional Board recommended minimum verification analyses and practical quantitation reporting limits should be followed. See attached Table 2.

Waste Oil Tanks

Contaminant Sought	EPA, DHS, or Other Sample Preparation Method Number	EPA, DHS, or Other Analysis Method Number	Method Detection Limit
			<u>Soil/Water</u>
TPH Diesel		EPA 8015D	10 ppm/0.05 ppm
TPH Gasoline		EPA 8015G	10 ppm/0.5 ppm
BTEX		EPA 8020	5 ppb/1 ppb
Total Lead		AA Spectroscopy	0.2 ppm/5 ppb
Oil & Grease		413.1	10 ppm/0.5 ppm

17. Submit Site Health and Safety Plan (See Instructions)

14. Describe methods to be used for rendering tank inert

Before tanks are pumped out and inerted, all associated piping must be flushed out into the tanks. All accessible associated piping must then be removed. Inaccessible piping must be plugged.

The Bay Area Air Quality Management District (771-6000), along with local Fire and Building Departments, must also be contacted for tank removal permits. Fire departments typically require the use of explosion proof combustible gas meters to verify tank inertness. It is the contractor's responsibility to bring a working combustible gas meter on site to verify tank inertness.

15. Tank History and Sampling Information

Hydraulic Lifts

Tank		Material to be sampled (tank contents, soil, ground-water, etc.)	Location and Depth of Samples
Capacity	Use History (see instructions)		
1. Unknown capacity	Installation of lifts and reservoir is unknown. The tanks possibly contained hydraulic fluid. The date of service discontinuation is unknown.	Soil/groundwater, if encountered	One at each end of tank/lift from native materials at base of pit, not to exceed 2 ft below tank/lift.
2. Unknown capacity			
3. Possible third UST capacity unknown			

One soil sample must be collected for every 20 feet of piping that is removed. A ground water sample must be collected should any ground water be present in the excavation.

Excavated/Stockpiled Soil	
Stockpiled Soil Volume (Estimated)	Sampling Plan
Unknown	See Modified Work Plan

Stockpiled soil must be placed on bermed plastic and must be completely covered by plastic sheeting.

16. Chemical methods and associated detection limits to be used for analyzing samples

The Tri-Regional Board recommended minimum verification analyses and practical quantitation reporting limits should be followed. See attached Table 2.

Hydraulic Lifts

Contaminant Sought	EPA, DHS, or Other Sample Preparation Method Number	EPA, DHS, or Other Analysis Method Number	Method Detection Limit
TPH Diesel		EPA 8015 D	<u>Soil/Water</u> 10 ppm/0.05 ppm
BTEX		EPA 8020	5 ppb/1 ppb
Oil & Grease		413.1	10 ppm/0.5 ppm

17. Submit Site Health and Safety Plan (See Instructions)

18. Submit Worker's Compensation Certificate copy

Name of Insurer Daugherty & Company, 2495 W. March Lane, Stockton

19. Submit Plot Plan (See Instructions)

20. Enclose Deposit (See Instructions)

21. Report any leaks or contamination to this office within 5 days of discovery. The report shall be made on an Underground Storage Tank Unauthorized Leak/Contamination Site Report form. (see Instructions)

22. Submit a closure report to this office within 60 days of the tank removal. This report must contain all the information listed in item 22 of the instructions.

I declare that to the best of my knowledge and belief the statements and information provided above are correct and true.

I understand that information in addition to that provided above may be needed in order to obtain an approval from the Department of Environmental Health and that no work is to begin on this project until this plan is approved.

I understand that any changes in design, materials or equipment will void this plan if prior approval is not obtained.

I understand that all work performed during this project will be done in compliance with all applicable OSHA (Occupational Safety and Health Administration) requirements concerning personnel health and safety. I understand that site and worker safety are solely the responsibility of the property owner or his agent and that this responsibility is not shared nor assumed by the County of Alameda.

Once I have received my stamped, accepted closure plan, I will contact the project Hazardous Materials Specialist at least three working days in advance of site work to schedule the required inspections.

Signature of Contractor

Name (please type) John P. Cummings, Office Director, SCS Engineers

Signature 

Date 6/5/91

Signature of Site Owner or Operator

Name (please type) Alvin H. Bacharach, Barbara Borsuk

Signature _____

Date _____

APPENDIX B
SITE HEALTH AND SAFETY PLAN

**EMPLOYEE HEALTH AND SAFETY PLAN,
POLICIES, AND PROCEDURES
FOR THE CLOSURE OF UNDERGROUND
HAZARDOUS WASTE TANKS
AND OTHER STANDARD FIELD OPERATIONS**

SCS Engineers
6761 Sierra Court, Suite D
Dublin, California 94568
(415) 829-0661

CONTENTS

<u>Section</u>		<u>Page</u>
1	Introduction	1
	General Overview	1
	Intent	1
	Authority and Responsibilities	1
2	Safety Rules, Procedures, and Policies	3
	General	3
	Protective Clothing	3
	Respirators	4
	Eye Protection	4
	Personnel and Equipment Decontamination	5
3	Chemical Abuse/Impairment	7
4	Health and Safety Plan	8
	Scope	8
	Composition of Typical Products Handled	8
	Contaminated Soils	9
	Assessment of Health and Safety Hazards	9
	Organization and Responsibilities	12
	Emergency Actions	13
<u>Appendix</u>		
A-1	Material Safety Data Sheets	
A-2	Site Specific Information and Signature Sheet	
A-3	Signature Sheet	

SECTION 1 INTRODUCTION

General Overview

The following Employee Health and Safety Plan, Policies, Procedures, and Practices have been established for field operations conducted by SCS Engineers, or their subcontractors, involving the removal and closure of underground hazardous waste storage tanks or soil and groundwater contamination assessment and remediation activities in Alameda County. This plan includes both job site activities, including tank removal, excavations, well installation and collection of soil and groundwater samples, and remediation activities, and off-site activities, including trucking and disposal operations, emergency response, and cleanup activities.

Intent

The intent of SCS Engineers Health and Safety Policies and Procedures is to:

- 1) Provide all employees and other individuals involved in both on-site and off-site activities with the safest possible work environment and to minimize or eliminate exposure to any hazardous substances or conditions.
- 2) Comply with the requirements of CFR Section 1900-1910 of the Code of Federal Regulations, and applicable OSHA and Cal OSHA standards.

Authority and Responsibilities

SCS has primary responsibility for the health and safety of their employees during the work outlined in the work plan. Each SCS subcontractor will be responsible for the safe and healthful performance of work by each of its employees or support personnel who may enter the site.

All subcontractors retained by SCS are required to ensure that all their employees, visitors, subcontractors, and suppliers/vendors, while on the work site and in the conduct of this investigation, comply with the provisions of this Health and Safety Plan and the minimum standards set forth under the Federal Occupational Safety and Health Act (OSHA). Any specific operation, machine, or process not covered will be governed by other applicable General Safety Orders of the OSHA, Cal/OSHA. The Subcontractor is required to know the safety regulations which apply to the operation.

SECTION 2
SAFETY RULES, PROCEDURES, AND POLICIES

General

- Employees must immediately notify the Health and Safety Officer, their Supervisor, or any other officer, of any unsafe working condition or equipment.

- A supervisor or his designate must always be present when hazardous materials are handled. No hazardous materials may be transferred or pumped, hoses disconnected/connected/drained, barrels handled, or any similar operation in any manner alone. Use the "Buddy" system - at least two people always must be present.

- Access to safety showers and fire extinguishers must be kept clear at all times.

- Smoking is not permitted on any job site unless specific smoking areas are provided and so marked.

- Any spill must be reported to a supervisor and cleaned up immediately. This includes small spills and spillage on drum transfer. Drum leaks shall be reported to a supervisor and over-packed.

Protective Clothing

Protective clothing is necessary to protect employees from hazardous products, spills, cleanup, soil contamination, and similar operations within the environment. SCS Engineers will provide appropriate protective clothing for various job assignments, at no cost, as required.

Protective clothing includes, but is not limited to:

- 1) Boots or protective shoes, depending on the job function.
- 2) Shirts, pants, or aprons sufficient to allow daily changes of clothes.
- 3) Class A, B, C, or D level personal protection equipment (PPE), as required.
- 4) Gloves appropriate for the materials handled or work environment.
- 5) Hard hats are required for all job site personnel.

Employees are required to:

- 1) Wear the designated protective clothing when instructed.
- 2) Maintain cleanliness of PPE.
- 3) Advise their supervisor of defects, loss, or damage to PPE.

Respirators

Company responsibility:

Whenever it has been determined that an airborne health hazard exists or may exist, SCS Engineers will provide and maintain the appropriate-level respirator.

Employee responsibility:

- 1) Use the appropriate respirator in accordance with the instructions and hazards determined for each particular work area, job site application, or job function.
- 2) Report any malfunction of the respirator to immediate supervisor.
- 3) Inspect the respirator prior to use for visible defects or damage.
- 4) Clean the respirator and periodically replace filters, as needed.
- 5) As preventative maintenance, store respirator in proper container or use plastic-lock bag.

Eye Protection

Safety glasses with side shields, goggles, or face shields will be provided to any employee who wants or is required to use them for any aspect or operation associated with removal, closure, sampling, or other site activities related to tank removals or other field operations.

In addition, individuals performing or working near the following operations will be required to use the indicated eye protection:

- 1) Welding, brazing, or metal flame cutting: welder's goggles with intensity filters.
- 2) Drumming: splash-proof goggles or face shield.
- 3) Pumping: face shield.

Personnel and Equipment Decontamination

Decontamination of equipment and personnel is necessary to confine the contaminants to the site and to preclude migration elsewhere. Upon leaving the work area, all major equipment, tools, and materials will be cleaned to remove grease, oil, or encrusted dirt.

Decontamination procedures are discussed in more depth below. Personnel decontamination will involve washing of hands and face with soap and water after removal of protective gear and prior to eating. Boots, respirators, gloves, and hard hats will be washed in a soap and water wash. Tyvek will be placed in a plastic bag for disposal.

Equipment Decontamination:

All major reusable equipment and other tools for boring activities will be decontaminated prior to leaving the work area. Cleaning will normally consist of scrubbing to remove encrusted materials, followed by a soap-and-water wash and potable water rinse using a high-pressure, low-volume water spray or steam cleaning unit. Containers of detergent solutions for cleaning tools, boots, and gloves will also be available.

A drill rig decontamination area will be established where the rig will be cleaned before it is moved out of the work area.

Personnel responsible for steam cleaning will use appropriate personal protective equipment.

Personnel Decontamination:

Decontamination of personnel will be performed within the designated decontamination zone. Decontamination will consist primarily of soap-and-water washing and water rinse

of exterior protective gear to remove contaminants, followed by removal of gear. Disposable coveralls will be removed by turning the clothing inside out. A general sequence of doffing procedures is outlined below. The extent of required washing, or modifications to the sequence, may be specified by the Site Health and Safety Officer as appropriate.

The minimum steps in decontamination will be as follows:

- Wash work gloves and boots;
- Rinse respirator; and
- Wash hands and face.

Contaminated protective clothing will be properly disposed. Provisions for emergency decontamination will be available as designated by the Site Health and Safety Officer at the drilling site. Clean water will be provided to rinse work gloves and boots.

Eating, Drinking, and Smoking:

Eating, drinking, or smoking will not be allowed in the work area and decontamination zone. Potable water will be available in areas just outside the work area.

SECTION 3
CHEMICAL ABUSE/IMPAIRMENT

As employees may be working near or with hazardous or dangerous materials and conditions, and operating or working near heavy equipment, it is imperative that employees not be impaired or under the influence of ANY chemical which reduces their effectiveness in reacting to a dangerous condition. Therefore, SCS Engineers, in order to protect all employees who depend on each other, establishes the following abuse/impairment policy:

- Chemical abuse/impairment is defined as use of alcohol, medication, drugs, or other chemical substances without a doctor's permission which alters, impairs, or changes the physical and mental condition of the employee.
- Consumption of any alcoholic beverage in any quantity at any job site is absolutely prohibited. Any person observed consuming alcoholic beverages during the work day, regardless of the hour or day, will be immediately fired.
- Any employee reporting to work at any location under the influence of alcohol, smelling of alcohol, or if alcoholic containers are found in any equipment, will be immediately fired.
- Any employee found to be using any other illegal drug at any time on any job site will be immediately fired.
- Any employee taking medication under a doctor's care or who has purchased over the counter medication must advise his supervisor.
- All employees are encouraged not to smoke. SCS Engineers will discuss any legitimate request of any employee to quit smoking and help place them in a program, if sponsored by the Company's health care provider. Employees are encouraged to participate in these medically supervised programs.

SECTION 4
SCS ENGINEERS HEALTH AND SAFETY PLAN

Scope

The SCS Engineers Health and Safety Plan outlined below is intended both to provide and ensure adequate safeguards to all personnel who may be exposed to hazardous materials or conditions during the normal course of their work conducting closure and other associated site operations and activities related to underground storage tank removal and other field operations. The scope of this plan does not include unexpected or unusual occurrences.

Composition of Typical Products Handled

Most products encountered in routine tank removal and closure operations and associated soil and groundwater contamination assessment and mitigation/remediation investigations are organic compounds that commonly include, but are not limited to:

- A) diesel fuel
- B) gasoline
 - 1) leaded
 - 2) unleaded
- C) waste oil and grease
- D) kerosene
- E) hydraulic lift fluid
- F) tank and pipe rinsate
 - 1) 99 percent water
 - 2) 1 percent detergents and trace elements
- G) possible inorganic heavy metals, such as lead or zinc
- H) polychlorinated biphenyls (PCBs)

Contaminated Soils

Results of laboratory soils analyses typically take two weeks or more to complete after tank removal. Treatment of soils, contamination procedures, and site remediation are separate processes which are covered by additional safety procedures not included in this list.

Assessment of Health and Safety Hazards

Initial site operations typically encompass only removal of cleaned tanks and product piping. Therefore, level D personal protective equipment (PPE) is the normal required level of protection at this stage of site operations.

Fire and Explosion:

Two fire extinguishers with a minimum class rating of 20 BC shall be kept within at least 50 feet of the removal operation at all times during work operations. Open flames or other ignition sources are not permitted anywhere within the area of operations. NO SMOKING signs will be posted in proximity to the work site. The use of welding or other electrical-spark producing equipment is specifically prohibited in the vicinity of a contaminated site or tank containing product residue. If such operations are determined to be necessary, approval of the Health and Safety Officer or other appropriate supervisor is required and the tank must previously have been rendered inert. The local fire district also should be notified in order to determine whether a fire inspector/observer should be present. Care always should be taken not to severely impact, crush, or puncture the tank prior to inerting, especially when it is known or suspected to contain volatile or potentially explosive compounds or gases.

Other Physical Hazards:

SCS Engineers routinely encourages fencing of all tank removal and excavation sites for the duration of work operations, if existing plant fencing and security is not present or adequate. If our clients refuse, a waiver must be signed wherein the client excludes SCS Engineers from any liability or responsibility contained therein owing to the lack of fencing. Normally, barricades and caution tape are used to restrict access to the area

of work operations, and may be used to secure a site overnight if no deep excavations or other hazards are present. If deep excavations must be left open unattended, then steel trench plates or plywood should be used to completely and securely cover the excavation. Work operations that can be completed during the same day and remain under the direct supervision of the Project Manager may be exempted from the fencing requirement, with the prior approval of the Health and Safety Officer.

It is expected that the work operations involving excavation, waste oil tank removals, and collection of soil samples in the Alice Street basement will be conducted in an area of both restricted access and limited air circulation. Consequently, the additional measures outlined below will be taken in order to ensure that safe and healthful working conditions are maintained. Ear protection will be worn by all employees and subcontractors at all times when work is in progress in this area. Dust masks and/or full-face respirators also will be available at all times for protection from dust and potential airborne contaminants stirred up during excavation and tank removal. At least 2 high-volume fans will be placed at existing grates in the basement ceiling/Alice Street sidewalk - one intake, one exhaust - to provide both fresh air to and air circulation within the basement area of work operations. Exhaust from stationary drilling and/or excavating equipment involved in the tank removal operations will be vented directly to the outside via closed lines. Only those vehicles or equipment directly required or involved in the removal operations will be permitted in the basement area of operations. Vehicles and other equipment shall be shut off when not in use. Equipment operators will need to exercise particular caution at all times when working in this area, both because of the low vertical clearance and the presence of overhead electrical lines near the excavation area.

No deep excavations are expected for this project. All soil sampling will be completed with mechanical equipment from the surface outside the excavation. No site personnel are allowed to enter any excavation deeper than 4 feet. Deeper excavations must be shored or braced, or must be performed using special excavation procedures following appropriate OSHA and Cal OSHA standards for stepping and/or sloping sidewalls.

If underground utilities are known or suspected to be located within or near the area of the planned excavation, U.S. Alert will be contacted in advance of the work operations to precisely locate and label the lines and/or associated facilities. Any site personnel working or excavating near operating utility lines of any kind (i.e., electrical, gas, water/sewer, etc.) should always exercise extreme caution and should immediately notify the Project Manager or other supervisor if any damage, leakage, or other problem is observed.

Chemical and Other Health Hazards:

The major chemicals suspected to be present are listed above. Material Safety Data Sheets (MSDS) are presented in Appendix A.

Airborne contaminants at the site could exceed currently recognized health limits for waste oil, gasoline, benzene, toluene, and xylene. Benzene is a suspect carcinogen which is regulated by Cal/OSHA and OSHA. Air purifying respirators are not approved for worker protection against benzene.

An organic vapor meter OVM will be routinely used to monitor the breathing zone for volatile organic compounds during excavation and other field activities. Respirators will be required if readings at any time exceed 300 ppm over background. Workers may continue work in respirators until concentrations reach 500 ppm. At that point, personnel will use airline respirators to continue work or evacuate the work zone until levels dissipate.

Contact with contaminated waste materials and soils would be expected to irritate the skin, with prolonged exposure leading to the development of skin lesions. For this reason direct skin contact with drilling soils will be avoided by wearing protective gloves. Protective gloves and safety goggles will be required in areas where waste materials and contaminated soil are handled.

Organization and Responsibilities

Project Manager:

A project-specific Senior Project Manager or Project Engineer or Scientist, or his/her designee, is specifically responsible for all aspects of daily operations and for each specific site operation regarding tank removals, soil/groundwater sampling, or well installations. This Project Manager is responsible for the project through its successful completion, and all questions or problems associated with the projects should be directed to him/her. The Project Manager also is responsible for daily safety briefings and updates or site-specific changes to work crews and subcontractors prior to the start of work operations. Any designee shall report directly to the Project Manager.

Site Health and Safety Officer:

The Project Manager is authorized to act as the Site Health and Safety Officer. The office Health and Safety Officer may appoint a designee to act as Health and Safety Officer for a specific job and he/she shall report directly to the Project Manager.

The Safety Officer is specifically given authority to take the following actions:

- Require specific health and safety precautions prior to site entry by subcontractors, their personnel, visitors, SCS personnel or any other job site participants. This includes hard hats, any appropriate eye, ear, or foot protection, respirators, or any other safety equipment that the site Safety Officer deems necessary.
- Require any worker, including subcontractor personnel, to obtain immediate medical attention.
- Deny access to the site or any portion thereof when imminent health and safety risk exists.
- Order the immediate evacuation of workers, including subcontractor personnel, from any area of the site when, in the Safety Officer's professional judgement, conditions warrant such action. This includes shutting the site down.

Emergency Actions

If any emergency involving actual or suspected personnel injury or adverse chemical exposure occurs, the Safety officer shall take the following steps:

- 1) Remove the exposed or injured person(s) from the immediate area of danger.
- 2) Render first aid, if necessary. Decontaminate the victim's outer clothing only after critical first aid has been administered.
- 3) Obtain paramedic services or ambulance services. Transport the victim(s) to the closest local hospital for proper medical care. This procedure IS TO BE FOLLOWED even if no visible injuries are apparent.
- 4) Other personnel shall be evacuated to a safe distance until it has been determined by the site Safety Officer or other emergency response personnel that a safe site exists to resume work. If any doubt or questions exist, further appropriate advice shall be sought.
- 5) At the first opportunity, the Safety Officer shall contact the Project Manager and provide details, including a written report, of the conditions leading to and response to the suspected incident and procedures taken to prevent any subsequent recurrence.
- 6) A written report of the incident shall be prepared by the Safety Officer and the Project Manager within twenty-four (24) hours following the incident. There are NO EXCEPTIONS.

Site Shut-Down:

The Safety Officer shall shut any job site down and evacuate all site personnel to safe distance, if any of the following conditions occur:

- a) Extremely strong odors
- b) Excavation conditions which are unsafe, including but not limited to dirt slippage and slumping, excessive moisture, exposed or damaged utilities, and other similar observances.
- c) Instability of any equipment or structure.
- d) In any of these events, or similar occurrences, in the judgement of the Safety Officer, work will stop at the site until a modified work plan is prepared and approved by the Project Manager and regulatory agencies as necessary.

Emergency Response and Containment:

The Safety Officer is authorized to implement appropriate emergency response in accordance with the SCS Engineers EMR procedure plan either to protect worker health and safety or to contain accidental spills so as to minimize further environmental damage. The Safety Officer is further authorized to utilize the closest available local EMR facilities when required by his judgement.

If no undue risk is present, site personnel may attempt to contain a spill using whatever safe means are available, prevent additional spillage, and prevent spill migration into any storm drains, sewers, or natural drainage and waterways.

Available On-Site Safety Equipment:

Fire extinguishers, first aid kits, water, level D suits and PPE, head protection, eye protection, and gloves are to be available at each site at all times during work operations.

APPENDIX A1

MATERIAL SAFETY DATA SHEETS

GASOLINES: AUTOMOTIVE (<4.23g lead/gal)

GAT

<p>Common Synonyms Motor spirit Petrol</p>	<p>Watery liquid Colorless to pale brown or pink</p> <p>Gasoline odor</p> <p>Floats on water. Flammable, misting vapor is produced.</p>		
<p>Stop discharge if possible. Keep people away. Shut off ignition sources and call fire department. Stay upwind and use water spray to "knock down" vapor. Isolate and remove discharged material. Notify local health and pollution control agencies.</p>			
<p>Fire</p>	<p>FLAMMABLE. Flashback along vapor trail may occur. Vapor may explode if ignited in an enclosed area. Extinguish with dry chemical, foam, or carbon dioxide. Water may be ineffective on fire. Cool exposed containers with water.</p>		
<p>Exposure</p>	<p>CALL FOR MEDICAL AID.</p> <p>VAPOR Inhaling to eyes, nose and throat. If inhaled, may cause dizziness, headache, difficult breathing or loss of consciousness. Move to fresh air. If breathing has stopped, give artificial respiration. If breathing is difficult, give oxygen.</p> <p>LIQUID Irritating to skin and eyes. If swallowed, will cause nausea or vomiting. Remove contaminated clothing and shoes. Flush affected areas with plenty of water. If IN EYES, hold eyelids open and flush with plenty of water. If SWALLOWED and victim is CONSCIOUS, have victim drink water to milk.</p> <p>DO NOT INDUCE VOMITING.</p>		
<p>Water Pollution</p>	<p>HARMFUL TO AQUATIC LIFE IN VERY LOW CONCENTRATIONS. Floating in shoreline. May be dangerous if it enters water intakes. Notify local health and wildlife officials. Notify operators of nearby water intakes.</p>		
<p>1. RESPONSE TO DISCHARGE (See Response Methods Handbook) Issue warning-high flammability Evacuate area Disperse and flush</p>		<p>2. LABEL 2.1 Category: Flammable liquid 2.2 Class: 3</p>	
<p>3. CHEMICAL DESIGNATIONS 3.1 CG Compatibility Class: Miscellaneous Hydrocarbon Mixtures 3.2 Formula (Mixture of hydrocarbons) 3.3 IMD/UN Designation: 3 1/1203 3.4 DOT ID No.: 1203 3.5 CAS Registry No.: Data not available</p>		<p>4. OBSERVABLE CHARACTERISTICS 4.1 Physical State (as shipped): Liquid 4.2 Color: Colorless to brown 4.3 Odor: Gasoline</p>	
<p>5. HEALTH HAZARDS</p>			
<p>5.1 Personal Protective Equipment: Protective goggles, gloves. 5.2 Symptoms Following Exposure: Irritation of mucous membranes and stimulation followed by depression of central nervous system. Breathing of vapor may also cause dizziness, headache, and incoordination or, in more severe cases, anesthesia, coma, and respiratory arrest. If liquid enters lungs, it will cause severe irritation causing gagging, pulmonary edema, and, later, signs of bronchopneumonia and pneumonia. Swallowing may cause irregular heartbeat. 5.3 Treatment of Exposure: INHALATION maintain respirator and administer oxygen, enforce bed rest if liquid is in lungs. INGESTION do NOT induce vomiting; stomach should be lavaged (by doctor) if appreciable quantity is swallowed. EYES wash with copious quantity of water. SKIN wipe off and wash with soap and water. 5.4 Threshold Limit Value: 300 ppm 5.5 Short Term Inhalation Limits: 500 ppm for 30 min. 5.6 Toxicity by Ingestion: Grade 2, LD₅₀ = 0.5 to 5 g/kg 5.7 Late Toxicity: None 5.8 Vapor (Gas) Irritant Characteristics: Vapors cause a slight stinging of the eyes or respiratory system if present in high concentrations. The effect is temporary. 5.9 Liquid or Solid Irritant Characteristics: Minimum hazard if spilled on clothing and allowed to remain; may cause stinging and reddening of the skin. 5.10 Odor Threshold: 0.25 ppm 5.11 ADLH Value: Data not available</p>			
<p>6. FIRE HAZARDS</p>			
<p>6.1 Flash Point: -36°F C.C. 6.2 Flammable Limits in Air: 1.4%-7.4% 6.3 Fire Extinguishing Agents: Foam, carbon dioxide, dry chemical 6.4 Fire Extinguishing Agents Not to be Used: Water may be ineffective 6.5 Special Hazards of Combustion Products: None 6.6 Behavior in Fire: Vapor is heavier than air and may have considerable distance to a source of ignition and flash back. 6.7 Ignition Temperature: 853°F 6.8 Electrical Hazard: Class I, Group D 6.9 Burning Rate: 4 mm/min. 6.10 Adiabatic Flame Temperature: Data not available 6.11 Stoichiometric Air to Fuel Ratio: Data not available 6.12 Flame Temperature: Data not available</p>			
<p>7. CHEMICAL REACTIVITY</p>			
<p>7.1 Reactivity With Water: No reaction 7.2 Reactivity with Common Materials: No reaction 7.3 Stability During Transport: Stable 7.4 Neutralizing Agents for Acids and Caustics: Not pertinent 7.5 Polymerization: Not pertinent 7.6 Inhibitor of Polymerization: Not pertinent 7.7 Molecular Ratio (Reactant to Product): Data not available 7.8 Reactivity Group: 33</p>			
<p>8. WATER POLLUTION</p>			
<p>8.1 Aquatic Toxicity: 100 ppm/24 hr./juvenile American shad/TL₅₀/fresh water 0.1 mg/l/24 hr./juvenile American shad/TL₅₀/salt water 8.2 Waterfowl Toxicity: Data not available 8.3 Biological Oxygen Demand (BOD): 0%, 5 days 8.4 Food Chain Concentration Potential: None</p>			
<p>9. SHIPPING INFORMATION</p>			
<p>9.1 Grades of Purity: Various octane ratings, military specifications 9.2 Storage Temperature: Ambient 9.3 Inert Atmosphere: No requirement 9.4 Venting: Open (Some varieties) or pressure-vacuum</p>			
<p>10. HAZARD ASSESSMENT CODE (See Hazard Assessment Handbook) A-T-U-V-W</p>			
<p>11. HAZARD CLASSIFICATIONS</p>			
<p>11.1 Code of Federal Regulations: Flammable liquid 11.2 NAS Hazard Rating for Bulk Water Transportation: Category Rating Fire 3 Health Vapor Inhalation 1 Liquid or Solid Inhalation 1 Poisons 2 Water Pollution Human Toxicity 1 Aquatic Toxicity 2 Aesthetic Effect 2 Reactivity Other Chemicals 0 Water 0 Self Reaction 0 11.3 NFPA Hazard Classification: Category Classification Health Hazard (Blue) 1 Flammability (Red) 3 Reactivity (Yellow) 0</p>			
<p>12. PHYSICAL AND CHEMICAL PROPERTIES</p>			
<p>12.1 Physical State at 15°C and 1 atm: Liquid 12.2 Molecular Weight: Not pertinent 12.3 Boiling Point at 1 atm: 140-200°F = 60-100°C = 332-472°K 12.4 Freezing Point: Not pertinent 12.5 Critical Temperature: Not pertinent 12.6 Critical Pressure: Not pertinent 12.7 Specific Gravity: 0.732 at 20°C (liquid) 12.8 Liquid Surface Tension: 19.23 dynes/cm = 0.019-0.023 N/m at 20°C 12.9 Liquid Water Interfacial Tension: 49.51 dynes/cm = 0.049-0.051 N/m at 20°C 12.10 Vapor (Gas) Specific Gravity: 3.4 12.11 Ratio of Specific Heats of Vapor (Gas): [ref] 1.054 12.12 Latent Heat of Vaporization: 125-180 Btu/lb = 71-81 cal/g = 3.0 - 3.4 x 10⁴ J/kg 12.13 Heat of Combustion: -18,720 Btu/lb = -10,400 cal/g = 435.1 x 10⁴ J/kg 12.14 Heat of Decomposition: Not pertinent 12.15 Heat of Solution: Not pertinent 12.16 Heat of Polymerization: Not pertinent 12.17 Heat of Fusion: Data not available 12.18 Limiting Value: Data not available 12.19 Reid Vapor Pressure: 7.4 psia</p>			
<p>NOTES</p>			

BENZENE

BNZ

<p>Common Synonyms Benzol Benzole</p>		<p>Wettable liquid</p>	<p>Colorless</p>	<p>Gasoline like odor</p>
<p>Floats on water. Flammable, emitting vapor is produced. Freezing point is 42°F.</p>				
<p>Avoid contact with liquid and vapor. Keep people away. Wear goggles and self-contained breathing apparatus. Shut off gas leak sources and call fire department. Stop discharge if possible. Stay upwind and use water spray to "knock down" vapor. Isolate and remove discharged material. Notify local health and pollution control agencies.</p>				
<p>Fire</p>	<p>FLAMMABLE. Flashback along vapor trail may occur. Vapor may explode if ignited in an enclosed area. Wear goggles and self-contained breathing apparatus. Extinguish with dry chemical, foam, or carbon dioxide. Water may be ineffective on fire. Cool expanded containers with water.</p>			
<p>Exposure</p>	<p>CALL FOR MEDICAL AID. VAPOR Irritating to eyes, nose and throat. If inhaled, may cause headache, difficult breathing, or loss of consciousness. Move to fresh air. If breathing has stopped give artificial respiration. If breathing is difficult, give oxygen. LIQUID Irritating to skin and eyes. Harmful if swallowed. Remove contaminated clothing and shoes. Flush affected areas with plenty of water. If in EYES, hold eyelids open and flush with plenty of water. If SWALLOWED and victim is CONSCIOUS, have victim drink water or milk.</p>			
<p>Water Pollution</p>	<p>HARMFUL TO AQUATIC LIFE IN VERY LOW CONCENTRATIONS. May be dangerous if it enters water intakes. Notify local health and waste officials. Notify operators of nearby water intakes.</p>			
<p>1. RESPONSE TO DISCHARGE (See Response Methods Handbook) Have warning-high flammability. Restrict access.</p>		<p>2. LABEL 2.1 Category: Flammable liquid 2.2 Class: 3</p>		
<p>3. CHEMICAL DESIGNATIONS 3.1 CG Compatibility Class: Aromatic hydrocarbon 3.2 Formula: C₆H₆ 3.3 IMDG/M Designation: 2.2/1114 3.4 DOT ID No.: 1114 3.5 CAS Registry No.: 71-43-2</p>		<p>4. OBSERVABLE CHARACTERISTICS 4.1 Physical State (as shipped): Liquid 4.2 Color: Colorless 4.3 Odor: Aromatic, rather pleasant aromatic odor, characteristic odor</p>		
<p>5. HEALTH HAZARDS</p> <p>5.1 Personal Protective Equipment: Hydrocarbon vapor canister, supplied air or a hose mask; hydrocarbon-insoluble rubber or plastic gloves, chemical goggles or face splash shield; hydrocarbon-insoluble apron such as neoprene.</p> <p>5.2 Symptoms Following Exposure: Dizziness, excitation, pallor, followed by flushing, weakness, headache, breathlessness, chest constriction. Coma and possible death.</p> <p>5.3 Treatment of Exposure: SKIN: Flush with water followed by soap and water; remove contaminated clothing and wash skin. EYES: Flush with plenty of water until irritator subsides. INHALATION: Remove from exposure immediately. Call a physician if breathing is irregular or stopped; start resuscitation; administer oxygen.</p> <p>5.4 Threshold Limit Value: 10 ppm</p> <p>5.5 Short Term Inhalation Limits: 75 ppm for 30 min.</p> <p>5.6 Toxicity by Ingestion: Grade 3, LD₅₀ = 30 to 500 mg/kg</p> <p>5.7 Late Toxicity: Leukemia</p> <p>5.8 Vapor (Gas) Irritant Characteristics: If present in high concentrations, vapors may cause irritation of eyes or respiratory system. The effect is temporary.</p> <p>5.9 Liquid or Solid Irritant Characteristics: Minimum hazard if spilled on clothing and allowed to remain; may cause staining and reddening of the skin.</p> <p>5.10 Odor Threshold: 4.66 ppm</p> <p>5.11 IDLH Value: 2,000 ppm</p>				

6. FIRE HAZARDS

6.1 Flash Point: 12°F C.C.

6.2 Flammable Limits in Air: 1.3%-7.8%

6.3 Fire Extinguishing Agents: Dry chemical, foam, or carbon dioxide

6.4 Fire Extinguishing Agents Not to be Used: Water may be ineffective

6.5 Special Hazards of Combustion Products: Not pertinent

6.6 Behavior in Fire: Vapor is heavier than air and may travel considerable distance to a source of ignition and flash back

6.7 Ignition Temperature: 1057°F

6.8 Electrical Hazard: Class I, Group D

6.9 Burning Rate: 8.8 mm/min.

6.10 Adiabatic Flame Temperature: Data not available

6.11 Stoichiometric Air to Fuel Ratio: Data not available

6.12 Flame Temperature: Data not available

7. CHEMICAL REACTIVITY

7.1 Reactivity with Water: No reaction

7.2 Reactivity with Common Materials: No reaction

7.3 Stability During Transport: Stable

7.4 Neutralizing Agents for Acids and Caustics: Not pertinent

7.5 Polymerization: Not pertinent

7.6 Inhibitor of Polymerization: Not pertinent

7.7 Molar Ratio (Reactant to Product): Data not available

7.8 Reactivity Group: 32

8. WATER POLLUTION

8.1 Aquatic Toxicity:
2 ppm/6 hr (minimum) (aerial/dissolved water)
20 ppm/24 hr (aerial/TL₅₀/tap water)

8.2 Waterpool Toxicity: Data not available

8.3 Biological Oxygen Demand (BOD):
1.7 lb/lb, 10 days

8.4 Food Chain Concentration Potential: None

9. SHIPPING INFORMATION

9.1 Grades of Purity:
Industrial pure 99+ %
Theophane-free 99+ %
Inversion 99+ %
Industrial 90% 95+ %
Reagent 99+ %

9.2 Storage Temperature: Open

9.3 Inert Atmosphere: No requirement

9.4 Venting: Pressure-relieving

10. HAZARD ASSESSMENT CODE
(See Hazard Assessment Handbook)
A-T-U-V-W

11. HAZARD CLASSIFICATIONS

11.1 Code of Federal Regulations: Flammable liquid

11.2 NFPA Hazard Rating for Bulk Water Transportation:

Category	Rating
Fire	3
Health	
Vapor Irritant	1
Liquid or Solid Irritant	1
Poison	3
Water Pollution	
Human Toxicity	3
Aquatic Toxicity	1
Asphyxiant Effect	3
Reactivity	
Other Chemical	2
Water	1
Self Reaction	0

11.3 NFPA Hazard Classification:

Category	Classification
Health Hazard (Blue)	2
Flammability (Red)	3
Reactivity (Yellow)	0

12. PHYSICAL AND CHEMICAL PROPERTIES

12.1 Physical State at 15°C and 1 atm: Liquid

12.2 Molecular Weight: 78.11

12.3 Boiling Point at 1 atm: 176°F = 80.1°C = 353.2°K

12.4 Freezing Point: 42.0°F = 5.5°C = 278.7°K

12.5 Critical Temperature: 552.0°F = 294.9°C = 562.1°K

12.6 Critical Pressure: 710 psia = 47.2 atm = 4.89 MN/m²

12.7 Specific Gravity: 0.878 at 20°C (liquid)

12.8 Liquid Surface Tension: 28.8 dynes/cm = 0.0288 N/m at 20°C

12.9 Liquid Water Interfacial Tension: 35.0 dynes/cm = 0.035 N/m at 20°C

12.10 Vapor (Gas) Specific Gravity: 2.7

12.11 Ratio of Specific Heats of Vapor (Gas): 1.081

12.12 Latent Heat of Vaporization: 169 Btu/lb = 34.1 cal/g = 394 ± 10³ J/kg

12.13 Heat of Combustion: -17,460 Btu/lb = -8060 cal/g = -406.0 ± 10³ J/kg

12.14 Heat of Decomposition: Not pertinent

12.15 Heat of Solution: Not pertinent

12.16 Heat of Polymerization: Not pertinent

12.25 Heat of Fusion: 30.45 cal/g

12.26 Limiting Value: Data not available

12.27 Reid Vapor Pressure: 3.27 psia

NOTES

TOLUENE

TOL

<p>Common Synonyms Toluol Methylbenzene Methylbenzol</p> <p>Water: liquid Colorless Pleasant odor</p> <p>Floats on water. Flammable, irritating vapor is produced.</p>		<p>6. FIRE HAZARDS</p> <p>6.1 Flash Point: 40°F C.C., 55°F O.C. 6.2 Flammable Limits in Air: 1.27%-7% 6.3 Fire Extinguishing Agents: Carbon dioxide or dry chemical for small fires, ordinary foam for large fires. 6.4 Fire Extinguishing Agents Not to be Used: Water may be ineffective. 6.5 Special Hazards of Combustion Products: Not pertinent. 6.6 Behavior in Fire: Vapor is heavier than air and may travel a considerable distance to a source of ignition, and flash back. 6.7 Ignition Temperature: 697°F 6.8 Electrical Hazard: Class I, Group D 6.9 Burning Rate: 57 mm/min. 6.10 Adiabatic Flame Temperature: Data not available</p> <p style="text-align: right;">(Continued)</p>		<p>10. HAZARD ASSESSMENT CODE (See Hazard Assessment Handbook) A-T-U</p>																																			
<p>Stop discharge if possible. Keep people away. Shut off ignition sources and call for department. Stay upwind and use water spray to "knock down" vapor. Avoid contact with liquid and vapor. Isolate and remove damaged material. Notify local health and pollution control agencies.</p>		<p>11. HAZARD CLASSIFICATIONS</p> <p>11.1 Code of Federal Regulations: Flammable liquid</p> <p>11.2 MAS Hazard Rating for Bulk Water Transportation:</p> <table border="1"> <thead> <tr> <th>Category</th> <th>Rating</th> </tr> </thead> <tbody> <tr> <td>Fire</td> <td>3</td> </tr> <tr> <td>Health</td> <td></td> </tr> <tr> <td>Vapor Irritant</td> <td>1</td> </tr> <tr> <td>Liquid or Solid Irritant</td> <td>1</td> </tr> <tr> <td>Poisons</td> <td>2</td> </tr> <tr> <td>Water Pollution</td> <td></td> </tr> <tr> <td>Human Toxicity</td> <td>1</td> </tr> <tr> <td>Aquatic Toxicity</td> <td>3</td> </tr> <tr> <td>Aesthetic Effect</td> <td>3</td> </tr> <tr> <td>Reactivity</td> <td></td> </tr> <tr> <td>Other Chemicals</td> <td>1</td> </tr> <tr> <td>Waxes</td> <td>0</td> </tr> <tr> <td>Soil Reaction</td> <td>0</td> </tr> </tbody> </table> <p>11.3 NFPA Hazard Classification:</p> <table border="1"> <thead> <tr> <th>Category</th> <th>Classification</th> </tr> </thead> <tbody> <tr> <td>Health Hazard (Blue)</td> <td>2</td> </tr> <tr> <td>Flammability (Red)</td> <td>3</td> </tr> <tr> <td>Reactivity (Yellow)</td> <td>0</td> </tr> </tbody> </table>		Category	Rating	Fire	3	Health		Vapor Irritant	1	Liquid or Solid Irritant	1	Poisons	2	Water Pollution		Human Toxicity	1	Aquatic Toxicity	3	Aesthetic Effect	3	Reactivity		Other Chemicals	1	Waxes	0	Soil Reaction	0	Category	Classification	Health Hazard (Blue)	2	Flammability (Red)	3	Reactivity (Yellow)	0
Category	Rating																																						
Fire	3																																						
Health																																							
Vapor Irritant	1																																						
Liquid or Solid Irritant	1																																						
Poisons	2																																						
Water Pollution																																							
Human Toxicity	1																																						
Aquatic Toxicity	3																																						
Aesthetic Effect	3																																						
Reactivity																																							
Other Chemicals	1																																						
Waxes	0																																						
Soil Reaction	0																																						
Category	Classification																																						
Health Hazard (Blue)	2																																						
Flammability (Red)	3																																						
Reactivity (Yellow)	0																																						
<p>Fire</p> <p>FLAMMABLE. Flashback along water trail may occur. Vapor may explode if ignited in an enclosed area. Vials, bottles and soft-cans and breathing apparatus (if long use) with dry chemical, foam, or carbon dioxide. Water may be ineffective on fire. Do not reject containers with water.</p>		<p>7. CHEMICAL REACTIVITY</p> <p>7.1 Reactivity with Water: No reaction 7.2 Reactivity with Common Materials: No reaction 7.3 Stability During Transport: Stable 7.4 Neutralizing Agents for Acids and Caustics: Not pertinent 7.5 Polymerization: Not pertinent 7.6 Initiator of Polymerization: Not pertinent 7.7 Oxidation (Resistant to Product): Data not available 7.8 Reactivity Group: 2</p>		<p>12. PHYSICAL AND CHEMICAL PROPERTIES</p> <p>12.1 Physical State at 15°C and 1 atm: Liquid 12.2 Molecular Weight: 92.14 12.3 Boiling Point at 1 atm: 231.1°F = 110.6°C = 393.8°K 12.4 Freezing Point: -138°F = -95.0°C = 178.2°K 12.5 Critical Temperature: 805.4°F = 318.0°C = 591.6°K 12.6 Critical Pressure: 596.1 psia = 40.55 atm = 4.108 MN/m² 12.7 Specific Gravity: 0.867 at 20°C (liquid) 12.8 Liquid Surface Tension: 28.0 dynes/cm = 0.0290 N/m at 20°C 12.9 Liquid Water Interfacial Tension: 26.1 dynes/cm = 0.0261 N/m at 25°C 12.10 Vapor (Gas) Specific Gravity: Not pertinent 12.11 Ratio of Specific Heats of Vapor (Gas): 1.088 12.12 Latent Heat of Vaporization: 155 Btu/lb = 86.1 cal/g = 3.61 x 10⁵ J/kg 12.13 Heat of Combustion: -17,430 Btu/lb = -8666 cal/g = -405.5 x 10³ J/kg 12.14 Heat of Decomposition: Not pertinent 12.15 Heat of Solution: Not pertinent 12.16 Heat of Polymerization: Not pertinent 12.25 Heat of Fusion: 17.17 cal/g 12.26 Limiting Value: Data not available 12.27 Reid Vapor Pressure: 1.1 psia</p>																																			
<p>Exposure</p> <p>VAPOR Irritating to eyes, nose and throat. If inhaled, may cause nausea, vomiting, headache, dizziness, difficult breathing, or loss of consciousness. Move to fresh air. If breathing has stopped give artificial respiration. If breathing difficult give oxygen.</p> <p>LIQUID Irritating to skin and eyes. If swallowed, will cause nausea, vomiting or loss of consciousness. Remove contaminated clothing and shoes. Flush affected areas with plenty of water. If in EYES, hold eyelids open and flush with plenty of water. If SWALLOWED and victim is CONSCIOUS, have victim drink water or milk. DO NOT INDUCE VOMITING.</p>		<p>8. WATER POLLUTION</p> <p>8.1 Aquatic Toxicity: 1180 mg/l/96 hr/funfish/TL₅₀/fresh water 8.2 Waterfowl Toxicity: Data not available 8.3 Biological Oxygen Demand (BOD): 0%, 5 days, 34% (floor), 8 days 8.4 Food Chain Concentration Potential: None</p>		<p>1. RESPONSE TO DISCHARGE (See Response Methods Handbook) Issue warning, high permeability. Evacuate area.</p>																																			
<p>Water Pollution</p> <p>Dangerous to aquatic life in high concentrations. Fouling to shoreline. May be dangerous if enters water intakes. Notify operators of nearby water intakes. Notify operators of nearby water intakes.</p>		<p>9. SHIPPING INFORMATION</p> <p>9.1 Grades of Purity: Research, reagent, solution of 89.6 + %, industrial contains 94 + %, with 1% xylene and small amounts of benzene and nonaromatic hydrocarbons, 90/120; less pure than industrial. 9.2 Storage Temperature: Ambient 9.3 Inert Atmosphere: No requirement 9.4 Venting: Open (flame arrester) or pressure-relieving</p>		<p>2. LABEL</p> <p>2.1 Category: Flammable liquid 2.2 Class: 3</p>																																			
<p>1. RESPONSE TO DISCHARGE (See Response Methods Handbook) Issue warning, high permeability. Evacuate area.</p>		<p>2. LABEL</p> <p>2.1 Category: Flammable liquid 2.2 Class: 3</p>		<p>3. CHEMICAL DESIGNATIONS</p> <p>3.1 CO Compatibility Class: Aromatic Hydrocarbon 3.2 Formula: C₇H₈ 3.3 IMO/UN Designation: 3.2/1204 3.4 DOT ID No.: 1294 3.5 CAS Registry No.: 108-88-3</p>																																			
<p>3. CHEMICAL DESIGNATIONS</p> <p>3.1 CO Compatibility Class: Aromatic Hydrocarbon 3.2 Formula: C₇H₈ 3.3 IMO/UN Designation: 3.2/1204 3.4 DOT ID No.: 1294 3.5 CAS Registry No.: 108-88-3</p>		<p>4. OBSERVABLE CHARACTERISTICS</p> <p>4.1 Physical State (at shipping): Liquid 4.2 Color: Colorless 4.3 Odor: Pungent, aromatic, benzene-like; distinct, pleasant</p>		<p>5. HEALTH HAZARDS</p> <p>5.1 Personal Protective Equipment: Air-supplied mask, goggles or face shield, plastic gloves. 5.2 Symptoms Following Exposure: Vapors irritate eyes and upper respiratory tract, cause dizziness, headache, anesthesia, respiratory arrest. Liquid irritates eyes and causes drying of skin. If aspirated, causes coughing, gagging, distress, and rapidly developing pulmonary edema. If ingested causes vomiting, giddiness, dizziness, depressed respiration. 5.3 Treatment of Exposure: INHALATION: remove to fresh air, give artificial respiration and oxygen if needed, call a doctor. INGESTION: do NOT induce vomiting, call a doctor. EYES: flush with water for at least 15 min. SKIN: wipe off, wash with soap and water. 5.4 Threshold Limit Value: 100 ppm 5.5 Short Term Inhalation Limits: 800 ppm for 30 min. 5.6 Toxicity by Ingestion: Grade 2, LD₅₀ = 0.3 to 6 g/kg 5.7 Late Toxicity: Kidney and liver damage may follow ingestion. 5.8 Vapor (Gas) Irritant Characteristics: Vapors cause a slight stinging of the eyes or respiratory system if present in high concentrations. The effect is temporary. 5.9 Liquid or Solid Irritant Characteristics: Minimum hazard. If spilled on clothing and allowed to remain, may cause stinging and reddening of the skin. 5.10 Odor Threshold: 0.17 ppm 5.11 IDLH Value: 2,000 ppm</p>																																			
<p>6. FIRE HAZARDS (Continued)</p> <p>6.11 Stoichiometric Air to Fuel Ratio: Data not available 6.12 Flame Temperature: Data not available</p>		<p>6. FIRE HAZARDS (Continued)</p> <p>6.11 Stoichiometric Air to Fuel Ratio: Data not available 6.12 Flame Temperature: Data not available</p>																																					

m-XYLENE

XLM

<p>Common Synonyms 1, 3-Dimethylbenzene Xylol</p>	<p>Waterly liquid Colorless Sweet odor</p> <p>Floats on water. Flammable, irritating vapor is produced.</p>
<p>Stop discharge if possible. Keep people away. Call fire department. Avoid contact with liquid and vapor. Isolate and remove discharged material. Notify local health and pollution control agencies.</p>	
<p style="text-align: center;">Fire</p>	<p>FLAMMABLE Flashback along vapor trail may occur. Vapor may explode if ignited in an enclosed area. Wear self-contained breathing apparatus. Extinguish with foam, dry chemical, or carbon dioxide. Water may be ineffective on fire. Cool emptied containers with water.</p>
<p style="text-align: center;">Exposure</p>	<p>CALL FOR MEDICAL AID.</p> <p>VAPOR Irritating to eyes, nose, and throat. If inhaled, may cause headache, difficult breathing, or loss of consciousness. Move to fresh air. If breathing has stopped give artificial respiration. If breathing is difficult give oxygen.</p> <p>LIQUID Irritating to skin and eyes. If swallowed, will cause nausea, vomiting, or loss of consciousness. Remove contaminated clothing and shoes. Flush affected areas with plenty of water. If in EYES, hold eyelids open and flush with plenty of water. If SWALLOWED and victim is CONSCIOUS, have victim drink water or milk. DO NOT INDUCE VOMITING.</p>
<p style="text-align: center;">Water Pollution</p>	<p>HARMFUL TO AQUATIC LIFE IN VERY LOW CONCENTRATIONS. Floating in shorelines. May be dangerous if it enters water intakes.</p> <p>Notify local health and wildlife officials. Notify operators of nearby water intakes.</p>
<p style="text-align: center;">1. RESPONSE TO DISCHARGE (See Response Methods Handbook)</p> <p>Issue warning-high flammability. Evacuate area. Should be removed. Chemical and physical treatment.</p>	<p style="text-align: center;">2. LABEL</p> <p>2.1 Category: Flammable liquid 2.2 Class: 3</p>
<p style="text-align: center;">3. CHEMICAL DESIGNATIONS</p> <p>3.1 CG Competency Class: Aromatic Hydrocarbon 3.2 Formula: mC₈H₁₀(C₈H₁₀) 3.3 IMD/UN Designation: 3.2/1307 3.4 DOT ID No.: 1307 3.5 CAS Registry No.: 106-38-3</p>	<p style="text-align: center;">4. OBSERVABLE CHARACTERISTICS</p> <p>4.1 Physical State (as shipped): Liquid 4.2 Color: Colorless 4.3 Odor: Like benzene, characteristic aromatic</p>
<p style="text-align: center;">5. HEALTH HAZARDS</p> <p>5.1 Personal Protective Equipment: Approved canister or air-supplied mask, goggles or face shield, plastic gloves and boots.</p> <p>5.2 Symptoms Following Exposure: Vapors cause headache and dizziness. Liquid irritates eyes and skin. Prolonged skin contact causes itching, distress, and rapidly developing pulmonary edema. If ingested, causes nausea, vomiting, cramps, headache, and coma can be fatal. Kidney and liver damage can occur.</p> <p>5.3 Treatment of Exposure: INHALATION remove to fresh air, administer artificial respiration and oxygen if required, call a doctor. INGESTION do NOT induce vomiting, call a doctor. EYES: flush with water for at least 15 min. SKIN wipe off, wash with soap and water.</p> <p>5.4 Threshold Limit Value: 100 ppm 5.5 Short Term Inhalation Limit: 300 ppm for 30 min. 5.6 Toxicity by Ingestion: Grade 3, LD₅₀ = 50 to 500 g/kg 5.7 Late Toxicity: Kidney and liver damage. 5.8 Vapor (Gas) Irritant Characteristics: Vapors cause a slight stinging of the eyes or respiratory system if present in high concentrations. The effect is temporary. 5.9 Liquid or Solid Irritant Characteristics: Minimum hazard. If spilled on clothing and allowed to remain, may cause stinging and reddening of the skin. 5.10 Color Threshold: 0.05 ppm 5.11 IDLN Value: 10,000 ppm</p>	

<p style="text-align: center;">6. FIRE HAZARDS</p> <p>6.1 Flash Point: 84°F C.C. 6.2 Flammable Limits in Air: 1.1%-6.4% 6.3 Fire Extinguishing Agents: Foam, dry chemical, or carbon dioxide 6.4 Fire Extinguishing Agents Not to be Used: Water may be ineffective. 6.5 Special Hazards of Combustion Products: Not pertinent 6.6 Behavior in Fire: Vapor is heavier than air and may travel considerable distance to a source of ignition and flash back. 6.7 Ignition Temperature: 866°F 6.8 Electrical Hazard: Class I, Group D 6.9 Burning Rate: 5.8 mm/min. 6.10 Adiabatic Flame Temperature: Data not available 6.11 Stoichiometric Air to Fuel Ratio: Data not available 6.12 Flame Temperature: Data not available</p>	<p style="text-align: center;">10. HAZARD ASSESSMENT CODE (See Hazard Assessment Handbook) A-T-U</p>																																				
<p style="text-align: center;">7. CHEMICAL REACTIVITY</p> <p>7.1 Reactivity With Water: No reaction 7.2 Reactivity with Common Materials: No reaction 7.3 Stability During Transport: Stable 7.4 Neutralizing Agents for Acids and Corrosives: Not pertinent 7.5 Polymerization: Not pertinent 7.6 Inhibitor of Polymerization: Not pertinent 7.7 Molar Ratio (Reactant to Product): Data not available 7.8 Reactivity Group: 32</p>	<p style="text-align: center;">11. HAZARD CLASSIFICATIONS</p> <p>11.1 Code of Federal Regulations: Flammable liquid</p> <p>11.2 NIOSH Hazard Rating for Bulk Water Transporters</p> <table style="width: 100%; border-collapse: collapse;"> <thead> <tr> <th style="text-align: left;">Category</th> <th style="text-align: left;">Rating</th> </tr> </thead> <tbody> <tr> <td>Fire</td> <td>3</td> </tr> <tr> <td>Health</td> <td></td> </tr> <tr> <td>Vapor Irritant</td> <td>1</td> </tr> <tr> <td>Liquid or Solid Irritant</td> <td>1</td> </tr> <tr> <td>Poison</td> <td>2</td> </tr> <tr> <td>Water Pollution</td> <td></td> </tr> <tr> <td>Human Toxicity</td> <td>1</td> </tr> <tr> <td>Aquatic Toxicity</td> <td>3</td> </tr> <tr> <td>Aesthetic Effect</td> <td>2</td> </tr> <tr> <td>Reactivity</td> <td></td> </tr> <tr> <td>Other Chemicals</td> <td>1</td> </tr> <tr> <td>Water</td> <td>0</td> </tr> <tr> <td>Sol' Reaction</td> <td>0</td> </tr> </tbody> </table> <p>11.3 NFPA Hazard Classifications</p> <table style="width: 100%; border-collapse: collapse;"> <thead> <tr> <th style="text-align: left;">Category</th> <th style="text-align: left;">Classification</th> </tr> </thead> <tbody> <tr> <td>Health Hazard (Blue)</td> <td>2</td> </tr> <tr> <td>Flammability (Red)</td> <td>3</td> </tr> <tr> <td>Reactivity (Yellow)</td> <td>0</td> </tr> </tbody> </table>	Category	Rating	Fire	3	Health		Vapor Irritant	1	Liquid or Solid Irritant	1	Poison	2	Water Pollution		Human Toxicity	1	Aquatic Toxicity	3	Aesthetic Effect	2	Reactivity		Other Chemicals	1	Water	0	Sol' Reaction	0	Category	Classification	Health Hazard (Blue)	2	Flammability (Red)	3	Reactivity (Yellow)	0
Category	Rating																																				
Fire	3																																				
Health																																					
Vapor Irritant	1																																				
Liquid or Solid Irritant	1																																				
Poison	2																																				
Water Pollution																																					
Human Toxicity	1																																				
Aquatic Toxicity	3																																				
Aesthetic Effect	2																																				
Reactivity																																					
Other Chemicals	1																																				
Water	0																																				
Sol' Reaction	0																																				
Category	Classification																																				
Health Hazard (Blue)	2																																				
Flammability (Red)	3																																				
Reactivity (Yellow)	0																																				
<p style="text-align: center;">8. WATER POLLUTION</p> <p>8.1 Aquatic Toxicity: 22 ppm/96 hr/bluegill/TL₅₀/fresh water 8.2 Waterfowl Toxicity: Data not available 8.3 Biological Oxygen Demand (BOD): 0 lb/lb, 5 days, C₁ (theor), 8 days 8.4 Food Chain Concentration Potential: Data not available</p>	<p style="text-align: center;">12. PHYSICAL AND CHEMICAL PROPERTIES</p> <p>12.1 Physical State at 15°C and 1 atm: Liquid 12.2 Molecular Weight: 106.16 12.3 Boiling Point at 1 atm: 296.4°F = 131.3°C = 405.1°K 12.4 Freezing Point: -54.2°F = -47.9°C = 225.3°K 12.5 Critical Temperature: 650.8°F = 343.8°C = 617.0°K 12.6 Critical Pressure: 513.8 atm = 34.95 psia = 3.540 MN/m² 12.7 Specific Gravity: 0.864 at 20°C (liquid) 12.8 Liquid Surface Tension: 26.6 dynes/cm = 0.0266 N/m at 20°C 12.9 Liquid Water Interfacial Tension: 36.4 dynes/cm = 0.0364 N/m at 30°C 12.10 Vapor (Gas) Specific Gravity: Not pertinent 12.11 Ratio of Specific Heats of Vapor (Gas): 1.071 12.12 Latent Heat of Vaporization: 147 Btu/lb = 81.0 cal/g = 3.43 X 10⁵ J/kg 12.13 Heat of Combustion: -17,554 Btu/lb = -9752.4 cal/g = -406.51 X 10³ J/kg 12.14 Heat of Decomposition: Not pertinent 12.15 Heat of Solution: Not pertinent 12.16 Heat of Polymerization: Not pertinent 12.25 Heat of Fusion: 26.01 cal/g 12.26 Limiting Value: Data not available 12.27 Red Vapor Pressure: 0.24 psia</p>																																				
<p style="text-align: center;">9. SHIPPING INFORMATION</p> <p>9.1 Grades of Purity: Research 99.99%; Pure 99.9%; Technical 99.2% 9.2 Storage Temperature: Ambient 9.3 Inert Atmosphere: No requirement 9.4 Venting: Open (flame arrester) or pressure-relieff</p>																																					
<p>NOTES</p>																																					

o-XYLENE

XLO

<p>Common Synonyms 1,2-Dimethylbenzene Xylol</p>	<p>Watery liquid Colorless Sweet odor</p> <p>Floats on water. Flammable, irritating vapor is produced.</p>	
<p>Stop discharge if possible. Keep people away. Call fire department. Avoid contact with liquid and vapor. Isolate and remove discharged material. Notify local health and pollution control agencies.</p>		
<p>Fire</p>	<p>FLAMMABLE Flashback during vapor trail may occur. Vapor may explode if ignited in an enclosed area. Wear self-contained breathing apparatus. Extinguish with foam, dry chemical, or carbon dioxide. Water may be ineffective or fire. Cool exposed containers with water.</p>	
<p>Exposure</p>	<p>CALL FOR MEDICAL AID</p> <p>VAPOR Irritating to eyes, nose and throat. If inhaled, will cause headache, difficult breathing, or loss of consciousness. Move to fresh air. If breathing has stopped, give artificial respiration. If breathing is difficult, give oxygen.</p> <p>LIQUID Irritating to skin and eyes. If swallowed, will cause nausea, vomiting, or loss of consciousness. Remove contaminated clothing and shoes. Flush affected areas with plenty of water. IF IN EYES, hold eyelids open and flush with plenty of water. IF SWALLOWED and victim is CONSCIOUS, have victim drink water or milk. DO NOT INDUCE VOMITING.</p>	
<p>Water Pollution</p>	<p>Dangerous to aquatic life in high concentrations. Fouling to shoreline. May be dangerous if it enters water intakes. Notify local health and waste officials. Notify operators of nearby water intakes.</p>	
<p>1. RESPONSE TO DISCHARGE (See Response Methods Handbook) Issue warning-high flammability. Evacuate area. Should be removed. Chemical and physical treatment.</p>		<p>2. LABEL 2.1 Category: Flammable liquid 2.2 Class: 3</p>
<p>3. CHEMICAL DESIGNATIONS</p> <p>3.1 CG Compatibility Class: Aromatic Hydrocarbon 3.2 Formula: $C_8H_{10}(CH_3)_2$ 3.3 HAO/UN Designation: 3.2/1307 3.4 DOT ID No.: 1307 3.5 CAS Registry No.: 95-47-8</p>		<p>4. OBSERVABLE CHARACTERISTICS</p> <p>4.1 Physical State (as shipped): Liquid 4.2 Color: Colorless 4.3 Odor: Benzene-like, characteristic aromatic</p>
<p>5. HEALTH HAZARDS</p>		
<p>6.1 Personal Protective Equipment: Approved canister or air-supplied mask, goggles or face shield, plastic gloves and boots. 6.2 Symptoms Following Exposure: Vapors cause headache and dizziness. Liquid irritates eyes and skin. If taken into lungs, causes severe coughing, distress, and rapidly developing pulmonary edema. If ingested, causes nausea, vomiting, cramps, headache, and coma. Can be fatal. Kidney and liver damage can occur. 6.3 Treatment of Exposure: INHALATION: remove to fresh air, administer artificial respiration and oxygen if required, call a doctor. INGESTION: do NOT induce vomiting, call a doctor. EYES: flush with water for at least 15 min. SKIN: wipe off, wash with soap and water. 6.4 Threshold Limit Value: 100 ppm 6.5 Short Term Inhalation Limits: 300 ppm for 30 min. 6.6 Toxicity by Ingestion: Grade 3, LD₅₀ = 50 to 500 mg/kg 6.7 Late Toxicity: Kidney and liver damage. 6.8 Vapor (Gas) Irritant Characteristics: Vapors cause a slight stinging of the eyes or respiratory system if present in high concentrations. The effect is temporary. 6.9 Liquid or Solid Irritant Characteristics: Minimal hazard if applied on clothing and allowed to remain, may cause stinging and reddening of the skin. 6.10 Odor Threshold: 0.02 ppm 6.11 IDLH Value: 10,000 ppm</p>		

<p>6. FIRE HAZARDS</p> <p>6.1 Flash Point: 63°F C.C., 75°F O.C. 6.2 Flammable Limits in Air: 1.1%-7.0% 6.3 Fire Extinguishing Agents: Foam, dry chemical, or carbon dioxide. 6.4 Fire Extinguishing Agents Not to be Used: Water may be ineffective. 6.5 Special Hazards of Combustion Products: Not pertinent. 6.6 Behavior in Fire: Vapor is heavier than air and may travel considerable distance to a source of ignition and flash back. 6.7 Ignition Temperature: 659°F 6.8 Electrical Hazard: Class I, Group D 6.9 Burning Rate: 5.8 mm/min 6.10 Adiabatic Flame Temperature: Data not available. 6.11 Stoichiometric Air to Fuel Ratio: Data not available. 6.12 Flame Temperature: Data not available.</p>	<p>10. HAZARD ASSESSMENT CODE (See Hazard Assessment Handbook) A-T-U</p>																																				
<p>7. CHEMICAL REACTIVITY</p> <p>7.1 Reactivity With Water: No reaction 7.2 Reactivity with Common Materials: No reaction 7.3 Stability During Transport: Stable 7.4 Neutralizing Agents for Acids and Caustics: Not pertinent. 7.5 Polymerization: Not pertinent. 7.6 Inhibitor of Polymerization: Not pertinent. 7.7 Heat Ratio (Reactant to Product): Data not available. 7.8 Reactivity Group: 2</p>	<p>11. HAZARD CLASSIFICATIONS</p> <p>11.1 Code of Federal Regulations: Flammable liquid 11.2 NIOSH Hazard Rating for Bulk Water Transportation:</p> <table style="width: 100%; border-collapse: collapse;"> <thead> <tr> <th style="text-align: left;">Category</th> <th style="text-align: left;">Rating</th> </tr> </thead> <tbody> <tr> <td>Fire</td> <td>3</td> </tr> <tr> <td>Health</td> <td></td> </tr> <tr> <td>Vapor Irritant</td> <td>1</td> </tr> <tr> <td>Liquid or Solid Irritant</td> <td>1</td> </tr> <tr> <td>Poison</td> <td>2</td> </tr> <tr> <td>Water Pollution</td> <td></td> </tr> <tr> <td>Human Toxicity</td> <td>1</td> </tr> <tr> <td>Aquatic Toxicity</td> <td>3</td> </tr> <tr> <td>Aesthetic Effect</td> <td>2</td> </tr> <tr> <td>Reactivity</td> <td></td> </tr> <tr> <td>Other Chemical</td> <td>1</td> </tr> <tr> <td>Water</td> <td>0</td> </tr> <tr> <td>Self Reaction</td> <td>0</td> </tr> </tbody> </table> <p>11.3 NFPA Hazard Classification:</p> <table style="width: 100%; border-collapse: collapse;"> <thead> <tr> <th style="text-align: left;">Category</th> <th style="text-align: left;">Classification</th> </tr> </thead> <tbody> <tr> <td>Health Hazard (Blue)</td> <td>2</td> </tr> <tr> <td>Flammability (Red)</td> <td>3</td> </tr> <tr> <td>Reactivity (Yellow)</td> <td>0</td> </tr> </tbody> </table>	Category	Rating	Fire	3	Health		Vapor Irritant	1	Liquid or Solid Irritant	1	Poison	2	Water Pollution		Human Toxicity	1	Aquatic Toxicity	3	Aesthetic Effect	2	Reactivity		Other Chemical	1	Water	0	Self Reaction	0	Category	Classification	Health Hazard (Blue)	2	Flammability (Red)	3	Reactivity (Yellow)	0
Category	Rating																																				
Fire	3																																				
Health																																					
Vapor Irritant	1																																				
Liquid or Solid Irritant	1																																				
Poison	2																																				
Water Pollution																																					
Human Toxicity	1																																				
Aquatic Toxicity	3																																				
Aesthetic Effect	2																																				
Reactivity																																					
Other Chemical	1																																				
Water	0																																				
Self Reaction	0																																				
Category	Classification																																				
Health Hazard (Blue)	2																																				
Flammability (Red)	3																																				
Reactivity (Yellow)	0																																				
<p>8. WATER POLLUTION</p> <p>8.1 Aquatic Toxicity: >100 mg/l/96 hr/D. magna/TL₅₀ fresh water 8.2 Waterfowl Toxicity: Data not available 8.3 Biological Oxygen Demand (BOD): C lb/lb 5 days, 2.5% (theor), 2 days 8.4 Food Chain Concentration Potential: Data not available</p>	<p>12. PHYSICAL AND CHEMICAL PROPERTIES</p> <p>12.1 Physical State at 15°C and 1 atm: Liquid 12.2 Molecular Weight: 106.16 12.3 Boiling Point at 1 atm: 291.8°F = 144.4°C = 417.8°K 12.4 Freezing Point: -13.3°F = -25.2°C = 248.0°K 12.5 Critical Temperature: 574.8°F = 301.1°C = 630.3°K 12.6 Critical Pressure: 541.5 atm = 36.84 psia = 3.732 MN/m² 12.7 Specific Gravity: 0.880 at 20°C (liquid) 12.8 Liquid Surface Tension: 30.55 dynes/cm = 0.03055 N/m at 15.5°C 12.9 Liquid Water Interfacial Tension: 36.06 dynes/cm = 0.03606 N/m at 20°C 12.10 Vapor (Gas) Specific Gravity: Not pertinent 12.11 Ratio of Specific Heats of Vapor (Gas): 1.088 12.12 Latent Heat of Vaporization: 149 Btu/lb = 82.6 cal/g = 3.47 x 10⁴ J/kg 12.13 Heat of Combustion: -17,514 Btu/lb = -9754.7 cal/g = -406.41 x 10⁴ J/kg 12.14 Heat of Decomposition: Not pertinent 12.15 Heat of Solution: Not pertinent 12.16 Heat of Polymerization: Not pertinent 12.25 Heat of Fusion: 30.64 cal/g 12.26 Limiting Value: Data not available 12.27 Reid Vapor Pressure: 6.28 psia</p>																																				
<p>9. SHIPPING INFORMATION</p> <p>9.1 Grades of Purity: Research: 99.99%; Pure: 99.7%, Commercial: 95+% 9.2 Storage Temperature: Ambient 9.3 Inert Atmosphere: No reaction 9.4 Venting Oper. (Rate or extent) or pressure-vacuum</p>	<p>NOTES</p>																																				

p-XYLENE

XLP

<p>Common Synonyms 1,4-Dimethylbenzene Xylol</p>	<p>Water: liquid Colorless Sweet odor</p> <p>Floats on water. Flammable emitting vapor is produced. Freezing point is 36°F.</p>
<p>Stop discharge if possible. Keep people away. Call fire department. Avoid contact with liquid and vapor. Isolate and remove discharged material. Notify local health and pollution control agencies.</p>	
<p style="text-align: center;">Fire</p>	<p>FLAMMABLE Flashback along vapor trail may occur. Vapor may explode if ignited in an enclosed area. Wear self-contained breathing apparatus. Extinguish with foam, dry chemical or carbon dioxide. Water may be ineffective on fire. Cool exposed containers with water.</p>
<p style="text-align: center;">Exposure</p>	<p>CALL FOR MEDICAL AID.</p> <p>VAPOR Irritating to eyes, nose and throat. If inhaled, will cause dizziness, drowsiness, or loss of consciousness. Move to fresh air. If breathing has stopped, give artificial respiration. If breathing is difficult, give oxygen.</p> <p>LIQUID Irritating to skin and eyes. If swallowed, will cause nausea, vomiting, loss of consciousness. Remove contaminated clothing and shoes. Flush affected areas with plenty of water. If in EYES, hold eyelids open and flush with plenty of water. If SWALLOWED and victim is CONSCIOUS, have victim drink water or milk. DO NOT INDUCE VOMITING.</p>
<p style="text-align: center;">Water Pollution</p>	<p>HARMFUL TO AQUATIC LIFE IN VERY LOW CONCENTRATIONS. Floating in streams. May be dangerous if it enters water intakes. Notify local health and waste officials. Notify operators of nearby water intakes.</p>
<p style="text-align: center;">1. RESPONSE TO DISCHARGE (See Response Methods Handbook)</p> <p>Leak: wearing high flammability Evacuate area Should be removed Chemical and physical treatment</p>	<p style="text-align: center;">2. LABEL</p> <p>2.1 Category: Flammable liquid 2.2 Class: 3</p>
<p style="text-align: center;">3. CHEMICAL DESIGNATIONS</p> <p>3.1 CG Compatibility Class: Aromatic hydrocarbon 3.2 Formula: C₈H₁₀(CH₃)₂ 3.3 MSD/WH Designation: 3.2/1307 3.4 DOT ID No.: 1307 3.5 CAS Registry No.: 106-42-3</p>	<p style="text-align: center;">4. OBSERVABLE CHARACTERISTICS</p> <p>4.1 Physical State (as shipped): Liquid 4.2 Color: Colorless 4.3 Odor: LA is benzene, characteristic aromatic</p>
<p style="text-align: center;">5. HEALTH HAZARDS</p> <p>5.1 Personal Protective Equipment: Approved canister or air-supplied mask, goggles or face shield, plastic gloves and boots.</p> <p>5.2 Symptoms Following Exposure: Vapors cause headache and dizziness. Liquid irritates eyes and skin. If taken into lungs, causes severe coughing, distress, and rapidly developing pulmonary edema. If ingested, causes nausea, vomiting, dizziness, headache, and coma. Can be fatal. Kidney and liver damage can occur.</p> <p>5.3 Treatment of Exposure: INHALATION: remove to fresh air, administer artificial respiration and oxygen if required, call a doctor. INGESTION: do NOT induce vomiting, call a doctor. EYES: flush with water for at least 15 min. SKIN: wipe off, wash with soap and water.</p> <p>5.4 Threshold Limit Value: 100 ppm 5.5 Short Term Inhalation Limit: 200 ppm for 30 min. 5.6 Toxicity by Ingestion: Grade 3, LD₅₀ = 30 to 500 mg/kg 5.7 Late Toxicity: Kidney and liver damage. 5.8 Vapor (Gas) Irritant Characteristics: Vapors cause a slight stinging of the eyes or respiratory system if present in high concentrations. The effect is temporary. 5.9 Liquid or Solid Irritant Characteristics: Minimal hazard if spilled on clothing and allowed to remain, may cause stinging and reddening of the skin. 5.10 Odor Threshold: 0.05 ppm 5.11 IDLH Value: 10,000 ppm</p>	

<p style="text-align: center;">6. FIRE HAZARDS</p> <p>6.1 Flash Point: 81°F C.C. 6.2 Flammable Limits in Air: 1.1%-8.6% 6.3 Fire Extinguishing Agents: Foam, dry chemical, or carbon dioxide 6.4 Fire Extinguishing Agents Not to be Used: Water may be ineffective. 6.5 Special Hazards of Combustion Products: Not pertinent 6.6 Behavior in Fire: Vapor is heavier than air and may travel considerable distance to a source of ignition and flash back. 6.7 Ignition Temperature: 570°F 6.8 Electrical Hazard: Class I, Group D 6.9 Burning Rate: 5.5 mm/min 6.10 Adiabatic Flame Temperature: Data not available 6.11 Stoichiometric Air to Fuel Ratio: Data not available 6.12 Flame Temperature: Data not available</p>	<p style="text-align: center;">7. CHEMICAL REACTIVITY</p> <p>7.1 Reactivity With Water: No reaction 7.2 Reactivity with Common Materials: No reaction 7.3 Stability During Transport: Stable 7.4 Neutralizing Agents for Acids and Caustics: Not pertinent 7.5 Polymerization: Not pertinent 7.6 Inhibitor of Polymerization: Not pertinent 7.7 Moles Ratio (Reactant to Product): Data not available 7.8 Reactivity Group: 2</p>
<p style="text-align: center;">8. WATER POLLUTION</p> <p>8.1 Aquatic Toxicity: 22 ppm/96 hr (bluegill/TL₅₀/fresh water) 8.2 Waterfowl Toxicity: Data not available 8.3 Biological Oxygen Demand (BOD): 0.6% in 5 days 8.4 Food Chain Concentration Potential: Data not available</p>	
<p style="text-align: center;">9. SHIPPING INFORMATION</p> <p>9.1 Grades of Purity: Research 99.99%; Pure 99.9%; Technical: 99.0% 9.2 Storage Temperature: Ambient 9.3 Inert Atmosphere: No requirement 9.4 Venting: Open flame arrester or pressure-relief</p>	

<p style="text-align: center;">10. HAZARD ASSESSMENT CODE (See Hazard Assessment Handbook) A-T-U</p>																																				
<p style="text-align: center;">11. HAZARD CLASSIFICATIONS</p> <p>11.1 Code of Federal Regulations: Flammable liquid 11.2 HAS Hazard Rating for Bulk Water Transportation:</p> <table style="width: 100%; border-collapse: collapse;"> <thead> <tr> <th style="text-align: left;">Category</th> <th style="text-align: left;">Rating</th> </tr> </thead> <tbody> <tr> <td>Fire</td> <td>3</td> </tr> <tr> <td>Health</td> <td></td> </tr> <tr> <td> Vapor Irritant</td> <td>1</td> </tr> <tr> <td> Liquid or Solid Irritant</td> <td>1</td> </tr> <tr> <td> Poison</td> <td>2</td> </tr> <tr> <td>Water Pollution</td> <td></td> </tr> <tr> <td> Human Toxicity</td> <td>1</td> </tr> <tr> <td> Aquatic Toxicity</td> <td>3</td> </tr> <tr> <td> Aesthetic Effect</td> <td>2</td> </tr> <tr> <td>Reactivity</td> <td></td> </tr> <tr> <td> Other Chemicals</td> <td>1</td> </tr> <tr> <td> Water</td> <td>0</td> </tr> <tr> <td> Self Reaction</td> <td>0</td> </tr> </tbody> </table> <p>11.3 NFPA Hazard Classification:</p> <table style="width: 100%; border-collapse: collapse;"> <thead> <tr> <th style="text-align: left;">Category</th> <th style="text-align: left;">Classification</th> </tr> </thead> <tbody> <tr> <td>Health Hazard (Blue)</td> <td>2</td> </tr> <tr> <td>Flammability (Red)</td> <td>3</td> </tr> <tr> <td>Reactivity (Yellow)</td> <td>0</td> </tr> </tbody> </table>	Category	Rating	Fire	3	Health		Vapor Irritant	1	Liquid or Solid Irritant	1	Poison	2	Water Pollution		Human Toxicity	1	Aquatic Toxicity	3	Aesthetic Effect	2	Reactivity		Other Chemicals	1	Water	0	Self Reaction	0	Category	Classification	Health Hazard (Blue)	2	Flammability (Red)	3	Reactivity (Yellow)	0
Category	Rating																																			
Fire	3																																			
Health																																				
Vapor Irritant	1																																			
Liquid or Solid Irritant	1																																			
Poison	2																																			
Water Pollution																																				
Human Toxicity	1																																			
Aquatic Toxicity	3																																			
Aesthetic Effect	2																																			
Reactivity																																				
Other Chemicals	1																																			
Water	0																																			
Self Reaction	0																																			
Category	Classification																																			
Health Hazard (Blue)	2																																			
Flammability (Red)	3																																			
Reactivity (Yellow)	0																																			
<p style="text-align: center;">12. PHYSICAL AND CHEMICAL PROPERTIES</p> <p>12.1 Physical State at 15°C and 1 atm: Liquid 12.2 Molecular Weight: 106.16 12.3 Boiling Point at 1 atm: 280.9°F = 138.3°C = 411.5°K 12.4 Freezing Point: 85.9°F = 13.3°C = 266.5°K 12.5 Critical Temperature: 645.4°F = 343.0°C = 616.2°K 12.6 Critical Pressure: 806.4 atm = 34.65 psia = 3.510 MN/m² 12.7 Specific Gravity: 0.861 at 20°C (liquid) 12.8 Liquid Surface Tension: 26.2 dynes/cm = 0.0283 N/m at 20°C 12.9 Liquid Water Interfacial Tension: 37.6 dynes/cm = 0.0376 N/m at 20°C 12.10 Vapor (Gas) Specific Gravity: Not pertinent 12.11 Ratio of Specific Heats of Vapor (Gas): 1.071 12.12 Latent Heat of Vaporization: 180 Btu/lb = 81 cal/g = 3.4 X 10⁴ J/kg 12.13 Heat of Combustion: -17,350 Btu/lb = -8734.7 cal/g = -406.41 X 10⁴ J/kg 12.14 Heat of Decomposition: Not pertinent 12.15 Heat of Solution: Not pertinent 12.16 Heat of Polymerization: Not pertinent 12.21 Heat of Fusion: 37.83 cal/g 12.24 Limiting Value: Data not available 12.27 Reid Vapor Pressure: 0.34 psia</p>																																				
<p>NOTES</p>																																				

ETHYLBENZENE

ETB

<p>Common Synonyms Phenyltoluene EB</p>	<p>Liquid</p>	<p>Colorless</p>	<p>Sweet gasoline-like odor</p> <p>Floats on water. Flammable, irritating vapor is produced.</p>
<p>Avoid contact with liquid and vapor. Keep people away. Wear goggles, self-contained breathing apparatus and rubber overclothing (including gloves). Shut off ignition sources and call fire department. Stop discharge if possible. Stop upwind and use water spray to knock down vapor clouds and remove discharged material. Notify local health and pollution control agencies.</p>			
Fire	<p>FLAMMABLE. Flashback along vapor trail may occur. Vapor may explode if ignited in an enclosed area. Wear goggles, self-contained breathing apparatus and rubber overclothing (including gloves). Extinguish with dry chemical foam or carbon dioxide. Water may be ineffective if too hot. Cool exposed containers with water.</p>		
Exposure	<p>CALL FOR MEDICAL AID</p> <p>VAPOR Irritating to eyes, nose and throat. If inhaled, may cause dizziness or difficult breathing. Move to fresh air. If breathing has stopped, give artificial respiration. If breathing is difficult, give oxygen.</p> <p>LIQUID Will burn skin and eyes. Harmful if swallowed. Remove contaminated clothing and shoes. Flush affected areas with plenty of water. If in EYES, hold eyes open and flush with plenty of water. If SWALLOWED and victim is CONSCIOUS, have victim drink water or milk. DO NOT INDUCE VOMITING.</p>		
Water Pollution	<p>HARMFUL TO AQUATIC LIFE IN VERY LOW CONCENTRATIONS. Floating in stormwater. May be dangerous if it enters water intakes. Notify local health and water officials. Notify operators of water/water intakes.</p>		
<p>1. RESPONSE TO DISCHARGE (See Response Methods Handbook) Mechanical containment should be removed. Chemical and physical treatment.</p>		<p>2. LABEL 2.1 Category: Flammable liquid 2.2 Class: 3</p>	
<p>3. CHEMICAL DESIGNATIONS 3.1 CO Compatibility Class: Aromatic hydrocarbon 3.2 Formula: C₈H₁₀ 3.3 RMO/UN Designation: 3.3/1175 3.4 DOT ID No.: 1175 3.5 CAS Registry No.: 100-61-4</p>		<p>4. OBSERVABLE CHARACTERISTICS 4.1 Physical State (as shipped): Liquid 4.2 Color: Colorless 4.3 Odor: Aromatic</p>	
<p>5. HEALTH HAZARDS</p>			
<p>5.1 Personal Protective Equipment: Self-contained breathing apparatus, safety goggles. 5.2 Symptoms Following Exposure: Inhalation may cause irritation of nose, dizziness, depression. Moderate irritator of eyes with corneal injury possible. Irritates skin and may cause blisters. 5.3 Treatment of Exposure: INHALATION If effects occur, remove victim to fresh air, keep him warm and quiet, and get medical help promptly. If breathing stops, give artificial respiration. INGESTION induce vomiting only upon physician's approval; material in lung may cause chemical pneumonia. SKIN AND EYES promptly flush with plenty of water (15 min for eyes) and get medical attention; remove and wash contaminated clothing before reuse. 5.4 Threshold Limit Value: 100 ppm 5.5 Short-Term Inhalation Limits: 700 ppm for 30 min. 5.6 Toxicity by Ingestion: Grade 2, LD₅₀ = 0.5 to 5 g/kg (rat) 5.7 Low Toxicity: Data not available. 5.8 Vapor (Gas) Irritant Characteristics: Vapors cause moderate irritator such that personnel will find high concentrations unpleasant. The effect is temporary. 5.9 Liquid or Solid Irritant Characteristics: Causes smothering of the skin and frost-bite-like burns on short exposure; may cause secondary burns on long exposure. 5.10 Odor Threshold: 140 ppm 5.11 MDM Value: 2,000 ppm</p>			

<p>6. FIRE HAZARDS</p> <p>6.1 Flash Point: 80°F O.C., 50°F C.C. 6.2 Flammable Limits in Air: 1.0%-6.7% 6.3 Fire Extinguishing Agents: Foam (most effective), water fog, carbon dioxide or dry chemical. 6.4 Fire Extinguishing Agents Not to be Used: Not pertinent. 6.5 Special Hazards of Combustion: Products: Irritating vapors are generated when heated. 6.6 Behavior in Fire: Vapor is heavier than air and may travel considerable distance to the source of ignition and flash back. 6.7 Ignition Temperature: 860°F 6.8 Electrical Hazard: Not pertinent. 6.9 Burning Rate: 5.8 mm/min 6.10 Adiabatic Flame Temperature: Data Not Available</p> <p style="text-align: right;"><i>(Continued)</i></p>	<p>10. HAZARD ASSESSMENT CODE (See Hazard Assessment Handbook) A-T-U</p> <p>11. HAZARD CLASSIFICATIONS</p> <p>11.1 Code of Federal Regulations: Flammable liquid</p> <p>11.2 NIOSH Hazard Rating for Bulk Water Transportation:</p> <table style="width: 100%; border-collapse: collapse;"> <thead> <tr> <th style="text-align: left;">Category</th> <th style="text-align: left;">Rating</th> </tr> </thead> <tbody> <tr> <td>Fire</td> <td>3</td> </tr> <tr> <td>Health</td> <td></td> </tr> <tr> <td>Vapor Irritant</td> <td>2</td> </tr> <tr> <td>Liquid or Solid Irritant</td> <td>2</td> </tr> <tr> <td>Poisons</td> <td>2</td> </tr> <tr> <td>Water Pollution</td> <td></td> </tr> <tr> <td>Human Toxicity</td> <td>1</td> </tr> <tr> <td>Aquatic Toxicity</td> <td>3</td> </tr> <tr> <td>Asphyxiant Effect</td> <td>2</td> </tr> <tr> <td>Reactivity</td> <td></td> </tr> <tr> <td>Other Chemicals</td> <td>1</td> </tr> <tr> <td>Water</td> <td>0</td> </tr> <tr> <td>Self Reaction</td> <td>0</td> </tr> </tbody> </table> <p>11.3 NFPA Hazard Classification:</p> <table style="width: 100%; border-collapse: collapse;"> <thead> <tr> <th style="text-align: left;">Category</th> <th style="text-align: left;">Classification</th> </tr> </thead> <tbody> <tr> <td>Health Hazard (Blue)</td> <td>2</td> </tr> <tr> <td>Flammability (Red)</td> <td>3</td> </tr> <tr> <td>Reactivity (Yellow)</td> <td>0</td> </tr> </tbody> </table>	Category	Rating	Fire	3	Health		Vapor Irritant	2	Liquid or Solid Irritant	2	Poisons	2	Water Pollution		Human Toxicity	1	Aquatic Toxicity	3	Asphyxiant Effect	2	Reactivity		Other Chemicals	1	Water	0	Self Reaction	0	Category	Classification	Health Hazard (Blue)	2	Flammability (Red)	3	Reactivity (Yellow)	0
Category	Rating																																				
Fire	3																																				
Health																																					
Vapor Irritant	2																																				
Liquid or Solid Irritant	2																																				
Poisons	2																																				
Water Pollution																																					
Human Toxicity	1																																				
Aquatic Toxicity	3																																				
Asphyxiant Effect	2																																				
Reactivity																																					
Other Chemicals	1																																				
Water	0																																				
Self Reaction	0																																				
Category	Classification																																				
Health Hazard (Blue)	2																																				
Flammability (Red)	3																																				
Reactivity (Yellow)	0																																				
<p>7. CHEMICAL REACTIVITY</p> <p>7.1 Reactivity With Water: No reaction 7.2 Reactivity with Common Materials: No reaction 7.3 Stability During Transport: Stable 7.4 Neutralizing Agents for Acids and Caustics: Not pertinent 7.5 Polymerization: Not pertinent 7.6 Inhibitor of Polymerization: Not pertinent 7.7 Male: Ratio (Reactant to Product): Data Not Available 7.8 Reactivity Group: 32</p>	<p>12. PHYSICAL AND CHEMICAL PROPERTIES</p> <p>12.1 Physical State at 15°C and 1 atm: Liquid 12.2 Molecular Weight: 106.17 12.3 Boiling Point at 1 atm: 277.2°F = 136.2°C = 400.4°K 12.4 Freezing Point: -129°F = -89°C = 178°K 12.5 Critical Temperature: 651.0°F = 343.9°C = 617.1°K 12.6 Critical Pressure: 327 psia = 35.6 atm = 3.61 MN/m² 12.7 Specific Gravity: 0.867 at 20°C (liquid) 12.8 Liquid Surface Tension: 29.2 dyne/cm = 0.0292 N/m at 20°C 12.9 Liquid Water Interfacial Tension: 35.45 dyne/cm = 0.03545 N/m at 20°C 12.10 Vapor (Gas) Specific Gravity: Not pertinent 12.11 Ratio of Specific Heats of Vapor (Gas): 1.071 12.12 Latent Heat of Vaporization: 144 Btu/lb = 80.4 cal/g = 3.35 X 10⁴ J/kg 12.13 Heat of Combustion: -17,780 Btu/lb = -8477 cal/g = -12.5 X 10⁴ J/kg 12.14 Heat of Decomposition: Not pertinent 12.15 Heat of Solution: Not pertinent 12.16 Heat of Polymerization: Not pertinent 12.25 Heat of Fusion: Data Not Available 12.26 Limiting Value: Data Not Available 12.27 Relic Vapor Pressure: 0.4 psia</p>																																				
<p>8. WATER POLLUTION</p> <p>8.1 Aquatic Toxicity: 25 ppm/96 hr/bluegill/TL₅₀/fresh water 8.2 Water/Fresh Toxicity: Data not available 8.3 Biological Oxygen Demand (BOD): 2.5% (Theor.), 2 days 8.4 Food Chain Concentration Potential: None</p>	<p>9. SHIPPING INFORMATION</p> <p>9.1 Grades of Purity, Research grade: 99.96%, pure grade: 99.5%, technical grade: 99.0% 9.2 Storage Temperature: Ambient 9.3 Inert Atmosphere: No requirement 9.4 Venting: Open (flame arrester) or pressure-vacuum</p>																																				
<p>6. FIRE HAZARDS (Continued)</p> <p>6.11 Stoichiometric Air to Fuel Ratio: Data Not Available 6.12 Flame Temperature: Data Not Available</p>																																					

KEROSENE

KRS

<p>Common Synonyms Kerosene Range of Fuel Oil No. 1 Jet Fuel JP-1</p>	<p>Watery liquid Colorless Fuel oil odor</p>	<p>Floats on water.</p>	<p>6. FIRE HAZARDS</p> <p>6.1 Flash Point: 100°F (38°C) 6.2 Flammable Limits in Air: 0.7%-5% 6.3 Fire Extinguishing Agents: Foam, dry chemical, or carbon dioxide 6.4 Fire Extinguishing Agents Not to be Used: Water may be ineffective 6.5 Special Hazards of Combustion Products: Not pertinent 6.6 Behavior in Fire: Not pertinent 6.7 Ignition Temperature: 444°F 6.8 Electrical Hazard: Not pertinent 6.9 Burning Rate: 4 mm/min 6.10 Adiabatic Flame Temperature: Data not available 6.11 Stoichiometric Air to Fuel Ratio: Data not available 6.12 Flame Temperature: Data not available</p>	<p>10. HAZARD ASSESSMENT CODE (See Hazard Assessment Handbook) A-T-U</p>																																				
<p>Stop discharge if possible Call fire department Avoid contact with liquid Isolate and remove discharged material Notify local health and pollution control agencies.</p>			<p>11. HAZARD CLASSIFICATIONS</p> <p>11.1 Code of Federal Regulations: Combustible liquid</p> <p>11.2 HAS Hazard Rating for Bulk Water Transportation:</p> <table style="width: 100%; border-collapse: collapse;"> <thead> <tr> <th style="text-align: left;">Category</th> <th style="text-align: left;">Rating</th> </tr> </thead> <tbody> <tr> <td>Fire</td> <td>2</td> </tr> <tr> <td>Health</td> <td></td> </tr> <tr> <td>Vapor Irritant</td> <td>1</td> </tr> <tr> <td>Liquid or Solid Irritant</td> <td>1</td> </tr> <tr> <td>Poisons</td> <td>1</td> </tr> <tr> <td>Water Pollution</td> <td></td> </tr> <tr> <td>Human Toxicity</td> <td>1</td> </tr> <tr> <td>Aquatic Toxicity</td> <td>1</td> </tr> <tr> <td>Acute Effect</td> <td>2</td> </tr> <tr> <td>Reactivity</td> <td></td> </tr> <tr> <td>Other Chemicals</td> <td>0</td> </tr> <tr> <td>Water</td> <td>0</td> </tr> <tr> <td>Sol Reaction</td> <td>0</td> </tr> </tbody> </table> <p>11.3 NFPA Hazard Classifications:</p> <table style="width: 100%; border-collapse: collapse;"> <thead> <tr> <th style="text-align: left;">Category</th> <th style="text-align: left;">Classification</th> </tr> </thead> <tbody> <tr> <td>Health Hazard (Blue)</td> <td>0</td> </tr> <tr> <td>Flammability (Red)</td> <td>2</td> </tr> <tr> <td>Reactivity (Yellow)</td> <td>0</td> </tr> </tbody> </table>		Category	Rating	Fire	2	Health		Vapor Irritant	1	Liquid or Solid Irritant	1	Poisons	1	Water Pollution		Human Toxicity	1	Aquatic Toxicity	1	Acute Effect	2	Reactivity		Other Chemicals	0	Water	0	Sol Reaction	0	Category	Classification	Health Hazard (Blue)	0	Flammability (Red)	2	Reactivity (Yellow)	0
Category	Rating																																							
Fire	2																																							
Health																																								
Vapor Irritant	1																																							
Liquid or Solid Irritant	1																																							
Poisons	1																																							
Water Pollution																																								
Human Toxicity	1																																							
Aquatic Toxicity	1																																							
Acute Effect	2																																							
Reactivity																																								
Other Chemicals	0																																							
Water	0																																							
Sol Reaction	0																																							
Category	Classification																																							
Health Hazard (Blue)	0																																							
Flammability (Red)	2																																							
Reactivity (Yellow)	0																																							
<p>Fire</p>	<p>Combustible. Extinguish with dry chemical, foam, or carbon dioxide. Water may be ineffective on fire. Cool exposed containers with water.</p>		<p>7. CHEMICAL REACTIVITY</p> <p>7.1 Reactivity With Water: No reaction 7.2 Reactivity with Common Materials: No reaction 7.3 Stability During Transport: Stable 7.4 Neutralizing Agents for Acids and Caustics: Not pertinent 7.5 Polymerization: Not pertinent 7.6 Inhibitor of Polymerization: Not pertinent 7.7 Male Ratio (Reactant to Product): Data not available 7.8 Reactivity Group: 23</p>																																					
<p>Exposure</p>	<p>CALL FOR MEDICAL AID</p> <p>LIQUID Irritating to skin and eyes. Harmful if swallowed. Remove contaminated clothing and shoes. Flush affected areas with plenty of water. IF IN EYES, hold eyelids open and flush with plenty of water. IF SWALLOWED and victim is CONSCIOUS, have victim drink water or milk. DO NOT INDUCE VOMITING.</p>		<p>12. PHYSICAL AND CHEMICAL PROPERTIES</p> <p>12.1 Physical State at 15°C and 1 atm: Liquid 12.2 Molecular Weight: Not pertinent 12.3 Boiling Point at 1 atm: 297-300°F = 200-260°C = 473-533°K 12.4 Freezing Point: -90°F = -45°C = 227°K 12.5 Critical Temperature: Not pertinent 12.6 Critical Pressure: Not pertinent 12.7 Specific Gravity: 0.80 at 15°C (liquid) 12.8 Liquid Surface Tension: 23.32 dynes/cm = 0.023-0.032 N/m at 20°C 12.9 Liquid Water Interfacial Tension: 47-49 dynes/cm = 0.047-0.049 N/m at 20°C 12.10 Vapor (Gas) Specific Gravity: Not pertinent 12.11 Ratio of Specific Heats of Vapor (Gas): Not pertinent 12.12 Latent Heat of Vaporization: 110 Btu/lb = 80 cal/g = 2.8 x 10⁴ J/kg 12.13 Heat of Combustion: -18,540 Btu/lb = -10,300 cal/g = -43.24 x 10⁴ J/kg 12.14 Heat of Decomposition: Not pertinent 12.15 Heat of Solution: Not pertinent 12.16 Heat of Polymerization: Not pertinent 12.25 Heat of Fusion: Data not available 12.26 Limiting Value: Data not available 12.27 Acid Vapor Pressure: 0.1 psia</p>																																					
<p>Water Pollution</p>	<p>Dangerous to aquatic life in high concentrations. Fouling to shorelines. May be dangerous if it enters water intakes. Notify local health and waste officials. Notify operators of nearby water intakes.</p>		<p>8. WATER POLLUTION</p> <p>8.1 Aquatic Toxicity: 2990 ppm/24 hr/blue/gill/TL₅₀/fresh water 8.2 Waterfowl Toxicity: Data not available 8.3 Biological Oxygen Demand (BOD): 25%, 5 days 8.4 Food Chain Concentration: Potential: None</p>																																					
<p>1. RESPONSE TO DISCHARGE (See Response Methods Handbook) Mechanical containment Should be removed Chemical and physical treatment</p>	<p>2. LABEL</p> <p>2.1 Category: None 2.2 Class: Not pertinent</p>		<p>3. CHEMICAL DESIGNATIONS</p> <p>3.1 CG Compatibility Class: Miscellaneous Hydrocarbon Mixtures 3.2 Formula: C₁₂H₂₆ 3.3 IMO/UN Designation: 3.3/1223 3.4 DOT ID No.: 1223 3.5 CAS Registry No.: 8008-20-8</p>																																					
<p>3. CHEMICAL DESIGNATIONS</p> <p>3.1 CG Compatibility Class: Miscellaneous Hydrocarbon Mixtures 3.2 Formula: C₁₂H₂₆ 3.3 IMO/UN Designation: 3.3/1223 3.4 DOT ID No.: 1223 3.5 CAS Registry No.: 8008-20-8</p>		<p>4. DESERVABLE CHARACTERISTICS</p> <p>4.1 Physical State (as shipped): Liquid 4.2 Color: Colorless to light brown 4.3 Odor: Characteristic</p>		<p>8. SHIPPING INFORMATION</p> <p>8.1 Grades of Purity: Light hydrocarbon 99.99% 8.2 Storage Temperature: Ambient 8.3 Inert Atmosphere: No requirement 8.4 Venting: Open (flame arrester)</p>																																				
<p>5. HEALTH HAZARDS</p> <p>5.1 Personal Protective Equipment: Protective gloves, goggles or face shield. 5.2 Symptoms Following Exposure: Vapor causes slight irritation of eyes and nose. Liquid irritates stomach; if taken into lungs causes coughing, distress, and rapidly developing pulmonary edema. 5.3 Treatment of Exposure: ASPIRATION enforce bed rest, administer oxygen, call a doctor. INGESTION do NOT induce vomiting, call a doctor. EYES wash with plenty of water. SKIN: wipe off and wash with soap and water. 5.4 Threshold Limit Value: 200 ppm 5.5 Short Term Inhalation Limits: 2500 mg/m³ for 30 min. 5.6 Toxicity by Ingestion: Grade 1, LD₅₀ = 3 to 15 g/kg 5.7 Lethal Toxicity: Data not available 5.8 Vapor (Gas) Irritant Characteristics: Vapors cause a slight stinging of the eyes or respiratory system if present in high concentrations. The effect is temporary. 5.9 Liquid or Solid Irritant Characteristics: Minimum hazard. If spilled on clothing and allowed to remain, may cause stinging and reddening of the skin. 5.10 Odor Threshold: 1 ppm 5.11 IDLH Value: Data not available</p>			<p style="text-align: center;">NOTES</p>																																					

OILS, FUEL: 1-D

OOD

<p>Common Synonyms Diesel oil (light)</p>	<p>Dry liquid</p> <p style="text-align: center;">Yellow-brown</p> <p>Lube or fuel oil color</p>	<p>Floats on water.</p>	
<p>Stop discharge if possible Call fire department Avoid contact with liquid Isolate and remove discharged material Notify local health and pollution control agencies.</p>			
Fire	<p>Combustible. Extinguish with dry chemical foam or carbon dioxide. Water may be ineffective on fire. Cool exposed containers with water.</p>		
Exposure	<p>CALL FOR MEDICAL AID.</p> <p>LIQUID Irritating to skin and eyes. Harmful if swallowed. Removes contaminated clothing and shoes. Flush affected areas with plenty of water. IF IN EYES, hold eyelids open and flush with plenty of water. IF SWALLOWED and victim is CONSCIOUS, have victim drink water or milk. DO NOT INDUCE VOMITING.</p>		
Water Pollution	<p>Dangerous to aquatic life in high concentrations. Floating in streams. May be dangerous if it enters water intakes. Notify local health and wildlife officials. Notify operators of nearby water intakes.</p>		
<p>1. RESPONSE TO DISCHARGE (See Response Methods Handbook) Mechanical containment Should be removed Chemical and physical treatment</p>		<p>2. LABEL</p> <p>2.1 Category: None 2.2 Class: Not pertinent</p>	
<p>3. CHEMICAL DESIGNATIONS</p> <p>3.1 CO Compatibility Class: Miscellaneous hydrocarbon mixtures 3.2 Formula: Not applicable 3.3 IMDG Designation: 3.1/1270 3.4 DOT ID No.: 1270 3.5 CAS Registry No.: Data not available</p>		<p>4. OBSERVABLE CHARACTERISTICS</p> <p>4.1 Physical State (as shipped): Liquid 4.2 Color: Light brown 4.3 Odor: Characteristic</p>	
<p>5. HEALTH HAZARDS</p> <p>5.1 Personal Protective Equipment: Protective gloves, goggles or face shield. 5.2 Symptoms Following Exposure: INHALATION causes headache and slight dizziness. INGESTION causes nausea, vomiting and cramping, depression of central nervous system ranging from mild headache to emphysema, coma, and death. pulmonary irritation secondary to exhalation of solvent, signs of kidney and liver damage may be delayed. ASPIRATION causes severe lung irritation with coughing, gagging, dyspnea, substernal distress, and rapidly developing pulmonary edema. later, signs of bronchopneumonia and pneumonia, acute onset of central nervous system excitement followed by depression. 5.3 Treatment of Exposure: INGESTION do NOT induce vomiting, seek medical attention. ASPIRATION enforce bed rest, administer oxygen. EYES wash with copious quantity of water. SKIN remove solvent by wiping and wash with soap and water. 5.4 Threshold Limit Value: No single value applicable. 5.5 Short Term Inhalation Limit: Data not available. 5.6 Toxicity by Ingestion: Grade 1; LD₅₀ = 5-15 g/kg 5.7 Late Toxicity: Data not available. 5.8 Vapor (Gas) Irritant Characteristics: Slight stinging of eyes or respiratory system if present in high concentrations. The effect is temporary. 5.9 Liquid or Solid Irritant Characteristics: Minimum hazard if spilled on clothing and allowed to remain, may cause stinging and reddening of skin. 5.10 Odor Threshold: 0.7 ppm 5.11 IDLH Value: Data not available</p>			

6. FIRE HAZARDS

6.1 Flash Point: 100°F C.C.
6.2 Flammable Limits in Air: 1.2%-8%
6.3 Fire Extinguishing Agents: Dry chemical, foam, or carbon dioxide
6.4 Fire Extinguishing Agents Not to Be Used: Water may be ineffective
6.5 Special Hazards of Combustion Products: Not pertinent
6.6 Behavior in Fire: Not pertinent
6.7 Ignition Temperature: 250-625°F
6.8 Electrical Hazard: Not pertinent
6.9 Burning Rate: 4 mm/min.
6.10 Autobaric Flame Temperature: Data not available
6.11 Flashbackable Air to Fuel Ratio: Data not available
6.12 Flame Temperature: Data not available

10. HAZARD ASSESSMENT CODE
(See Hazard Assessment Handbook)
A-T-U

11. HAZARD CLASSIFICATIONS

11.1 Code of Federal Regulations: Combustible liquid
11.2 HAS Hazard Rating for Bulk Water Transportation: Not listed
11.3 NFPA Hazard Classification

Category	Class/Division
Health Hazard (Blue)	0
Flammability (Red)	2
Reactivity (Yellow)	0

7. CHEMICAL REACTIVITY

7.1 Reactivity With Water: No reaction
7.2 Reactivity with Common Materials: No reaction
7.3 Stability During Transport: Stable
7.4 Neutralizing Agents for Acids and Caustics: Not pertinent
7.5 Polymerization: Not pertinent
7.6 Inhibitor of Polymerization: Not pertinent
7.7 Heat Ratio (Reactant to Product): Data not available
7.8 Reactivity Group: 30

12. PHYSICAL AND CHEMICAL PROPERTIES

12.1 Physical State at 15°C and 1 atm: Liquid
12.2 Molecular Weight: Not pertinent
12.3 Boiling Point at 1 atm: 300-340°F = 150-200°C = 496-506°K
12.4 Freezing Point: -30°F = -34°C = 240°K
12.5 Critical Temperature: Not pertinent
12.6 Critical Pressure: Not pertinent
12.7 Specific Gravity: 0.87-0.88 at 15°C (liquid)
12.8 Liquid Surface Tension: 23-32 dynes/cm = 0.022-0.032 N/m at 20°C
12.9 Liquid Water Interfacial Tension: 47-49 dynes/cm = 0.047-0.049 N/m at 20°C
12.10 Vapor (Gas) Specific Gravity: Not pertinent
12.11 Ratio of Specific Heats of Vapor (Gas): Not pertinent
12.12 Latent Heat of Vaporization: 110 Btu/lb = 60 cal/g = 2.5 x 10⁴ J/kg
12.13 Heat of Combustion: -18,540 Btu/lb = -10,300 cal/g = -431.24 x 10⁴ J/kg
12.14 Heat of Decomposition: Not pertinent
12.15 Heat of Solution: Not pertinent
12.16 Heat of Polymerization: Not pertinent
12.25 Heat of Fusion: Data not available
12.26 Limiting Value: Data not available
12.27 Reid Vapor Pressure: Data not available

8. WATER POLLUTION

8.1 Aquatic Toxicity: 254 mg/1/24 hr/juvenile American shad/TL₅₀/salt water
8.2 Waterfowl Toxicity: 20 mg/kg LD₅₀ (maltard)
8.3 Biological Oxygen Demand (BOD): Data not available
8.4 Food Chain Concentration Potential: None

9. SHIPPING INFORMATION

9.1 Grades of Purity: Diesel fuel 1-D (ASTM)
9.2 Storage Temperature: Ambient
9.3 Inert Atmosphere: No requirement
9.4 Venting Open (Flame arrestor)

NOTES

OILS, FUEL: 2-D

OTD

<p>Common Synonyms Diesel oil, medium</p>	<p>Dry liquid Yellow-brown Lube or fuel oil color</p>	<p>Flasks or water.</p>	
<p>Stop discharge if possible. Call fire department. Avoid contact with liquid. Wash and remove discharged material. Notify local health and pollution control agencies.</p>			
Fire	<p>Combustible. Extinguish with dry chemical, foam, carbon dioxide. Water may be ineffective on fire. Cool exposed containers with water.</p>		
Exposure	<p>CALL FOR MEDICAL AID. LUBRICATING OILS Irritating to skin and eyes. Harmful if swallowed. Remove contaminated clothing and shoes. Flush affected areas with plenty of water. If IN EYES, hold eyelids open and flush with plenty of water. If SWALLOWED, and victim is CONSCIOUS, have victim drink water or milk. DO NOT INDUCE VOMITING.</p>		
Water Pollution	<p>Dangerous to aquatic life in high concentrations. Floating in shorelines. May be dangerous if it enters water intakes. Notify local health and waste officials. Notify operators of nearby water intakes.</p>		
<p>1. RESPONSE TO DISCHARGE (See Response Methods Handbook) Mechanical containment Should be removed Chemical and physical treatment</p>	<p>2. LABEL 2.1 Category: None 2.2 Class: Not pertinent</p>		
<p>3. CHEMICAL DESIGNATIONS 3.1 CG Compatibility Class: Miscellaneous Hydrocarbon Mixtures 3.2 Formula: Not applicable 3.3 IMO/IUM Designation: 2/1/2/2/D 3.4 DOT ID No.: 127D 3.5 CAS Registry No.: Data not available</p>	<p>4. OBSERVABLE CHARACTERISTICS 4.1 Physical State (as shipped): Liquid 4.2 Color: Light brown 4.3 Odor: Characteristic</p>		
<p>5. HEALTH HAZARDS</p>			
<p>5.1 Personal Protective Equipment: Protective gloves, goggles or face shield. 5.2 Symptoms Following Exposure: INGESTION causes nausea, vomiting, and cramping; depression of central nervous system ranging from mild headache to anaesthesia, coma, and death; pulmonary irritation secondary to inhalation of solvent vapors; signs of kidney and liver damage may be delayed. ASPIRATION causes severe lung irritation with coughing, gagging, dyspnea, substernal distress, and rapidly developing pulmonary edema, later, signs of bronchopneumonia and pneumonia; acute onset of central nervous system involvement followed by depression. 5.3 Treatment of Exposure: INGESTION do NOT induce vomiting. ASPIRATION enforce bed rest; administer oxygen; seek medical attention. EYES wash with copious quantity of water. SKIN: remove solvent by wiping and wash with soap and water. 5.4 Threshold Limit Value: No single TLV applicable. 5.5 Short Term Inhalation Limits: Data not available. 5.6 Toxicity by Ingestion: Grade 1, LD50 = 8-15 g/kg 5.7 Lethal Toxicity: Data not available. 5.8 Vapor (Gas) Irritant Characteristics: Slight stinging of eyes or respiratory system if present in high concentrations. The effect is temporary. 5.9 Liquid or Solid Irritant Characteristics: Minimum hazard if spilled on clothing and allowed to remain; may cause stinging and reddening of skin. 5.10 Dermal Threshold: Data not available. 5.11 IDLN Value: Data not available.</p>			

<p>6. FIRE HAZARDS 6.1 Flash Point: 125°F C.C. 6.2 Flammable Limits in Air: 1.3% - 6.0% 6.3 Fire Extinguishing Agents: Dry chemical, foam, or carbon dioxide 6.4 Fire Extinguishing Agents Not to be Used: Water may be ineffective 6.5 Specific Hazards of Combustion Products: Not pertinent 6.6 Behavior in Fire: Not pertinent 6.7 Ignition Temperature: 490-545°F 6.8 Electrical Hazard: Not pertinent 6.9 Burning Rate: 4 mm/min 6.10 Adiabatic Flame Temperature: Data not available 6.11 Stoichiometric Air to Fuel Ratio: Data not available 6.12 Flame Temperature: Data not available</p>	<p>10. HAZARD ASSESSMENT CODE (See Hazard Assessment Handbook) A-T-U</p>								
<p>7. CHEMICAL REACTIVITY 7.1 Reactivity With Water: No reaction 7.2 Reactivity with Common Materials: No reaction 7.3 Stability During Transport: Stable 7.4 Neutralizing Agents for Acids and Caustics: Not pertinent 7.5 Polymerization: Not pertinent 7.6 Inhibitor of Polymerization: Not pertinent 7.7 Molar Ratio (Reactant to Product): Data not available 7.8 Reactivity Group: 20</p>	<p>11. HAZARD CLASSIFICATIONS 11.1 Code of Federal Regulations: Combustible liquid 11.2 HAS Hazard Rating for Bulk Water Transportation: Not listed 11.3 NFPA Hazard Classification</p> <table style="width: 100%; border-collapse: collapse;"> <tr> <td style="text-align: center;">Category</td> <td style="text-align: center;">Classification</td> </tr> <tr> <td style="text-align: center;">Health Hazard (Blue)</td> <td style="text-align: center;">0</td> </tr> <tr> <td style="text-align: center;">Flammability (Red)</td> <td style="text-align: center;">3</td> </tr> <tr> <td style="text-align: center;">Reactivity (Yellow)</td> <td style="text-align: center;">0</td> </tr> </table>	Category	Classification	Health Hazard (Blue)	0	Flammability (Red)	3	Reactivity (Yellow)	0
Category	Classification								
Health Hazard (Blue)	0								
Flammability (Red)	3								
Reactivity (Yellow)	0								
<p>8. WATER POLLUTION 8.1 Aquatic Toxicity: 204 mg/l/24 hr/juvenile American shad TL₅₀ salt water 8.2 Waterway Toxicity: Data not available 8.3 Biological Oxygen Demand (BOD): Data not available 8.4 Food Chain Concentration Potential: None</p>	<p>12. PHYSICAL AND CHEMICAL PROPERTIES 12.1 Physical State at 15°C and 1 atm: Liquid 12.2 Molecular Weight: Not pertinent 12.3 Boiling Point at 1 atm: 340-340°F = 282-230°C = 555-611°K 12.4 Freezing Point: 0°F = 15°C = 255°K 12.5 Critical Temperature: Not pertinent 12.6 Critical Pressure: Not pertinent 12.7 Specific Gravity: 0.87-0.88 at 20°C (liquid) 12.8 Liquid Surface Tension: Data not available 12.9 Liquid Water Intertfacial Tension: Data not available 12.10 Vapor (Gas) Specific Gravity: Not pertinent 12.11 Ratio of Specific Heats of Vapor (Gas): Not pertinent 12.12 Latent Heat of Vaporization: Not pertinent 12.13 Heat of Combustion: -16,440 Btu/lb = -10,800 cal/g = -45.17 x 10³ J/kg 12.14 Heat of Decomposition: Not pertinent 12.15 Heat of Solution: Not pertinent 12.16 Heat of Polymerization: Not pertinent 12.25 Heat of Fusion: Data not available 12.26 Limiting Value: Data not available 12.27 Reid Vapor Pressure: Data not available</p>								
<p>9. SHIPPING INFORMATION 9.1 Grades of Purity: Diesel fuel 2-D (ASTM) 9.2 Storage Temperature: Ambient 9.3 Inert Atmosphere: No requirement 9.4 Venting: Open (flame arrestor)</p>									
<p>NOTES</p>									

POLYCHLORINATED BIPHENYL

PCB

Common Synonyms PCB Dichlorinated biphenyl Arochlor Halogenated arses Polychlorobiphenyls		Dry liquid to solid powder Light yellow liquid, or white powder Weak odor
Sinks in water.		
Size: Measure if possible. Keep people away. Avoid contact with liquid and solid. Call fire department. Notify local health and pollution control agencies.		
Fire	Combustible. Extinguish with water, foam, dry chemical, or carbon dioxide.	
Exposure	CALL FOR MEDICAL AID. LIQUID OR SOLID irritates to skin and eyes. Flush affected areas with plenty of water. If in EYES, hold eyes open and flush with plenty of water.	
Water Pollution	HARMFUL TO AQUATIC LIFE IN VERY LOW CONCENTRATIONS. May be dangerous if it enters water intakes. Notify local health and wildlife officials. Notify operators of nearby water intakes.	
1. RESPONSE TO DISCHARGE (See Response Methods Handbook) Issue warning water contaminant should be removed. Chemical and physical treatment.		2. LABEL 2.1 Category: None 2.2 Class: Not pertinent
3. CHEMICAL DESIGNATIONS 3.1 CG Compatibility Class: Not listed 3.2 Formula: C ₁₂ H ₁₀ Cl ₂ 3.3 IMO/IUN Designation: Not listed 3.4 DOT ID No.: 2918 3.5 CAS Registry No.: 1238-26-3		4. OBSERVABLE CHARACTERISTICS 4.1 Physical State (as shipped): Liquid or solid 4.2 Color: Pale yellow (liquid), colorless (solid) 4.3 Odor: Practically odorless
5. HEALTH HAZARDS 5.1 Personal Protective Equipment: Goggles and protective garments. 5.2 Symptoms Following Exposure: Acne from skin contact. 5.3 Treatment of Exposure: SKIN wash with soap and water. 5.4 Threshold Limit Value: 0.5 to 1.0 mg/m ³ 5.5 Short Term Inhalation Limits: Data not available 5.6 Toxicity by Ingestion: Grade 2, oral rat LD ₅₀ = 2980 mg/kg 5.7 Late Toxicity: Causes chromosomal abnormalities in rats, birds; defects in birds 5.8 Vapor (Gas) Irritant Characteristics: Vapors cause severe irritation of eyes and throat and cause eye and lung injury. They cannot be tolerated even at low concentrations. 5.9 Liquid or Solid Irritant Characteristics: Contact with skin may cause irritation. 5.10 Odor Threshold: Data not available 5.11 IDLN Value: 5 to 10 mg/m ³		

6. FIRE HAZARDS 6.1 Flash Point: > 206°F 6.2 Flammable Limits in Air: Data not available 6.3 Fire Extinguishing Agents: Water, foam, dry chemical, or carbon dioxide 6.4 Fire Extinguishing Agents Not to be Used: Not pertinent 6.5 Special Hazards of Combustion: Products: Irritating gases are generated in fires. 6.6 Behavior in Fire: Not pertinent 6.7 Ignition Temperature: Data not available 6.8 Electrical Hazard: Not pertinent 6.9 Burning Rate: Data not available 6.10 Adiabatic Flame Temperature: Data not available 6.11 Stoichiometric Air to Fuel Ratio: Data not available 6.12 Flame Temperature: Data not available	10. HAZARD ASSESSMENT CODE (See Hazard Assessment Handbook) II
7. CHEMICAL REACTIVITY 7.1 Reactivity With Water: No reaction 7.2 Reactivity with Common Materials: No reaction 7.3 Stability During Transport: Stable 7.4 Neutralizing Agents for Acids and Caustics: Not pertinent 7.5 Polymerization: Not pertinent 7.6 Inhibitor of Polymerization: Not pertinent 7.7 Molar Ratio (Reactant to Product): Data not available 7.8 Reactivity Group: Data not available	11. HAZARD CLASSIFICATIONS 11.1 Code of Federal Regulation: OSHA 11.2 NIOSH Hazard Rating for Bulk Water Transportation: Not listed 11.3 NFPA Hazard Classification: Not listed
8. WATER POLLUTION 8.1 Aquatic Toxicity: 0.278 ppm/96 hr/blu/gill/TL ₅₀ /fresh water 0.025 ppm/306-1080 hr/fresh/TL ₅₀ /sea water 8.2 Waterfowl Toxicity: LD ₅₀ 2000 ppm (molar duck) 8.3 Biological Oxygen Demand (BOD): Very low 8.4 Food Chain Concentration Potential: High	12. PHYSICAL AND CHEMICAL PROPERTIES 12.1 Physical State at 15°C and 1 atm: Solid 12.2 Molecular Weight: Not pertinent 12.3 Boiling Point at 1 atm: Very high 12.4 Freezing Point: Not pertinent 12.5 Critical Temperature: Not pertinent 12.6 Critical Pressure: Not pertinent 12.7 Specific Gravity: 1.3-1.8 at 20°C (liquid) 12.8 Liquid Surface Tension: Not pertinent 12.9 Liquid Water Interfacial Tension: Not pertinent 12.10 Vapor (Gas) Specific Gravity: Not pertinent 12.11 Ratio of Specific Heats of Vapor (Gas): Not pertinent 12.12 Latent Heat of Vaporization: Not pertinent 12.13 Heat of Combustion: Not pertinent 12.14 Heat of Decomposition: Not pertinent 12.15 Heat of Solution: Not pertinent 12.16 Heat of Polymerization: Not pertinent 12.17 Heat of Fusion: Data not available 12.18 Limiting Value: Data not available 12.19 Reid Vapor Pressure: Data not available
9. SHIPPING INFORMATION 9.1 Grades of Purity: 11 grades (some liquid, some solids); which differ primarily in the chlorine content (20% to 80% by weight) 9.2 Storage Temperature: Ambient 9.3 Inert Atmosphere: No requirement 9.4 Venting: Open	
NOTES	

APPENDIX A2
SITE SPECIFIC EMERGENCY INFORMATION

**SITE SPECIFIC
EMERGENCY INFORMATION**

Job Site: Harrison Street Garage
1432 Harrison Street
Oakland, California 94612

Contact Person: John P. Cummings; Office Director/Site Health & Safety Officer
SCS Engineers
(415) 829-0661

Nels R. Johnson; Project Manager
SCS Engineers
(415) 829-0661

Emergency Phone Numbers: Dial 911, report location,
nature of injury or accident,
and assistance required.

Fire Protection/Paramedics: Dial 911

Poison Control Center/San Francisco: 1-800-523-2222
or 415-476-6600

National Response Center (NRC): For toxic chemical
and oil spills
1-800-424-8802

Hospitals/Emergency Services (Figure 1):

Nearest: Peralta Hospital
450 30th Street
Oakland, California
415-451-4900

Other Hospitals in Area:

Providence Hospital
3100 Summit Street
Oakland, California
415-835-4500

Kaiser-Permanente Medical Center
280 W. MacArthur Boulevard
Oakland, California
415-596-1000

Merritt Hospital
Hawthorne and Webster Streets
Oakland, California
415-655-4000

Telephones are available in offices on the site and a cellular phone also will be present. A job site safety meeting will be held daily with the crew, including subcontractors, prior to starting excavation. NO SMOKING signs will be posted in proximity to the work site(s). Two fire extinguishes with a minimum class rating of 20BC shall be kept within at least 50 feet of the removal operation at all times during work operations. There shall be no ignition sources allowed within the area while removal operations are in progress. A first aid kit shall be present on site during all removal operations.

A copy of this notice shall be conspicuously posted in the area adjacent to removal operations, along with a copy of the fire department permit.



LOCATIONS OF OAKLAND HOSPITALS NEAR HARRISON STREET GARAGE
 1432 Harrison Street, Oakland, California

APPENDIX A3
SIGNATURE SHEET

SIGNATURE SHEET

All employees of SCS Engineers, its subcontractors, or other agents must certify by signing this document that they have completed the appropriate OSHA-approved training and that they have read and will comply with this Site Health and Safety Plan.

Signature/Company Date

Signature/Company Date

Signature/Company Date

Signature/Company Date

Signature/Company Date

Signature/Company Date

Signature/Company Date

Signature/Company Date

Signature/Company Date

Signature/Company Date

Signature/Company Date

APPENDIX C
TANK REMOVAL CONTRACTOR'S
WORKMAN'S COMPENSATION INSURANCE CERTIFICATES

CERTIFICATE OF INSURANCE

12/31/90

This certificate is issued as a matter of information only and confers no rights upon the certificate holder. This certificate does not amend, extend or alter the coverage afforded by the policies listed below.

PRODUCER	C	Letter A	Pacific Compensation Ins. Co.
Daugherty & Company	O		
2495 West March Lane	M	Letter B	
Stockton CA 95207	P		
	A	Letter C	
INSURED	N		
Falcon Energy Associates	I	Letter D	
P. O. Box 1257	E		
Stockton CA 95201	S	Letter E	

"LIMITS AT POLICY INCEPTION"

This is to certify that policies of insurance listed below have been issued to the insured named above for the policy period indicated. Notwithstanding any requirement, term or condition of any contract or other document with respect to which this certificate may be issued or may pertain, the insurance afforded by the policies described herein is subject to all the terms, exclusions and conditions of such policies. Limits shown may have been reduced by paid claims.

-----COVERAGES-----					
Co Ltr	Type of Insurance	Policy #	Policy Effective	Policy Expiration	All Limits in Thousands
GENERAL LIABILITY					
()	Commercial GL				Gnl Aggregate
()	() Claims Made				Prd-CompOp Agg
()	() Occurrence				Pers & Adv Inj
()	Owners & Contr				Each Occur
()					Fire Damage
()					Medical Exp
AUTOMOBILE LIABILITY					
()	Any Auto				CSL
()	All Owned				B.I./Person
()	Scheduled				B.I./Accident
()	Hired				P.D.
()	Non-Owned				
()	Garage Liab				
EXCESS LIABILITY					
()	Umbrella Form				Each Occur Aggregate
()	O.T. Umbrella				
WORKERS COMPENSATION					
A	W.C.	WP012191	11/30/90	11/30/91	STATUTORY
	Employers Liab.				Each Accident \$1,000
					Disease/Pol \$1,000
					Disease/Emp \$1,000
OTHER					

DESCRIPTION OF Operations/Locations/Vehicles/Restrictions/Special Items

RE: As their interest may appear.

CANCELLATION: Should any of the above described policies be cancelled before the expiration date thereof, the issuing company will endeavor to mail ten days written notice to the certificate holder named below but failure to mail such notice shall impose no obligation or liability of any kind upon the company, its agents or representatives.

NAME and ADDRESS of CERTIFICATE HOLDER

SITE ADDRESS

1432 Harrison Street
Oakland, CA 94612

R. J. Daugherty
Authorized Representative

ADDENDUM CERTIFICATE OF INSURANCE

ISSUED BY (DATE)
 RAV 1568
 12/12/90

THIS CERTIFICATE IS ISSUED AS A MATTER OF INFORMATION ONLY AND CONFERS NO RIGHTS UPON THE CERTIFICATE HOLDER. THIS CERTIFICATE DOES NOT AMEND, EXTEND OR ALTER THE COVERAGE AFFORDED BY THE POLICIES BELOW.

PRODUCER

Corroon & Black of Missouri, Inc.
 8112 Maryland Avenue
 St. Louis, Missouri 63105-3721

COMPANIES AFFORDING COVERAGE

- COMPANY LETTER **A** Gotham Insurance Company
- COMPANY LETTER **B** Ocean Marine Indemnity
- COMPANY LETTER **C**
- COMPANY LETTER **D**
- COMPANY LETTER **E**

INSURED

Kiesel Enterprises, Inc. et al
~~Falcon Energy Associates~~
 4801 Fyler Avenue
 St. Louis, Missouri 63116

COVERAGES

THIS IS TO CERTIFY THAT THE POLICIES OF INSURANCE LISTED BELOW HAVE BEEN ISSUED TO THE INSURED NAMED ABOVE FOR THE POLICY PERIOD INDICATED. NOTWITHSTANDING ANY REQUIREMENT, TERM OR CONDITION OF ANY CONTRACT OR OTHER DOCUMENT WITH RESPECT TO WHICH THIS CERTIFICATE MAY BE ISSUED OR MAY PERTAIN, THE INSURANCE AFFORDED BY THE POLICIES DESCRIBED HEREIN IS SUBJECT TO ALL THE TERMS, EXCLUSIONS AND CONDITIONS OF SUCH POLICIES. LIMITS SHOWN MAY HAVE BEEN REDUCED BY PAID CLAIMS.

CO LTR	TYPE OF INSURANCE	POLICY NUMBER	POLICY EFFECTIVE DATE (MM/DD/YYYY)	POLICY EXPIRATION DATE (MM/DD/YYYY)	LIMITS
A	GENERAL LIABILITY <input checked="" type="checkbox"/> COMMERCIAL GENERAL LIABILITY CLAIMS MADE <input checked="" type="checkbox"/> OCCUR. OWNER'S & CONTRACTOR & PROT. <input checked="" type="checkbox"/> Coverage includes sudden and accidental pollution, subject to 72 hours as defined in policy.	MMO-35827	12/01/90	12/01/91	GENERAL AGGREGATE \$ 2,000,000 PRODUCTS-COMP/OP AGG. \$ 1,000,000 PERSONAL & ADV. INJURY \$ 1,000,000 EACH OCCURRENCE \$ 1,000,000 FIRE DAMAGE (Any one line) \$ 50,000 MED. EXPENSE (Any one person) \$ 5,000
	AUTOMOBILE LIABILITY				COMBINED SINGLE LIMIT \$ BODILY INJURY (Per person) \$ BODILY INJURY (Per accident) \$ PROPERTY DAMAGE \$
B	EXCESS LIABILITY UMBRELLA FORM <input checked="" type="checkbox"/> OTHER THAN UMBRELLA FORM	GCM 13974	12/01/90	12/01/91	EACH OCCURRENCE \$ 5,000,000 AGGREGATE \$ 5,000,000
	WORKER'S COMPENSATION AND EMPLOYERS' LIABILITY				STATUTORY LIMITS EACH ACCIDENT \$ DISEASE-POLICY LIMIT \$ DISEASE-EACH EMPLOYEE \$
	OTHER				

DESCRIPTION OF OPERATIONS/LOCATIONS/VEHICLES/SPECIAL ITEMS

CERTIFICATE HOLDER

SITE ADDRESS

1432 Harrison Street
 Oakland, CA 94612

CANCELLATION

SHOULD ANY OF THE ABOVE DESCRIBED POLICIES BE CANCELLED BEFORE THE EXPIRATION DATE THEREOF, THE ISSUING COMPANY WILL ENDEAVOR TO MAIL 30 DAYS WRITTEN NOTICE TO THE CERTIFICATE HOLDER NAMED TO THE LEFT, BUT FAILURE TO MAIL SUCH NOTICE SHALL IMPOSE NO OBLIGATION OR LIABILITY OF ANY KIND UPON THE COMPANY, ITS AGENTS OR REPRESENTATIVES.

AUTHORIZED REPRESENTATIVE

Timothy J. Denis
 Timothy J. Denis

ACORD

ISSUE DATE (MM/DD/YY)
12/12/80

PRODUCER
 Charles L. Crane Agency
100 South Fourth Street
St. Louis
MO 000069102

THIS CERTIFICATE IS ISSUED AS A MATTER OF INFORMATION ONLY AND CONFERS NO RIGHTS UPON THE CERTIFICATE HOLDER. THIS CERTIFICATE DOES NOT AMEND, EXTEND OR ALTER THE COVERAGE AFFORDED BY THE POLICIES BELOW.

COMPANIES AFFORDING COVERAGES

- COMPANY LETTER **A** The Continental Ins. Companies
- COMPANY LETTER **B** KEMPER
- COMPANY LETTER **C** PACIFIC EMPLOYERS INSURANCE CO
- COMPANY LETTER **D**
- COMPANY LETTER **E**

INSURED
FALCON ENERGY INC
P.O. BOX 1257
STOCKTON
CA 952010000

THIS IS TO CERTIFY THAT POLICIES OF INSURANCE LISTED BELOW HAVE BEEN ISSUED TO THE INSURED NAMED ABOVE FOR THE POLICY PERIOD INDICATED, NOTWITHSTANDING ANY REQUIREMENT, TERM OR CONDITION OF ANY CONTRACT OR OTHER DOCUMENT WITH RESPECT TO WHICH THIS CERTIFICATE MAY BE ISSUED OR MAY PERTAIN, THE INSURANCE AFFORDED BY THE POLICIES DESCRIBED HEREIN IS SUBJECT TO ALL THE TERMS, EXCLUSIONS, AND CONDITIONS OF SUCH POLICIES.

CD	TR	TYPE OF INSURANCE	POLICY NUMBER	POLICY EFFECTIVE DATE (MM/DD/YY)	POLICY EXPIRATION DATE (MM/DD/YY)	ALL LIMITS IN THOUSANDS	
		<input type="checkbox"/> GENERAL LIABILITY <input type="checkbox"/> COMMERCIAL GENERAL LIABILITY <input type="checkbox"/> CLAIMS MADE <input type="checkbox"/> OCCURRENCE <input type="checkbox"/> OWNER'S & CONTRACTORS PROTECTIVE				GENERAL AGGREGATE	\$
						PRODUCTS-COMP/OPS AGGREGATE	\$
						PERSONAL & ADVERTISING INJURY	\$
						EACH OCCURRENCE	\$
						FIRE DAMAGE (ANY ONE FIRE)	\$
						MEDICAL EXPENSE (ANY ONE PERSON)	\$
		AUTOMOBILE LIABILITY <input checked="" type="checkbox"/> ANY AUTO <input checked="" type="checkbox"/> ALL OWNED AUTOS <input checked="" type="checkbox"/> SCHEDULED AUTOS <input checked="" type="checkbox"/> HIRED AUTOS <input checked="" type="checkbox"/> NON-OWNED AUTOS <input type="checkbox"/> GARAGE LIABILITY	81CLP05168765	9/18/80	8/18/91	CSL	\$1,200,
						BODILY INJURY (PER PERSON)	\$
						BODILY INJURY (PER ACCIDENT)	\$
						PROPERTY DAMAGE	\$
		EXCESS LIABILITY <input checked="" type="checkbox"/> OTHER THAN UMBRELLA FORM	XMO033611	12/01/80	12/01/91	EACH OCCURRENCE	\$4,000,
						AGGREGATE	4,000,
		WORKERS' COMPENSATION AND EMPLOYERS' LIABILITY				STATUTORY	
						(EACH ACCIDENT)	\$
						(DISEASE-POLICY LIMIT)	\$
						(DISEASE-EACH EMPLOYEE)	\$
		OTHER <input checked="" type="checkbox"/> CONT. EQUIP	3AT58756400	9/30/90	9/30/91		PER FORM

DESCRIPTION OF OPERATIONS / LOCATIONS / VEHICLES ~~XXXXXXXXXX~~ SPECIAL ITEMS

SITE ADDRESS

1432 Harrison Street
Oakland, CA 94612

SHOULD ANY OF THE ABOVE DESCRIBED POLICIES BE CANCELLED BEFORE THE EXPIRATION DATE THEREOF, THE ISSUING COMPANY WILL ENDEAVOR TO MAIL 010 DAYS WRITTEN NOTICE TO THE CERTIFICATE HOLDER, NAMED TO THE LEFT, BUT FAILURE TO MAIL SUCH NOTICE SHALL IMPOSE NO OBLIGATION OR LIABILITY OF ANY KIND UPON THE COMPANY, ITS AGENTS OR REPRESENTATIVES.

AUTHORIZED REPRESENTATIVE

BY *Ric W P...*

GROUNDWATER SAMPLING DATA SHEET

Well No.: _____ Monthly/Quarterly/Annual/Other (circle one) Sample

Explain "Other" Sample: _____

Sampling Date: _____ Time: _____ Weather: _____

Sampler Name: _____ Company: _____ Title: _____

Sample No.: _____

Type of Sampler/Pump Used: _____

Groundwater Surface Elevation (ft.): _____

Sample Depth: _____

Describe Well Purging Before Sampling: _____

time pump on: _____ time pump off: _____

Type, Volume, Details of Sample Containers: _____

Field Preservation of Samples (if any) - Describe: _____

Analytical Lab Sent To, How Packaged and Shipped, Date/Time: _____

Describe Analytical Testing Requested: _____

Analytical Results To Be Sent To: _____

Field Parameters: Spec. Conductance (umhos/cm) _____ pH _____

Temperature _____

Other Field Conditions: _____

File No.: _____ Reviewed By: _____

cc: _____

Remarks: _____



SCS ENGINEERS
STEARNS, CONRAD AND SCHMIDT
CONSULTING ENGINEERS, INC.

