



GETTLER-RYAN INC.

SITE SAFETY PLAN JOB #1180.01

GENERAL INFORMATION:

SITE: Company: Chevron USA #9-3322
 Location: 7225 Bancroft Avenue/73rd Avenue
 City: Oakland, California

PLAN PREPARED BY: Gettler-Ryan Inc. (G-R)

 Date: August 14, 1996

OBJECTIVES: To provide a plan for the safe completion of the site work.

**PROPOSED DATE
OF SITE WORK:** August 19, 1996

**DOCUMENTATION/
SUMMARY:** Hazardous materials may be present, caution is advised.

 Site work includes:
 Removal and installation of underground piping, removal
 and installation of new tank and service islands, reusing
 existing hallmark dispensers. Work also includes various
 site improvements (see plans).

SITE/WASTE CHARACTERISTICS:

WASTE TYPE(S):	Liquid	Solid	Gas
CHARACTERISTIC(S):	Volatile	Flammable	Toxic

FACILITY DESCRIPTION: Gasoline service station with underground utilities.

STATUS: Active, to be closed during construction.

HAZARD EVALUATION:

PARAMETER: TLV: 300 ppm THC
HEALTH: Ingestion, inhalation, absorption
LEL: 10% Gastechtor max.

SPECIAL PRECAUTIONS
AND COMMENTS: Correct safety procedures must be followed, per G-R
Health and Safety Plan.

SITE SAFETY WORKPLAN:

PERIMETER ESTABLISHMENT: Site to be fenced while under construction. Use barricades
and flagging to restrict access to tank and other work
areas.

PERSONAL PROTECTION: Level of Protection: EPA Level D
Modifications: Rubber gloves, hard hats, orange vests.
Surveillance Equipment and Material: Gastech

SITE ENTRY PROCEDURES: Authorized personnel only inside fences during
construction.

DECONTAMINATION
PROCEDURES: Personnel: Wash thoroughly with detergent solution and
water.

Equipment: Steam Clean if necessary.

FIRST AID: As applicable.

WORK LIMITATIONS: (Time of day, weather, heat/cold stress): None.

PROJECT-DERIVED
MATERIAL DISPOSAL: All materials removed from the tank hole to be sampled,
placed on visqueen on site and covered until classified for
proper disposal or reuse. Recycle materials to maximum
extent possible.

Site Safety Plan
Job #1180.01

TEAM COMPOSITION: Mike O'Sullivan - Job Foreman, Site Safety Officer,
& Competent Person
3 Laborers
1 Field Technician from Geo Tech Co.
Excavation crew from Another Excavator
See Subcontractor List

EMERGENCY INFORMATION:

LOCAL RESOURCES: Ambulance/Hospital Dial 911
Police/Sheriff/Hwy.Patrol Dial 911
Fire Department Dial 911

SITE RESOURCES: Water Supply
Telephone
Visqueen
Fire Extinguisher
First Aid Kit
Sorbant Pads

EMERGENCY CONTACT: Gettler-Ryan Inc. (510) 551-7555
Project Manager, Dave Byron (510) 551-7555 x215
Safety Manager, Barry McCoy (510) 551-7555 x253
Chevron Engineer, Rina Krakovsky (510) 842-4387

EMERGENCY ROUTES: Nearest emergency hospital is:

HUMANA HOSPITAL (510) 357-8450
13855 E. 14th Street
San Leandro, California

MAP ATTACHED