



August 14, 1989

8/15/89

Mr. Scott Seery
Hazardous Materials Specialist
Alameda County Health Care Division
80 Swan Way, Rm 200
Oakland, CA 94621

RE: REVISED PLAN OF CORRECTION FOR WASTE OIL TANK AT SHELL SERVICE
STATION, 3496 CASTRO VALLEY BOULEVARD, CASTRO VALLEY, CA

Dear Mr. Seery:

On behalf of Mr. Ted Simas of Xtra Oil Company I am providing you with the a revised Plan of Correction for the former waste oil tank located at the above address in response to our agreement to follow the format of the Regional Water Quality Control Board, Workplan for Initial Subsurface Investigation - Appendix A.

I. Introduction:

A 550-gallon waste oil tank was removed from the above property in 1989. Soil samples were not taken at the time of removal and, subsequently, the owner was contacted by your office requiring that a Plan of Correction be submitted for the proposed work. The following is the proposed plan to address agency concerns.

The subject waste oil tank was removed on November 11, 1988 and disposed of under a hazardous waste manifest, Appendix A. The tank was empty of all contents at the time of removal. An unauthorized release report was recently submitted and a copy is contained in Appendix B in response to the soil sample results obtained by ASE on April 24, 1989, Appendix C.

A. Site Location. The site is located at 3496 Castro Valley Boulevard, Castro Valley, California.

B. Background. We were contacted by the owner of the site, Mr. Ted Simas, in early April 1989 and asked to collect a soil samples, per agency requirements, from beneath a 550-gallon waste oil tank located at the above address. On April 24, 1989 I contacted Mr. Scott Seery of Alameda County Health Services Department to inform him of the projected soil sample collection. Mr. Seery indicated that a Plan of Correction should be prepared prior to any activity at the site and submitted for his review.

D. Site History. The site was purchased in 1983 from ARCO Petroleum and since that time has been a retail fuel station for transportation fuels operating under the Shell Oil.

The underground storage tanks and lines are constructed of single-walled carbon steel. There are four operating tanks; 1-10,000 diesel, 1-10,000 gallon leaded

gasoline, and 2-10,000 gallon unleaded gasoline, Figure 1. No other tanks exist at the site. The site is served by four standard service islands with four dispensers per island. Tank testing records indicate that the subject waste oil tank was not tested by the present owner and it is not known if the previous owner performed the tests. Tank testing results for the remaining tanks indicates that the tanks are within acceptable standards, Appendix D.

II. Site Description

A. The site is located in a commercial/residential area of Castro Valley, California. The site is a retail Shell Service Station located at the Southwest corner of Castro Valley Boulevard and Redwood Road in Castro Valley, California (Figure 1). The station retails fuel only and does not have garage facilities. Currently, the station has four 10,000-gallon underground fuel tanks servicing the facility. The subject waste oil tank was used by the previous owner and was not in use under the present owner since the station changed ownership in 1983.

B. Soil Sampling Results.

On May 5, 1989 a single soil sample was taken in native soil from beneath the former 550-gallon waste oil tank. The sample was taken from a backhoe bucket by driving a 2-inch by 4-inch brass tube into the soil using a wooden mallet. The sample was removed from the soil, capped with Teflon tape and plastic end caps and placed on ice for delivery to the laboratory. The sample depth was approximately 11 feet below ground surface; groundwater was not encountered. The sample was analyzed for TPH-Heavy (EPA 3550/8015), Total Oil and Grease (EPA 9071), and volatile organics (EPA 8240 GC/MS). Detectable constituents only are shown in Table I; all other constituents were below the level of detection.

III. Plan for Determining Extent of Soil and Groundwater Contamination on Site.

A. Based on the results of the soil sample taken from the former waste oil tank, we intent to further evaluate the impact of the release of contaminants from the waste oil tank on soil and groundwater in the vicinity of the site. ASE intends to complete the work in three tasks.

Task 1 Re-excavate soil from the waste oil tank and stockpile the soil on visqueen. We intend to excavate as much of the contaminated soil as possible. Soil samples will be taken from the excavated pit to confirm if the contaminated soil was removed. Soil samples will be collected from the stockpiled soil and the results will determine the suitability of disposal at a Class I or Class II site. No on site treatment is proposed.

Task 2 In accordance with agency guidelines, we intent to install and sample one groundwater monitoring well within 10 feet of the waste oil tank. According to the Alameda County Water District - Zone 7, the seasonal high for groundwater in the vicinity is 40 to 45 feet. Should groundwater not be encountered, the well will be completed into a clay aquitard 5-feet in thickness. Based on the results of the samples taken from the well, additional wells may be proposed.

Task 3 ASE will prepare a written report summarizing the work performed

after completion of all field work and once analytical results are known. The report will include recommendations for further work and well sampling.

Task 1 - Re-excavate Tank Pit.

The excavation will take place in the area of the former waste oil tank. We proposed to excavate the pit and stockpile the removed soil on-site. Soil samples will be taken from areas from within the pit and from the stockpiled soil. At this time it is not known the quantity of soil to be removed, however every attempt will be made to remove all contaminated soil. Once the excavation is complete and soil sample results are known, the pit will be backfilled with imported backfill to ground surface. hand?

We do not propose on-site treatment due to the limited size area available for current soil remediation techniques. The contaminated soil will be hauled to either a Class I or Class II disposal site within California, pending sample results.

Task 2 - Install a Groundwater Monitoring Well.

The hydrogeologic information in the site area is limited, however, groundwater is expected to be found at 40 to 45 feet.

The well will be installed within 10 feet of the waste oil tank and will be constructed of 4-inch diameter PVC casing with a locking christy box street cover. The proposed well will be installed to 15 feet into groundwater or terminated in an aquitard of at least 5 feet in thickness.

In the event that groundwater is not encountered either before a 5-foot clay aquitard is encountered or a depth of 45 feet is reached, the well will be completed to that depth. If groundwater is found, than two subsequent 2-inch diameter perimeter wells will be installed (proposed location, Figure 1).

Groundwater well MW-1 will be used to monitor groundwater on a monthly basis for the first quarter than quarterly for three quarters (per requirements of Alameda County Water District). Groundwater wells MW-2 and MW-3 will provide depth to groundwater measurements and direction of groundwater flow will be determined from the three wells.

The actual well construction of all wells will follow Alameda County Water District requirements. A typical well installation diagram is shown in Figure 2. In addition to following the requirements of Alameda County Water District we intent to design a gravel pack and well casing slot size based on the formation material encountered. Soil samples will be collected beginning at the maximum depth of the excavation and then at 5-foot intervals to groundwater.

Following installation each well will be developed, sampled and analyzed for the waste oil protocol (LUFT). Drill cuttings will either be stockpiled with the excavated soil material or placed into hazardous waste drums (17-H). The extracted groundwater from well development will be placed in separate 17-H drums. All drums will be manifested as necessary. The completed wells will be measured from top of casing to a bench mark with elevation above mean sea level (MSL) to the nearest 0.01 feet.

Task 3 - Provide a Written Report.

The report will describe the excavation activities, sample results, and will provide recommendations for further actions. Prior to installing the well(s) the report will be submitted for agency review.

We expect to begin the excavation upon approval from the Alameda County Health Department and complete the work contained above by September 25, 1989.


We look forward to your comments at your earliest convenience.

Respectfully submitted,


Terrance E. Carter
AQUA SCIENCE ENGINEERS, INC.


FIGURE 1 - Site Plan - 3496 Castro Valley Boulevard, Castro Valley, California.

FIGURE 2 - Typical Well Construction Diagram



SITE LOCATION

PROP. LINE 135.11



SITE: 3495 CASTRO VALLEY BLVD.
CASTRO VALLEY, CA

CASTRO VALLEY BLVD.

FIGURE 1.




FIGURE 2.

AQUA SCIENCE ENGINEERS
TYPICAL MONITORING FACILITY

**APPENDIX A:
HAZARDOUS WASTE MANIFEST DOCUMENTS**

IN CASE OF AN EMERGENCY OR SPILL, CALL THE NATIONAL RESPONSE CENTER 1-800-424-8802; WITHIN CALIFORNIA CALL 1-800-852-7550

UNIFORM HAZARDOUS WASTE MANIFEST

1. Generator's US EPA ID No.

Manifest Document No.

2. Page 1 of

information in the shaded areas is not required by Federal law.

C11C10010112719099118215

A. State Manifest Document Number
87891825

3. Generator's Name and Mailing Address
XTRA OIL CO. DURANT AVE. DENVER CO 80202

B. State Generator's ID

4. Generator's Phone (415) 544-0330

C. State Transporter's ID
902465

5. Transporter 1 Company Name
HEH SMP SERVICE CO. INC. CAD 004771168

D. Transporter's Phone
(415) 543-0906

7. Transporter 2 Company Name

F. Transporter's Phone

9. Designated Facility Name and Site Address
HEH SMP SERVICE CO. INC. 220 CHINA BASIN STREET SAN FRANCISCO CA 94107

10. US EPA ID Number
CAD004771168

G. State Facility's ID
381-001-78

H. Facility's Phone
(415) 543-0906

11. US DOT Description (including Proper Shipping Name, Hazard Class, and ID Number)

a. **ASH WASTE, METAL, WASTE OIL NOS. CALIFORNIA REGULATED WASTE 0101 TIP 1101010**

12. Containers No. Type

13. Total Quantity

14. Unit Wt/Vol

15. Waste No.

State **512**

EPA/Other **NA**

State **512**

EPA/Other

J. Additional Descriptions for Materials Listed Above

K. Handling Codes for Wastes Listed Above

1,000 gallon underground waste oil tank w/ approx 50 gallons sludge remaining.

a. **01**

16. Special Handling Instructions and Additional Information:
Wear protective gear as required.

16. GENERATOR'S CERTIFICATION: I hereby declare that the contents of this consignment are fully and accurately described above by proper shipping name and are classified, packed, marked, and labeled, and are in all respects in proper condition for transport by highway according to applicable international and national government regulations.

If I am a large quantity generator, I certify that I have a program in place to reduce the volume and toxicity of waste generated to the degree I have determined to be economically practicable and that I have selected the practicable method of treatment, storage, or disposal currently available to me which minimizes the present and future threat to human health and the environment; OR, if I am a small quantity generator, I have made a good faith effort to minimize my waste generation and select the best waste management method that is available to me and that I can afford.

Printed/Typed Name: **CAROL SIMAS** Signature: *Carol Simas* Month Day Year: **11/10/78**

17. Transporter 1 Acknowledgement of Receipt of Materials
 Printed/Typed Name: **SIDNEY W FOSTER** Signature: *Sidney W Foster* Month Day Year: **11/10/78**

18. Transporter 2 Acknowledgement of Receipt of Materials
 Printed/Typed Name: Signature: Month Day Year:

19. Discrepancy Indication Space

20. Facility Owner or Operator Certification of receipt of hazardous materials covered by this manifest except as noted in item 19
 Printed/Typed Name: **Clelland Valley** Signature: *Clelland Valley* Month Day Year: **11/10/78**

**APPENDIX B:
UNAUTHORIZED RELEASE FORM**

UNDERGROUND STORAGE TANK UNAUTHORIZED RELEASE (LEAK)/CONTAMINATION SITE REPORT

EMERGENCY <input type="checkbox"/> YES <input checked="" type="checkbox"/> NO		HAS STATE OFFICE OF EMERGENCY SERVICES REPORT BEEN FILED? <input type="checkbox"/> YES <input type="checkbox"/> NO		STATE TANK ID #	
REPORT DATE 0m 7m 2d 4d 8y 9y		LOCAL CASE #		REGIONAL BOARD CASE #	
NAME OF INDIVIDUAL FILING REPORT TERRANCE CARTER		PHONE (415) 820-9391		SIGNATURE	
REPRESENTING <input type="checkbox"/> LOCAL AGENCY <input type="checkbox"/> OTHER <input checked="" type="checkbox"/> OWNER/OPERATOR <input type="checkbox"/> REGIONAL BOARD		COMPANY OR AGENCY NAME AQUA SCIENCE ENGINEERS, INC.			
ADDRESS 2500 Old Crow Canyon Rd., #121, San Ramon, CA 94583					
NAME Xtra Oil		<input type="checkbox"/> UNKNOWN		CONTACT PERSON Ted Simas	
ADDRESS 2200 Durant Street, Berkeley, CA 94704		CITY		STATE ZIP	
FACILITY NAME (IF APPLICABLE) Xtra Oil Shell Oil		OPERATOR Ted Simas		PHONE (415) 548-0330	
ADDRESS 3496 Castro Valley Blvd., Castro Valley, CA					
CROSS STREET Redwood		TYPE OF AREA <input checked="" type="checkbox"/> COMMERCIAL <input type="checkbox"/> INDUSTRIAL <input checked="" type="checkbox"/> RESIDENTIAL <input type="checkbox"/> RURAL <input type="checkbox"/> OTHER		TYPE OF BUSINESS <input type="checkbox"/> RETAIL FUEL STATION <input type="checkbox"/> UNKNOWN <input type="checkbox"/> OTHER	
LOCAL AGENCY Alameda County Health		AGENCY NAME		CONTACT PERSON Scott Seery	
REGIONAL BOARD SFRWQCB				PHONE (415) 271-4320	
TSCD Underground tank program				()	
SUBSTANCES INVOLVED					
(1)		CAS # (ATTACH EXTRA SHEET IF NEEDED)		NAME	
(2)				QUANTITY LOST (GALLONS) <input type="checkbox"/> UNKNOWN	
DATE DISCOVERED 1m 1m 0d 7d 8y 8y		HOW DISCOVERED <input type="checkbox"/> INVENTORY CONTROL <input type="checkbox"/> SUBSURFACE MONITORING <input type="checkbox"/> ROUTINE MONITORING <input checked="" type="checkbox"/> TANK REMOVAL <input type="checkbox"/> NUISANCE CONDITIONS <input type="checkbox"/> OTHER:			
DATE DISCHARGE BEGAN M M D D Y Y <input type="checkbox"/> UNKNOWN		METHOD USED TO STOP DISCHARGE (CHECK ALL THAT APPLY) <input type="checkbox"/> REMOVE CONTENTS <input type="checkbox"/> REPLACE TANK <input checked="" type="checkbox"/> CLOSE TANK <input type="checkbox"/> REPAIR TANK <input type="checkbox"/> REPAIR PIPING <input type="checkbox"/> CHANGE PROCEDURES <input type="checkbox"/> OTHER			
HAS DISCHARGE BEEN STOPPED? <input checked="" type="checkbox"/> YES <input type="checkbox"/> NO IF YES, DATE M M D D Y Y		SOURCE(S) OF DISCHARGE <input checked="" type="checkbox"/> TANK LEAK <input type="checkbox"/> UNKNOWN <input type="checkbox"/> PIPING LEAK <input type="checkbox"/> OTHER (SPECIFY)		TANKS ONLY/CAPACITY GAL AGE <input type="checkbox"/> YRS. <input checked="" type="checkbox"/> UNKNOWN MATERIAL <input type="checkbox"/> STEEL <input type="checkbox"/> FIBERGLASS <input type="checkbox"/> OTHER	
RESOURCES AFFECTED		WATER SUPPLIES AFFECTED		THREATENED UN- KNOWN	
AIR (VAPOR) <input type="checkbox"/> YES <input checked="" type="checkbox"/> NO		PUBLIC DRINKING WATER <input type="checkbox"/> YES <input type="checkbox"/> NO		<input type="checkbox"/> YES <input type="checkbox"/> NO	
SOIL (VAPOSE ZONE) <input type="checkbox"/> YES <input type="checkbox"/> NO		PRIVATE DRINKING WATER <input type="checkbox"/> YES <input type="checkbox"/> NO		<input type="checkbox"/> YES <input type="checkbox"/> NO	
GROUNDWATER <input type="checkbox"/> YES <input type="checkbox"/> NO		INDUSTRIAL <input type="checkbox"/> YES <input type="checkbox"/> NO		<input type="checkbox"/> YES <input type="checkbox"/> NO	
SURFACE WATER OR STORM DRAIN <input type="checkbox"/> YES <input type="checkbox"/> NO		AGRICULTURAL <input type="checkbox"/> YES <input type="checkbox"/> NO		<input type="checkbox"/> YES <input type="checkbox"/> NO	
BUILDING OR UTILITY VAULT <input type="checkbox"/> YES <input type="checkbox"/> NO		OTHER (SPECIFY) <input type="checkbox"/> YES <input type="checkbox"/> NO		<input type="checkbox"/> YES <input type="checkbox"/> NO	
OTHER (SPECIFY)		GROUNDWATER BASIN NAME SF Bay		<input type="checkbox"/> UNKNOWN	
COMMENTS:					

**APPENDIX C:
LABORATORY DATA AND CHAIN-OF-CUSTODY**

11/008 502
(170810)

P.O. Box 535, San Ramon, CA 94583-0535



(415) 820-9391

Project Name: Simon Hill Site: Hanford Date: 5/1/89 Laboratory: LA 11

Sample ID	Sample/Container Type	Analyze/ Hold	Analyze For:	Method - Detection Limit	Notes/Remarks
<u>11</u>	<u>BT</u>	<u>A</u>	<u>Water Pce</u> <u>Potential PCBs</u>		<u>TR 72341</u> <u>10/2</u>

S = Soil M = Water O = Other
G = Glass BT = Brass Tube P = Plastic Y = Vial D = Other

Chain of Custody

- = Collate all samples for single analysis.
- = Collate and analyze two top samples and if clean, do not analyze other sample.
- = Call ASE for instructions.
- = See attached protocol.

1. Sampled by: James Cook
 2. Courier: Donald Tokaraki
Pace 1230 AM
5/1/89

3. Received by Lab: LA 11
 Date: 5/1/89 Time: 3:45 PM

4. Received in Office: Date: _____

APPENDIX D
TANK TESTING RESULTS

HUNTER ENVIRONMENTAL SERVICES, INC.
 18350 MT. LANGLEY STREET, SUITE 101
 FOUNTAIN VALLEY, CA 92708
 800-247-9014 800 247-2186

FINAL TEST RESULTS
 TEST DATE: 8/12/88

CUSTOMER: SHELL
 ADDRESS: 3495 CASTRO VALLEY BLVD.
 CASTRO VALLEY, CA

LOCATION/IDENTIFICATION NO.:

TEST RESULTS SUMMARY

NO.	SYSTEM PRODUCT	TANK SIZE		WATER INCHES	LEVEL INCHES	LEAK LOKATOR RESULTS		RECOMMENDATIONS
		GALLONS	DIA/MATL			AIR GH	CONCLUSION	
1	DIESEL	10000	95/ST	0	169	-.037	TIGHT	

PRODUCT LINES - HYDROSTATIC PRESSURE TEST RESULTS

NO.	PRODUCT	TYPE OF PUMP		POUNDS APPLIED	POUNDS HELD	MINUTES HELD	PRODUCT LOSS CC's	PRODUCT LOSS GH	CONCLUSION /RESULT
		REMOTE	SUCTION						
1	DIESEL	WAYNE		50		10			PASS

NOTE: On suction systems, NEVER put more than 15 psi on any pump system.

DETAIL OF TEST RESULTS

NO.	SYSTEM PRODUCT	TEST NO.	TEST LEVEL (IN.)	TIME		LEAK RATE		TEMPERATURE COMPENSATION		ABSOLUTE LEAK RATE		CHECK TEST Y/N
				CLOCK STATE	DURATION (HR-MIN)	CC/DIV	CC/MIN	DELTA °F	CC/MIN	CC/MIN GH		
1	DIESEL	1	169	11:30	:30	4.562	+7.557	+0.035	+9.935	-2.378	-.037	N

*LEVEL - Inches from Tank Bottom to Test Level
 ALR - Absolute Leak Rate (Measured Leak Rate - Temperature Compensation) in Gallons Per Hour
 CONCLUSION - NFPA 329 criterion of +/- 0.05 GPA is used to certify tightness

CERTIFICATION

CERTIFIED

This is to certify that the above tank systems were tested, using the HUNTER ENVIRONMENTAL SERVICES, INC. LEAK LOKATOR according to all standard operating procedures. Those indicated as tight at full system meet the criterion established by the National Fire Protection Association Pamphlet 329 for Precision Testing.

Tests Conducted and Certified By: Test Van No. 4
 Team Manager: A. CHAND

HUNTER ENVIRONMENTAL SERVICES, INC.
 18350 MT. LANGLEY STREET, SUITE 101
 FOUNTAIN VALLEY, CA 92708
 800-247-9014 800-247-2186

FINAL TEST RESULTS
 TEST DATE: 8/10/88

CUSTOMER: XIRA OIL
 ADDRESS: 3495 CASTRO VALLEY BLVD.
 CASTRO VALLEY, CA

LOCATION/IDENTIFICATION NO.:

TEST RESULTS SUMMARY

NO.	SYSTEM PRODUCT	TANK SIZE		WATER INCHES	LEVEL INCHES	LEAK LOKATOR RESULTS		
		GALLONS	DIA/MATL			AIR GPH	CONCLUSION	RECOMMENDATIONS
1	S/U	10000	95/ST	0	150	-.010	TIGHT	
2	U/L	10000	95/ST	0	159	+.011	TIGHT	
3	REG	10000	95/ST	0	154	+.041	TIGHT	
4	DIESEL	10000	95/ST	0	NO TEST			

OTHER INFORMATION: NO TEST ON DIESEL DUE TO LACK OF PRODUCT. RUNNING PRESSURE TESTS DUE TO INTERNAL CHECK VALVE.

PRODUCT LINES - HYDROSTATIC PRESSURE TEST RESULTS

NO.	SYSTEM PRODUCT	TYPE OF PUMP		POUNDS APPLIED	POUNDS HELD	MINUTES HELD	PRODUCT LOSS CC's	PRODUCT LOSS GPH	CONCLUSION /RESULT
		REMOTE	SUCTION						
1	S/U	TORHEIM		29		15			PASS
2	U/L	TORHEIM		27		15			PASS
3	REG	RED JACKET		50		15			PASS
4	DIESEL	TORHEIM		28		15			PASS

NOTE: On suction systems, NEVER put more than 15 psi on any pump system.

DETAIL OF TEST RESULTS

NO.	SYSTEM PRODUCT	TEST NO.	TEST LEVEL (IN.)	TIME		LEAK RATE		TEMPERATURE COMPENSATION		ABSOLUTE LEAK RATE		CHECK TEST Y/N
				CLOCK STATE	DURATION (HR-MIN)	CC/DIV	CC/MIN	DELTA °F	CC/MIN	CC/MIN	GPH	
1	S/U	1	150	10:40	:35	1.522	+21.827	+0.054	+22.482	-.655	-.010	N
2	U/L	1	159	11:20	:30	1.195	+7.410	+0.016	+6.661	+0.749	+0.011	N
3	REG	1	154	9:50	:45	1.360	+7.603	+0.012	+4.996	+2.607	+0.041	N

*LEVEL - Inches from Tank Bottom to Test Level
 ALR - Absolute Leak Rate (Measured Leak Rate - Temperature Compensation) in Gallons Per Hour
 CONCLUSION - NFPA 329 criterion of +/- 0.05 GPA is used to certify tightness

CERTIFICATION

CERTIFIED

This is to certify that the above tank systems were tested, using the HUNTER ENVIRONMENTAL SERVICES, INC. LEAK LOKATOR according to all standard operating procedures. Those indicated as tight at full system meet the criterion established by the National Fire Protection Association Pamphlet 329 for Precision Testing.

Tests Conducted and Certified By: Test Van No. 32
 Team Manager: E. PRICE
 Tank Testing Specialist: S. PARRAS

TANK AND LOCATION DATA

DATE: 1-31-86

CUSTOMER: SHELL


CITY: Castro Valley

D. # 810910

STATE: CA

WEATHER	TIME	TEMPERATURE	COMMENTS
BEFORE TEST - Rain	10:00	450	
AFTER TEST -	5:00		

SCHEMATIC:



BEFORE DELIVERY	PRODUCT/TANK NO.	T1 SUP		T2 unL		T3 Reg		T4 Diesel		FILL	
		FILL	Gauge	FILL	Gauge	FILL	Gauge	FILL	Gauge	FILL	C
	LEVEL										
	GALLONS										
	WATER	0		0		0		0			
	TOP OF RISER	135		134		135		135			
	GRADE	141		141		142		141			
	DROP TUBE	ALUM		ALUM		ALUM		ALUM			
	CAPACITY, GALLONS	10000		10000		10000		10000			
	DIAMETER, INCHES	9.5		9.5		9.5		9.5			
	MATERIAL	ST		ST		ST		ST			
	PUMP TYPE	Weyne		Weyne		RT		Weyne			
	TYPE OF COVER	Conc		Conc		Conc		Conc			
	AGE OF TANK	N/A		N/A		N/A		N/A			
	SIPHON	no		no		no		no			
	TANK OPENINGS	1-4		1-4		1-4		1-4			
	EXTRACTORS	none		none		none		none			
	TYPE	Stage II		Stage II		Stage II		Stage I			

PRODUCT	GALLONS	DIAMETER	INCHES	TEST LEVEL	RECOMMENDATIONS	TEST TANK NO.
Sup	10000	95/ST	0	148	-004	T
unl	10000	95/ST	0	147	+000	T
Reg	10000	95/ST	0	146	-002	T
Diesel	10000	95/ST	0	147	+002	T

OTHER INFORMATION

PRODUCT LINES - HYDROSTATIC PRESSURE TEST RESULTS

SYSTEM	TYPE OF PUMP		# APPLIED	MINUTES APPLIED	PRODUCT LOSS CC'S	PRODUCT LOSS GPH	CONCLUSION RESULT
PRODUCT	REMOTE	SUCTION					
Sup	Wayne		50 PSI	10			T
unl	Wayne		50 PSI	10			T
Reg	RJ		50 PSI	10			T
Diesel	Wayne		50 PSI	10			T

NOTE: On suction systems, NEVER put more than 15 psi on any pump system.

OTHER CONTRACTORS, OFFICIALS, CUSTOMER REPRESENTATIVES PRESENT

DETAIL OF TEST RESULTS

SYSTEM PRODUCT	TEST NO.	TEST (INCHES)	TIME		LEAK RATE		TEMPERATURE COMPENSATION		ABSOLUTE LEAK RATE		CONCLUSION
			START	END	CC/MIN	CC/MIN	TEMP	CC/MIN	CC/MIN	GPH	
Sup	148	186	15 min		3.7	-2.037	-0.016	-2.727	-1.3	-0.004	T
unl	147	2:30	27 min		4.22	-3.922	-0.010	-4.829	-1.682	-0.010	T
Reg	146	2:00	17 min		3.79	+3.609	+0.008	+3.284	-0.75	-0.002	T
Diesel	147	3:33	16 min		3.77	+2.754	+0.002	+3.67	+1.187	+0.002	T

VEL - INCHES FROM TANK BOTTOM TO TEST LEVEL

TEMP - ABSOLUTE LEAK RATE (MEASURED LEAK RATE - TEMPERATURE COMPENSATION) IN GALLONS PER HOUR

CONCLUSION - NFPA 328 CRITERION OF ±0.05 GPH IS USED TO CERTIFY TIGHTNESS

CERTIFICATION This is to certify that the above described tank systems were tested, using the HUNTER ENVIRONMENTAL SERVICES, INC. LEAK LOCATOR according to all standard operating procedures. Those indicated as tight at full system meet the criterion established by the National Fire Protection Association Pamphlet 329 for Precision Testing.

TESTS CONDUCTED BY		CERTIFIED BY	
TANK NO.	TANK TESTING SPECIALIST	SIGNATURE	DATE
L-17	Nick Havnrik Eric Price	Nick Havnrik Team Mgr	9-31-86