

# UNDERGROUND STORAGE TANK UNAUTHORIZED RELEASE (LEAK) / CONTAMINATION SITE REPORT

EMERGENCY <input type="checkbox"/> YES <input checked="" type="checkbox"/> NO		HAS STATE OFFICE OF EMERGENCY SERVICES REPORT BEEN FILED? <input type="checkbox"/> YES <input checked="" type="checkbox"/> NO		FOR LOCAL AGENCY USE ONLY I HEREBY CERTIFY THAT I AM A DESIGNATED GOVERNMENT EMPLOYEE AND THAT I HAVE REPORTED THIS INFORMATION TO LOCAL OFFICIALS PURSUANT TO SECTION 25100.7 OF THE HEALTH AND SAFETY CODE.		
REPORT DATE 1/21/04 9:2		CASE #		SIGNED: [Signature] DATE: 7-15-93		
REPORTED BY	NAME OF INDIVIDUAL FILING REPORT <del>Scott Hooton</del> <b>FREITH</b>		PHONE (206) 394-5239		SIGNATURE [Signature]	
	REPRESENTING <input type="checkbox"/> LOCAL AGENCY <input checked="" type="checkbox"/> OWNER/OPERATOR <input type="checkbox"/> REGIONAL BOARD <input type="checkbox"/> OTHER		COMPANY OR AGENCY NAME BP OIL COMPANY - NORTHWEST DIVISION			
	ADDRESS SOUTHCENTER PLACE BLDG. 16400 SOUTHCENTER PARKWAY ; SUITE 301 TUKWILA WA 98188					
RESPONSIBLE PARTY	NAME BP OIL COMPANY		CONTACT PERSON SCOTT HOOTON		PHONE (206) 394-5239	
	ADDRESS SAME AS ABOVE					
SITE LOCATION	FACILITY NAME (IF APPLICABLE) #11105		OPERATOR BP OIL COMPANY		PHONE (510) 889-0579	
	ADDRESS 3519 CASTRO VALLEY BOULEVARD		CASTRO VALLEY, CA		ALAMEDA	
	CROSS STREET REDWOOD ROAD					
IMPLEMENTING AGENCIES	LOCAL AGENCY ALAMEDA County Health Dept		AGENCY NAME Food Control Water Cont. District, Dist. 7		CONTACT PERSON Scott SEERY	
	REGIONAL BOARD SAN FRANCISCO BAY REGION RWQCB		CONTACT PERSON Rich Hiatt		PHONE (510) 464-2600	
SUBSTANCES INVOLVED	(1) NAME GASOLINE				QUANTITY LOST (GALLONS) <input checked="" type="checkbox"/> UNKNOWN	
	(2) <input type="checkbox"/> UNKNOWN					
DISCOVERY/ABATEMENT	DATE DISCOVERED 01/21/04 9:2		HOW DISCOVERED <input type="checkbox"/> INVENTORY CONTROL <input type="checkbox"/> TANK TEST <input type="checkbox"/> TANK REMOVAL <input type="checkbox"/> SUBSURFACE MONITORING <input type="checkbox"/> MISUSE CONDITIONS <input checked="" type="checkbox"/> OTHER ASSESSMENT			
	DATE DISCHARGE BEGAN <input checked="" type="checkbox"/> UNKNOWN		METHOD USED TO STOP DISCHARGE (CHECK ALL THAT APPLY) <input type="checkbox"/> REMOVE CONTENTS <input type="checkbox"/> REPLACE TANK <input type="checkbox"/> GLOSE TANK <input type="checkbox"/> REPAIR TANK <input type="checkbox"/> REPAIR PIPING <input type="checkbox"/> CHANGE PROCEDURE <input type="checkbox"/> OTHER			
	HAS DISCHARGE BEEN STOPPED? <input type="checkbox"/> YES <input type="checkbox"/> NO IF YES, DATE					
SOURCE/ CAUSE	SOURCE OF DISCHARGE <input type="checkbox"/> TANK LEAK <input checked="" type="checkbox"/> UNKNOWN <input type="checkbox"/> PIPING LEAK <input type="checkbox"/> OTHER		CAUSE(S) <input type="checkbox"/> OVERFILL <input type="checkbox"/> RUPTURE/FAILURE <input type="checkbox"/> SPILL <input type="checkbox"/> CORROSION <input checked="" type="checkbox"/> UNKNOWN <input type="checkbox"/> OTHER			
	CHECK ONE ONLY <input type="checkbox"/> UNDETERMINED <input type="checkbox"/> SOIL ONLY <input checked="" type="checkbox"/> GROUNDWATER <input type="checkbox"/> DRINKING WATER - (CHECK ONLY IF WATER WELLS HAVE ACTUALLY BEEN AFFECTED)					
CURRENT STATUS	CHECK ONE ONLY <input type="checkbox"/> NO ACTION TAKEN <input type="checkbox"/> PRELIMINARY SITE ASSESSMENT WORKPLAN SUBMITTED <input type="checkbox"/> POLLUTION CHARACTERIZATION					
	<input type="checkbox"/> LEAK BEING CONFIRMED <input checked="" type="checkbox"/> PRELIMINARY SITE ASSESSMENT UNDERWAY <input type="checkbox"/> POST CLEANUP MONITORING IN PROGRESS					
	<input type="checkbox"/> REMEDIATION PLAN <input type="checkbox"/> CASE CLOSED (CLEANUP COMPLETED OR UNNECESSARY) <input type="checkbox"/> CLEANUP UNDERWAY					
REMEDIAL ACTION	CHECK APPROPRIATE ACTION(S) (SEE BACK FOR DETAILS) <input type="checkbox"/> CAP SITE (CD) <input type="checkbox"/> EXCAVATE & DISPOSE (ED) <input type="checkbox"/> REMOVE FREE PRODUCT (FP) <input type="checkbox"/> ENHANCED BIO DEGRADATION (IT)					
	<input type="checkbox"/> CONTAINMENT BARRIER (CB) <input type="checkbox"/> EXCAVATE & TREAT (ET) <input type="checkbox"/> PUMP & TREAT GROUNDWATER (GT) <input type="checkbox"/> REPLACE SUPPLY (RS) <input type="checkbox"/> VACUUM EXTRACT (VE) <input type="checkbox"/> NO ACTION REQUIRED (NA) <input type="checkbox"/> TREATMENT AT HOOKUP (HU) <input type="checkbox"/> VENT SOIL (VS) <input type="checkbox"/> OTHER (OT)					
COMMENTS	MAXIMUM CONCENTRATION IN GROUND WATER = 2300 ppb TPH-G - 370 ppb BENZENE MAXIMUM CONCENTRATION IN SOIL = 220,000 ppb TPH-G AND 1400 ppb BENZENE					
	EXTENT IN SOIL AND GROUND WATER UNDEFINED - ASSESSMENT UNDERWAY					

\* Note: This report not received by ADESH until 7-14-93.