

PLEASANTON FIRE DEPARTMENT

Company Inspection Record

RECEIVED
 2:29 pm, Apr 16, 2009
 Alameda County
 Environmental Health

Agency Address 4191 FIRST ST. Suite

Month Day Year
11 10 08

BUILDING DETAILS

Building Owners Name ARMOUR OIL CO.	Owners Business Address Same <input type="checkbox"/> P.O. 81002 SAN DIEGO 92138	Telephone Number 619 129 1100
Responsible Name LAVIE CARDOZA	Responsible Address 2117 135th S.L. 94577	Telephone Number 135 118 5300
Doing Business As GAS N SAVE	Telephone Number 462 1365	Class B.1 Inspection Number <input checked="" type="checkbox"/> 3 <input type="checkbox"/> 3 <input type="checkbox"/> 4

DEPARTMENT

Inspectors Name HALVORSEN/HAENDEL	Time 11 00	Responsible Signature <i>Lavie Cardoza</i>
---	----------------------	---

A LIFE HAZARDS

Exit and Aisles 1 <input type="checkbox"/>	Occupant Loads 2 <input type="checkbox"/>
Decorations 3 <input type="checkbox"/>	Emergency Lighting 4 <input type="checkbox"/>

C COMMON HAZARDS

Housekeeping 1 <input checked="" type="checkbox"/>	Heating - AC Equip. 2 <input checked="" type="checkbox"/>
Smoking 3 <input type="checkbox"/>	Motors 4 <input checked="" type="checkbox"/>
Electrical 5 <input type="checkbox"/>	

B FIRE PROTECTION

Automatic Sprinklers 1 <input type="checkbox"/>	Standpipes 2 <input type="checkbox"/>
Fire Assemblies 3 <input type="checkbox"/>	First Aid Appliances 4 <input type="checkbox"/>
Fire Alarms 5 <input type="checkbox"/>	Hydrants 6 <input type="checkbox"/>

D SPECIAL HAZARDS

Vertical Openings 1 <input type="checkbox"/>	Grease Ducts 2 <input type="checkbox"/>
Flammable Liquids 3 <input checked="" type="checkbox"/>	Other 4 <input type="checkbox"/>
Other 5 <input type="checkbox"/>	

CORRECTION DETAILS

Item	Remarks	Call Back Date	Completed
D.3	PUMP HOLD OPEN AT NOZZLES MUST BE REMOVED AT PUMPS B-1, B-4, B-6, B-7, B-5, B-9, B-11, A-2, A-5, A-11, A-12.	11/11/9	WORK
D.3	IMPACT VALVE AT B-6 WIRED OPEN, REPLACE TRIP MECHANISM; ALSO A-9. DO NOT USE UNTIL REPAIRED.	11/11/9	WORK
D.3	PUMP #12 FUEL FILTER DAMAGED, REPLACE TODAY.	11/10/8	WORK
D.3	REMOVE GASOLINE ACCUMULATED UNDER PUMP ISLAND.	11/10/8	WORK
C.2	HEATING DEVICE IN CASHIER ROOM MUST BE INSTALLED NOT LESS THAN 2 FEET ABOVE FLOOR.	11/11/9	WORK
C.1	"NO SMOKING - STOP MOTOR" SIGNS NEED TO BE POSTED AND CLEARLY VISIBLE FROM DISPENSING AREA. (DONE AT ALL ^{ALL} FOUR ISLANDS)	11/11/9	WORK
	ATTACHED, HOWEVER, ON MASONRY - REQUIRE	11/2/6	

WILL NOT BE USED ON FLOOR LEVEL - 24 MIN

This report is for the sole use of the Fire Marshal. Estimations made herein represent "likely" and "most probable" cause and effect. Any question as to the validity of reported conditions should be referred to the State Fire Marshal's Office. This is neither intended nor

STATE OF CALIFORNIA
OFFICE OF THE STATE FIRE MARSHAL
FIRE INCIDENT REPORT

(916)372-6391

INCIDENT NO.
40195

Pleasanton F.D.

DEL CORR

OCCUPANT NAME ARCO		RELATIONSHIP	ALARM SOURCE	TEL. BOX <input checked="" type="checkbox"/>	PPAS <input type="checkbox"/>	RADIO <input type="checkbox"/>
ADDRESS 4191 FIRST ST		ROOM / APT. NO.	CITY PLEASANTON CA	ZIP 94566	TELEPHONE NO. (CALL BACK) 462-1365	
OWNER NAME ARMOR OIL	ADDRESS Box 81002 San Diego	CITY 92138	ZIP 92138	CENSUS/PARCEL NO. 4507		
MANAGER Miss Mrs. RICKENBACH	ADDRESS Box 26243 Sacramento	CITY 95824	ZIP 95824	TELEPHONE NO. 846-8275		

A. INFORMATION (PAGE 1)

FIRE DEPT. ID 01095	INCIDENT NO. 40195	EXPOSURE NO.	TIME 1.733	MONTH 02	DAY 20	YEAR 84	DAY CODE 2	COUNTY OF FIRE	DIST/CITY 01	OUT OF JURISDICTION CHECK IF YES <input type="checkbox"/>
-------------------------------	------------------------------	--------------	----------------------	--------------------	------------------	-------------------	----------------------	----------------	------------------------	--

B. PROPERTY CLASSIFICATION (PAGE 1)

CODE 5.1	TYPE OF INCIDENT GASOLINE LEAK	CONSTR. DATE PRE 72 <input type="checkbox"/> POST 72 <input type="checkbox"/>
CODE	PROPERTY CLASSIFICATION (COMPLEX)	
CODE	PROPERTY CLASSIFICATION (INDIVIDUAL)	

C. PROPERTY TYPE (PAGE 1)

PROPERTY MANAGEMENT								
1 <input checked="" type="checkbox"/>	2 <input type="checkbox"/>	3 <input type="checkbox"/>	4 <input type="checkbox"/>	5 <input type="checkbox"/>	6 <input type="checkbox"/>	7 <input type="checkbox"/>	8 <input type="checkbox"/>	9 <input type="checkbox"/>
CODE STRUCTURE, BUILDING OR VEHICLE - PROPERTY TYPE								
BUILDING NO. STORIES								
STRUCTURE, BUILDING - CONSTRUCTION TYPE								
1 <input type="checkbox"/>	2 <input type="checkbox"/>	3 <input type="checkbox"/>	4 <input type="checkbox"/>	5 <input type="checkbox"/>	6 <input type="checkbox"/>	7 <input type="checkbox"/>	8 <input type="checkbox"/>	9 <input type="checkbox"/>
FIRE RATED YES <input type="checkbox"/>								

D. EXTENT OF DAMAGE (PAGE 1)

CODE	EXTENT OF DAMAGE - FIRE
CODE	EXTENT OF DAMAGE - SMOKE
CODE	EXTENT OF DAMAGE - WATER
ESTIMATED LOSS - PROPERTY	
ESTIMATED LOSS - CONTENTS	

E. LOCATION & CAUSE (PAGE 1)

CODE	LEVEL OF ORIGIN
CODE	SOURCE OF HEAT CAUSING IGNITION
CODE	FORM OF HEAT CAUSING IGNITION
CODE	ACT OR OMISSION CAUSING IGNITION

F. AREA, MATERIALS & SMOKE SPREAD (PAGE 1)

CODE	AREA OF ORIGIN
CODE	TYPE OF MATERIAL FIRST IGNITED
CODE	FORM OF MATERIAL FIRST IGNITED
CODE	MAIN AVENUES SMOKE SPREAD

G. SPREAD OF FIRE (PAGE 1)

CODE	MAIN AVENUES FIRE SPREAD
CODE	TYPE MATERIAL CAUSING SPREAD
CODE	FORM MATERIAL CAUSING SPREAD
CODE	ACT OR OMISSION CAUSING SPREAD

H. PROTECTION FACILITIES (PAGE 1)

CODE	SPRINKLERS - TYPE
CODE	SPRINKLERS - EFFECTIVENESS
CODE	STANDPIPES - TYPE
CODE	STANDPIPES - EFFECTIVENESS
CODE	PORTABLE EXTINGUISHERS - TYPE
CODE	PORTABLE EXTINGUISHERS - EFFECTIVENESS

I. PROTECTION FACILITIES (PAGE 1)

CODE	PRIVATE BRIGADE - TYPE		
CODE	PRIVATE BRIGADE - EFFECTIVENESS		
CODE	SPECIAL HAZARD PROTECTION - TYPE		
CODE	SPECIAL HAZARD PROTECTION - EFFECTIVENESS		
CODE	SIGNAL OR WARNING SYSTEM TYPE	CODE	EFFECTIVENESS
CODE	SIGNAL WARNING SYSTEM - MEANS OF ACTIVATION		
CODE	SIGNAL WARNING SYSTEM - TYPE DETECTORS		
CODE	WATCHMAN EFFECTIVENESS	CODE	OTHER FACILITIES EFFECTIVENESS

J. MISCELLANEOUS (PAGE 1)

FIREFIGHTER NO. INJURED	NO. OF DEATHS	CIVILIANS NO. INJURED	NO. OF DEATHS
-------------------------	---------------	-----------------------	---------------

SEE PAGE 601 SUBMITTED FOR EACH DEATH

PLEASANTON FIRE DEPARTMENT
INTER-OFFICE MEMORANDUM

TO: CAPT. LAURENCE
FROM: LT. HAWORSEN
SUBJECT: GAS N' SAVE

DATE: 11/8/82

DURING AN INSPECTION ON THIS DATE, WE FOUND A DAMAGED FUEL FILTER LEADING FROM FUEL SUPPLY TO THE PUMP. THERE WAS APPROXIMATELY 9 GALLONS OF GASOLINE IN THE BASE SAND AREA DIRECTLY BELOW THE PUMP ISLAND. BOB BELL, SACRAMENTO REPRESENTATIVE FOR ARMOUR OIL CO. WAS NOTIFIED OF THIS HAZARDOUS CONDITION. HE AUTHORIZED CENTRAL PETROLEUM MAINTENANCE CO. TO REPAIR/REPLACE THE PART(S) REQUIRED FOR CORRECTION. AT THE SAME TIME WE FOUND WHAT APPEARED TO BE 030" STEEL WIRE USED IN TWO (2) PLACES WHERE THE FUSIBLE LINKS SHOULD HOLD THE IMPACT VALVE LEVERS OPEN. WE REMOVED THE WIRES AND PLACED THE TWO PUMPS OUT OF SERVICE UNTIL THE LINKS CAN BE REPLACED.

THERE WERE NO SIGNS REQUESTING MOTORS BE SHUTOFF AND SMOKING PROHIBITED. IT APPEARS THEIR MAINTENANCE PROGRAM IS RUN BY CRISIS. THE CPM CO. REP. ROY GIBSON SAID THE FILTER THAT FAILED APPEARED TO BE ORIGINAL EQUIPMENT. HE RECOMMENDED TO LAMIE CARDOZA, STATION MANAGER, ALL OF THE FILTERS THAT WERE AS OLD AS THE ONE THAT FAILED, BE REPLACED. CALLBACK INSPECTION FOR OTHER DISCREPANCIES WILL BE 11/19/82.

ALL OF THE IMMEDIATE HAZARDS WERE CORRECTED. TIME SPENT: 2.5H