

3/27/90

Met onsite w/ Paradise, Kaprelian, B.P. and Alton
GeoScience.

They have excavated the entire pit, and have cleaned
up most of the vertical contamination in the pit. There
are a couple of questionable sidewall samples that indicate
lateral ~~vertical~~ contamination.

B.P.'s consultant, Alton GeoScience, has installed
3 (~~2~~³) monitoring wells at the site. 2 other wells installed
by a previous consultant, and they have some data on those
wells.

One of the wells may end up being destroyed. Located
closest to the pit, the well cap sustained some damage
during the excavation process. This well is about 5-10' deeper
than base of excavation, and water in the well measured
at approx 16 feet. Both consultants concur that there
may be a clay layer over the aquifer which is preventing
water from filling the excavation, which is at 24 feet.
This visit showed no water in the pit.

I spoke to Peter DeSantis, B.P.'s rep and told
him that our office did not have a copy of any of
the reports the consultant had. If he wanted to set
the tanks, ~~we~~ our office needed to have copies of the
available reports, and a commitment that they
would address groundwater contamination. We sampled
the well, and I had approx 1/4 inch of "scum". Sampled

by trailer. I was told by Brady Nagle of Alton, Georgia
that I would receive reports and proposed work plan
to B.P.

10/10 Set tanks today. Unable to make appointment, but
~~will~~ let Gary Collins of OFD know



KAPREALIAN ENGINEERING, INC.
Consulting Engineers

HAGOP KEVORK
CIVIL ENGINEER
(707) 746-6915

P.O. BOX 996
BENICIA, CA 94510

Refer J. De Santos
BP oil
33305 First ways.
Bla B-16c

**HYDRO
ENVIRONMENTAL
TECHNOLOGIES, INC.**

Federal Way
Seattle WA 98003
206 874 7522
206 874 8261

Markus Niebanck
Regional Manager

2363 Mariner Square Drive
Suite 243
Alameda, CA 94501
Tel 510-521-2684
Fax 510-521-5078

1-800-347-HETI
Massachusetts
New York

CITY OF OAKLAND



John P. Roemer

Inspector
FIRE PREVENTION BUREAU

PHONE (415)
273-3853

1330 BROADWAY, OAKLAND, CA 94612