

RECEIVED MAR 23 1990

SCOTT CO.

MECHANICAL CONTRACTORS
 1919 Market Street
 P.O. Box 12954
 Oakland, California 94604
 (415) 834-2333

Contractors License No. 184480

March 21, 1990

Walton Engineering
 837 Riske Lane
 West Sacramento, California 95691

Attention: Mark

Reference: 3 tanks @ 4035 Park Boulevard, Oakland
 Line Test @ Exxon, 1040 El Camino, Prunedale

Gentlemen:

On March 1, 1990, we precision tested three (3) underground storage tanks using the "Petro-Tite" system.

The results for the tank tests were as follows:

<u>PRODUCT</u>	<u>CAPACITY</u>	<u>RESULTS</u>
Unleaded	10,000	-.003 gph
Regular	8,000	+.048 gph
Supreme	8,000	-.006 gph

All the above leak rates are within the NFPA criteria of ± 0.050 gallons per hour; therefore, these tanks and attached piping can be considered liquid tight at this time.

The test results are attached.

If you have any additional questions or if we can be of further assistance to you, please call us at (415) 834-2333, extension 3379.

Very truly yours,

SCOTT CO. OF CALIFORNIA

Jay Groh
 Environmental Estimator

JG:jj

Enclosures as stated

Data Chart for Tank System Tightness Test

DATE 2-28-90

PLEASE PRINT STATION # _____

1. OWNER Property Tank(s) _____
 Address: Beacon 4035 Park Blvd. Oakland Ca
 Name: _____ Telephone: _____

2. OPERATOR MaJtaba Karimabadi / Jason Golob
 Address: _____ Telephone: _____

3. REASON FOR TEST (Complete Fully)
Had full system test done @ station and failed. Tanks excavated to tank top & contamination found. Scott Co. is doing water test for Desert Industries. This test is being done for Regular tank only.

4. WHO REQUESTED TEST AND WHEN
 Name: _____ Title: _____ Company or Affiliation: _____ Date: _____
 Address: _____ Telephone: _____

5. TANK INVOLVED
 Identify by Number: #1 of 1 Capacity: 8,000 Brand/Supplier: Beacon Shell: Regular Approx. Age: _____
 Material/Type: Steel w/ Fiberglass liner

6. INSTALLATION DATA
 Location: Right side of station Cover: Asphalt Dia: 4" Walls: 1 1/2" Spacing: None Pumps: Remote Red-Jacks
 North/South/East/West: _____ Dimensions: _____
 Depth of station: _____ Cover: _____
 Size, Shell: _____ Drop: _____
 Size, Shell: _____ Pressure: _____
 Size, Shell: _____

7. UNDERGROUND WATER
 Depth to the water table: Below Tank Bottom No Yes

8. FILL-UP ARRANGEMENTS
 Tanks to be filled: 2nd on 2-28-90 Date Arranged by: Desert and or Walton
 Entry product to "top off" and how tank filled: four and site to product? Counter HD Lead
Tank fill w/ H₂O, provided on site
 Transport or other contact for water or supply: Scott Co. Jay Gray (415) 834-2353 ext. 3370

9. CONTRACTOR, MECHANICS, or other contractor involved
SCOTT-BROADWAY SERVICE

10. OTHER INFORMATION OR REMARKS
Desert industries, (doing tank excavation) removed vapor recovery and product line for test. Tank tested only with vent line intact. Pumped over at end of tank, product line, vapor recovery & fill.
 Additional information on any items shown. Attach or attach to be attached when testing is in progress or completed. Volume or quantity present during test, etc.

11. TEST RESULTS
 Tests were made on the above tank systems in accordance with test procedures prescribed for as detailed on attached test sheets with results as follows:

Tank Identification	Test	Leakage Indicated	Date Tested
<u>#1 of 1 Regular</u>	<u>Yes</u>	<u>+ .048 gph</u>	<u>2-28-90</u>

12. SENSOR CERTIFICATION
 12.1 This is to certify that these tank systems were tested on the date(s) above. Those indicated as "tight" meet the criteria established by the National Fire Protection Association Paragraph 222.
 Testimony: Paul Ferreira Date: 2/28/90
 Signature: Scott-Broadway Co Paul Ferreira
 Address: 1018 Markon St. Granddella

STATION # _____

14. Beacon 4035 Park Blvd. Oakland Ca
 Name of Shipper, Owner or Dealer: _____
 Address (to be printed): _____

15. TANK TO TEST # 1 of 1
 Name of product: Regular Tank (A.P.)
 Size of tank: _____
 Location: Front

15A. BRIEF DIAGRAM OF TANK FIELD

 TANK FIELD: 1 TANK
 NOT BEING TESTED TANK: 1

16. CAPACITY
 Working Capacity: 8,000
 Gross Capacity: 8,139

17. FILL-UP FOR TEST
 This tank(s) is/are: 95
 Total Capacity: 95

18. SPECIAL CONDITIONS AND PROCEDURES TO TEST THIS TANK
 Use standard test methods. Check below and record procedures in log 075.
 Use multiple pressure test procedure for all tanks. Your procedure does not apply to other tanks.
 Complete special notes: _____

19. TANK MEASUREMENTS FOR TEST ASSEMBLY
 System of tank to be tested: _____
 Add up for "T" probe only: _____
 Total height to determine - Appendix: _____

20. EXTENSION HOSE SETTING
 Total length in feet: _____
 Number hoses on extension tank or air source: _____
 Initial tank top: _____

21. VAPOR RECOVERY SYSTEM
 Type of product: TANK
 Temperature of sample: H₂O
 Difference (in): Top-Off
 Overhead A.P. density: Total
 Vapor recovery system: No Yes

22. Thermometer reading after circulation: 53.53
 Thermometer used: 307

23. Coefficient of expansion (Complete after circulation)
 Coefficient of expansion: 0.0005703
 Total quantity in tank: 307
 Volume change in tank: 0.01513

24. FOR TESTING WITH WATER
 Temperature after circulation: 53.0
 Total quantity in tank: _____
 Volume change in tank: _____

25. (a) 8,149 (b) 0.0005703 (c) 41,449
 Total quantity in tank: _____
 Volume change in tank: _____


26. (a) 4,449 (b) 0.01513
 Total quantity in tank: _____
 Volume change in tank: _____

27. (a) 4,449 (b) 0.01513
 Total quantity in tank: _____
 Volume change in tank: _____

28. (a) 4,449 (b) 0.01513
 Total quantity in tank: _____
 Volume change in tank: _____

29. (a) 4,449 (b) 0.01513
 Total quantity in tank: _____
 Volume change in tank: _____

30. (a) 4,449 (b) 0.01513
 Total quantity in tank: _____
 Volume change in tank: _____



Data Chart for Tank System Tightness Test

STATION # Beacon DATE 3-1-90

1. OWNER Property Beacon 4035 Park Blvd Oakland Ca 94602

2. OPERATOR Tanks failed initial tank tightness test. The tank and liner have been uncovered and are being re-tested

3. REASON FOR TEST (Specify Policy)

4. WHO REQUESTED TEST AND WHEN

5. TANK INVOLVED

6. INSTALLATION DATA

7. UNDERGROUND WATER

8. FILL-UP ARRANGEMENTS

9. CONTRACTOR, MECHANIC, OR OTHER PERSONNEL INVOLVED SCOTT-BROADWAY SERVICE

10. OTHER INFORMATION OR REMARKS

11. TEST RESULTS

Tank Identification	Type	Leakage Indicated	Date Tested
#1 of 1 Supreme Tank w/ H ₂ O	Yes	-.006 gph	3-1-90

12. SENSOR CERTIFICATION

13. This is to certify that these tank systems were tested on the date(s) above. Those indicated as "Tight" meet the criteria established by the National Fire Protection Association Paragraph 828.

Signature: SCOTT-BROADWAY Co.
 1115 MARKET ST. OAKLAND, CA

STATION # Beacon 4035 Park Blvd Oakland Ca 94602

15. TANK TO TEST #1 of 1 Supreme Tank w/ H₂O

16. CAPACITY 8,000 Gallons

17. FILL-UP FOR TEST 95 Test Duration

18. SPECIAL CONDITIONS AND PROCEDURES TO TEST THIS TANK Water to tank Special arrangements for test High water table in tank location

19. BRIEF DIAGRAM OF TANK FIELD

20. COEFFICIENT OF EXPANSION (Complete after circulation)

21. VAPOR RECOVERY SYSTEM NPT MODULATED

22. COEFFICIENT OF RECIPROCAL METHOD

23. FILL-UP ARRANGEMENTS

24. TEST RESULTS

Item	Value
Water Chart	8,134
Test Resulting Chart	10
Capacity Engineering Data	8,149
Chart Applied with	
Other	

18. SPECIAL CONDITIONS AND PROCEDURES TO TEST THIS TANK

19. BRIEF DIAGRAM OF TANK FIELD

20. TANK MEASUREMENTS FOR TEST ASSEMBLY

21. VAPOR RECOVERY SYSTEM

22. COEFFICIENT OF RECIPROCAL METHOD

23. FILL-UP ARRANGEMENTS

24. TEST RESULTS

25. COEFFICIENT OF EXPANSION (Complete after circulation)

26. FILL-UP ARRANGEMENTS

27. FILL-UP ARRANGEMENTS

28. FILL-UP ARRANGEMENTS

29. FILL-UP ARRANGEMENTS

30. FILL-UP ARRANGEMENTS

31. FILL-UP ARRANGEMENTS

32. FILL-UP ARRANGEMENTS

33. FILL-UP ARRANGEMENTS

34. FILL-UP ARRANGEMENTS

35. FILL-UP ARRANGEMENTS

36. FILL-UP ARRANGEMENTS

37. FILL-UP ARRANGEMENTS

38. FILL-UP ARRANGEMENTS

39. FILL-UP ARRANGEMENTS

40. FILL-UP ARRANGEMENTS

41. FILL-UP ARRANGEMENTS

42. FILL-UP ARRANGEMENTS

43. FILL-UP ARRANGEMENTS

44. FILL-UP ARRANGEMENTS

45. FILL-UP ARRANGEMENTS

46. FILL-UP ARRANGEMENTS

47. FILL-UP ARRANGEMENTS

48. FILL-UP ARRANGEMENTS

49. FILL-UP ARRANGEMENTS

50. FILL-UP ARRANGEMENTS

51. FILL-UP ARRANGEMENTS

52. FILL-UP ARRANGEMENTS

53. FILL-UP ARRANGEMENTS

54. FILL-UP ARRANGEMENTS

55. FILL-UP ARRANGEMENTS

56. FILL-UP ARRANGEMENTS

57. FILL-UP ARRANGEMENTS

58. FILL-UP ARRANGEMENTS

59. FILL-UP ARRANGEMENTS

60. FILL-UP ARRANGEMENTS

61. FILL-UP ARRANGEMENTS

62. FILL-UP ARRANGEMENTS

63. FILL-UP ARRANGEMENTS

64. FILL-UP ARRANGEMENTS

65. FILL-UP ARRANGEMENTS

66. FILL-UP ARRANGEMENTS

67. FILL-UP ARRANGEMENTS

68. FILL-UP ARRANGEMENTS

69. FILL-UP ARRANGEMENTS

70. FILL-UP ARRANGEMENTS

71. FILL-UP ARRANGEMENTS

72. FILL-UP ARRANGEMENTS

73. FILL-UP ARRANGEMENTS

74. FILL-UP ARRANGEMENTS

75. FILL-UP ARRANGEMENTS

76. FILL-UP ARRANGEMENTS

77. FILL-UP ARRANGEMENTS

78. FILL-UP ARRANGEMENTS

79. FILL-UP ARRANGEMENTS

80. FILL-UP ARRANGEMENTS

81. FILL-UP ARRANGEMENTS

82. FILL-UP ARRANGEMENTS

83. FILL-UP ARRANGEMENTS

84. FILL-UP ARRANGEMENTS

85. FILL-UP ARRANGEMENTS

86. FILL-UP ARRANGEMENTS

87. FILL-UP ARRANGEMENTS

88. FILL-UP ARRANGEMENTS

89. FILL-UP ARRANGEMENTS

90. FILL-UP ARRANGEMENTS

91. FILL-UP ARRANGEMENTS

92. FILL-UP ARRANGEMENTS

93. FILL-UP ARRANGEMENTS

94. FILL-UP ARRANGEMENTS

95. FILL-UP ARRANGEMENTS


96. FILL-UP ARRANGEMENTS

97. FILL-UP ARRANGEMENTS

98. FILL-UP ARRANGEMENTS

99. FILL-UP ARRANGEMENTS

100. FILL-UP ARRANGEMENTS



The above conditions are to be used for dry soil conditions to establish a positive pressure atmosphere, or when having the tank pressure rise to compensate for the presence of radioactive vapor in the tank area.

Refer to NFPA 30, Section 3.2.2.2 and 3.2.2.3 and the unit manufacturer regarding alternate system test procedures.

below tank top

* If fill pipe extends above tank top of tank

25.

Volume change per % (25)

Range (25)

VOLUME change per digit. Compute to 4 decimal places.

This is test factor (A)

LOG OF TEST PROCEDURE		HYDROSTATIC PRESSURE CONTROL		VOLUME MEASUREMENT (O) INCHES TO .001 IN.			TEMPERATURE COMPENSATION FACTOR (C)			NET VOLUME CHANGES EACH READING	ACCUMULATED GAINS	
27. TIME (H:M:S)	28. Record details of setting up and running test. (Use full length of line if needed.)	29. Reading No.	30. Standby Level in Inches		32. Product in Graduate		35. Thermal Error Reading	36. Change Higher & Lower - (C)	37. Correction (+) = (+) = Expansion - (-) = (-) = Contraction	38. Net Volume Change Expansion (+) or Contraction (-) = 22(V) - 23(T)	39. High Level Error Total End Subtotal	
			Beginning of Reading	Level to which Reduced	Before Reading	After Reading						Product Replaced (-)
8:14	Water test											
8:20	Arrived @ site. Tank scavenged, product line removed from submerged pump, removed drop tube. Only lines hooked up are the V.R. line and vent line.											
8:45	Set Up Equipment											
8:50	Start Circulation											
9:02	1st Thermo Reading											
9:05	Start 42" High level test		42			.950						
10:00		1	34.2			.950	.540	.410	441	+5	+1.009	-.401
10:10		2	34.0			.540	.140	.400	447	+6	+1.010	-.390
10:20	Filled Graduate	3	33.2			.810	.385	.425	452	+5	+1.009	-.416
10:40		4	33.4			.385			456	+4		
		5										
	At this point removed vapor recovery line since tank was losing a substantial amount. I bled V.R. line prior to this and could not remove an air pocket, visible thru fiberglass line. Left vent line hooked up @ this point because it was buried. Tank test only w/ vent line intact!											
10:55	Started Circulation											
11:00	1st Thermo Reading								10403			(.0017)
11:05	Start 42" High level test		42			1.000						
11:10	1st high level Reading	1	34.3			1.000	.580	.420	419	+9	+1.015	-.0435
11:15		2	33.7			.580	.115	.465	425	+6	+1.010	-.0475
12:00	Filled Graduate	3	32.4			.980	.445	.535	430	+5	+1.009	-.544
12:05	Filled Graduate	4	34.4			.445	.030	.415	436	+6	+1.010	-.415
12:10		5	35.4			.990	.645	.345	441	+5	+1.009	-.354
12:15		6	35.4			.645	.245	.350	443	+2	+1.003	-.353
12:20	Filled Graduate	7	35.7			1.000	.060	.240	451	+8	+1.014	-.359
12:25		8	35.8			.660	.525	.335	455	+4	+1.007	-.342
12:30		9	35.9			.925	.000	.325	464	+9	+1.015	-.340
12:35	Filled Graduate	10	36.0			.970	.645	.305	469	+5	+1.009	-.314
12:40		11	36.2			.665	.370	.295	476	+7	+1.012	-.307
12:45		12	36.4			.370	.080	.290	480	+4	+1.007	-.297
12:50	Drop to low level Wait 1/2 hour											
3:00	Start 12" low level test		12			.650			482			
3:05	1st low level Reading	1	11.5			.650	.625	.025	483	+1	+1.002	-.027
	During the 1/2 hr. wait the tank did not bank back. For the amount of water added and the extended high level readings, the tanks should have gained, and we observed nothing but losses. At this point we removed the vent line and plugged it. The test was restarted at high level where it held solid at 42" and eventually gained. Because the tank was well circulated and gained about 42", we started the test at low level w/ permission from Desert Industries.											
3:10	Drop to low level Wait 1/2 hour.											
3:15	Start 12" low level test		12			.300			455			
3:20	1st low level Reading	1	12.0			.300	.300	+1.000	56	+1	+1.002	-.002
3:25	Continued low level Readings	2	12.0			.300	.300	+1.000	56	+0	+1.000	-.000
3:30		3	12.0			.300	.300	+1.000	58	+2	+1.003	-.003
3:35		4	12.1			.300	.305	+1.005	58	+0	+1.000	-.000
3:40		5	12.0			.305	.305	+1.000	60	+2	+1.003	-.003
3:45		6	12.1			.305	.310	+1.005	60	+0	+1.000	-.000
3:50		7	12.0			.310	.310	+1.000	63	+3	+1.005	-.005
3:55		8	12.0			.310	.310	+1.000	63	+0	+1.000	-.000
4:00		9	12.1			.310	.315	+1.005	67	+4	+1.007	-.007
4:05		10	12.0			.315	.315	+1.000	69	+2	+1.003	-.003
4:10		11	12.0			.315	.315	+1.000	69	+0	+1.000	-.000
4:15		12	12.0			.315	.315	+1.000	70	+1	+1.002	-.002

Volume change per % (24) 7.74

Volume change per % (24)

Change in % by test range (23)

Volume change per digit. Compute to 4 decimal places.

This is test factor (2)

100 OF TEST PROCEDURES

30. HYDRAULIC PRESSURE CONTROL

31. VOLUME MEASUREMENTS IN RECORD BY AIR CH.

34. TEMPERATURE CORRECTIONS BY FACTOR OF

38. NET VOLUME CHANGES EACH READING

39. ACCUMULATED CHANGE

22. Test No.	28. Record details of setting up and running test. (Use full length of line if needed.)	29. Reading No.	30. Hydraulic Pressure Control		31. Volume Measurements in Record by Air Ch.			34. Temperature Corrections by Factor of			38. Net Volume Changes Each Reading	39. Accumulated Change
			32a. Beginning of Reading	32b. Level to which Reduced	32. Pressure in Arteries		35. Thermal Error Reading	36. Change Higher = Lower = (c)	37. Corrective (+) or (-) or Correction =			
					Before Reading	After Reading				Product Restored (-)		
	Continued low level Reading	14	12.0	12	.320	.320	+1.000	75	+4	+1.007	-1.007	-1.014
		15	12.0		.320	.320	+1.000	77	+2	+1.009	-1.009	-1.027
		16	12.1		.320	.325	+1.005	77	+0	+1.000	+1.005	-1.012
		17	12.0		.325	.325	+1.000	77	+0	+1.000	+1.000	-1.012
		18	12.0		.325	.325	+1.000	78	+1	+1.002	-1.002	-1.014
		19	12.0		.325	.325	+1.000	78	+0	+1.000	+1.000	-1.014
		20	12.1		.325	.330	+1.005	79	+1	+1.002	+1.003	-1.011
		21	12.0		.330	.330	+1.000	79	+0	+1.000	+1.000	-1.011
		22	12.0		.330	.330	+1.000	79	+0	+1.000	+1.000	-1.011
		23	12.0		.330	.330	+1.000	83	+4	+1.007	-1.007	-1.018
	STOP TEST	24	12.1		.330	.335	+1.005	83	+0	+1.000	+1.005	-1.013

$(-1.018 \div 2) = [-.006 \text{ gph}]$

Data Chart for Tank System Tightness Test

DATE 3-1-90

PLEASE PRINT STATION # Beacon

1. OWNER Property Tanks Beacon Park Blvd. Oakland Ca

2. OPERATOR Same As Above

3. REASON FOR TEST (Explain Fully) Contamination found in station. Try to find if problem is from tanks or lines. 2-27-90 Regular tanks passed H₂O test, 2-28-90 Supreme passed H₂O test.

4. WHO REQUESTED TEST AND WHEN Beacon

5. TANK INVOLVED

Identify by Division	Capacity	Best Supplier	Grade	Approx. Age	Shell/Fiberglass
<u>H₂O 1 unlabel</u>	<u>10,000</u>	<u>H₂O test</u>	<u>H₂O</u>		<u>Fiberglass</u>

6. INSTALLATION DATA

Location	Cover	File	Size	Depth	Notes
	<u>Asphalt</u>	<u>4"</u>	<u>2"</u>	<u>None</u>	<u>Remote Res/Jacket</u>

7. UNDERGROUND WATER Below tank bottom

8. FILL-UP ARRANGEMENTS 2-1-90 Arranged by Beacon

9. CONTRACTOR, MECHANICS, SCOTT-SERVICE

10. OTHER INFORMATION OR REMARKS Removed vent line, product line & Stage I V.R. Stage II V.R. was left in place.

11. TEST RESULTS

Tank Identification	Tight	Leakage Indicated	Date Tested
<u>#1 of 1 Unlabel</u>	<u>YES</u>	<u>-.003 gph</u>	<u>3-1-90</u>

12. SENSOR CERTIFICATION 1756 10630

13. This is to certify that these tank systems were tested on the date(s) above. Those indicated as "Tight" meet the criteria established by the National Fire Protection Association Paragraph 225.

Paul Ferrer SCOTT-CO. 1919 MARKET ST OAKLAND, CA.

14. Beacon Park Blvd Oakland Ca 3-1-90

15. TANK TO TEST # 1 of 1 Test done w/ H₂O

16. CAPACITY 10000 10,157

17. FILL-UP FOR TEST 95

18. SPECIAL CONDITIONS AND PROCEDURES TO TEST THIS TANK

19. TANK MEASUREMENTS FOR TEST ASSEMBLY 141

20. EXTENSION HOSE SETTING: 46 48

21. VAPOR RECOVERY SYSTEM CHAPER

22. COEFFICIENT OF EXPANSION RECIPROCAL METHOD 10.167

23. FOR TESTING WITH WATER 10.167

18. SPECIAL CONDITIONS AND PROCEDURES TO TEST THIS TANK

19. TANK MEASUREMENTS FOR TEST ASSEMBLY


20. EXTENSION HOSE SETTING

21. VAPOR RECOVERY SYSTEM

22. COEFFICIENT OF EXPANSION RECIPROCAL METHOD

23. FOR TESTING WITH WATER

24. FOR TESTING WITH WATER



The above information shall be used for dry test conditions. It is the responsibility of the contractor to ensure that the test is conducted in accordance with the test procedure. The contractor shall be responsible for the presence of the test medium in the tank.

LOG OF TEST PROCEDURES		32. Standpipe Level in Inches		32. Product in Gallons		33. Product Applied (-)		35. Thermal Sensor Reading		36. Change Higher - Lower - 10		37. Compensation (+) or (-) Expansion - Contraction +		38. NET VOLUME CHANGING EACH READING		39. ACCUMULATED CHANGE	
DATE	Record details of setting up and running test. (Use full length of line if needed)	29. Reading At	Beginning of Reading	Level in inches Retained	Before Reading	After Reading	Product Recovered (-)	Thermal Sensor Reading	Change Higher - Lower - 10	Compensation (+) or (-) Expansion - Contraction +	Temperature Adjustment Volume Minus Expansion (+) or Contraction (-) (200°F - 20°F)	At Low Level Correct Change for Heat (20°F - 20°F)		At Low Level Correct Change for Heat (20°F - 20°F)			
7:22	ARRIVED AT SITE, REMOVED DROPTUBE, VAPOR RECOVERY LINES, DISPENSER COVERS, BLEED PLUGS IN REMOTE PUMPS OR SUCTION SYSTEM, ETC.																
9:10	SET-UP EQUIPMENT																
9:15	START CIRCULATION																
10:02	1ST THERMO READING							10718									
10:15	START 42" HIGH-LEVEL TEST			42		.370		729	+11								
10:40	1ST HIGH-LEVEL READING	1	39.5		.370	.295	.075	714	+15	+0.033							
11:30	CONT'D HIGH-LEVEL READINGS	2	39.5		.295	.220	.075	45	+1	+0.002							
11:15	"	3	40.0		.220	.155	.065	49	+4	+0.009							
11:30	"	4	40.2		.155	.110	.045	52	+3	+0.007							
11:45	"	5	40.5		.110	.075	.035	56	+4	+0.009							
12:02	"	6	41.0		.075	.050	.025	58	+2	+0.004							
12:15	"	7	41.5		.050	.030	.020	62	+4	+0.009							
12:30	"	8	42.0		.030	.015	.015	64	+2	+0.004							
12:35	DROP TO LOW-LEVEL, WAIT 1/2 HOUR																
1:05	START 12" LOW LEVEL TEST					.410		75	+19								
1:18	1ST LOW-LEVEL READING	1	12.0	12	.410	.410	+000	75	+0	+000							
1:15	CONT'D LOW-LEVEL READINGS	2	12.0		.410	.410	+000	75	+0	+000							
1:30	"	3	12.0		.410	.410	+000	78	+3	+007							
1:35	"	4	12.1		.410	.415	+005	80	+2	+004							
1:40	"	5	12.0		.415	.415	+000	80	+0	+000							
1:45	"	6	12.0		.415	.415	+000	81	+1	+002							
1:50	"	7	12.0		.415	.415	+000	81	+0	+000							
1:55	"	8	12.1		.415	.420	+005	81	+0	+000							
1:58	"	9	12.0		.420	.420	+000	85	+4	+009							
1:55	"	10	12.0		.420	.420	+000	85	+0	+000							
2:02	"	11	12.0		.420	.420	+000	85	+0	+000							
2:05	"	12	12.1		.420	.425	+005	86	+1	+002							

2:12	CONT'D LOW LEVEL READINGS	13	12.0	12	.425	.425	+000	86	+0	+000						
2:15	"	14	12.0		.425	.425	+000	86	+0	+000						
2:20	"	15	12.1		.425	.430	+005	86	+0	+000						
2:25	"	16	12.0		.430	.430	+000	86	+0	+000						
2:30	"	17	12.0		.430	.430	+000	89	+3	+007						
2:35	"	18	12.1		.435	.435	+005	91	+2	+004						
2:40	"	19	12.0		.435	.435	+000	91	+0	+000						
2:45	"	20	12.0		.435	.435	+000	91	+0	+000						
2:50	"	21	12.0		.435	.435	+000	91	+0	+000						
2:55	"	22	12.1		.435	.440	+005	92	+1	+002						
3:00	"	23	12.0		.440	.440	+000	93	+1	+002						
3:05	"	24	12.1		.440	.445	+005	94	+1	+002						

$(.006) \div 2 = -.003 \text{ GPH}$

P-T Tank Test Data Chart
Additional Info

1. Net Volume Change at Completion of Precision Test: -.003 GPH
Signature of Tester: [Signature]
Date: _____

2. Statement:
 Tank and product handling system has been tested tight according to the Precision Test Criteria as established by N.P.F.A. publication 322. This is not intended to indicate permission of a leak.
 OR
 Tank and product handling system has failed the tank tightness test according to the Precision Test Criteria as established by N.P.F.A. publication 322.

It is the responsibility of the owner and/or operator of this system to immediately advise state and local authorities of any implied hazard and the possibility of any reportable pollution to the environment as a result of the indicated failure of this system. Health Consultants Incorporated does not assume any responsibility or liability for any loss of product to the environment.

Tank Owner/Operator: _____
Date: _____