

TEST RECORD

TANK - LINES - PUMP

JOB NO: 163-1
COMPANY: Shell DATE: 5-10-82
ADDRESS: 1737 First St. 1/2" O St. CITY: Lancaster
PRODUCT: Regular (Blue) GASOLINE METERED THROUGH PUMP OR DISPENSER: _____

METER READING: OLD _____ NEW _____
WATER PUMPED OUT OF TANK OR WATER IN TANK: _____

TYPE OF SYSTEM: SUB-PUMP & DISPENSER CONVENTIONAL PUMP _____

TANK TEST: _____ HOURS _____ MINUTES

GAUGE STICK READING: BEFORE TEST _____ AFTER TEST _____

LINE TEST: Regular _____ 88 ^{lbs} HOURS 1 hr. MINUTES

NOTES: _____

Started test @ 10:30 A.M.
Stopped test @ 11:30 A.M.

Test

GETTLER-RYAN INC.

GENERAL CONTRACTORS

BY: Barry McAdams
DATE: 5-10-82

Data Chart for Tank System Tightness Test

Job 163



PLEASE PRINT

1. OWNER Property Tank(s)

2. OPERATOR

3. REASON FOR TEST (Explain Fully)

4. WHO REQUESTED TEST AND WHEN

5. WHO IS PAYING FOR THIS TEST?

6. TANK(S) INVOLVED

7. INSTALLATION DATA

8. UNDERGROUND WATER

9. FILL-UP ARRANGEMENTS

10. CONTRACTOR, MECHANICS, any other contractor involved

11. OTHER INFORMATION OR REMARKS

12. TEST RESULTS

13. CERTIFICATION

SHELL OIL CO 1737 FIRST ST 477-7781
 Name Address Representative Telephone
 LIVERMORE
 Name Address Representative Telephone

SELLING STATION

STAN ROWER ENGINEER SHELL OIL CO 429-82
 Name Title Company or Affiliation Date Telephone
 Address Telephone

SHELL OIL CO STAN ROWER ENGINEER
 Company, Agency or Individual Person Authorizing Title Telephone
 Billing Address City State Zip
 Attention of: Order No. Other Instructions

Identify by Direction	Capacity	Brand/Supplier	Grade	Approx. Age	Steel/Fiberglass
CLOSEST TO REAR OF STATION	8000	SHELL	BLUE (OLD RED)	?	STEEL

Location	Cover	Fills	Vents	Siphones	Pumps
WEST OF ISLANDS <small>North inside driveway. Rear of station, etc.</small>	FULL 6x4x8 <small>Concrete, Black Top, Earth, etc.</small>	4" <small>Size, Thread make, Drop tubes, Remote Fills</small>	2" <small>Size, Manifoldd</small>	NONE <small>Which tanks?</small>	REMOTE <small>Section, Remote, Make if known</small>

Depth to the Water table 4' ?
 Is the water over the tank? Yes No

Tanks to be filled by 5-4-82 Date Arranged by STAN ROWER
 Name Telephone
 Extra product to "top off" and run TSTT. How and who to provide? Consider NO Lead.
 Terminal or other contact for notice or inquiry
 Company Name Telephone

GETLER & MAN INC.
 JIM ROSS

TESTED COMPLETE SYSTEM ALL LINES ATTACHED
 Additional information on any items above. Officials or others to be advised when testing is in progress or completed. Visitors or observers present during test etc.

Tests were made on the above tank systems in accordance with test procedures prescribed for as detailed on attached test charts with results as follows:

Tank Identification	Tight	Leakage Indicated	Date Tested
8000 GALLON BLUE TANK	YES		5-6-82

This is to certify that these tank systems were tested on the date(s) shown. Those indicated as "Tight" meet the criteria established by the National Fire Protection Association Pamphlet 300.

5-6-82 Date
 Jim Ross Testimonials
 GETLER & MAN INC. James P. Ross
 1992 NATIONAL AVE. HAYWARD, CA

Data Chart for Tank System Tightness Test

petro title
TANK TESTER

Job 163

PLEASE PRINT

1. OWNER Property <input type="checkbox"/> Tank(s) <input type="checkbox"/>	SHELL OIL CO 1737 FIRST ST 447-7781 <small>Name Address Telephone</small> LIORANORE <small>Name Address Telephone</small>														
	SHELL OIL CO 1737 FIRST ST 447-7781 <small>Name Address Telephone</small> LIORANORE <small>Name Address Telephone</small>														
2. OPERATOR	SHELL OIL CO 1737 FIRST ST 447-7781 <small>Name Address Telephone</small> LIORANORE <small>Name Address Telephone</small>														
3. REASON FOR TEST (Explain Fully)	FUELING STATION														
4. WHO REQUESTED TEST AND WHEN	STAN POWEL ENGINEER SHELL OIL CO 4-29-82 <small>Name Title Company or Affiliation Date</small> Address Telephone														
5. WHO IS PAYING FOR THIS TEST?	SHELL OIL CO STAN POWEL ENGINEER <small>Company, Agency or Individual Person Authorizing Title Telephone</small> Billing Address City State Zip Attention of: Order No. Other Instructions														
6. TANK(S) INVOLVED	Identify by Direction FARTHER FROM ISLANDS CENTER TANK	Capacity 5000 (BOTH)	Brand/Supplier SHELL	Grade WHITE (602 YELLOW)	Approx. Age ?	Steel/Fiberglass STEEL									
7. INSTALLATION DATA	Location WEST OF ISLANDS <small>North inside driveway, floor of station, etc.</small>	Cover FULL SLAB <small>Concrete, Black Top, Earth, etc.</small>	Fills 3' <small>Size, Thread make, Drop tubes, Remote Fills</small>	Vents 2" <small>Size, Manifoldded</small>	Siphones YES 2-5000 GALLON <small>Which tanks?</small>	Pumps REMOTE <small>Suction, Remote, Make if known</small>									
8. UNDERGROUND WATER	Depth to the Water table _____ ? _____" Is the water over the tank? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No														
9. FILL-UP ARRANGEMENTS	Tanks to be filled <u>TRANSFERRED</u> IN. 5-6-82 Date Arranged by _____ <small>Extra product to "top off" and run TSTT. How and who to provide? Consider NO Lead.</small> Terminal or other contact for notice or inquiry _____ <small>Company Name Telephone</small>														
10. CONTRACTOR, MECHANICS, any other contractor involved	GETTNER & MYAN INC. JIM REED														
11. OTHER INFORMATION OR REMARKS	1) TESTED COMPLETE SYSTEM ALL LINES ATTACHED 2) TESTED TWO 5000 GALLON TANKS ON A SIPHONE Additional information on any items above, Officials or others to be advised when testing is in progress or completed. Visitors or observers present during test etc.														
12. TEST RESULTS	Tests were made on the above tank systems in accordance with test procedures prescribed for as detailed on attached test charts with results as follows: petro title 102-1576 <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th>Tank Identification</th> <th>Tight</th> <th>Leakage Indicated</th> <th>Date Tested</th> </tr> </thead> <tbody> <tr> <td># 1 - 5000 GALLON WHITE</td> <td>BOTH TIGHT</td> <td></td> <td>5-6-82</td> </tr> <tr> <td># 2 - 5000 GALLON WHITE</td> <td></td> <td></td> <td></td> </tr> </tbody> </table>			Tank Identification	Tight	Leakage Indicated	Date Tested	# 1 - 5000 GALLON WHITE	BOTH TIGHT		5-6-82	# 2 - 5000 GALLON WHITE			
Tank Identification	Tight	Leakage Indicated	Date Tested												
# 1 - 5000 GALLON WHITE	BOTH TIGHT		5-6-82												
# 2 - 5000 GALLON WHITE															
13. CERTIFICATION	This is to certify that these tank systems were tested on the date(s) shown. Those indicated as "Tight" meet the criteria established by the National Fire Protection Association Pamphlet 328. Date: 5-6-82 Testers: JIM REED Testing Contractor or Company: GETTNER & MYAN INC. Address: 1992 NATIONAL AVE. HAWAII CA.														

14. SHELL OIL CO. 1737 FIRST ST LIVERMORE CA 5-6-82
 Name of Supplier, Owner or Dealer Address No. and Street(s) City State Date of Test

15. TANK TO TEST
 FARTHEST FROM ISLANDS
 Identify by position
 WHITE TANK #1
 Brand and Grade

16. CAPACITY
 Nominal Capacity 5000 Gallons
 By most accurate capacity chart available 5155 Gallons
 Is there doubt as to True Capacity?
 See Section "DETERMINING TANK CAPACITY"
 From
 Station Chart
 Tank Manufacturer's Chart
 Company Engineering Data
 Charts supplied with Petro-Tite
 Other

17. FILL-UP FOR TEST
 Stick Water Bottom before Fill-up $\frac{3}{8}$ to 1/2 in. Gallons Inventory
 Total Gallons on Reading 5205
 TOP OFF 20
 5225
 Fill up STICK BEFORE AND AFTER EACH COMPARTMENT DROP OR EACH METERED DELIVERY QUANTITY
 Tank Diameter Product in full tank (up to fill pipe)

18. SPECIAL CONDITIONS AND PROCEDURES TO TEST THIS TANK
 See manual sections applicable. Check below and record procedure in log (28).
 Water in tank High water table in tank excavation Line(s) being tested with LVLLT
 1) TESTED COMPLETE SYSTEM ALL LINES ATTACHED VAPOR RECOVERY SYSTEM
 2) TESTED WITH ANOTHER 5000 GALLON TANK ON A SIGNAGE Stage I Stage II

19. TANK MEASUREMENTS FOR TSTT ASSEMBLY
 Bottom of tank to Grade* 135 1/2"
 Add 30" for 4" L
 Add 24" for 3" L or air seal
 Total tubing to assemble Approximate

20. EXTENSION HOSE SETTING
 Tank top to grade* 40 1/2"
 Extend hose on suction tube 8" or more below tank top

21. TEMPERATURE/VOLUME FACTOR (a) TO TEST THIS TANK
 Is Today Warmer? Colder? *F Product in Tank *F Fill-up Product on Truck *F Expected Change (+ or -)
 22. Thermal Sensor reading after circulation 15947 digits
 23. Digits per *F in range of expected change 325 digits
 24. 5225 x .00058073 = 3.031545 gallons
 total quantity in full tank (16 or 17) coefficient of expansion for involved product volume change in this tank per *F
 25. 3.031545 + 325 = .0093
 volume change per *F (24) Digits per *F in test Range (23) Volume change per digit. Compute to 4 decimal places. This is test factor (a)

*If fill pipe extends above grade, use top of fill.

26. LOG OF TEST PROCEDURES		29. Reading in.	30. HYDROSTATIC PRESSURE CONTROL	31. VOLUME MEASUREMENTS (N) RECORD TO .001 GAL.			34. TEMPERATURE COMPENSATION USE FACTOR (a)			35. Thermal Sensor Reading	36. Change Higher + Lower - (c)	37. Compensation (e) = (a) - Expansion + Contraction -	38. NET VOLUME CHANGES EACH READING	39. ACCUMULATED CHANGE
27. IN	28. Record details of setting up and running test. (Use full length of line if needed.)	Beginning of Reading	Level to which Restored	32. Product in Products		Product Replaced (-)	Thermal Sensor Reading	Change Higher + Lower - (c)	Compensation (e) = (a) - Expansion + Contraction -	Temperature Adjustment	Volume Meas Expansion (+) or Contraction (-) @ 55(F) - @ 57(F)	At High Level record Total End Subtotal	At Low Level compute Change per Hour (APPS optional)	
IN OR F.	Before Reading			After Reading	Product Recovered (+)									
1200	TRANSFERED GAS													

Petro Tite TANK TESTER



HEATH CONSULTANTS INCORPORATED

100 TORCA DRIVE STOUGHTON, MA 02072 (617) 344-1400

Data Chart for Tank System Tightness Test

petro title
TANK TESTER

Job 163

PLEASE PRINT

1. OWNER Property <input type="checkbox"/> Tank(s) <input type="checkbox"/>	SHELL OIL CO 1737 FIRST ST			447-7781	
	Name: LIVERMORE		Address:	Telephone:	
2. OPERATOR					
Name: Address: Telephone:					
3. REASON FOR TEST (Explain Fully)					
SEWING STATION					
4. WHO REQUESTED TEST AND WHEN					
STAN ROLVER		ENGINEER	SHELL OIL CO	4-29-82	
Name		Title	Company or Affiliation	Date	
Address: Telephone:					
5. WHO IS PAYING FOR THIS TEST?					
SHELL OIL CO		STAN ROLVER	ENGINEER		
Company, Agency or Individual		Person Authorizing	Title	Telephone	
Billing Address: City: State: Zip:					
Attention of: Order No. Other Instructions:					
6. TANK(S) INVOLVED					
Identify by Direction	Capacity	Brand/Supplier	Grade	Approx. Age	Steel/Fiberglass
CLOBERTO ISLANDS	5000	SHELL	RED (OLD TAN)	?	STEEL
7. INSTALLATION DATA					
Location	Cover	Fills	Vents	Siphones	Pumps
WEST OF ISLANDS <small>North inside driveway, Rear of station, etc.</small>	FULL SLAB <small>Concrete, Black Top, Earth, etc.</small>	3" <small>Size, Thread make, Drop tubes, Remote FWS</small>	1 1/2" <small>Size, Manufactured</small>	NONE <small>Which tanks?</small>	REMOTE <small>Suction, Remote, Make if known</small>
8. UNDERGROUND WATER					
Depth to the Water table: ?				Is the water over the tank? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	
9. FILL-UP ARRANGEMENTS					
Tanks to be filled: 730 fr. 5-4-82 Date Arranged by: STAN ROLVER					
Extra product to "top off" and run TSTT. How and who to provide? Consider NO Lead.					
Terminal or other contact for notice or inquiry: Company: Name: Telephone:					
10. CONTRACTOR, MECHANICS, any other contractor involved					
GETTLER & RYAN INC. JIM REED					
11. OTHER INFORMATION OR REMARKS					
TESTED COMPLETE SYSTEM ALL LINES ATTACHED					
Additional information on any items above. Officials or others to be advised when testing is in progress or completed. Visitors or observers present during test etc.					
12. TEST RESULTS					
Tests were made on the above tank systems in accordance with test procedures prescribed for petro title as detailed on attached test charts with results as follows:					
Tank Identification	Tight	Leakage Indicated	Date Tested		
5000 GALLON RED	YES		5-4-82		
13. CERTIFICATION					
5-4-82 Date		This is to certify that these tank systems were tested on the date(s) shown. Those indicated as "Tight" meet the criteria established by the National Fire Protection Association Pamphlet 329.			
JIM REED Technician		GETTLER & RYAN INC. Testing Contractor or Company 1992 NATIONAL AVE Address			
Serial No. of Thermal Sensor		Signature: J. P. Reed MAYNARD CA			

14. SHELL OIL CO. 1737 FIRST ST LIVERMORE CA 5-4-82

16. TANK TO TEST: CLOSEST TO ISLANDS, RED TANK

18. CAPACITY: Nominal Capacity 5000, By most accurate capacity chart available 5155

17. FILL-UP FOR TEST: Stick Water Bottom before FILL-up 8 to 1/2 in. Gallons

Stick Readings to 1/2 in. Gallons Total Gallons to Reading: TANKER DROP 5255, TOP OF 15, 5270

17. FILL-UP FOR TEST (continued): Tank Diameter, Product in full tank (up to fill pipe)

18. SPECIAL CONDITIONS AND PROCEDURES TO TEST THIS TANK: TESTED COMPLETE SYSTEM ALL LINES ATTACHED, VAPOR RECOVERY SYSTEM ATTACHED

18. SPECIAL CONDITIONS AND PROCEDURES TO TEST THIS TANK (continued): Water in tank, High water table in tank excavation, Line(s) being tested with LVLTL

19. TANK MEASUREMENTS FOR TEST ASSEMBLY: Bottom of tank to Grade 135, Add 30" for 4" L, Add 24" for 2" L or air seal, Total tubing to assemble Approximate, Tank extension hose setting 40

21. TEMPERATURE/VOLUME FACTOR (a) TO TEST THIS TANK: Is Tank Warmer? Color? Product in Tank, Fill-up Product on Truck, Expected Change

22. Thermal Sensor reading after circulation 14855, 67

23. Digits per °F in range of expected change 326

24. 5270 x .00057881 = 3.050276 gallons

25. 3.050276 + 526 = .0093 This is test factor (a)

Petro Tite Tank Tester

HEATH CONSULTANTS INCORPORATED

100 TORCA DRIVE STOURTON, MA 02072 (617) 344-1400

27. TIME		28. Record details of setting up and running test. (Use full length of line if needed.)	29. Reading in	30. HYDROSTATIC PRESSURE CONTROL		31. VOLUME MEASUREMENTS IN GALLONS TO 1/2 IN.			34. TEMPERATURE COMPENSATION SEE FACTOR (a)			38. NET VOLUME CHANGE EACH READING	39. ACCUMULATED CHANGE
MIN	SEC			Beginning of Reading	Level to which Restored	Product in Standard	Product Restored (-)	Product Restored (+)	Thermal Sensor Reading	Change Higher + Lower - (c)	Computation (b) + (c) = Expansion + Contraction -		
730		ARRIVED ON SITE											
845		TANKER TOPPED OFF											
930		SET UP TESTER											
920		FILLED TESTER & BLEW OFF AIR									.0093		
940		RAISED TO 42"											
1015		READING AT 42"	0	42		.0000		14855					
1030		" " "	1	42.2	42	.0000	1800	+1800	14878	+23	+2139	-.0339	
1045		" " "	2	43.2	42	1800	2500	+0700	14901	+23	+2139	-.1439	
1100		" " "	3	41.7	42	2500	2200	-.0300	14925	+24	+2232	-.2532	
1115		" " "	4	41.0	42	2200	1500	-.0700	14946	+21	+1953	-.2653	
1130		" " "	5	39.9	42	1500	0400	-.1100	14967	+21	+1953	-.3053	
1145		" " "	6	39.9	42	1000	8900	-.1100	14988	+21	+1953	-.3053	
1200		" " "	7	38.7	42	6900	7500	-.1400	15011	+23	+2139	-.3539	
1201		LOWERED STANDPIPE TO 12"		42	12		16000	GALLONS FROM STANDPIPE					
1215		READING AT 12"	8	12.6	12	.8400	.8700	+0300	15030	+19	+1767	-.1467	
1230		" " "	9	12.1	12	.8700	.8800	+0100	15048	+18	+1674	-.1574	
1245		" " "	10	12.0	12	.8800	.8800	-	15065	+17	+1581	-.1581	
1300		" " "	11	12.0	12	.8800	.8800	-	15082	+17	+1581	-.1581	-.6203
1315		" " "	12	11.9	12	.8800	.8700	-.0100	15099	+17	+1581	-.1681	-.6417
1330		" " "	13	11.9	12	.8700	.8600	-.0100	15017	+18	+1674	-.1774	-.6617
1345		" " "	14	11.9	12	.8600	.8500	-.0100	15032	+15	+1395	-.1495	-.6531
1400		" " "	15	13.0	12	.8500	.9000	+0500	15043	+11	+1023	-.0523	-.5473
1415		" " "	16	14.8	12	.0300	1800	+1500	15058	+15	+1395	+0105	-.3687
1430		" " "	17	14.9	12	.1800	3400	+1600	15073	+15	+1395	+0205	-.2118
1445		" " "	18	14.5	12	.5400	4800	+1400	15088	+15	+1295	+0005	-.0208
1600		" " "	19	14.5	12	.4800	6200	+1400	15103	+15	+1395	+0005	+0320
* TANK TANKER LAST KNOWN READING +.0320													

DATA CHART
For Use With

petroleum
THE CODE

1 LOCATION: 1737 Fict Street @ 'O' Livermore, Ca.
Street No. and/or Corner City State Telephone No.

2 OWNER: Shell Oil Co. Stan Rolker E.N.J.
Name Address Representative Postcode Telephone No.

3 OPERATOR: None - Closed Station
Name Dealer, Mgr. or Other Address (if different than Location) Telephone No.

4 REASON FOR TEST: Selling station to Agip/Oil Co.

5 TEST REQUESTED BY: Stan Rolker Exp Shell Oil Co.
Name Position Order No. Billing Address

6 SPECIAL INSTRUCTIONS: _____

7 CONTRACTOR OR COMPANY MAKING TEST MECHANIC(S) NAME: Garber

8 IS A TANK TEST TO BE MADE WITH THIS LINE TEST? YES NO

9 MAKE AND TYPE OF PUMP OR DISPENSERS: Rolker w/let reactors

10 WEATHER: Warm TEMPERATURE IN TANKS _____ °F _____ °C COVER OVER LINES: Gas: -/V APPROXIMATE BURIAL DEPTH: 3'-6"
Concrete, Block Top, etc.

Shell Oil Co
Calif
No 5
Livermore
City

11 IDENTIFY EACH LINE AS TESTED	12 TIME (MILITARY)	13 LOG OF TEST PROCEDURES, AMBIENT TEMPERATURE, WEATHER, ETC.	14 PRESSURE psi OR kPa		15 VOLUME		16 TEST RESULTS CONCLUSIONS, REPAIRS AND COMMENTS	
			BEFORE	AFTER	READING			NET CHANGE
					BEFORE	AFTER		
Blue	1345	Pressurized	⊖	30	.046	.003	.043	Leak indicated no conclusive test as this test gave indications of trapped air in line. Suggest 90° Air test. Tested w/ Plug in.
	1350	"	⊖	30	.100	.055	.045	
	1355	"	⊖	30	.055	.013	.042	
	1400	"	⊖	30	.100	.059	.041	
	1405	"	⊖	-	.059	-	-	
Red	1445	Pressurized	⊖	30	.00	.050		Tested with plug in.
	1500	Realing	30	30	.050	.050		
	1515	"	30	30	.050	.050		
	1530	"	30	⊖	.050	.050	⊖	
		Line tight						
White	1445	Pressurized	⊖	30	.100	.041		Tested w/ P.T tank test and no plug.
	1500	Realing	30	30	.041	.041		
	1515	"	30	30	.041	.041		
	1530	"	30	⊖	.041	.041	⊖	
		Line tight						