

# Environmental Technology

4606 Meridian Ave. Suite G  
San Jose, CA. 95124 (408) 723-3837

ACCEPTED

DEPARTMENT OF ENVIRONMENTAL HEALTH  
478 - 27th Street 4th Floor  
Oakland, CA 94612  
Telephone: (415) 874-7237



These plans have been reviewed and found to be acceptable and essentially meet the requirements of State and local health laws. Changes to your plans indicated by this Department are to assure compliance with State and local laws. The project proposed herein is now released for issuance of any required building permit.

Copy of these accepted plans must be on the job and available to all contractors and crafters involved with the construction and installation. **December 10, 1987**

Any change or alteration of these plans and specifications must be submitted to this Department of Fire and Building Inspection Department for review if such changes meet the requirements of applicable laws.

Notify this Department at least 48 hours prior to the following required inspections:

- Pre-Cast
- Final Inspection

*Pulling of Tank*

Mr. Storm Goranson  
Alameda County  
Division of Hazardous Materials  
470 27th St.  
Oakland, CA. 94612

Re: Tank closure plan application for 1750 Ferro St, Oakland, CA. 94607 (Union Pacific Railroad)

issuance of a permit to the applicant. The applicant must comply with all applicable laws and regulations.

THERE IS A FINANCIAL PENALTY FOR NOT OBTAINING THESE INSPECTIONS.

*sl/nmm*

Concerning the proposed closure as indicated at the above address, we respectfully submit the following items for your review.

TANK: 1) 3000 gal. bulk oil  
CONSTRUCTION: Single wall steel

- The site map showing the location of the tank and related piping is enclosed herewith.
- All residual materials within the tank will be pumped out, containerized, and shipped under proper manifest to a State registered disposal facility.
- A minimum of 15 lbs. of dry ice per 1000 gallons of tank volume will be inserted into the tank so as to render the atmosphere within the tank inert. A meter will be on site to demonstrate that the LEL is below 25% prior to removing the tank.
- Any soils found to be containing over 100 PPM of volatile hydrocarbons will be excavated and either removed from the site and/or treated on site in accordance with all applicable local, State, and Federal guidelines and laws. A meter will be available on site to test and demonstrate the PPM concentration of the soil.
- Soil samples taken from below the tank will be tested for volatile hydrocarbons (EPA #8240), total oil and grease (EPA #3550 and 503E), and total hydrocarbons (EPA #3550). Samples will be taken to GT Labs, 48-C Pike Ln., Concord, CA. 94520, (415) 685-7852, State Cert. #194.
- Work will be performed by Environmental Technology, State Contractors Lic. #: 429586 and 1036534.

*C-61/D40*

This application is hereby submitted for your approval. Should there be need for any further information, please contact me.

Thank you for your consideration.

Sincerely,

A handwritten signature in black ink, appearing to read "Stuart G. Solomon", with a long horizontal flourish extending to the right.

Environmental Technology  
Stuart G. Solomon