

ExxonMobil Environmental Services Company

4096 Piedmont Avenue #194
Oakland, California 94611
510 547 8196 Telephone
510 547 8706 Facsimile

Jennifer C. Sedlachek
Project Manager

RECEIVED

1:41 pm, Oct 07, 2009

Alameda County
Environmental Health

ExxonMobil

October 2, 2009

Ms. Barbara Jakub, P.G.
Alameda County Health Care Services Agency
Department of Environmental Health
1131 Harbor Bay Parkway, Room 250
Alameda, California 94502-6577

RE: Former Exxon RAS #70104/1725 Park Street, Alameda, California.

Dear Ms. Jakub:

Attached for your review and comment is a copy of the letter report entitled *Groundwater Monitoring and Remediation Status Report, Second Quarter 2009*, dated October 2, 2009, for the above-referenced site. The report was prepared by Environmental Resolutions, Inc. (ERI) of Petaluma, California, and details groundwater monitoring, sampling, and remedial activities for the subject site.

I declare, under penalty of perjury, that the information and/or recommendations contained in the attached document or report is true and correct to the best of my knowledge.

If you have any questions or comments, please contact me at 510.547.8196.

Sincerely,



Jennifer C. Sedlachek
Project Manager

Attachment: ERI's Groundwater Monitoring and Remediation Status Report, Second Quarter 2009,
dated October 2, 2009

cc: w/ attachment
Mr. Shay Wideman, The Valero Companies, Environmental Liability Management

w/o attachment
Ms. Paula Sime, Environmental Resolutions, Inc.



Southern California
Northern California
Central California
Pacific Northwest
New England
Southwest
Montana
Texas

October 5, 2009
ERI 250611.Q092

Ms. Jennifer C. Sedlachek
ExxonMobil Environmental Services Company
4096 Piedmont Avenue
Oakland, California 94611

SUBJECT **Groundwater Monitoring and Remediation Status Report, Second Quarter 2009**
Former Exxon Service Station 70104
1725 Park Street, Alameda, California

Alameda County RO#448

INTRODUCTION

At the request of ExxonMobil Environmental Services Company, on behalf of ExxonMobil Oil Corporation (ExxonMobil), Environmental Resolutions, Inc. (ERI) performed second quarter 2009 groundwater monitoring and sampling and remedial activities at the subject site. This report covers activities from March 13, 2009, through June 11, 2009. Relevant plates, tables, and appendices are included at the end of this report. Currently, the site operates as a Valero-branded service station.

GROUNDWATER MONITORING AND SAMPLING SUMMARY

Gauging and sampling date:	05/27/09
Wells gauged and sampled:	MW1 through MW9, MW11
Wells gauged only:	EW1, EW3, EW5
Remediation system status on sampling date:	GWPTS active; SVE system active, AS system inactive
Presence of NAPL:	Not observed
Concurrently sampled:	Shell-branded service station (former XTRA Oil Company), 1701 Park Street, Alameda, California Concurrent Sampling was not conducted this quarter
Laboratory:	Calscience Environmental Laboratories, Inc. Garden Grove, California
Analyses performed:	EPA Method 8015B TPHd, TPHg EPA Method 8021B BTEX EPA Method 8260B MTBE, ETBE, TAME, TBA, EDB, 1,2-DCA, DIPE EPA Method 8260B Ethanol (select samples)

Environmental Resolutions, Inc.

601 North McDowell Boulevard, Petaluma, CA 94954 | Tel: 707.766.2000 | Fax: 707.789.0414 | A/C10-611383

Waste disposal: 219 gallons purge and decon water transferred to the GWPTS on 05/27/09

REMEDIATION SYSTEM SUMMARY

Groundwater Pump and Treat – Prior Systems

A GWPTS operated at the site from October 1994 to March 2000. The system was retrofitted and again operated from June 2002 to February 2004. A total of 32.2 pounds of TPHg, 4.92 pounds of benzene, and 7.71 pounds of MTBE were removed by the GWPTS during its periods of operation.

Air Sparge/Soil Vapor Extraction – Prior Systems

An AS/SVE system operated at the site from February 1998 to March 2000. The AS/SVE system was retrofitted and again operated from June 2000 to February 2004. A total of 1,022.4 pounds of TPHg and 11.81 pounds of benzene were removed by the AS/SVE system during its periods of operation.

Systems Retrofit – 2005

ERI retrofitted the GWPTS and AS/SVE system again in 2005. ERI modified the SVE system to use an 8.45-horsepower regenerative blower (Siemens 2BH1 800-7A) capable of producing 360 scfm. ERI also modified groundwater extraction wells EW1 through EW5 to simultaneously extract soil vapor and pump and treat groundwater; however, well EW5 is not currently used. Other components and processes of the systems remain unchanged. The retrofitted systems began operation on June 27, 2005.

Current GWPTS Configuration

The GWPTS operates in conjunction with the AS/SVE system to pump down the groundwater table, expose petroleum hydrocarbons in soil, and address dissolved-phase hydrocarbons in groundwater. Groundwater is currently extracted from wells EW1 through EW4 using pneumatic pumps and is directed to a holding tank. Water is periodically transferred from the holding tank through a particulate filter and three 500-pound GAC vessels connected in series prior to discharge to the sanitary sewer under permit through East Bay Municipal Utilities District (EBMUD). The volume of discharged groundwater is recorded using a totalizing flow meter.

Current AS/SVE System Configuration

The current AS/SVE system consists of a regenerative blower, a moisture separator, three vapor-phase 500-pound GAC vessels connected in series, an exhaust stack for discharge to the atmosphere, and associated monitoring instrumentation. The 500-pound GAC vessels have a maximum flow capacity of 300 scfm. Water generated in the moisture separator is pumped to the GWPTS.

An oil-less air compressor is available for air sparging (subsurface air injection), through a trench in the vicinity of the extraction wells to help volatilize hydrocarbons suspended in soil. Air sparging is not currently performed but is available for use in the future.

System start-up dates:	<u>AS/SVE System</u>	02/16/98
	<u>GWPTS</u>	10/10/94
System discharge permits:	<u>AS/SVE System</u>	BAAQMD Plant No. 8252
	<u>GWPTS</u>	EBMUD Permit No. 50266631
System reporting periods:	<u>AS/SVE System</u>	03/13/09 – 06/11/09
	<u>GWPTS</u>	03/13/09 – 06/11/09

System modifications during reporting period: None
System status during reporting period: SVE System Active
GWPTS Active
AS System Inactive

Laboratory: Calscience Environmental Laboratories, Inc.
 Garden Grove, California

Effluent analyses performed: AS/SVE System
 EPA TO-3M TPHg
 EPA TO-15M MTBE, BTEX
GWPTS
 EPA Method 8015B TPHg
 EPA Method 8021B BTEX, MTBE

System Performance:

AS/SVE System

Period	Mass of TPHg Removed (pounds)	Mass of Benzene Removed (pounds)	Mass of MTBE Removed (pounds)
03/13/09 – 06/11/09	<5.037	<0.0016	0.2926
To date:	<1,715.45	<27.71	<14.28

GWPTS

Period	Volume of Groundwater Treated (gallons)	Mass of TPHg Removed (pounds)	Mass of Benzene Removed (pounds)	Mass of MTBE Removed (pounds)
03/13/09 – 06/11/09	104,770	<0.279	<0.0005	0.434
To date:	4,094,140	<67.2	<5.169	43.964

CONCLUSIONS

The groundwater monitoring and sampling data are consistent with the historical data for the site. Current remediation efforts are effectively removing residual and dissolved-phase hydrocarbons beneath the site.

In accordance with correspondence received from the ACEH on July 24, 2009, monitoring and sampling at this site has been reduced to semi-annual.

DOCUMENT DISTRIBUTION

ERI recommends forwarding copies of this report to:

Ms. Barbara Jakub, P.G.
Alameda County Health Care Services Agency
Department of Environmental Health
1131 Harbor Bay Parkway, Room 250
Alameda, California 94502-6577

Mr. Shay Wideman
The Valero Companies
Environmental Liability Management
685 West Third Street
Hanford, California 93230

LIMITATIONS

For any documents cited that were not generated by ERI, the data taken from those documents is used "as is" and is assumed to be accurate. ERI does not guarantee the accuracy of this data and makes no warranties for the referenced work performed nor the inferences or conclusions stated in these reports.

This document was prepared in accordance with generally accepted standards of environmental, geological, and engineering practices in California at the time of investigation. No soil engineering or geotechnical references are implied or should be inferred. The evaluation of the geologic conditions at the site for this investigation is made from a limited number of data points. Subsurface conditions may vary away from these data points.

Please call Ms. Paula Sime, ERI's project manager for this site, at (707) 766-2000 with any questions regarding this report.



Sincerely,
Environmental Resolutions, Inc.

Jennifer L. Lacy
SCANNED IMAGE
Jennifer L. Lacy
Senior Staff Scientist

Heidi Dieffenbach-Carle
SCANNED IMAGE
Heidi Dieffenbach-Carle
P.G. 6793


Enclosures:

Acronym List

- | | |
|------------|--|
| Plate 1 | Site Vicinity Map |
| Plate 2 | Select Analytical Results |
| Plate 3 | Groundwater Elevation Map |
| Table 1A | Cumulative Groundwater Monitoring and Sampling Data |
| Table 1B | Additional Cumulative Groundwater Monitoring and Sampling Data |
| Table 2 | Well Construction Details |
| Table 3 | Operation and Performance Data for Air Sparge/Soil Vapor Extraction System |
| Table 4 | Operation and Performance Data for Groundwater Extraction and Treatment System |
| Appendix A | Groundwater Sampling Protocol |
| Appendix B | Laboratory Analytical Reports and Chain-of-Custody Records |
| Appendix C | Field Data Sheets |


ACRONYM LIST

µg/L	Micrograms per liter	NEPA	National Environmental Policy Act
µs	Microsiemens	NGVD	National Geodetic Vertical Datum
1,2-DCA	1,2-dichloroethane	NPDES	National Pollutant Discharge Elimination System
acfm	Actual cubic feet per minute	O&M	Operations and Maintenance
AS	Air sparge	ORP	Oxidation-reduction potential
bgs	Below ground surface	OSHA	Occupational Safety and Health Administration
BTEX	Benzene, toluene, ethylbenzene, and total xylenes	OVA	Organic vapor analyzer
CEQA	California Environmental Quality Act	P&ID	Process & Instrumentation Diagram
cfm	Cubic feet per minute	PAH	Polycyclic aromatic hydrocarbon
COC	Chain of Custody	PCB	Polychlorinated biphenyl
CPT	Cone Penetration (Penetrometer) Test	PCE	Tetrachloroethene or perchloroethylene
DIPE	Di-isopropyl ether	PID	Photo-ionization detector
DO	Dissolved oxygen	PLC	Programmable logic control
DOT	Department of Transportation	POTW	Publicly owned treatment works
DPE	Dual-phase extraction	ppmv	Parts per million by volume
DTW	Depth to water	PQL	Practical quantitation limit
EDB	1,2-dibromoethane	psi	Pounds per square inch
EPA	Environmental Protection Agency	PVC	Polyvinyl chloride
ESL	Environmental screening level	QA/QC	Quality assurance/quality control
ETBE	Ethyl tertiary butyl ether	RBSL	Risk-based screening levels
FID	Flame-ionization detector	RCRA	Resource Conservation and Recovery Act
fpm	Feet per minute	RL	Reporting limit
GAC	Granular activated carbon	scfm	Standard cubic feet per minute
gpd	Gallons per day	SSTL	Site-specific target level
gpm	Gallons per minute	STLC	Soluble threshold limit concentration
GWPTS	Groundwater pump and treat system	SVE	Soil vapor extraction
HVOC	Halogenated volatile organic compound	SVOC	Semivolatile organic compound
J	Estimated value between MDL and PQL (RL)	TAME	Tertiary amyl methyl ether
LEL	Lower explosive limit	TBA	Tertiary butyl alcohol
LPC	Liquid-phase carbon	TCE	Trichloroethene
LRP	Liquid-ring pump	TOC	Top of well casing elevation; datum is msl
LUFT	Leaking underground fuel tank	TOG	Total oil and grease
LUST	Leaking underground storage tank	TPHd	Total petroleum hydrocarbons as diesel
MCL	Maximum contaminant level	TPHg	Total petroleum hydrocarbons as gasoline
MDL	Method detection limit	TPHmo	Total petroleum hydrocarbons as motor oil
mg/kg	Milligrams per kilogram	TPHs	Total petroleum hydrocarbons as stoddard solvent
mg/L	Milligrams per liter	TRPH	Total recoverable petroleum hydrocarbons
mg/m ³	Milligrams per cubic meter	UCL	Upper confidence level
MPE	Multi-phase extraction	USCS	Unified Soil Classification System
MRL	Method reporting limit	USGS	United States Geologic Survey
msl	Mean sea level	UST	Underground storage tank
MTBE	Methyl tertiary butyl ether	VCP	Voluntary Cleanup Program
MTCA	Model Toxics Control Act	VOC	Volatile organic compound
NAI	Natural attenuation indicators	VPC	Vapor-phase carbon
NAPL	Non-aqueous phase liquid		




3-D TopoQuads Copyright © 1999 DeLorme Yarmouth, ME 04096 Source Data: USGS 550 ft Scale: 1:19,200 Detail: 13-0 Datum: WGS84

EXPLANATION



APPROXIMATE SCALE



SOURCE:
Modified from a map
provided by
DeLorme 3-D TopoQuads

SITE VICINITY MAP

FORMER EXXON SERVICE STATION 70104
1725 Park Street
Alameda, California

PROJECT NO.

2506

PLATE

1




Analyte Concentrations in ug/L
Sampled May 27, 2009

Total Petroleum Hydrocarbons
as gasoline
Benzene
Methyl Tertiary Butyl Ether
(EPA Method 8260B)
Tertiary Butyl Alcohol


- < Less Than the Stated Laboratory Reporting Limit
- ug/L Micrograms per Liter
- NS Not sampled
- k Elevated reporting limit due to high levels of non-target compounds.

NOTES:

Wells MW12, EW2, and EW4 not routinely monitored or sampled.



APPROXIMATE SCALE



FN 2506 09 2QTR_QM



**SELECT ANALYTICAL RESULTS
May 27, 2009**

FORMER EXXON SERVICE STATION 70104
1725 Park Street
Alameda, California

EXPLANATION


- MW11 Groundwater Monitoring Well
- EW4 Recovery Well
- MW10 Destroyed Groundwater Monitoring Well
- MW4 Groundwater Monitoring Well By Others
- VW2 Vapor Extraction Well
- AS1 Air Sparge/Soil Vapor Well

PROJECT NO.

2506

PLATE

2



March 1, 2004, through May 27, 2009


Rose diagram developed by evaluating the groundwater gradient direction from the quarterly monitoring data. Each circle on the rose diagram represents the number of monitoring events that the gradient plotted in that 22 1/2 degree sector.

GROUNDWATER FLOW DIRECTION ROSE DIAGRAM

N Compass Direction
22 Data Points Shown



APPROXIMATE SCALE



Notes:

Wells MW12, EW2, and EW4 not routinely monitored or sampled.

NM Not Measured

12.0-----Line of Equal Groundwater Elevation; datum is mean sea level

FN 2506 09 2QTR_QM



**GROUNDWATER ELEVATION MAP
May 27, 2009**

FORMER EXXON SERVICE STATION 70104
1725 Park Street
Alameda, California

EXPLANATION

- MW11 Groundwater Monitoring Well
- 12.10 Groundwater elevation in feet; datum is mean sea level
- EW4 Recovery Well
- MW10 Destroyed Groundwater Monitoring Well

- MW4 Groundwater Monitoring Well By Others
- VW2 Vapor Extraction Well
- AS1 Air Sparge/Soil Vapor Well

PROJECT NO.
2506

PLATE
3

**TABLE 1A
CUMULATIVE GROUNDWATER MONITORING AND SAMPLING DATA**

Former Exxon Service Station 70104
1725 Park Street
Alameda, California

Well ID	Sampling Date	TOC Elev. (feet)	DTW (feet)	GW Elev. (feet)	NAPL (feet)	TPHd (µg/L)	TPHg (µg/L)	MTBE 8021B (µg/L)	MTBE 8260B (µg/L)	B (µg/L)	T (µg/L)	E (µg/L)	X (µg/L)
MW1	09/12/94	17.35	7.11	10.24	No	---	1,600a	---	---	200	1.9	210	6.6
MW1	10/01/94	17.35	7.44	9.91	No	---	1,400a	---	---	200	<0.5	160	6.6
MW1	01/13/95	17.35	5.13	12.22	No	---	2,100a	---	---	410b	17	280b	89
MW1	04/27/95	17.35	6.57	10.78	No	---	4,700	---	---	460	41	340	270
MW1	08/03/95	17.35	7.46	9.89	No	---	1,900	30	---	140	<5.0	160	9.9
MW1	10/17/95	17.35	7.67	9.68	No	---	280	5.5	---	6.2	<0.5	13	0.75
MW1	01/24/96	17.35	6.52	10.83	No	---	740	440	---	21	1.4	38	3.1
MW1	04/24/96	17.35	5.95	11.40	No	---	7,800	250	---	200	110	1,000	740
MW1	07/26/96	17.35	7.60	9.75	No	---	620	23	---	8.0	0.99	26	1.0
MW1	10/30/96	17.35	8.06	9.29	No	---	700	33	---	14	2.9	85	3.5
MW1	01/31/97	17.35	5.12	12.23	No	---	7,600	<200	---	420	33	1,400	480
MW1	04/10/97	17.35	---	---	---	---	---	---	---	---	---	---	---
MW1	07/10/97	17.35	7.54	9.81	No	---	580	12	---	10	<0.5	<0.5	<0.5
MW1	10/08/97	17.35	---	---	---	---	---	---	---	---	---	---	---
MW1	01/28/98	17.35	4.48	12.87	No	---	820	---	<2.5	110	2.8	170	14
MW1	04/14/98	17.35	4.69	12.66	---	---	---	---	---	---	---	---	---
MW1	07/30/98	17.35	6.19	11.16	No	---	2,700	41	---	210	<5.0	550	<5.0
MW1	10/19/98	17.35	6.72	10.63	No	---	---	---	---	---	---	---	---
MW1	01/13/99	17.35	6.52	10.83	No	---	491	9.78	---	8.0	<0.5	<0.5	<0.5
MW1	04/28/99	17.35	5.37	11.98	---	---	---	---	---	---	---	---	---
MW1	07/09/99	17.35	6.39	10.96	No	---	1,030	10.6	---	114	8.07	184	0.644
MW1	10/25/99	17.35	6.68	10.67	No	---	---	---	---	---	---	---	---
MW1	01/21/00	17.35	6.20	11.15	No	---	<50	5.1	---	<1.0	<1.0	<1.0	<1.0
MW1	04/14/00	17.35	5.18	12.17	No	---	---	---	---	---	---	---	---
MW1	06/16/00	17.35	Property transferred to Valero Refining Company.										---
MW1	07/05/00	17.35	5.93	11.42	No	---	88	200	---	4.3	<0.5	0.61	<0.5
MW1	10/03/00	17.35	6.51	10.84	No	---	<50	240	---	0.72	<0.5	<0.5	<0.5
MW1	01/02/01	17.35	6.17	11.18	No	---	<50	68	---	0.75	<0.5	<0.5	<0.5
MW1	04/02/01	17.35	7.42	9.93	No	---	140	4.3	---	<0.5	<0.5	4.1	1.1
MW1	07/02/01	17.35	6.27	11.08	No	---	74	14	---	<0.5	<0.5	<0.5	<0.5
MW1	10/15/01	17.35	6.64	10.71	No	---	110	83	---	2.6	<0.5	<0.5	<0.5
MW1	Nov-01	17.29	Well surveyed in compliance with AB 2886 requirements.										---
MW1	02/04/02	17.29	5.08	12.21	No	52.0	75.0	67.1	---	0.70	<0.50	0.50	<0.50
MW1	05/06/02	17.29	5.48	11.81	No	129	793	702	1,004	8.6	<0.5	0.5	1.1
MW1	08/22/02	17.29	7.14	10.15	No	602	1,150	181	---	120	0.8	9.0	3.6
MW1	11/08/02	17.29	6.19	11.10	No	504	947	182	---	95.6	4.0	3.7	2.7
MW1	02/07/03	17.29	6.00	11.29	No	610	1,190	284	---	89.7	3.8	45.3	13.2
MW1	05/02/03	17.29	5.76	11.53	No	797	1,020	296	---	75.8	9.0	5.7	11.9
MW1	08/14/03	17.29	7.04	10.25	No	531d	822	201	---	33.9	2.8	1.5	1.9
MW1	11/14/03	17.29	6.41	10.88	No	560d	574	276	---	19.8	1.8	2.0	2.2

TABLE 1A
CUMULATIVE GROUNDWATER MONITORING AND SAMPLING DATA

Former Exxon Service Station 70104
1725 Park Street
Alameda, California

Well ID	Sampling Date	TOC Elev. (feet)	DTW (feet)	GW Elev. (feet)	NAPL (feet)	TPHd (µg/L)	TPHg (µg/L)	MTBE 8021B (µg/L)	MTBE 8260B (µg/L)	B (µg/L)	T (µg/L)	E (µg/L)	X (µg/L)
MW1	03/01/04	17.29	4.63	12.66	No	785d	1,430	---	895	46.2	3.1	14.2	9.2
MW1	06/15/04	17.29	6.05	11.24	No	204d	621	668	---	11.1	<0.5	<0.5	<0.5
MW1	09/13/04	17.29	6.62	10.67	No	221d	754	479	---	34.4	1.5	1.1	1.2
MW1	12/22/04	17.29	5.67	11.62	No	288d, f	775	253	---	38.8	1.0	1.8	0.8
MW1	03/24/05	17.29	4.63	12.66	No	471d	952	---	120	41.6	1.4	12.8	6.0
MW1	06/14/05	17.29	5.55	11.74	No	695d	605	---	91	37.9	2.5	2.6	2.5
MW1	09/12/05	17.29	8.16	9.13	No	280d	1,410	---	4,780	1.43	<0.50	0.82	1.08
MW1	12/13/05	17.29	6.86	10.43	No	182d	4,610	---	6000h	2.35	0.71	<0.50	<0.50
MW1	03/13/06	17.29	6.31	10.98	No	470d	6,800i	---	4,600	70	<25	76	56
MW1	06/12/06	17.29	2.01	15.28	No	300d,f	16,000i	---	16,000	<50	<50	<50	<50
MW1	09/08/06	17.29	6.61	10.68	No	62d	4,200i	---	4,700	<25	<25	<25	<25
MW1	12/05/06	17.29	7.94	9.35	No	<47	6,300i	---	9,300	<25	<25	<25	<25
MW1	03/12/07	17.29	5.53	11.76	No	120d	3,300i	---	3,400	<25	<25	<25	<25
MW1	05/29/07	17.29	7.15	10.14	No	277d	2,680	---	3,550	2.86	0.97	1.70	3.71f
MW1	08/29/07	17.29	7.44	9.85	No	94d	3,500i	---	3,100	<25	<25	<25	<25
MW1	11/29/07	17.29	7.04	10.25	No	58d	3,600i	---	5,000	<25	<25	<25	<25
MW1	02/27/08	17.29	5.80	11.49	No	130d	2,700i	---	3,600	<25	<25	<25	<25
MW1	05/28/08	17.29	6.50	10.79	No	165d	1,720f	---	3,840	<0.50	<0.50	<0.50	<0.50
MW1	08/27/08	17.29	6.91	10.38	No	180	1,400	---	3,000	<0.50	<0.50	<0.50	<1.0
MW1	11/25/08	17.29	6.96	10.33	No	250	1,800	---	1,300	<0.50	<0.50	0.65	<1.0
MW1	02/25/09	17.29	4.99	12.30	No	170	1,100	---	1,300	3.2	0.98	3.1	<1.0
MW1	05/27/09	17.29	5.85	11.44	No	100	840	---	3,600	3.6	0.64	0.92	1.51
MW2	09/12/94	16.67	6.71	9.96	No	---	31,000a	---	---	4,400	120	1,700	2,100
MW2	10/01/94	16.67	7.22	9.45	No	---	45,000a	---	---	4,500	250	1,800	2,400
MW2	01/13/95	16.67	4.46	12.21	No	---	---	---	---	---	---	---	---
MW2	04/27/95	16.67	6.92	9.75	No	---	44,000	---	---	7,000	840	2,400	3,400
MW2	08/03/95	16.67	6.96	9.71	No	---	30,000	37,000	---	4,600	170	1,600	1,100
MW2	10/17/95	16.67	7.83	8.84	No	---	45,000	14,000	---	5,400	190	2,000	1,500
MW2	01/24/96	16.67	6.45	10.22	No	---	30,000	4,100	---	5,000	810	2,200	2,200
MW2	04/24/96	16.67	6.00	10.67	No	---	34,000	22,000	---	8,700	410	2,200	2,000
MW2	07/26/96	16.67	7.14	9.53	No	---	40,000	18,000	---	10,000	<200	1,800	760
MW2	10/30/96	16.67	6.95	9.72	No	---	43,000	18,000	---	9,100	<250	2,400	730
MW2	01/31/97	16.67	5.07	11.60	No	---	28,000	8,000	---	2,400	630	1,500	3,300
MW2	04/10/97	16.67	---	---	---	---	---	---	---	---	---	---	---
MW2	07/10/97	16.67	7.34	9.33	No	---	18,000	2,600	---	2,900	82	1,500	530
MW2	10/08/97	16.67	---	---	---	---	---	---	---	---	---	---	---
MW2	01/28/98	16.67	4.46	12.21	No	---	29,000	---	28,000	5,600	410	1,500	720
MW2	04/14/98	16.67	4.48	12.19	---	---	---	---	---	---	---	---	---
MW2	07/30/98	16.67	6.01	10.66	No	---	24,000	6,300	---	7,500	<200	1,300	280
MW2	10/19/98	16.67	6.35	10.32	No	---	---	---	---	---	---	---	---

**TABLE 1A
CUMULATIVE GROUNDWATER MONITORING AND SAMPLING DATA**

Former Exxon Service Station 70104
1725 Park Street
Alameda, California

Well ID	Sampling Date	TOC Elev. (feet)	DTW (feet)	GW Elev. (feet)	NAPL (feet)	TPHd (µg/L)	TPHg (µg/L)	MTBE 8021B (µg/L)	MTBE 8260B (µg/L)	B (µg/L)	T (µg/L)	E (µg/L)	X (µg/L)
MW2	01/13/99	16.67	6.54	10.13	No	---	18,400	2,200	---	4,750	211	1,760	45.3
MW2	04/28/99	16.67	5.54	11.13	---	---	---	---	---	---	---	---	---
MW2	07/09/99	16.67	6.45	10.22	No	---	14,100	3,410	---	4,270	80.1	1,300	339
MW2	10/25/99	16.67	---	---	---	---	---	---	---	---	---	---	---
MW2	01/21/00	16.67	---	---	---	---	---	---	---	---	---	---	---
MW2	02/11/00	16.67	---	---	No	---	<50	15	---	<1.0	<1.0	<1.0	<1.0
MW2	04/14/00	16.67	4.69	11.98	No	---	---	---	---	---	---	---	---
MW2	06/16/00	16.67	Property transferred to Valero Refining Company.										
MW2	07/05/00	16.67	5.44	11.23	No	---	150	86	---	15	<0.5	6.2	2.8
MW2	10/03/00	16.67	6.31	10.36	No	---	200	2,500	---	35	0.51	5.1	12
MW2	01/02/01	16.67	---	---	---	---	---	---	---	---	---	---	---
MW2	04/02/01	16.67	5.00	11.67	No	---	<50	680	---	3.6	<0.5	<0.5	<0.5
MW2	07/02/01	16.67	5.62	11.05	No	---	1,400	890	---	13	1.1	<0.5	1.1
MW2	10/15/01	16.67	7.55	9.12	No	---	620	1,900	---	190	3.5	4.5	7
MW2	Nov-01	16.39	Well surveyed in compliance with AB 2886 requirements.										
MW2	02/04/02	16.39	4.71	11.68	No	69.0	122	7.10	---	31.4	5.40	9.10	10.4
MW2	05/06/02	16.39	5.08	11.31	No	252	1,250	646	958	125	22.5	68.2	63.1
MW2	08/22/02	16.39	6.88	9.51	No	178	1,270	652	---	269	<0.5	4.3	10.6
MW2	11/08/02	16.39	6.20	10.19	No	83	158	177	---	14.0	0.7	0.6	1.0
MW2	02/07/03	16.39	5.72	10.67	No	<50	173	78.1	---	43.1	3.4	4.5	5.5
MW2	05/02/03	16.39	4.18	12.21	No	56	60.0	50.5	---	4.10	<0.5	0.6	1.4
MW2	08/14/03	16.39	6.00	10.39	No	62d	1,080	506	---	143	1.1	0.7	2.0
MW2	11/14/03	16.39	5.81	10.58	No	132d	362	93.9	---	74.0	0.6	1.6	3.7
MW2	03/01/04	16.39	3.86	12.53	No	<100	<50.0	---	1.40	4.80	1.1	1.1	5.1
MW2	06/15/04	16.39	5.30	11.09	No	<50	<50.0	1.1	---	2.00	2.5	0.5	3.3
MW2	09/13/04	16.39	5.81	10.58	No	57d	<50.0	10.7	---	1.60	<0.5	<0.5	2.5
MW2	12/22/04	16.39	5.17	11.22	No	69d,f	<50.0	0.9	---	0.70	<0.5	<0.5	0.8
MW2	03/24/05	16.39	3.81	12.58	No	78d	54.0	---	0.80	6.30	0.5	1.1	1.5
MW2	06/14/05	16.39	4.89	11.50	No	84d	<50.0	---	<0.50	1.00	<0.5	<0.5	<0.5
MW2	09/12/05	16.39	7.26	9.13	No	65.2d	152	---	15.1	2.94	<0.50	<0.50	<0.50
MW2	12/13/05	16.39	5.87	10.52	No	88.4d	107	---	28.6	24.3	<0.50	<0.50	0.82
MW2	03/13/06	16.39	4.70	11.69	No	<47	<50	---	1.3	6.8	<0.50	<0.50	1.6
MW2	06/12/06	16.39	5.79	10.60	No	130d,f	140	---	0.69	9.1	2.2	4.2	21
MW2	09/08/06	16.39	5.96	10.43	No	<47	71	---	18	1.9	<0.50	<0.50	<0.50
MW2	12/05/06	16.39	---	---	No	520d	97	---	26	6.2	<0.50	<0.50	<0.50
MW2	03/12/07	16.39	4.97	11.42	No	48d	160	---	11	51	<1.0	<1.0	<1.0
MW2	05/29/07	16.39	5.90	10.49	No	93.5d	172	---	18.4	59.6	<0.50	<0.50	0.56f
MW2	08/29/07	16.39	6.51	9.88	No	99d	260	---	47	79	<1.0	<1.0	<1.0
MW2	11/29/07	16.39	6.33	10.06	No	89d	440	---	55	170	<2.5	<2.5	<2.5
MW2	02/27/08	16.39	4.67	11.72	No	<47	<250	---	2.8	2.6	<2.5	3.5	13
MW2	05/28/08	16.39	5.63	10.76	No	153d	88.8	---	4.03	7.43	<0.50	<0.50	<0.50

**TABLE 1A
CUMULATIVE GROUNDWATER MONITORING AND SAMPLING DATA**

Former Exxon Service Station 70104
1725 Park Street
Alameda, California

Well ID	Sampling Date	TOC Elev. (feet)	DTW (feet)	GW Elev. (feet)	NAPL (feet)	TPHd (µg/L)	TPHg (µg/L)	MTBE 8021B (µg/L)	MTBE 8260B (µg/L)	B (µg/L)	T (µg/L)	E (µg/L)	X (µg/L)
MW2	08/27/08	16.39	6.19	10.20	No	<50	55	---	2.0	1.7	<0.50	1.4	1.2
MW2	11/25/08	16.39	6.04	10.35	No	<50	61	---	1.8	0.80	<0.50	<0.50	<1.0
MW2	02/25/09	16.39	4.39	12.00	No	<50	99	---	1.5	2.6	1.2	4.0	4.4
MW2	05/27/09	16.39	5.10	11.29	No	<50	63	---	1.2	5.5	<0.50	<0.50	<1.0
MW3	09/12/94	17.11	6.58	10.53	No	---	3,100a	---	---	580	8	340	100
MW3	10/01/94	17.11	6.85	10.26	No	---	3,800a	---	---	640	11	230	130
MW3	01/13/95	17.11	5.27	11.84	No	---	3,800a	---	---	690	24	210	130
MW3	04/27/95	17.11	6.05	11.06	No	---	7,500	---	---	940	35	810	530
MW3	08/03/95	17.11	6.71	10.40	No	---	1,900	24	---	380	<5.0	140	45
MW3	10/17/95	17.11	7.46	9.65	No	---	6,100	<5.0	---	950	29	230	190
MW3	01/24/96	17.11	5.83	11.28	No	---	3,000	<100	---	730	15	190	110
MW3	04/24/96	17.11	5.38	11.73	No	---	11,000	<100	---	1,200	130	1,000	1,400
MW3	07/26/96	17.11	6.80	10.31	No	---	2,500	250	---	800	16	24	56
MW3	10/30/96	17.11	7.20	9.91	No	---	5,200	2,900	---	1,300	28	170	180
MW3	01/31/97	17.11	4.31	12.80	No	---	---	---	---	---	---	---	---
MW3	04/10/97	17.11	---	---	---	---	---	---	---	---	---	---	---
MW3	07/10/97	17.11	---	---	---	---	---	---	---	---	---	---	---
MW3	10/08/97	17.11	---	---	---	---	---	---	---	---	---	---	---
MW3	01/28/98	17.11	4.03	13.08	No	---	---	---	---	---	---	---	---
MW3	04/14/98	17.11	3.80	13.31	No	---	---	---	---	---	---	---	---
MW3	07/30/98	17.11	5.84	11.27	No	---	---	---	---	---	---	---	---
MW3	10/19/98	17.11	6.25	10.86	No	---	---	---	---	---	---	---	---
MW3	01/13/99	17.11	6.14	10.97	No	---	---	---	---	---	---	---	---
MW3	04/28/99	17.11	4.95	12.16	---	---	---	---	---	---	---	---	---
MW3	07/09/99	17.11	---	---	---	---	---	---	---	---	---	---	---
MW3	10/25/99	17.11	---	---	---	---	---	---	---	---	---	---	---
MW3	01/21/00	17.11	---	---	---	---	---	---	---	---	---	---	---
MW3	04/14/00	17.11	---	---	---	---	---	---	---	---	---	---	---
MW3	06/16/00	17.11	Property transferred to Valero Refining Company.										
MW3	07/05/00	17.11	---	---	---	---	---	---	---	---	---	---	---
MW3	10/03/00	17.11	---	---	---	---	---	---	---	---	---	---	---
MW3	01/02/01	17.11	5.78	11.33	No	560c	2,700	3,100	---	1300	8.8	11	21.3
MW3	04/02/01	17.11	4.71	12.40	No	620	3,700	1,400	---	1,400	11	36	21
MW3	07/02/01	17.11	5.82	11.29	No	880	5,300	1,200	---	1,300	32	30	730
MW3	10/15/01	17.11	6.12	10.99	No	210d	2,300	1,800	---	630	2.5	8.2	3.34
MW3	Nov-01	17.02	Well surveyed in compliance with AB 2886 requirements.										
MW3	02/04/02	17.02	4.59	12.43	No	402	8,830	1,420	---	2,300	166	150	158
MW3	05/06/02	17.02	4.84	12.18	No	1,300	7,950	544	967	1,930	18.0	80.0	648
MW3	08/22/02	17.02	6.42	10.60	No	416	2,270	298	---	506	3.5	8.0	6.5
MW3	11/08/02	17.02	5.66	11.36	No	193	1,640	470	---	330	1.8	4.9	2.7

**TABLE 1A
CUMULATIVE GROUNDWATER MONITORING AND SAMPLING DATA**

Former Exxon Service Station 70104
1725 Park Street
Alameda, California

Well ID	Sampling Date	TOC Elev. (feet)	DTW (feet)	GW Elev. (feet)	NAPL (feet)	TPHd (µg/L)	TPHg (µg/L)	MTBE 8021B (µg/L)	MTBE 8260B (µg/L)	B (µg/L)	T (µg/L)	E (µg/L)	X (µg/L)
MW3	02/07/03	17.02	4.99	12.03	No	800	1,360	662	---	328	6.5	9.0	35.0
MW3	05/02/03	17.02	4.73	12.29	No	562	2,500	300	---	306	4.8	17.5	29.1
MW3	08/14/03	17.02	6.02	11.00	No	227d	2,040	367	---	356	3.4	3.9	3.2
MW3	11/14/03	17.02	6.01	11.01	No	280d	1,880	794	---	244	2.6	3.7	4.5
MW3	03/01/04	17.02	3.71	13.31	No	484d	3,660	---	288	865	11.5	22.5	20.5
MW3	06/15/04	17.02	5.28	11.74	No	866d	9,980	180	---	1,120	82.0	86.0	1,740
MW3	09/13/04	17.02	5.91	11.11	No	390d	1,640	183	---	454	4.8	6.7	6.8
MW3	12/22/04	17.02	4.88	12.14	No	209d,f	1,770	44.9	---	230	2.8	8.2	9.2
MW3	03/24/05	17.02	3.59	13.43	No	808d	4,800	---	128	930	45.1	59.6	425
MW3	06/14/05	17.02	4.71	12.31	No	1,440d	6,080	---	144	1,330	34.0	39.0	217
MW3	09/12/05	17.02	7.03	9.99	No	417d	1,480	---	114	447	4.48	8.40	13.9
MW3	12/13/05	17.02	5.89	11.13	No	317d	1,160	---	26.5	218	2.19	3.87	6.70
MW3	03/13/06	17.02	4.41	12.61	No	640d	2,800	---	45	830	12	10	17
MW3	06/12/06	17.02	5.41	11.61	No	620d,f	4,800	---	43	580	20	42	480
MW3	09/08/06	17.02	6.16	10.86	No	130d	810	---	22	130	<2.5	<2.5	<2.5
MW3	12/05/06	17.02	6.61	10.41	No	110d	720	---	16	100	<2.5	<2.5	<2.5
MW3	03/12/07	17.02	4.70	12.32	No	160d	720	---	12	79	<2.5	4.1	4.4
MW3	05/29/07	17.02	5.87	11.15	No	195d	782	---	14.7	109	1.76	1.89	2.79f
MW3	08/29/07	17.02	6.64	10.38	No	100d	530	---	10	64	<2.5	<2.5	<2.5
MW3	11/29/07	17.02	6.32	10.70	No	100d	560	---	9.8	72	<2.5	<2.5	<2.5
MW3	02/27/08	17.02	4.49	12.53	No	130d	690	---	12	110	<2.5	7.5	8.8
MW3	05/28/08	17.02	6.19	10.83	No	819d	1,640f	---	13.8f	85.6	<0.50	130	37.5
MW3	08/27/08	17.02	6.35	10.67	No	150	700	---	9.5	54	0.65	1.3	1.1
MW3	11/25/08	17.02	6.15	10.87	No	110	460	---	7.8	56	0.64	1.1	<1.0
MW3	02/25/09	17.02	4.11	12.91	No	84	260	---	9.3	48	0.73	3.2	2.9
MW3	05/27/09	17.02	5.14	11.88	No	<50	2,400	---	9.1	220	12	79	260
MW4	09/12/94	17.34	6.80	10.54	No	---	5,200a	---	---	900	57	310	490
MW4	10/01/94	17.34	7.09	10.25	No	---	9,100a	---	---	1,200	66	360	380
MW4	01/13/95	17.34	4.66	12.68	No	---	25,000a	---	---	1,300	200	550	1,000
MW4	04/27/95	17.34	5.54	11.80	No	---	5,900	---	---	650	130	350	590
MW4	08/03/95	17.34	6.92	10.42	No	---	4,200	5,700	---	1,000	<12	170	140
MW4	10/17/95	17.34	7.50	9.84	No	---	6,900	1,700	---	1,300	30	360	380
MW4	01/24/96	17.34	5.81	11.53	No	---	6,300	830	---	1,900	46	290	330
MW4	04/24/96	17.34	5.44	11.90	No	---	5,000	1,600	---	1,800	<20	190	130
MW4	07/26/96	17.34	7.03	10.31	No	---	9,100	1,200	---	1,700	<25	340	280
MW4	10/30/96	17.34	7.57	9.77	No	---	5,300	1,500	---	1,100	35	420	300
MW4	01/31/97	17.34	4.22	13.12	No	---	6,500	40,000	---	1,200	28	490	130
MW4	04/10/97	17.34	---	---	---	---	---	---	---	---	---	---	---
MW4	07/10/97	17.34	7.56	9.78	No	---	10,000	11,000	---	1,100	120	470	720
MW4	10/08/97	17.34	---	---	---	---	---	---	---	---	---	---	---

**TABLE 1A
CUMULATIVE GROUNDWATER MONITORING AND SAMPLING DATA**

Former Exxon Service Station 70104
1725 Park Street
Alameda, California

Well ID	Sampling Date	TOC Elev. (feet)	DTW (feet)	GW Elev. (feet)	NAPL (feet)	TPHd (µg/L)	TPHg (µg/L)	MTBE 8021B (µg/L)	MTBE 8260B (µg/L)	B (µg/L)	T (µg/L)	E (µg/L)	X (µg/L)
MW4	01/28/98	17.34	3.70	13.64	No	---	1,700	---	4,900	450	6.8	220	73
MW4	04/14/98	17.34	3.81	13.53	---	---	---	---	---	---	---	---	---
MW4	07/30/98	17.34	5.96	11.38	No	---	2,900	2,800	---	680	<10	220	56
MW4	10/19/98	17.34	6.51	10.83	No	---	---	---	---	---	---	---	---
MW4	01/13/99	17.34	6.24	11.10	No	---	2,140	1,800	---	146	<10	60.9	16.2
MW4	04/28/99	17.34	4.80	12.54	---	---	---	---	---	---	---	---	---
MW4	07/09/99	17.34	6.04	11.30	No	---	1,300	1,310	---	322	<2.5	76.1	<2.5
MW4	10/25/99	17.34	6.51	10.83	No	---	---	---	---	---	---	---	---
MW4	01/21/00	17.34	5.75	11.59	No	---	2,200	1,000	---	410	3.70	40	14.4
MW4	04/14/00	17.34	4.39	12.95	No	---	---	---	---	---	---	---	---
MW4	06/16/00	17.34	Property transferred to Valero Refining Company.										
MW4	07/05/00	17.34	5.48	11.86	No	---	1,600	260	---	400	3.9	100	84
MW4	10/03/00	17.34	6.22	11.12	No	---	1,600	190	---	280	2	64	34.10
MW4	01/02/01	17.34	5.93	11.41	No	---	840	1,000	---	210	2.5	45	28.10
MW4	04/02/01	17.34	4.89	12.45	No	---	1,900	320	---	340	8.5	110	116
MW4	07/02/01	17.34	5.83	11.51	No	---	100	<2	---	3.9	<0.5	0.65	<0.5
MW4	10/15/01	17.34	6.36	10.98	No	---	930	360	---	140	7	24	10
MW4	Nov-01	17.29	Well surveyed in compliance with AB 2886 requirements.										
MW4	02/04/02	17.29	4.35	12.94	No	774	1,250	46.1	---	124	4.40	46.7	43.5
MW4	05/06/02	17.29	4.95	12.34	No	776	2,040	1,410	2,120	165	5.0	42.0	39.0
MW4	08/22/02	17.29	6.65	10.64	No	445	1,570	1,070	---	73.3	<0.5	9.9	6.8
MW4	11/08/02	17.29	5.60	11.69	No	680	2,340	1,200	---	169	4.3	34.9	23.3
MW4	02/07/03	17.29	4.97	12.32	No	429	2,250	672	---	125	24.9	60.0	109
MW4	05/02/03	17.29	4.92	12.37	No	631	2,450	1,230	---	82.9	2.8	26.4	24.7
MW4	08/14/03	17.29	6.35	10.94	No	444	1,160	286	---	97.0	2.8	14.6	7.4
MW4	11/14/03 e	17.29	---	---	---	---	---	---	---	---	---	---	---
MW4	03/01/04	17.29	3.65	13.64	No	571d	1,860	---	66.7	104	4.4	38.3	25.4
MW4	06/15/04	17.29	5.60	11.69	No	453d	632	35.0	---	63.8	1.6	7.3	5.9
MW4	09/13/04	17.29	6.23	11.06	No	444d	1,120	93.4	---	126	3.9	17.8	9.7
MW4	12/22/04	17.29	5.01	12.28	No	561d,f	1,600	31.2	---	105	3.9	24.8	13.3
MW4	03/24/05	17.29	3.64	13.65	No	756d	2,120	---	255	94.9	4.9	44.6	32.3
MW4	06/14/05	17.29	4.84	12.45	No	992d	1,760	---	20.3	105	5.2	25.2	15.1
MW4	09/12/05	17.29	7.41	9.88	No	351d	922	---	524	48.2	<0.50	1.63	1.70
MW4	12/13/05	17.29	6.18	11.11	No	728d	1,970	---	836h	144	4.63	15.9	8.64
MW4	03/13/06	17.29	4.71	12.58	No	590d	1,400	---	16	84	2.7	22	15
MW4	06/12/06	17.29	5.88	11.41	No	330d,f	840	---	11	83	3.0	9.8	11
MW4	09/08/06	17.29	6.48	10.81	No	320d	1,000	---	65	88	3.4	6.1	3.6
MW4	12/05/06	17.29	7.15	10.14	No	240d	680	---	78	43	<2.5	3.2	<2.5
MW4	03/12/07	17.29	4.62	12.67	No	390d	1,200	---	44	57	1.8	11	7.4
MW4	05/29/07	17.29	6.32	10.97	No	772d	531	---	8.65	51.6	2.39	6.59	4.63f
MW4	08/29/07	17.29	7.02	10.27	No	250d	470	---	6.8	40	<2.5	4.2	3.0

**TABLE 1A
CUMULATIVE GROUNDWATER MONITORING AND SAMPLING DATA**

Former Exxon Service Station 70104
1725 Park Street
Alameda, California

Well ID	Sampling Date	TOC Elev. (feet)	DTW (feet)	GW Elev. (feet)	NAPL (feet)	TPHd (µg/L)	TPHg (µg/L)	MTBE 8021B (µg/L)	MTBE 8260B (µg/L)	B (µg/L)	T (µg/L)	E (µg/L)	X (µg/L)
MW4	11/29/07	17.29	6.61	10.68	No	320d	680	---	5.1	46	<2.5	6.8	4.2
MW4	02/27/08	17.29	4.87	12.42	No	440d	1,000	---	3.4	56	<2.5	18	5.7
MW4	05/28/08	17.29	6.00	11.29	No	714d	627f	---	4.13f	61.6	<0.50	7.36	2.88
MW4	08/27/08	17.29	6.64	10.65	No	400	410	---	2.1	25	1.5	3.7	2.9
MW4	11/25/08	17.29	6.49	10.80	No	<50	970	---	<0.50	57	2.9	7.2	3.5
MW4	02/25/09	17.29	4.22	13.07	No	300	1,300	---	<2.5	50	4.4	23	11
MW4	05/27/09	17.29	5.40	11.89	No	<50	1,300	---	<2.5k	53	2.9	11	7.6
MW5	09/12/94	16.71	7.12	9.59	No	---	10,000a	---	---	2,300	17	320	230
MW5	10/01/94	16.71	7.06	9.65	Sheen	---	11,000a	---	---	2,300	19	220	200
MW5	01/13/95	16.71	4.85	11.86	Sheen	---	---	---	---	---	---	---	---
MW5	04/27/95	16.71	6.51	10.20	No	---	14,000	---	---	2,200	72	540	350
MW5	08/03/95	16.71	7.24	9.47	No	---	<10,000	39,000	---	2,100	<100	210	<100
MW5	10/17/95	16.71	7.80	8.91	No	---	13,000	38,000	---	1,800	14	240	170
MW5	01/24/96	16.71	6.66	10.05	No	---	10,000	20,000	---	2,400	79	340	190
MW5	04/24/96	16.71	5.80	10.91	No	---	13,000	33,000	---	3,700	120	520	170
MW5	07/26/96	16.71	7.67	9.04	No	---	15,000	140,000	---	3,400	53	280	76
MW5	10/30/96	16.71	7.77	8.94	No	---	10,000	110,000a	---	2,600	76	260	150
MW5	01/31/97	16.71	4.90	11.81	No	---	10,000	---	34,000	2,400	66	430	140
MW5	04/10/97	16.71	---	---	---	---	---	---	---	---	---	---	---
MW5	07/10/97	16.71	7.65	9.06	No	---	9,800	36,000	52,000	1,400	120	190	120
MW5	10/08/97	16.71	---	---	---	---	---	---	---	---	---	---	---
MW5	01/28/98	16.71	3.95	12.76	No	---	6,500	---	15,000	1,500	34	73	57
MW5	04/14/98	16.71	4.30	12.41	---	---	---	---	---	---	---	---	---
MW5	07/30/98	16.71	5.86	10.85	No	---	8,300	4,300	---	1,700	26	110	66
MW5	10/19/98	16.71	6.20	10.51	No	---	---	---	---	---	---	---	---
MW5	01/13/99	16.71	6.37	10.34	No	---	4,780	3,650	---	1,240	11.1	<10	<10
MW5	04/28/99	16.71	5.25	11.46	---	---	---	---	---	---	---	---	---
MW5	07/09/99	16.71	6.08	10.63	No	---	4,360	2,360	---	1,780	18.6	45	<5.0
MW5	10/25/99	16.71	6.46	10.25	No	---	---	---	---	---	---	---	---
MW5	01/21/00	16.71	5.79	10.92	No	---	2,600	3,100	---	720	4.7	25	11.3
MW5	04/14/00	16.71	4.57	12.14	No	---	---	---	---	---	---	---	---
MW5	06/16/00	16.71	Property transferred to Valero Refining Company.										
MW5	07/05/00	16.71	5.37	11.34	No	---	5,100	380	---	1,800	14	52	34
MW5	10/03/00	16.71	5.93	10.78	No	---	5,800	630	---	2,000	8.9	59	21
MW5	01/02/01	16.71	5.68	11.03	No	---	4,800	1,100	---	1,600	9.6	38	15
MW5	04/02/01	16.71	4.87	11.84	No	---	6,800	1,500	---	2,000	40	150	49
MW5	07/02/01	16.71	5.77	10.94	No	---	4,100	960	---	1,600	20	35	21
MW5	10/15/01	16.71	6.15	10.56	No	---	3,900	1,000	---	1,400	8.7	17	15.7
MW5	Nov-01	16.64	Well surveyed in compliance with AB 2886 requirements.										
MW5	02/04/02	16.64	4.69	11.95	No	976	4,380	620	---	1,440	38.0	84.0	50.0

**TABLE 1A
CUMULATIVE GROUNDWATER MONITORING AND SAMPLING DATA**

Former Exxon Service Station 70104
1725 Park Street
Alameda, California

Well ID	Sampling Date	TOC Elev. (feet)	DTW (feet)	GW Elev. (feet)	NAPL (feet)	TPHd (µg/L)	TPHg (µg/L)	MTBE 8021B (µg/L)	MTBE 8260B (µg/L)	B (µg/L)	T (µg/L)	E (µg/L)	X (µg/L)
MW5	05/06/02	16.64	5.00	11.64	No	1,360	3,810	764	1,220	1,110	20.0	26.0	26.0
MW5	08/22/02	16.64	6.98	9.66	No	695	3,190	545	---	823	9.0	11.0	31.0
MW5	11/08/02	16.64	5.31	11.33	No	645	3,360	746	---	1,050	9.4	11.1	17.8
MW5	02/07/03	16.64	5.75	10.89	No	689	3,550	400	---	1,100	25.0	65.0	29.0
MW5	05/02/03	16.64	5.34	11.30	No	934	4,070	439	---	818	16.9	31.9	28.6
MW5	08/14/03	16.64	6.37	10.27	No	988d	3,860	286	---	912	15.6	16.2	24.0
MW5	11/14/03	16.64	6.01	10.63	No	1,000d	3,450	198	---	841	15.0	14.8	17.4
MW5	03/01/04	16.64	4.04	12.60	No	711d	3,160	---	52.7	767	21.5	32.5	26.5
MW5	06/15/04	16.64	5.47	11.17	No	600d	4,520	52.0	---	930	14.5	17.5	24.5
MW5	09/13/04	16.64	5.99	10.65	No	686d	3,960	70.0	---	998	12.0	14.0	20.0
MW5	12/22/04	16.64	5.08	11.56	No	1,200d, f	3,110	52.6	---	1,000	58.5	91.9	90.3
MW5	03/24/05	16.64	3.85	12.79	No	1,240d	3,370	---	30.7	962	24.3	80.5	80.0
MW5	06/14/05	16.64	4.92	11.72	No	1,640d	4,210	---	28.1	976	25.0	51.0	64.0
MW5	09/12/05	16.64	7.86	8.78	No	780d	1,130	---	23.4	481	6.44	4.94	10.1
MW5	12/13/05	16.64	6.22	10.42	No	1,090d	2,210	---	18.7	698	8.07	9.59	8.15
MW5	03/13/06	16.64	5.52	11.12	No	770d	3,000	---	10	510	17	63	37
MW5	06/12/06	16.64	6.42	10.22	No	490d,f	2,200	---	6.8	290	14	22	40
MW5	09/08/06	16.64	6.07	10.57	No	600d	2,300	---	7.9	360	<10	<10	<10
MW5	12/05/06	16.64	7.71	8.93	No	710d	1,900	---	7.1	300	6.3	<5.0	5.7
MW5	03/12/07	16.64	4.95	11.69	No	630d	2,300	---	5.5	310	23	32	37
MW5	05/29/07	16.64	6.51	10.13	No	1,710d	2,880	---	5.24	438	18.3	19.3	45.6f
MW5	08/29/07	16.64	7.03	9.61	No	590d	2,000	---	6.3	220	<5.0	<5.0	9.0
MW5	11/29/07	16.64	6.67	9.97	No	480d	1,400	---	4.8	150	7.2	<5.0	6.9
MW5	02/27/08	16.64	5.22	11.42	No	830d	2,600	---	2.8	260	22	79	65
MW5	05/28/08	16.64	6.10	10.54	No	1,630d	2,040f	---	4.17f	249	10.7	16.8	29.0
MW5	08/27/08	16.64	6.32	10.32	No	1,100	2,300	---	<5.0	170	5.1	5.5	9.4
MW5	11/25/08	16.64	6.36	10.28	No	1,000	2,700	---	<5.0	220	8.7	10	12
MW5	02/25/09	16.64	4.25	12.39	No	950	3,100	---	<5.0k	290	22	68	50
MW5	05/27/09	16.64	5.26	11.38	No	1,600	3,100	---	<5.0k	47	2.5	7.7	8.3
MW6	09/12/94	17.56	6.88	10.68	No	---	1,500a	---	---	150	4.4	170	85
MW6	10/01/94	17.56	7.15	10.41	No	---	87a	---	---	120	<0.5	99	38
MW6	01/13/95	17.56	4.80	12.76	No	---	9,900a	---	---	710	220	780	1,100
MW6	04/27/95	17.56	6.14	11.42	No	---	3,900	---	---	340	40	460	320
MW6	08/03/95	17.56	6.83	10.73	No	---	1,100	65	---	89	<2.5	110	63
MW6	10/17/95	17.56	7.66	9.90	No	---	8,500	<5.0	---	410	74	850	110
MW6	01/24/96	17.56	5.86	11.70	No	---	31,000	<5.0	---	560	1,500	2,200	7,500
MW6	04/24/96	17.56	5.39	12.17	No	---	15,000	280	---	460	570	1,400	3,300
MW6	07/26/96	17.56	6.97	10.59	No	---	27,000	1,300	---	270	660	1,600	5,500
MW6	10/30/96	17.56	7.45	10.11	No	---	28,000	900	---	490	440	1,800	6,200
MW6	01/31/97	17.56	4.30	13.26	No	---	7,000	770	---	190	1,000	380	1,400

**TABLE 1A
CUMULATIVE GROUNDWATER MONITORING AND SAMPLING DATA**

Former Exxon Service Station 70104
1725 Park Street
Alameda, California

Well ID	Sampling Date	TOC Elev. (feet)	DTW (feet)	GW Elev. (feet)	NAPL (feet)	TPHd (µg/L)	TPHg (µg/L)	MTBE 8021B (µg/L)	MTBE 8260B (µg/L)	B (µg/L)	T (µg/L)	E (µg/L)	X (µg/L)
MW6	04/10/97	17.56	---	---	---	---	---	---	---	---	---	---	---
MW6	07/10/97	17.56	7.57	9.99	No	---	6,800	1,100	---	200	<50	300	860
MW6	10/08/97	17.56	7.48	10.08	No	---	51,000	580	---	870	7,300	2,600	12,000
MW6	01/28/98	17.56	3.74	13.82	No	---	15,000	---	2,400	650	2,300	900	2,700
MW6	04/14/98	17.56	3.92	13.64	No	---	25,000	---	2,100	850	3,300	1,200	4,300
MW6	07/30/98	17.56	6.09	11.47	No	---	5,900	910	---	270	65	500	630
MW6	10/19/98	17.56	6.56	11.00	No	---	---	---	---	---	---	---	---
MW6	01/13/99	17.56	6.35	11.21	No	---	3,150	422	---	204	107	297	304
MW6	04/28/99	17.56	4.89	12.67	No	---	15,300	---	436	1,270	980	1,100	3,320
MW6	07/09/99	17.56	6.07	11.49	No	---	1,140	439	---	121	9.95	160	4.69
MW6	10/25/99	17.56	6.11	11.45	No	---	2,200	3,400	---	590	<10	22	12.1
MW6	01/21/00	17.56	5.86	11.70	No	---	1,300	1,000	---	95	15	94	74
MW6	04/14/00	17.56	4.29	13.27	No	---	13,000	420	---	440	630	840	3,000
MW6	06/16/00	17.56	Property transferred to Valero Refining Company.										
MW6	07/05/00	17.56	5.39	12.17	No	---	5,800	830	---	1,000	13	550	798
MW6	10/03/00	17.56	6.14	11.42	No	---	490	3,800	---	61	<0.5	74	12
MW6	01/02/01	17.56	---	---	---	---	---	---	---	---	---	---	---
MW6	04/02/01	17.56	4.70	12.86	No	400	16,000	450	---	370	690	870	3,200
MW6	07/02/01	17.56	8.73	8.83	No	520	3,700	2,000	---	330	<5	160	32
MW6	10/15/01	17.56	6.24	11.32	No	1,100d	27,000	790	---	<12	<12	<12	<12
MW6	Nov-01	17.31	Well surveyed in compliance with AB 2886 requirements.										
MW6	02/04/02	17.31	4.24	13.07	No	168	14,800	545	---	425	120	1,480	4,030
MW6	05/06/02	17.31	4.83	12.48	No	1,540	8,580	380	522.0	988	24.0	866	1,080
MW6	08/22/02	17.31	6.49	10.82	No	10,400	4,050	716	---	44.5	11.5	460	270
MW6	11/08/02	17.31	5.49	11.82	No	822	5,640	1,150	---	49.3	42.7	586	858
MW6	02/07/03	17.31	4.89	12.42	No	1,590	14,300	572	---	134	393	1,000	3,720
MW6	05/02/03	17.31	4.68	12.63	No	1,550	8,880	1,560	---	92.0	167	672	1,530
MW6	08/14/03	17.31	6.15	11.16	No	666d	6,560	3,780	---	28.2	5.3	133	184
MW6	11/14/03	17.31	6.03	11.28	No	338d	5,370	4,520	---	26.4	3.1	44.9	45.0
MW6	03/01/04	17.31	3.60	13.71	No	1,630d	9,020	---	134	223	265	546	1,700
MW6	06/15/04	17.31	5.41	11.90	No	521d	6,920	3,470	---	300	10.0	97.0	173
MW6	09/13/04	17.31	6.06	11.25	No	122d	1,010	733	---	23	<5.0	11.0	<5.0
MW6	12/22/04	17.31	4.98	12.33	No	884d,f	4,050	75.4	---	101	169	208	980
MW6	03/24/05	17.31	3.59	13.72	No	1,310d	7,650	---	129	460	46.0	365	1,240
MW6	06/14/05	17.31	4.67	12.64	No	895d	1,940	---	153	195	7.6	26.3	18.3
MW6	09/12/05	17.31	7.12	10.19	No	182d	560	---	286	10.2	<0.50	<0.50	<0.50
MW6	12/13/05	17.31	5.98	11.33	No	212d	397	---	88.1	12.6	2.64	3.31	4.58
MW6	03/13/06	17.31	4.28	13.03	No	850d	4,300	---	110	440	40	130	900
MW6	06/12/06	17.31	5.40	11.91	No	350d,f	1,600	---	<5.0	120	<10	<10	31
MW6	09/08/06	17.31	6.34	10.97	No	66d	290	---	16	4.0	<0.50	<0.50	<0.50
MW6	12/05/06	17.31	6.74	10.57	No	75d	260	---	23	3.5	<0.50	<0.50	1.8

**TABLE 1A
CUMULATIVE GROUNDWATER MONITORING AND SAMPLING DATA**

Former Exxon Service Station 70104
1725 Park Street
Alameda, California

Well ID	Sampling Date	TOC Elev. (feet)	DTW (feet)	GW Elev. (feet)	NAPL (feet)	TPHd (µg/L)	TPHg (µg/L)	MTBE 8021B (µg/L)	MTBE 8260B (µg/L)	B (µg/L)	T (µg/L)	E (µg/L)	X (µg/L)
MW6	03/12/07	17.31	4.71	12.60	No	170d	890	---	11	12	2.8	12	88
MW6	05/29/07	17.31	5.96	11.35	No	169d	318	---	7.08	7.77	1.03	<0.50	0.98f
MW6	08/29/07	17.31	6.80	10.51	No	60d	170	---	<2.5	3.1	<0.50	<0.50	<0.50
MW6	11/29/07	17.31	6.46	10.85	No	<47	180	---	<2.5	<0.50	<0.50	<0.50	<0.50
MW6	02/27/08	17.31	4.44	12.87	No	1,200d	14,000	---	30	82	250	1,200	4,500
MW6	05/28/08	17.31	5.75	11.56	No	3,610d	19,800	---	6.45f	33.4	30.2	1,080	3,270f
MW6	08/27/08	17.31	6.50	10.81	No	2,600	7,600	---	<50	33	16	710	1,800
MW6	11/25/08	17.31	6.27	11.04	No	2,100	8,100	---	<50	74	100	2,100	2,600
MW6	02/25/09	17.31	4.09	13.22	No	1,900	7,700	---	<50	75	250	1,200	1,700
MW6	05/27/09	17.31	5.26	12.05	No	88	5,100	---	<10	4.2	1.6	43	72
MW7	09/12/94	17.12	6.43	10.69	No	---	6,000a	---	---	490	50	280	70
MW7	10/01/94	17.12	6.71	10.41	No	---	8,900a	---	---	940	670	310	160
MW7	01/13/95	17.12	4.29	12.83	No	---	20,000a	---	---	590	780	970	4,200
MW7	04/27/95	17.12	5.00	12.12	No	---	8,800	---	---	410	32	410	230
MW7	08/03/95	17.12	6.53	10.59	No	---	4,900	17,000	---	390	<50	290	<50
MW7	10/17/95	17.12	7.23	9.89	No	---	6,700	17,000	---	530	26	240	25
MW7	01/24/96	17.12	5.26	11.86	No	---	9,300	60,000	---	2,000	390	350	230
MW7	04/24/96	17.12	5.06	12.06	No	---	9,000	360,000	---	2,400	850	150	130
MW7	07/26/96	17.12	6.62	10.50	No	---	4,800	86,000	---	530	25	60	46
MW7	10/30/96	17.12	7.09	10.03	No	---	3,400	28,000	---	180	9.8	58	38
MW7	01/31/97	17.12	3.65	13.47	No	---	3,800	45,000	---	300	18	48	37
MW7	04/10/97	17.12	---	---	---	---	---	---	---	---	---	---	---
MW7	07/10/97	17.12	7.44	9.68	No	---	3,500	18,000	---	70	<25	<25	<25
MW7	10/08/97	17.12	---	---	---	---	---	---	---	---	---	---	---
MW7	01/28/98	17.12	3.06	14.06	No	---	100	---	250	1.0	<0.5	<0.5	0.67
MW7	04/14/98	17.12	3.10	14.02	---	---	---	---	---	---	---	---	---
MW7	07/30/98	17.12	5.78	11.34	No	---	100	670	---	1.4	<0.5	<0.5	<0.5
MW7	10/19/98	17.12	6.25	10.87	No	---	---	---	---	---	---	---	---
MW7	01/13/99	17.12	5.98	11.14	No	---	273	530	---	<2.5	<2.5	<2.5	<2.5
MW7	04/28/99	17.12	4.32	12.80	---	---	---	---	---	---	---	---	---
MW7	07/09/99	17.12	5.67	11.45	No	---	139	860	---	3.79	7.10	1.19	8.65
MW7	10/25/99	17.12	6.23	10.89	No	---	<50	<1.0	---	<1.0	<1.0	<1.0	<1.0
MW7	01/21/00	17.12	5.41	11.71	No	---	410	500	---	10	2.5	<1.0	2.5
MW7	04/14/00	17.12	3.84	13.28	No	---	---	---	---	---	---	---	---
MW7	06/16/00	17.12	Property transferred to Valero Refining Company.										
MW7	07/05/00	17.12	5.05	12.07	No	---	140	480	---	<0.5	<0.5	<0.5	0.56
MW7	10/03/00	17.12	5.88	11.24	No	---	370	1,900	---	<0.5	0.62	<0.5	3.20
MW7	01/02/01	17.12	5.52	11.60	No	---	120	1,500	---	2.2	<0.5	<0.5	<0.5
MW7	04/02/01	17.12	4.26	12.86	No	---	120	1,500	---	0.91	<0.5	<0.5	<0.5
MW7	07/02/01	17.12	5.42	11.70	No	---	110	740	---	4.1	<0.5	0.75	0.84

**TABLE 1A
CUMULATIVE GROUNDWATER MONITORING AND SAMPLING DATA**

Former Exxon Service Station 70104
1725 Park Street
Alameda, California

Well ID	Sampling Date	TOC Elev. (feet)	DTW (feet)	GW Elev. (feet)	NAPL (feet)	TPHd (µg/L)	TPHg (µg/L)	MTBE 8021B (µg/L)	MTBE 8260B (µg/L)	B (µg/L)	T (µg/L)	E (µg/L)	X (µg/L)
MW7	10/15/01	17.12	7.50	9.62	No	---	170	740	---	<0.5	<0.5	<0.5	0.69
MW7	Nov-01	17.06	Well surveyed in compliance with AB 2886 requirements.										
MW7	02/04/02	17.06	3.81	13.25	No	88.0	928	610	---	<0.50	<0.50	<0.50	<0.50
MW7	05/06/02	17.06	4.51	12.55	No	72	591	565	712.0	2.4	<0.5	2.5	4.1
MW7	08/22/02	17.06	6.25	10.81	No	<50	586	482	---	2.5	<2.5	<2.5	3.0
MW7	11/08/02	17.06	5.03	12.03	No	<50	463	319	---	1.7	<0.5	<0.5	0.6
MW7	02/07/03	17.06	4.57	12.49	No	<50	344	440	---	0.9	0.9	0.8	3.5
MW7	05/02/03	17.06	4.39	12.67	No	<50	323	307	---	0.80	<0.5	<0.5	<0.5
MW7	08/14/03	17.06	5.96	11.10	No	<50	197	45.5	---	2.00	<0.5	<0.5	1.0
MW7	11/14/03	17.06	6.04	11.02	No	<50	146	48.0	---	1.50	<0.5	0.6	1.7
MW7	03/01/04	17.06	2.91	14.15	No	138d	<50.0	---	8.10	<0.50	<0.5	<0.5	<0.5
MW7	06/10/04	17.06	5.18	11.88	No	293d	9,830	26.0	---	501	2,280	205	1,920
MW7	09/13/04	17.06	5.85	11.21	No	292d	1,350	82.5	---	64.5	<2.5	6.5	225
MW7	12/22/04	17.06	4.51	12.55	No	173d,f	<50.0	12.2	---	0.50	<0.5	0.8	<0.5
MW7	03/24/05	17.06	2.92	14.14	No	124d	<50.0	---	2.10	<0.50	<0.5	<0.5	<0.5
MW7	06/14/05	17.06	4.31	12.75	No	89d	<50.0	---	4.50	<0.50	<0.5	<0.5	<0.5
MW7	09/12/05	17.06	6.92	10.14	No	68.0d	<50.0	---	10.8	<0.50	<0.50	<0.50	<0.50
MW7	12/13/05	17.06	5.71	11.35	No	249d	<50.0	---	5.93	<0.50	<0.50	<0.50	<0.50
MW7	03/13/06	17.06	3.66	13.40	No	<47	<50	---	3.0	<0.50	<0.50	<0.50	<0.50
MW7	06/12/06	17.06	5.22	11.84	No	<47	<50	---	2.3	<0.50	<0.50	<0.50	<0.50
MW7	09/08/06	17.06	6.27	10.79	No	<47	<50	---	6.1	<0.50	<0.50	<0.50	<0.50
MW7	12/05/06	17.06	6.61	10.45	No	<47	<50	---	4.1	<0.50	<0.50	<0.50	<0.50
MW7	03/12/07	17.06	4.41	12.65	No	<47	<50	---	5.2	<0.50	<0.50	<0.50	<0.50
MW7	05/29/07	17.06	5.72	11.34	No	178d	<50.0	---	1.84	<0.50	<0.50	<0.50	<0.50
MW7	08/29/07	17.06	6.64	10.42	No	<47	<50	---	3.8	<0.50	<0.50	<0.50	<0.50
MW7	11/29/07	17.06	6.26	10.80	No	<47	<50	---	3.3	<0.50	<0.50	<0.50	<0.50
MW7	02/27/08	17.06	4.11	12.95	No	<47	57	---	3.7	2.1	1.0	5.4	19
MW7	05/28/08	17.06	5.53	11.53	No	111d	<50.0	---	1.83f	<0.50	<0.50	<0.50	<0.50
MW7	08/27/08	17.06	6.25	10.81	No	<50	<50	---	1.6	<0.50	<0.50	<0.50	<1.0
MW7	11/25/08	17.06	6.02	11.04	No	<50	<50	---	2.1	<0.50	<0.50	<0.50	<1.0
MW7	02/25/09	17.06	3.50	13.56	No	<50	<50	---	0.97	<0.50	<0.50	<0.50	<1.0
MW7	05/27/09	17.06	5.01	12.05	No	<50	<50	---	1.8	<0.50	<0.50	<0.50	<1.0
MW8	09/12/94	16.33	6.42	9.91	No	---	<50a	---	---	<0.5	<0.5	<0.5	<0.5
MW8	10/01/94	16.33	6.62	9.71	No	---	<50a	---	---	<0.5	<0.5	<0.5	<0.5
MW8	01/13/95	16.33	5.25	11.08	No	---	<50a	---	---	<0.5	<0.5	<0.5	<0.5
MW8	04/27/95	16.33	6.00	10.33	No	---	<50	---	---	<0.5	<0.5	<0.5	<0.5
MW8	08/03/95	16.33	6.28	10.05	No	---	<50	<2.5	---	<0.5	<0.5	<0.5	<0.5
MW8	10/17/95	16.33	6.93	9.40	No	---	<50	<5.0	---	<0.5	<0.5	<0.5	<0.5
MW8	01/24/96	16.33	5.71	10.62	No	---	<50	<5.0	---	<0.5	<0.5	<0.5	<0.5
MW8	04/24/96	16.33	5.52	10.81	No	---	<50	<5.0	---	<0.5	<0.5	<0.5	<0.5

**TABLE 1A
CUMULATIVE GROUNDWATER MONITORING AND SAMPLING DATA**

Former Exxon Service Station 70104
1725 Park Street
Alameda, California

Well ID	Sampling Date	TOC Elev. (feet)	DTW (feet)	GW Elev. (feet)	NAPL (feet)	TPHd (µg/L)	TPHg (µg/L)	MTBE 8021B (µg/L)	MTBE 8260B (µg/L)	B (µg/L)	T (µg/L)	E (µg/L)	X (µg/L)
MW8	07/26/96	16.33	6.27	10.06	No	---	<50	230	---	<0.5	<0.5	<0.5	<0.5
MW8	10/30/96	16.33	6.69	9.64	No	---	<50	<5.0	---	<0.5	<0.5	<0.5	<0.5
MW8	01/31/97	16.33	5.18	11.15	No	---	---	---	---	---	---	---	---
MW8	04/10/97	16.33	---	---	---	---	---	---	---	---	---	---	---
MW8	07/10/97	16.33	---	---	---	---	---	---	---	---	---	---	---
MW8	10/08/97	16.33	---	---	---	---	---	---	---	---	---	---	---
MW8	01/28/98	16.33	5.11	11.22	No	---	---	---	---	---	---	---	---
MW8	04/14/98	16.33	5.02	11.31	No	---	<50	<2.5	---	<0.5	<0.5	<0.5	<0.5
MW8	07/30/98	16.33	5.84	10.49	No	---	<50	6.6	---	<0.5	<0.5	<0.5	<0.5
MW8	10/19/98	16.33	6.07	10.26	No	---	<50	<2.5	---	<0.5	<0.5	<0.5	<0.5
MW8	01/13/99	16.33	5.59	10.74	No	---	<50	<2.0	---	<0.5	<0.5	<0.5	<0.5
MW8	04/28/99	16.33	5.38	10.95	No	---	<50	---	<0.5	<0.5	<0.5	<0.5	<0.5
MW8	07/09/99	16.33	5.71	10.62	No	---	<50	3.01	<0.5	<0.5	<0.5	<0.5	<0.5
MW8	10/25/99	16.33	6.15	10.18	No	---	<50	<1.0	---	<1.0	<1.0	<1.0	<1.0
MW8	01/21/00	16.33	6.51	9.82	No	---	<50	<1.0	---	<1.0	<1.0	<1.0	<1.0
MW8	04/14/00	16.33	5.54	10.79	Brown	---	<50	<1	---	<1	<1	<1	<1
MW8	06/16/00	16.33	Property transferred to Valero Refining Company.										
MW8	07/05/00	16.33	5.67	10.66	No	---	<50	<2	---	<0.5	<0.5	<0.5	<0.5
MW8	10/03/00	16.33	6.02	10.31	No	---	<50	<2	---	<0.5	<0.5	<0.5	<0.5
MW8	01/02/01	16.33	5.95	10.38	No	140c	<50	<2	---	<0.5	<0.5	<0.5	<0.5
MW8	04/02/01	16.33	---	---	---	---	---	---	---	---	---	---	---
MW8	07/02/01	16.33	5.76	10.57	No	<50	<50	<2	---	<0.5	<0.5	<0.5	<0.5
MW8	10/15/01	16.33	6.19	10.14	No	<50	<50	<2	---	<0.5	<0.5	<0.5	<0.5
MW8	Nov-01	16.24	Well surveyed in compliance with AB 2886 requirements.										
MW8	02/04/02 e	16.24	---	---	---	---	---	---	---	---	---	---	---
MW8	05/06/02	16.24	5.31	10.93	No	<50	<50.0	0.5	<0.50	<0.5	<0.5	<0.5	<0.5
MW8	08/22/02	16.24	6.07	10.17	No	<50	<50.0	<0.5	---	<0.5	<0.5	<0.5	<0.5
MW8	11/08/02	16.24	5.91	10.33	No	<50	<50.0	<0.5	---	<0.5	<0.5	<0.5	<0.5
MW8	02/07/03	16.24	5.34	10.90	No	<50	<50.0	<0.5	---	<0.5	<0.5	<0.5	<0.5
MW8	05/02/03	16.24	5.27	10.97	No	<50	<50.0	<0.5	---	<0.50	<0.5	<0.5	<0.5
MW8	08/14/03	16.24	5.60	10.64	No	<50	<50.0	<0.5	---	<0.50	<0.5	<0.5	<0.5
MW8	11/14/03	16.24	6.01	10.23	No	55d	<50.0	<0.5	---	<0.50	<0.5	0.7	1.7
MW8	03/01/04	16.24	5.16	11.08	No	<50	<50.0	---	<0.50	<0.50	<0.5	<0.5	<0.5
MW8	06/15/04	16.24	5.36	10.88	No	<50	<50.0	<0.50	---	<0.50	<0.5	<0.5	<0.5
MW8	09/13/04	16.24	5.81	10.43	No	<50	<50.0	0.9	---	<0.50	<0.5	<0.5	0.7
MW8	12/22/04	16.24	5.42	10.82	No	<50	<50.0	<0.50	---	0.50	<0.5	0.5	<0.5
MW8	03/24/05	16.24	5.03	11.21	No	<50	<50.0	---	<0.50	<0.50	<0.5	<0.5	<0.5
MW8	06/14/05	16.24	5.09	11.15	No	<50	<50.0	---	<0.50	<0.50	<0.5	<0.5	<0.5
MW8	09/12/05	16.24	6.24	10.00	No	69.5d	<50.0	---	<0.500	<0.50	<0.50	<0.50	<0.50
MW8	12/13/05	16.24	5.69	10.55	No	<50.0	<50.0	---	<0.500	<0.50	<0.50	<0.50	<0.50
MW8	03/13/06	16.24	5.28	10.96	No	<47	<50	---	<0.50	0.69	<0.50	<0.50	<0.50

**TABLE 1A
CUMULATIVE GROUNDWATER MONITORING AND SAMPLING DATA**

Former Exxon Service Station 70104
1725 Park Street
Alameda, California

Well ID	Sampling Date	TOC Elev. (feet)	DTW (feet)	GW Elev. (feet)	NAPL (feet)	TPHd (µg/L)	TPHg (µg/L)	MTBE 8021B (µg/L)	MTBE 8260B (µg/L)	B (µg/L)	T (µg/L)	E (µg/L)	X (µg/L)
MW8	06/12/06	16.24	4.58	11.66	No	<47	<50	---	<0.50	<0.50	<0.50	<0.50	<0.50
MW8	09/08/06	16.24	4.58	11.66	No	<50	<50	---	<0.50	<0.50	<0.50	<0.50	<0.50
MW8	12/05/06	16.24	6.02	10.22	No	<47	<50	---	<0.50	<0.50	<0.50	<0.50	<0.50
MW8	03/12/07	16.24	5.31	10.93	No	<47	<50	---	<0.50	<0.50	<0.50	<0.50	<0.50
MW8	05/29/07	16.24	5.71	10.53	No	<47.6	<50.0	---	<0.500	<0.50	<0.50	<0.50	<0.50
MW8	08/29/07	16.24	6.16	10.08	No	<47	<50	---	<0.50	<0.50	<0.50	<0.50	<0.50
MW8	11/29/07	16.24	6.08	10.16	No	<47	<50	---	<0.50	<0.50	<0.50	<0.50	<0.50
MW8	02/27/08	16.24	5.25	10.99	No	<47	<50	---	<0.50	<0.50	<0.50	<0.50	<0.50
MW8	05/28/08	16.24	5.83	10.41	No	<47.2	<50.0	---	<0.500	<0.50	<0.50	<0.50	<0.50
MW8	08/27/08	16.24	6.14	10.10	No	<50	<50	---	<0.50	<0.50	<0.50	<0.50	<1.0
MW8	11/25/08	16.24	6.07	10.17	No	<50	<50	---	<0.50	<0.50	<0.50	<0.50	<1.0
MW8	02/25/09	16.24	5.26	10.98	No	<50	<50	---	<0.50	0.53 l	0.77	<0.50	<1.0
MW8	05/27/09	16.24	5.12	11.12	No	<50	<50	---	<0.50	<0.50	<0.50	<0.50	<1.0
MW9	09/12/94	15.62	6.84	8.78	No	---	<50a	---	---	<0.5	<0.5	<0.5	<0.5
MW9	10/01/94	15.62	6.97	8.65	No	---	<50a	---	---	<0.5	<0.5	<0.5	<0.5
MW9	01/13/95	15.62	6.18	9.44	No	---	<50a	---	---	<0.5	<0.5	<0.5	<0.5
MW9	04/27/95	15.62	6.58	9.04	No	---	<50	---	---	<0.5	<0.5	<0.5	<0.5
MW9	08/03/95	15.62	6.72	8.90	No	---	<50	<2.5	---	<0.5	<0.5	<0.5	<0.5
MW9	10/17/95	15.62	7.09	8.53	No	---	<50	<5.0	---	<0.5	<0.5	<0.5	<0.5
MW9	01/24/96	15.62	6.46	9.16	No	---	<50	<5.0	---	<0.5	<0.5	<0.5	<0.5
MW9	04/24/96	15.62	6.43	9.19	No	---	<50	<5.0	---	<0.5	<0.5	<0.5	<0.5
MW9	07/26/96	15.62	6.80	8.82	No	---	<50	<5.0	---	<0.5	<0.5	<0.5	<0.5
MW9	10/30/96	15.62	6.94	8.68	No	---	<50	<5.0	---	<0.5	<0.5	<0.5	<0.5
MW9	01/31/97	15.62	6.10	9.52	No	---	---	---	---	---	---	---	---
MW9	04/10/97	15.62	---	---	---	---	---	---	---	---	---	---	---
MW9	07/10/97	15.62	---	---	---	---	---	---	---	---	---	---	---
MW9	10/08/97	15.62	---	---	---	---	---	---	---	---	---	---	---
MW9	01/28/98	15.62	5.66	9.96	No	---	---	---	---	---	---	---	---
MW9	04/14/98	15.62	---	---	---	---	---	---	---	---	---	---	---
MW9	07/30/98	15.62	6.17	9.45	No	---	---	---	---	---	---	---	---
MW9	10/19/98	15.62	6.40	9.22	No	---	---	---	---	---	---	---	---
MW9	01/13/99	15.62	6.28	9.34	No	---	---	---	---	---	---	---	---
MW9	04/28/99	15.62	5.87	9.75	No	---	<50	---	<0.5	<0.5	<0.5	<0.5	<0.5
MW9	07/09/99	15.62	6.24	9.38	No	---	<50	<2.0	---	<0.5	<0.5	<0.5	<0.5
MW9	10/25/99	15.62	6.67	8.95	No	---	<50	<1.0	---	<1.0	<1.0	<1.0	<1.0
MW9	01/21/00	15.62	6.93	8.69	No	---	<50	<1.0	---	<1.0	<1.0	<1.0	<1.0
MW9	04/14/00	15.62	6.05	9.57	Turbid	---	<50	<1	---	<1	<1	<1	<1
MW9	06/16/00	15.62	Property transferred to Valero Refining Company.				---	---	---	---	---	---	---
MW9	07/05/00	15.62	6.34	9.28	No	---	<50	<2	---	<0.5	<0.5	<0.5	<0.5
MW9	10/03/00	15.62	6.52	9.10	No	---	<50	<2	---	<0.5	<0.5	<0.5	<0.5

TABLE 1A
CUMULATIVE GROUNDWATER MONITORING AND SAMPLING DATA

Former Exxon Service Station 70104
1725 Park Street
Alameda, California

Well ID	Sampling Date	TOC Elev. (feet)	DTW (feet)	GW Elev. (feet)	NAPL (feet)	TPHd (µg/L)	TPHg (µg/L)	MTBE 8021B (µg/L)	MTBE 8260B (µg/L)	B (µg/L)	T (µg/L)	E (µg/L)	X (µg/L)
MW9	01/02/01	15.62	6.53	9.09	No	---	<50	<2	---	<0.5	<0.5	<0.5	<0.5
MW9	04/02/01	15.62	6.21	9.41	No	---	<50	<2	---	<0.5	<0.5	0.57	0.73
MW9	07/02/01	15.62	6.40	9.22	No	---	<50	<2	---	<0.5	<0.5	<0.5	<0.5
MW9	10/15/01	15.62	6.65	8.97	No	---	<50	<2	---	<0.5	<0.5	<0.5	<0.5
MW9	Nov-01	15.56	Well surveyed in compliance with AB 2886 requirements.										
MW9	02/04/02	15.56	4.77	10.79	No	<50.0	<50.0	0.50	---	<0.50	<0.50	<0.50	<0.50
MW9	05/06/02	15.56	6.29	9.27	No	<50	<50.0	<0.5	<0.50	<0.5	<0.5	<0.5	<0.5
MW9	08/22/02	15.56	6.70	8.86	No	<50	<50.0	<0.5	---	<0.5	<0.5	<0.5	<0.5
MW9	11/08/02	15.56	6.55	9.01	No	<50	<50.0	<0.5	---	<0.5	<0.5	<0.5	<0.5
MW9	02/07/03	15.56	6.35	9.21	No	<50	<50.0	<0.5	---	<0.5	<0.5	<0.5	<0.5
MW9	05/02/03	15.56	6.16	9.40	No	91	<50.0	<0.5	---	<0.50	<0.5	<0.5	<0.5
MW9	08/14/03	15.56	6.54	9.02	No	<50	<50.0	<0.5	---	<0.50	<0.5	<0.5	<0.5
MW9	11/14/03	15.56	6.60	8.96	No	<50	<50.0	<0.5	---	<0.50	<0.5	<0.5	<0.5
MW9	03/01/04	15.56	5.89	9.67	No	<50	<50.0	---	<0.50	<0.50	<0.5	<0.5	<0.5
MW9	06/15/04	15.56	6.43	9.13	No	<50	<50.0	<0.50	---	<0.50	<0.5	<0.5	<0.5
MW9	09/13/04	15.56	6.58	8.98	No	<50	<50.0	<0.50	---	<0.50	<0.5	<0.5	<0.5
MW9	12/22/04	15.56	6.28	9.28	No	<50	<50.0	<0.50	---	<0.50	<0.5	<0.5	<0.5
MW9	03/24/05	15.56	5.61	9.95	No	<50	<50.0	---	<0.50	<0.50	<0.5	<0.5	<0.5
MW9	06/14/05	15.56	6.06	9.50	No	<50	<50.0	---	<0.50	<0.50	<0.5	<0.5	<0.5
MW9	09/12/05	15.56	6.65	8.91	No	<50.0	<50.0	---	<0.500	<0.50	<0.50	<0.50	<0.50
MW9	12/13/05	15.56	6.32	9.24	No	<50.0	<50.0	---	<0.500	<0.50	<0.50	<0.50	<0.50
MW9	03/13/06	15.56	5.90	9.66	No	<47	<50	---	<0.50	<0.50	<0.50	<0.50	<0.50
MW9	06/12/06	15.56	5.96	9.60	No	<47	<50	---	<0.50	<0.50	<0.50	<0.50	<0.50
MW9	09/08/06	15.56	6.43	9.13	No	<47	<50	---	<0.50	<0.50	<0.50	<0.50	<0.50
MW9	12/05/06	15.56	6.45	9.11	No	<47	<50	---	<0.50	<0.50	<0.50	<0.50	<0.50
MW9	03/12/07	15.56	5.98	9.58	No	<47	<50	---	<0.50	<0.50	<0.50	<0.50	<0.50
MW9	05/29/07	15.56	6.32	9.24	No	<47.6	<50.0	---	<0.500	<0.50	<0.50	<0.50	<0.50
MW9	08/29/07	15.56	6.51	9.05	No	<47	<50	---	<0.50	<0.50	<0.50	<0.50	<0.50
MW9	11/29/07	15.56	6.49	9.07	No	<47	<50	---	<0.50	<0.50	<0.50	<0.50	<0.50
MW9	02/27/08	15.56	5.90	9.66	No	<47	<50	---	<0.50	<0.50	<0.50	0.56	2.2
MW9	05/28/08	15.56	6.40	9.16	No	63.5d	<50.0	---	0.800f	<0.50	<0.50	<0.50	<0.50
MW9	08/27/08	15.56	6.57	8.99	No	<50	<50	---	<0.50	<0.50	<0.50	<0.50	<1.0
MW9	11/25/08	15.56	6.57	8.99	No	<50	<50	---	<0.50	<0.50	<0.50	<0.50	<1.0
MW9	02/25/09	15.56	5.69	9.87	No	<50	<50	---	<0.50	<0.50	<0.50	<0.50	<1.0
MW9	05/27/09	15.56	6.21	9.35	No	<50	<50	---	0.67	<0.50	<0.50	<0.50	<1.0
MW10	09/12/94	16.79	7.04	9.75	No	---	71a	---	---	<0.5	<0.5	1.6	<0.5
MW10	10/01/94	16.79	7.30	9.49	No	---	330a	---	---	1.1	<0.5	2.8	0.73
MW10	01/13/95	16.79	6.04	10.75	No	---	90a	---	---	<0.5	<0.5	<0.5	<0.5
MW10	04/27/95	16.79	6.66	10.13	No	---	140	---	---	<0.5	<0.5	5.4	1.3
MW10	08/03/95	16.79	7.23	9.56	No	---	150	<2.5	---	<0.5	<0.5	<0.5	<0.5

**TABLE 1A
CUMULATIVE GROUNDWATER MONITORING AND SAMPLING DATA**

Former Exxon Service Station 70104
1725 Park Street
Alameda, California

Well ID	Sampling Date	TOC Elev. (feet)	DTW (feet)	GW Elev. (feet)	NAPL (feet)	TPHd (µg/L)	TPHg (µg/L)	MTBE 8021B (µg/L)	MTBE 8260B (µg/L)	B (µg/L)	T (µg/L)	E (µg/L)	X (µg/L)
MW10	10/17/95	16.79	7.93	8.86	No	---	<50	95	---	<0.5	<0.5	<0.5	<0.5
MW10	01/24/96	16.79	6.43	10.36	No	---	760	24	---	1.6	0.52	62	28
MW10	04/24/96	16.79	6.42	10.37	No	---	110	6.8	---	<0.5	<0.5	7.1	<0.5
MW10	07/26/96	16.79	7.47	9.32	No	---	140	<5.0	---	<0.5	<0.5	12	0.86
MW10	10/30/96	16.79	7.88	8.91	No	---	<50	5.6	---	<0.5	<0.5	<0.5	<0.5
MW10	01/31/97	16.79	5.88	10.91	No	---	<50	10	---	<0.5	<0.5	<0.5	<0.5
MW10	04/10/97	16.79	---	---	---	---	---	---	---	---	---	---	---
MW10	07/10/97	16.79	7.32	9.47	No	---	<50	<2.5	---	<0.5	<0.5	<0.5	<0.5
MW10	10/08/97	16.79	---	---	---	---	---	---	---	---	---	---	---
MW10	12/12/97	Well destroyed.											
MW11	10/17/95	18.04	7.72	10.32	No	---	34,000	890	---	3,800	150	950	4,500
MW11	01/24/96	18.04	5.97	12.07	No	---	44,000	<500	---	3,800	1,200	2,100	9,800
MW11	04/24/96	18.04	5.84	12.20	No	---	34,000	720	---	2,900	1,400	1,700	8,300
MW11	07/26/96	18.04	6.98	11.06	No	---	39,000	800	---	4,600	4,200	950	9,500
MW11	10/30/96	18.04	7.54	10.50	No	---	53,000	990	---	4,200	3,600	2,100	9,600
MW11	01/31/97	18.04	5.00	13.04	No	---	23,000	---	310	170	2,500	940	4,300
MW11	04/10/97	18.04	---	---	No	---	29,000	200	---	1,200	440	970	6,400
MW11	07/10/97	18.04	7.30	10.74	No	---	42,000	690	---	1,700	870	1,900	12,000
MW11	10/08/97	18.04	7.62	10.42	No	---	42,000	1,100	---	1,700	2,500	1,400	9,900
MW11	01/28/98	18.04	4.77	13.27	No	---	35,000	---	6,800	2,400	3,500	1,700	7,900
MW11	04/14/98	18.04	4.68	13.36	No	---	15,000	---	1,200	1,700	250	500	2,000
MW11	07/30/98	18.04	6.33	11.71	No	---	24,000	1,700	---	1,600	560	1,000	4,300
MW11	10/19/98	18.04	6.65	11.39	No	---	29,000	1,700	---	1,200	2,500	920	4,900
MW11	01/13/99	18.04	6.42	11.62	No	---	50,900	1,920	---	2,210	6,440	2,030	10,600
MW11	04/28/99	18.04	5.30	12.74	No	---	59,400	---	2,390	3,790	4,260	1,790	2,970
MW11	07/09/99	18.04	6.22	11.82	No	---	51,500	4,630	---	5,890	5,340	2,370	12,700
MW11	10/25/99	18.04	6.77	11.27	No	---	51,000	1,700	---	3,900	5,800	2,300	12,300
MW11	01/21/00	18.04	6.47	11.57	No	---	56,000	1,100	---	2,300	4,600	2,100	11,600
MW11	04/14/00	18.04	5.09	12.95	No	---	42,000	2,100	---	3,000	2,600	1,600	8,000
MW11	06/16/00	18.04	Property transferred to Valero Refining Company.										
MW11	07/05/00	18.04	5.93	12.11	No	---	32,000	3,900	---	3,000	2,700	1,300	6,200
MW11	10/03/00	18.04	6.57	11.47	No	---	46,000	4,300	---	2,900	3,600	1,600	7,900
MW11	01/02/01	18.04	6.46	11.58	No	1,600c	44,000	4,200	---	3,900	3,600	1,300	6,500
MW11	04/02/01	18.04	5.44	12.60	No	2,000	39,000	3,100	---	2,600	3,600	1,500	7,500
MW11	07/02/01	18.04	9.10	8.94	No	2,300	45,000	3,000	---	2,000	2,000	1,400	7,200
MW11	10/15/01	18.04	8.10	9.94	No	1,400d	55,000	2,600	---	5,100	5,700	1,900	9,100
MW11	Nov-01	17.98	Well surveyed in compliance with AB 2886 requirements.										
MW11	02/04/02	17.98	5.14	12.84	No	2,430	37,800	1,910	---	3,340	3,550	1,450	6,480
MW11	05/06/02	17.98	5.51	12.47	No	3,000	27,200	1,350	1,984	1,420	1,580	1,110	4,960
MW11	08/22/02	17.98	6.63	11.35	No	5,660	28,100	2,240	---	2,020	1,520	1,120	5,360

**TABLE 1A
CUMULATIVE GROUNDWATER MONITORING AND SAMPLING DATA**

Former Exxon Service Station 70104
1725 Park Street
Alameda, California

Well ID	Sampling Date	TOC Elev. (feet)	DTW (feet)	GW Elev. (feet)	NAPL (feet)	TPHd (µg/L)	TPHg (µg/L)	MTBE 8021B (µg/L)	MTBE 8260B (µg/L)	B (µg/L)	T (µg/L)	E (µg/L)	X (µg/L)
MW11	11/08/02	17.98	5.34	12.64	No	3,680	26,000	246	---	1,170	2,130	1,020	5,390
MW11	02/07/03	17.98	5.42	12.56	No	4,360	50,000	1,400	---	3,660	4,500	1,920	8,600
MW11	05/02/03	17.98	5.17	12.81	No	2,330	41,200	1,080	---	1,980	1,860	1,450	7,100
MW11	08/14/03	17.98	6.42	11.56	No	5,480d	46,700	1,140	---	3,360	2,150	1,870	7,640
MW11	11/14/03	17.98	6.39	11.59	No	3,530d	45,800	240	---	2,070	3,300	2,010	8,680
MW11	03/01/04	17.98	4.58	13.40	No	2,030d	5,540	---	61.7	246	350	205	904
MW11	06/15/04	17.98	5.83	12.15	No	2,090d	48,100	580	---	2,040	2,160	2,430	10,100
MW11	09/13/04	17.98	6.41	11.57	No	3,220d	40,300	250	---	2,210	1,290	1,930	8,350
MW11	12/22/04	17.98	5.49	12.49	No	1,770d,f	20,800	105	---	1,060	1,540	750	3,220
MW11	03/24/05	17.98	4.22	13.76	No	643d	4,030	---	800	64.0	52.1	114	532
MW11	06/14/05	17.98	5.42	12.56	No	3,830d	36,900	---	351	1,330	2,760	1,520	6,870
MW11	09/12/05	17.98	7.18	10.80	No	4,020d	16,600	---	245	1,050	795	1,090	4,190
MW11	12/13/05	17.98	6.52	11.46	No	2,670d	28,700	---	97.0	942	527	1,320	6,070
MW11	03/13/06	17.98	4.95	13.03	No	1,100d	5,000	---	<0.50	17	<10	130	730
MW11	06/12/06	17.98	5.77	12.21	No	1,300d,f	28,000	---	21	920	1,500	1,400	5,100
MW11	09/08/06	17.98	6.70	11.28	No	2,300d	21,000	---	25	990	790	1,000	3,700
MW11	12/05/06	17.98	6.93	11.05	No	2,900d	21,000	---	37	700	510	1,000	4,500
MW11	03/12/07	17.98	5.40	12.58	No	1,200d	13,000	---	28	420	280	580	2,700
MW11	05/29/07	17.98	6.40	11.58	No	2,850d	26,400	---	51.8	844	724	1,520	3,940f
MW11	08/29/07	17.98	7.11	10.87	No	2,200d	16,000	---	56	640	210	760	2,600
MW11	11/29/07	17.98	6.91	11.07	No	1,400d	16,000	---	28	550	160	750	2,600
MW11	02/27/08	17.98	5.16	12.82	No	1,300d	13,000	---	11	390	370	800	3,200
MW11	05/28/08	17.98	6.35	11.63	No	4,660d	31,900	---	29.8f	632	1,100	1,280	4,910f
MW11	08/27/08	17.98	7.06	10.92	No	1,200	13,000	---	<25	370	470	490	2,000
MW11	11/25/08	17.98	6.89	11.09	No	3,900	17,000	---	<25	580	470	990	3,700
MW11	02/25/09	17.98	4.87	13.11	No	200	1,500	---	<2.5	5.8	2.8	21	97
MW11	05/27/09	17.98	5.88	12.10	No	<50	18,000	---	<10	710	990	1,200	5,200
MW12	10/17/95	16.30	6.38	9.92	No	---	<50	<5.0	---	<0.5	<0.5	<0.5	<0.5
MW12	01/24/96	16.30	4.86	11.44	No	---	<50	<5.0	---	<0.5	<0.5	<0.5	<0.5
MW12	04/24/96	16.30	4.46	11.84	No	---	<50	<5.0	---	<0.5	0.68	<0.5	0.72
MW12	07/26/96	16.30	5.90	10.40	No	---	<50	<5.0	---	<0.5	<0.5	<0.5	<0.5
MW12	10/30/96	16.30	6.56	9.74	No	---	<50	<5.0	---	<0.5	<0.5	<0.5	<0.5
MW12	01/31/97	16.30	4.57	11.73	No	---	<50	<5.0	---	<0.5	<0.5	<0.5	<0.5
MW12	04/10/97	16.30	---	---	---	---	---	---	---	---	---	---	---
MW12	07/10/97	16.30	---	---	---	---	---	---	---	---	---	---	---
MW12	10/08/97	16.30	---	---	---	---	---	---	---	---	---	---	---
MW12	01/28/98	16.30	3.90	12.40	No	---	---	---	---	---	---	---	---
MW12	04/14/98	16.30	3.67	12.63	No	---	---	---	---	---	---	---	---
MW12	07/30/98	16.30	5.00	11.30	No	---	---	---	---	---	---	---	---
MW12	10/19/98	16.30	---	---	No	---	---	---	---	---	---	---	---

**TABLE 1A
CUMULATIVE GROUNDWATER MONITORING AND SAMPLING DATA**

Former Exxon Service Station 70104
1725 Park Street
Alameda, California

Well ID	Sampling Date	TOC Elev. (feet)	DTW (feet)	GW Elev. (feet)	NAPL (feet)	TPHd (µg/L)	TPHg (µg/L)	MTBE 8021B (µg/L)	MTBE 8260B (µg/L)	B (µg/L)	T (µg/L)	E (µg/L)	X (µg/L)
MW12	01/13/99	16.30	5.19	11.11	No	---	---	---	---	---	---	---	---
MW12	04/28/99	16.30	4.53	11.77	---	---	---	---	---	---	---	---	---
MW12	07/09/99- 04/14/00	Not monitored or sampled.											
MW12	06/16/00	16.30	Property transferred to Valero Refining Company.										
MW12	07/05/00- 04/02/01	Not monitored or sampled.											
MW12	07/02/01	16.30	8.34	7.96	No	---	---	---	---	---	---	---	---
MW12	10/15/01	16.30	---	---	---	---	---	---	---	---	---	---	---
MW12	Nov-01	16.15	Well surveyed in compliance with AB 2886 requirements.										
MW12	02/04/02 - Present	Not monitored or sampled.											
EW1	09/12/94	16.22	6.13	10.09	No	---	400a	---	---	40	<0.5	10	5.4
EW1	10/01/94	16.22	7.63	8.59	No	---	3,400a	---	---	<0.5	4.4	30	11
EW1	01/13/95	16.22	11.46	4.76	No	---	680a	---	---	40	<0.5	12	16
EW1	04/27/95	16.22	15.47	0.75	No	---	---	---	---	---	---	---	---
EW1	08/03/95	16.22	13.85	2.37	No	---	<125	590	---	2.7	<1.2	<1.2	<1.2
EW1	10/17/95	16.22	8.05	8.17	No	---	3,600	400	---	220	<0.5	160	36
EW1	01/24/96	16.22	11.07	5.15	No	---	64	260	---	4.3	<0.5	1.3	0.53
EW1	04/24/96	16.22	6.20	10.02	No	---	740	3,000	---	130	2.3	35	2.1
EW1	07/26/96	16.22	13.93	2.29	No	---	<50	960	---	<0.5	<0.5	<0.5	<0.5
EW1	10/30/96	16.22	13.74	2.48	No	---	<50	5,300	---	0.52	<0.5	<0.5	<0.5
EW1	01/31/97	16.22	8.40	7.82	No	---	---	---	---	---	---	---	---
EW1	04/10/97	16.22	---	---	---	---	---	---	---	---	---	---	---
EW1	07/10/97	16.22	---	---	---	---	---	---	---	---	---	---	---
EW1	10/08/97	16.22	---	---	---	---	---	---	---	---	---	---	---
EW1	01/28/98	16.22	3.35	12.87	No	---	---	---	---	---	---	---	---
EW1	04/14/98	16.22	3.52	12.70	No	---	---	---	---	---	---	---	---
EW1	07/30/98	16.22	5.48	10.74	No	---	---	---	---	---	---	---	---
EW1	10/19/98	16.22	5.77	10.45	No	---	---	---	---	---	---	---	---
EW1	01/13/99	16.22	5.49	10.73	No	---	---	---	---	---	---	---	---
EW1	04/28/99	16.22	4.31	11.91	No	---	---	---	---	---	---	---	---
EW1	07/09/99- 04/14/00	Not monitored or sampled.											
EW1	06/16/00	16.22	Property transferred to Valero Refining Company.										
EW1	07/05/00- 10/15/01	Not monitored or sampled.											
EW1	Nov-01	16.27	Well surveyed in compliance with AB 2886 requirements.										
EW1	02/04/02	16.27	---	---	---	---	---	---	---	---	---	---	---
EW1	05/06/02	16.27	4.94	11.33	No	---	---	---	---	---	---	---	---
EW1	08/22/02 e	16.27	---	---	---	---	---	---	---	---	---	---	---
EW1	11/08/02	16.27	3.80	12.47	No	---	---	---	---	---	---	---	---
EW1	02/07/03	16.27	12.45	3.82	No	---	---	---	---	---	---	---	---
EW1	05/02/03	16.27	6.55	9.72	No	---	---	---	---	---	---	---	---
EW1	08/14/03	16.27	---	---	No	---	---	---	---	---	---	---	---

**TABLE 1A
CUMULATIVE GROUNDWATER MONITORING AND SAMPLING DATA**

Former Exxon Service Station 70104
1725 Park Street
Alameda, California

Well ID	Sampling Date	TOC Elev. (feet)	DTW (feet)	GW Elev. (feet)	NAPL (feet)	TPHd (µg/L)	TPHg (µg/L)	MTBE 8021B (µg/L)	MTBE 8260B (µg/L)	B (µg/L)	T (µg/L)	E (µg/L)	X (µg/L)
EW1	11/14/03	16.27	---	---	No	---	---	---	---	---	---	---	---
EW1	03/01/04	16.27	---	---	No	---	---	---	---	---	---	---	---
EW1	06/15/04	16.27	4.47	11.80	No	---	---	---	---	---	---	---	---
EW1	09/13/04	16.27	5.12	11.15	No	---	---	---	---	---	---	---	---
EW1	12/22/04	16.27	4.17	12.10	No	---	---	---	---	---	---	---	---
EW1	03/24/05	16.27	2.97	13.30	No	---	---	---	---	---	---	---	---
EW1	06/14/05	16.27	3.98	12.29	No	---	---	---	---	---	---	---	---
EW1	09/12/05	16.27	14.39	1.88	No	---	---	---	---	---	---	---	---
EW1	12/13/05	16.27	12.7	3.57	No	---	---	---	---	---	---	---	---
EW1	03/13/06	16.27	11.43	4.84	No	---	---	---	---	---	---	---	---
EW1	06/12/06	16.27	11.78	4.49	No	---	---	---	---	---	---	---	---
EW1	09/08/06	16.27	5.18	11.09	No	---	---	---	---	---	---	---	---
EW1	12/05/06	16.27	10.48	5.79	No	---	---	---	---	---	---	---	---
EW1	03/12/07	16.27	3.82	12.45	No	---	---	---	---	---	---	---	---
EW1	05/29/07	16.27	14.9	1.37	No	---	---	---	---	---	---	---	---
EW1	08/29/07	16.27	7.82	8.45	No	---	---	---	---	---	---	---	---
EW1	11/29/07	16.27	6.23	10.04	No	---	---	---	---	---	---	---	---
EW1	02/27/08	16.27	4.38	11.89	No	---	---	---	---	---	---	---	---
EW1	05/28/08	16.27	6.51	9.76	No	---	---	---	---	---	---	---	---
EW1	08/27/08	16.27	4.75	11.52	No	---	---	---	---	---	---	---	---
EW1	11/25/08	16.27	7.21	9.06	No	---	---	---	---	---	---	---	---
EW1	02/25/09	16.27	3.45	12.82	No	---	---	---	---	---	---	---	---
EW1	05/27/09	16.27	4.14	12.13	No	---	---	---	---	---	---	---	---
EW2	09/12/94	16.05	6.09	9.96	No	---	8,800a	---	---	2,000	79	180	290
EW2	10/01/94	16.05	7.32	8.73	No	---	9,500a	---	---	1,400	6.7	700	310
EW2	01/13/95	16.05	14.38	1.67	No	---	5,700a	---	---	930	270	21	280
EW2	04/27/95	16.05	15.23	0.82	No	---	---	---	---	---	---	---	---
EW2	08/03/95	16.05	7.19	8.86	No	---	830	1,600	---	170	27	36	64
EW2	10/17/95	16.05	18.97	-2.92	No	---	180	3,600	---	<0.5	<0.5	<0.5	5.1
EW2	01/24/96	16.05	20.32	-4.27	No	---	1,700	6,400	---	290	82	14	170
EW2	04/24/96	16.05	9.46	6.59	No	---	3,500	7,300	---	670	200	110	490
EW2	07/26/96	16.05	16.50	-0.45	No	---	1,400	14,000	---	250	56	10	220
EW2	10/30/96	16.05	20.30	-4.25	No	---	1,500	13,000	---	200	44	8.8	190
EW2	01/31/97	16.05	19.21	-3.16	No	---	---	---	---	---	---	---	---
EW2	04/10/97	16.05	---	---	---	---	---	---	---	---	---	---	---
EW2	07/10/97	16.05	---	---	---	---	---	---	---	---	---	---	---
EW2	10/08/97	16.05	---	---	---	---	---	---	---	---	---	---	---
EW2	01/28/98	16.05	3.35	12.70	No	---	---	---	---	---	---	---	---
EW2	04/14/98	16.05	3.45	12.60	No	---	---	---	---	---	---	---	---
EW2	07/30/98	16.05	11.50	4.55	No	---	---	---	---	---	---	---	---

**TABLE 1A
CUMULATIVE GROUNDWATER MONITORING AND SAMPLING DATA**

Former Exxon Service Station 70104
1725 Park Street
Alameda, California

Well ID	Sampling Date	TOC Elev. (feet)	DTW (feet)	GW Elev. (feet)	NAPL (feet)	TPHd (µg/L)	TPHg (µg/L)	MTBE 8021B (µg/L)	MTBE 8260B (µg/L)	B (µg/L)	T (µg/L)	E (µg/L)	X (µg/L)
EW2	10/19/98	16.05	5.67	10.38	No	---	---	---	---	---	---	---	---
EW2	01/13/99	16.05	9.57	6.48	No	---	---	---	---	---	---	---	---
EW2	04/28/99	16.05	10.15	5.90	No	---	---	---	---	---	---	---	---
EW2	07/09/99- 04/14/00	Not monitored or sampled.											
EW2	06/16/00	16.05	Property transferred to Valero Refining Company.										
EW2	07/05/00- 10/15/01	Not monitored or sampled.											
EW2	Nov-01	16.07	Well surveyed in compliance with AB 2886 requirements.										
EW2	02/04/02 - Present	Not monitored or sampled.											
EW3	09/12/94	16.02	6.12	9.90	No	---	300a	---	---	44	5.9	12	31
EW3	10/01/94	16.02	10.52	5.50	No	---	140a	---	---	12	0.42	1.7	3.7
EW3	01/13/95	16.02	18.13	-2.11	No	---	230a	---	---	4.6	7.6	1.2	6.6
EW3	04/27/95	16.02	23.07	-7.05	No	---	---	---	---	---	---	---	---
EW3	08/03/95	16.02	22.90	-6.88	No	---	<200	1,400	---	<2.0	<2.0	<2.0	<2.0
EW3	10/17/95	16.02	22.87	-6.85	No	---	74	2,400	---	4.4	<0.5	<0.5	<0.5
EW3	01/24/96	16.02	20.97	-4.95	No	---	120	2,300	---	16	<0.5	<0.5	<0.5
EW3	04/24/96	16.02	18.10	-2.08	No	---	180	3,800	---	34	3.7	8.9	11
EW3	07/26/96	16.02	13.14	2.88	No	---	180	2,000	---	45	0.7	<0.5	2.1
EW3	10/30/96	16.02	9.24	6.78	No	---	660	2,800	---	60	8.2	<0.5	100
EW3	01/31/97	16.02	11.10	4.92	No	---	---	---	---	---	---	---	---
EW3	04/10/97	16.02	---	---	---	---	---	---	---	---	---	---	---
EW3	07/10/97	16.02	---	---	---	---	---	---	---	---	---	---	---
EW3	10/08/97	16.02	---	---	---	---	---	---	---	---	---	---	---
EW3	01/28/98	16.02	3.42	12.60	No	---	---	---	---	---	---	---	---
EW3	04/14/98	16.02	3.50	12.52	No	---	---	---	---	---	---	---	---
EW3	07/30/98	16.02	18.57	-2.55	No	---	---	---	---	---	---	---	---
EW3	10/19/98	16.02	5.65	10.37	No	---	---	---	---	---	---	---	---
EW3	01/13/99	16.02	13.85	2.17	No	---	---	---	---	---	---	---	---
EW3	04/28/99	16.02	4.52	11.50	No	---	---	---	---	---	---	---	---
EW3	07/09/99- 04/14/00	Not monitored or sampled.											
EW3	06/16/00	16.02	Property transferred to Valero Refining Company.										
EW3	07/05/00- 10/15/01	Not monitored or sampled.											
EW3	Nov-01	16.08	Well surveyed in compliance with AB 2886 requirements.										
EW3	02/04/02	16.08	---	---	---	---	---	---	---	---	---	---	---
EW3	05/06/02	16.08	5.38	10.70	No	---	---	---	---	---	---	---	---
EW3	08/22/02	16.08	13.00	3.08	No	---	---	---	---	---	---	---	---
EW3	11/08/02	16.08	4.19	11.89	No	---	---	---	---	---	---	---	---
EW3	02/07/03	16.08	21.15	-5.07	No	---	---	---	---	---	---	---	---
EW3	05/02/03	16.08	23.50	-7.42	No	---	---	---	---	---	---	---	---
EW3	08/14/03	16.08	6.07	10.01	No	---	---	---	---	---	---	---	---
EW3	11/14/03	16.08	6.04	10.04	No	---	---	---	---	---	---	---	---

**TABLE 1A
CUMULATIVE GROUNDWATER MONITORING AND SAMPLING DATA**

Former Exxon Service Station 70104
1725 Park Street
Alameda, California

Well ID	Sampling Date	TOC Elev. (feet)	DTW (feet)	GW Elev. (feet)	NAPL (feet)	TPHd (µg/L)	TPHg (µg/L)	MTBE 8021B (µg/L)	MTBE 8260B (µg/L)	B (µg/L)	T (µg/L)	E (µg/L)	X (µg/L)
EW3	03/01/04	16.08	3.98	12.10	No	---	---	---	---	---	---	---	---
EW3	06/15/04	16.08	4.80	11.28	No	---	---	---	---	---	---	---	---
EW3	09/13/04	16.08	5.56	10.52	No	---	---	---	---	---	---	---	---
EW3	12/22/04	16.08	4.51	11.57	No	---	---	---	---	---	---	---	---
EW3	03/24/05	16.08	3.23	12.85	No	---	---	---	---	---	---	---	---
EW3	06/14/05	16.08	4.31	11.77	No	---	---	---	---	---	---	---	---
EW3	09/12/05	16.08	32.48	-16.40	No	---	---	---	---	---	---	---	---
EW3	12/13/05	16.08	5.66	10.42	No	---	---	---	---	---	---	---	---
EW3	03/13/06	16.08	4.48	11.60	No	---	---	---	---	---	---	---	---
EW3	06/12/06	16.08	4.97	11.11	No	---	---	---	---	---	---	---	---
EW3	09/08/06	16.08	5.65	10.43	No	---	---	---	---	---	---	---	---
EW3	12/05/06	16.08	6.99	9.09	No	---	---	---	---	---	---	---	---
EW3	03/12/07	16.08	4.36	11.72	No	---	---	---	---	---	---	---	---
EW3	05/29/07	16.08	5.84	10.24	No	---	---	---	---	---	---	---	---
EW3	08/29/07	16.08	7.38	8.70	No	---	---	---	---	---	---	---	---
EW3	11/29/07	16.08	5.99	10.09	No	---	---	---	---	---	---	---	---
EW3	02/27/08	16.08	4.53	11.55	No	---	---	---	---	---	---	---	---
EW3	05/28/08	16.08	5.52	10.56	No	---	---	---	---	---	---	---	---
EW3	08/27/08	16.08	6.03	10.05	No	---	---	---	---	---	---	---	---
EW3	11/25/08	16.08	6.05	10.03	No	---	---	---	---	---	---	---	---
EW3	02/25/09	16.08	3.88	12.20	No	---	---	---	---	---	---	---	---
EW3	05/27/09	16.08	4.88	11.20	No	---	---	---	---	---	---	---	---
EW4	09/12/94	16.61	5.69	10.92	No	---	4,000a	---	---	1,700	12	210	77
EW4	10/01/94	16.61	7.90	8.71	No	---	460a	---	---	100	1.5	15	11
EW4	01/13/95	16.61	11.36	5.25	No	---	520a	---	---	89	8.8	1.6	82
EW4	04/27/95	16.61	16.30	0.31	No	---	---	---	---	---	---	---	---
EW4	08/03/95	16.61	6.45	10.16	No	---	42,000	17,000	---	3,100	1,100	2,000	8,200
EW4	10/17/95	16.61	15.89	0.72	No	---	92	2,500	---	6.3	<0.5	<0.5	<0.5
EW4	01/24/96	16.61	6.03	10.58	No	---	220	9,200	---	79	2.5	2.9	10
EW4	04/24/96	16.61	4.97	11.64	No	---	4,600	860	---	49	36	69	1,100
EW4	07/26/96	16.61	6.54	10.07	No	---	2,900	15,000	---	610	6.2	200	300
EW4	10/30/96	16.61	6.53	10.08	No	---	550	3,400	---	68	11	<2.5	71
EW4	01/31/97	16.61	3.98	12.63	No	---	---	---	---	---	---	---	---
EW4	04/10/97	16.61	---	---	---	---	---	---	---	---	---	---	---
EW4	07/10/97	16.61	---	---	---	---	---	---	---	---	---	---	---
EW4	10/08/97	16.61	---	---	---	---	---	---	---	---	---	---	---
EW4	01/28/98	16.61	3.22	13.39	No	---	---	---	---	---	---	---	---
EW4	04/14/98	16.61	3.20	13.41	No	---	---	---	---	---	---	---	---
EW4	07/30/98	16.61	4.89	11.72	No	---	---	---	---	---	---	---	---
EW4	10/19/98	16.61	5.16	11.45	No	---	---	---	---	---	---	---	---

**TABLE 1A
CUMULATIVE GROUNDWATER MONITORING AND SAMPLING DATA**

Former Exxon Service Station 70104
1725 Park Street
Alameda, California

Well ID	Sampling Date	TOC Elev. (feet)	DTW (feet)	GW Elev. (feet)	NAPL (feet)	TPHd (µg/L)	TPHg (µg/L)	MTBE 8021B (µg/L)	MTBE 8260B (µg/L)	B (µg/L)	T (µg/L)	E (µg/L)	X (µg/L)
EW4	01/13/99	16.61	5.57	11.04	No	---	---	---	---	---	---	---	---
EW4	04/28/99	16.61	4.27	12.34	No	---	---	---	---	---	---	---	---
EW4	07/09/99- 04/14/00	Not monitored or sampled.											
EW4	06/16/00	16.61	Property transferred to Valero Refining Company.										
EW4	07/05/00- 10/15/01	Not monitored or sampled.											
EW4	Nov-01	15.69	Well surveyed in compliance with AB 2886 requirements.										
EW4	02/04/02 - Present	Not monitored or sampled.											
EW5	09/12/94	16.51	6.30	10.21	No	---	180a	---	---	26	1.7	11	12
EW5	10/01/94	16.51	11.83	4.68	No	---	130a	---	---	16	0.92	5.7	8.5
EW5	01/13/95	16.51	12.54	3.97	No	---	130a	---	---	0.6	0.8	0.6	2.9
EW5	04/27/95	16.51	13.11	3.40	No	---	---	---	---	---	---	---	---
EW5	08/03/95	16.51	11.99	4.52	No	---	70	210	---	<0.5	<0.5	<0.5	<0.5
EW5	10/17/95	16.51	13.43	3.08	No	---	78	50	---	1.5	<0.5	<0.5	3.0
EW5	01/24/96	16.51	9.72	6.79	No	---	2,500	350	---	280	66	22	370
EW5	04/24/96	16.51	8.13	8.38	No	---	6,400	400	---	690	240	380	1,300
EW5	07/26/96	16.51	10.00	6.51	No	---	850	84	---	82	2.5	2.4	100
EW5	10/30/96	16.51	9.82	6.69	No	---	1,200	68	---	110	5.1	2.2	120
EW5	01/31/97	16.51	9.00	7.51	No	---	---	---	---	---	---	---	---
EW5	04/10/97	16.51	---	---	---	---	---	---	---	---	---	---	---
EW5	07/10/97	16.51	---	---	---	---	---	---	---	---	---	---	---
EW5	10/08/97	16.51	---	---	---	---	---	---	---	---	---	---	---
EW5	01/28/98	16.51	3.54	12.97	No	---	---	---	---	---	---	---	---
EW5	04/14/98	16.51	3.65	12.86	No	---	---	---	---	---	---	---	---
EW5	07/30/98	16.51	7.63	8.88	No	---	---	---	---	---	---	---	---
EW5	10/19/98	16.51	5.75	10.76	No	---	---	---	---	---	---	---	---
EW5	01/13/99	16.51	7.03	9.48	No	---	---	---	---	---	---	---	---
EW5	04/28/99	16.51	8.80	7.71	No	---	---	---	---	---	---	---	---
EW5	07/09/99- 04/14/00	Not monitored or sampled.											
EW5	06/16/00	16.51	Property transferred to Valero Refining Company.										
EW5	07/05/00- 10/15/01	Not monitored or sampled.											
EW5	Nov-01	16.67	Well surveyed in compliance with AB 2886 requirements.										
EW5	02/04/02	16.67	---	---	---	---	---	---	---	---	---	---	---
EW5	05/06/02	16.67	4.78	11.89	No	---	---	---	---	---	---	---	---
EW5	08/22/02	16.67	6.61	10.06	No	---	---	---	---	---	---	---	---
EW5	11/08/02	16.67	3.74	12.93	No	---	---	---	---	---	---	---	---
EW5	02/07/03	16.67	6.40	10.27	No	---	---	---	---	---	---	---	---
EW5	05/02/03	16.67	5.91	10.76	No	---	---	---	---	---	---	---	---
EW5	08/14/03	16.67	6.28	10.39	No	---	---	---	---	---	---	---	---
EW5	11/14/03	16.67	6.19	10.48	No	---	---	---	---	---	---	---	---
EW5	03/01/04	16.67	4.02	12.65	No	---	---	---	---	---	---	---	---

**TABLE 1A
CUMULATIVE GROUNDWATER MONITORING AND SAMPLING DATA**

Former Exxon Service Station 70104
1725 Park Street
Alameda, California

Well ID	Sampling Date	TOC Elev. (feet)	DTW (feet)	GW Elev. (feet)	NAPL (feet)	TPHd (µg/L)	TPHg (µg/L)	MTBE 8021B (µg/L)	MTBE 8260B (µg/L)	B (µg/L)	T (µg/L)	E (µg/L)	X (µg/L)
EW5	06/15/04	16.67	4.97	11.70	No	---	---	---	---	---	---	---	---
EW5	09/13/04	16.67	5.47	11.20	No	---	---	---	---	---	---	---	---
EW5	12/22/04	16.67	4.71	11.96	No	---	---	---	---	---	---	---	---
EW5	03/24/05	16.67	3.15	13.52	No	---	---	---	---	---	---	---	---
EW5	06/14/05	16.67	4.28	12.39	No	---	---	---	---	---	---	---	---
EW5	09/12/05	16.67	7.46	9.21	No	---	---	---	---	---	---	---	---
EW5	12/13/05	16.67	5.47	11.20	No	---	---	---	---	---	---	---	---
EW5	03/13/06	16.67	3.71	12.96	No	---	---	---	---	---	---	---	---
EW5	06/12/06	16.67	4.36	12.31	No	---	---	---	---	---	---	---	---
EW5	09/08/06	16.67	5.70	10.97	No	---	---	---	---	---	---	---	---
EW5	12/05/06	16.67	6.41	10.26	No	---	---	---	---	---	---	---	---
EW5	03/12/07	16.67	4.48	12.19	No	---	---	---	---	---	---	---	---
EW5	05/29/07	16.67	5.76	10.91	No	---	---	---	---	---	---	---	---
EW5	08/29/07	16.67	6.36	10.31	No	---	---	---	---	---	---	---	---
EW5	11/29/07	16.67	6.04	10.63	No	---	---	---	---	---	---	---	---
EW5	02/27/08	16.67	4.38	12.29	No	---	---	---	---	---	---	---	---
EW5	05/28/08	16.67	5.25	11.42	No	---	---	---	---	---	---	---	---
EW5	08/27/08	16.67	5.94	10.73	No	---	---	---	---	---	---	---	---
EW5	11/25/08	16.67	5.84	10.83	No	---	---	---	---	---	---	---	---
EW5	02/25/09	16.67	3.51	13.16	No	---	---	---	---	---	---	---	---
EW5	05/27/09	16.67	4.75	11.92	No	---	---	---	---	---	---	---	---

TABLE 1A
CUMULATIVE GROUNDWATER MONITORING AND SAMPLING DATA

Former Exxon Service Station 70104
1725 Park Street
Alameda, California

Notes:	
TOC Elev.	= Top of well casing elevation; datum is mean sea level.
DTW	= Depth to water.
GW Elev.	= Groundwater elevation; datum is mean sea level.
NAPL	= Non aqueous phase liquid.
TPHd	= Total petroleum hydrocarbons as diesel using EPA Method 5030/8015 (modified).
TPHg	= Total petroleum hydrocarbons as gasoline analyzed using EPA Method 5030/8015B (modified).
MTBE 8021B	= Methyl tertiary butyl ether analyzed using EPA Method 8021B.
MTBE 8260B	= Methyl tertiary butyl ether analyzed using EPA Method 8260B.
BTEX	= Benzene, toluene, ethylbenzene, and total xylenes analyzed using EPA Method 8021B.
EDB	= 1,2-dibromoethane analyzed using EPA Method 8260B.
1,2-DCA	= 1,2-dichloroethane analyzed using EPA Method 8260B.
TAME	= Tertiary amyl methyl ether analyzed using EPA Method 8260B.
TBA	= Tertiary butyl alcohol analyzed using EPA Method 8260B.
ETBE	= Ethyl tertiary butyl ether analyzed using EPA Method 8260B.
DIPE	= Di-isopropyl ether analyzed using EPA Method 8260B.
Ethanol	= Ethanol analyzed using EPA Method 8260B.
µg/L	= Micrograms per liter.
<	= Less than the stated laboratory method reporting limit.
---	= Not measured/Not sampled/Not analyzed.
a	= Total volatile hydrocarbons by DHS /LUFT Manual Method.
b	= Results obtained from a 1:10 dilution analyzed on January 17, 1995.
c	= Diesel-range hydrocarbons reportedly detected in bailer blank; result is suspect.
d	= Hydrocarbon pattern does not resemble the requested fuel.
e	= Well inaccessible.
f	= Analyte detected in laboratory method blank; result is suspect.
g	= Concentration estimated. Analyte exceeded calibration range. Reanalysis not performed due to holding time requirements.
h	= Initial analysis within holding time. Reanalysis for required dilution, confirmation, or QA/QC was past holding time.
i	= Elevated result due to single analyte peak(s) in the quantitation range.
j	= Calibration verification recovery above the method control limit. A high bias may be indicated.
k	= Elevated reporting limit due to high levels of non-target compounds.
l	= Analyte presence not confirmed by second column or GC/MS analysis.

**TABLE 1B
ADDITIONAL CUMULATIVE GROUNDWATER MONITORING AND SAMPLING DATA**

Former Exxon Service Station 70104
1725 Park Street
Alameda, California

Well ID	Sampling Date	EDB (µg/L)	1,2-DCA (µg/L)	TAME (µg/L)	TBA (µg/L)	ETBE (µg/L)	DIPE (µg/L)	Ethanol (µg/L)
MW1	09/12/94 - 04/14/00	Not analyzed for these analytes.						
MW1	06/16/00	Property transferred to Valero Refining Company.						
MW1	07/05/00 - 02/04/02	Not analyzed for these analytes.						
MW1	05/06/02	<0.50	<0.50	<0.50	297	<0.50	<0.50	---
MW1	08/22/02 - 11/14/03	Not analyzed for these analytes.						
MW1	03/01/04	<0.50	<0.50	<0.50	42.3	<0.50	<0.50	---
MW1	06/15/04	---	---	---	---	---	---	<100
MW1	09/13/04	---	---	---	---	---	---	---
MW1	12/22/04	---	---	---	---	---	---	---
MW1	03/24/05	<0.50	<0.50	<0.50	3,020	<0.50	<0.50	<50.0
MW1	06/14/05	<0.50	<0.50	<0.50	6,590	<0.50	<0.50	<50.0
MW1	09/12/05	<0.500	<0.500	<0.500	10,900	<0.500	<0.500	<50.0
MW1	12/13/05	<0.500	<0.500	<0.500	6,590h	<0.500	<0.500	<50.0
MW1	03/13/06	<50	<50	<50	15,000	<50	<50	---
MW1	06/12/06	<50	<50	<50	26,000	<50	<50	---
MW1	09/08/06	<25	<25	<25	22,000	<25	<25	---
MW1	12/05/06	<25	<25	<25	12,000	<25	<25	---
MW1	03/12/07	<100	<100	<100	9,000	<100	<100	---
MW1	05/29/07	<0.500	<0.500	1.11	12,100	<0.500	<0.500	---
MW1	08/29/07	<50	<50	<50	12,000	<50	<50	---
MW1	11/29/07	<50	<50	<50	11,000	<50	<50	---
MW1	02/27/08	<50	<50	<50	11,000	<50	<50	---
MW1	05/28/08	<0.500	<0.500	<25.0	14,100	<0.500	<0.500	---
MW1	08/27/08	<0.50	<0.50	1.5	11,000	<0.50	<0.50	<50
MW1	11/25/08	<50	<50	<50	4,700	<50	<50	<5,000
MW1	02/25/09	<50	<50	<50	5,100	<50	<50	---
MW1	05/27/09	<25	<25	<25	9,100	<25	<25	---
MW2	09/12/94 - 04/14/00	Not analyzed for these analytes.						
MW2	06/16/00	Property transferred to Valero Refining Company.						
MW2	07/05/00 - 10/15/01	Not analyzed for these analytes.						
MW2	02/04/02	---	---	---	---	69	---	---
MW2	05/06/02	<0.50	<0.50	<0.50	44.8	252	<0.50	---
MW2	08/22/02	---	---	---	---	178	---	---
MW2	11/08/02	---	---	---	---	83	---	---
MW2	02/07/03	---	---	---	---	<50	---	---
MW2	05/02/03	---	---	---	---	56	---	---
MW2	08/14/03	---	---	---	---	62	---	---
MW2	11/14/03	---	---	---	---	132	---	---
MW2	03/01/04	<0.50	<0.50	<0.50	<10.0	<0.50	<0.50	---
MW2	06/15/04	---	---	---	---	---	---	<100
MW2	09/13/04	---	---	---	---	---	---	---

**TABLE 1B
ADDITIONAL CUMULATIVE GROUNDWATER MONITORING AND SAMPLING DATA**

Former Exxon Service Station 70104
1725 Park Street
Alameda, California

Well ID	Sampling Date	EDB (µg/L)	1,2-DCA (µg/L)	TAME (µg/L)	TBA (µg/L)	ETBE (µg/L)	DIPE (µg/L)	Ethanol (µg/L)
MW2	12/22/04	---	---	---	---	---	---	---
MW2	03/24/05	<0.50	<0.50	<0.50	37	<0.50	<0.50	<50.0
MW2	06/14/05	<0.50	1.90	<0.50	41.1	<0.50	<0.50	<50.0
MW2	09/12/05	<0.500	<0.500	<0.500	181	<0.500	<0.500	<50.0
MW2	12/13/05	<0.500	<0.500	<0.500	159	<0.500	0.680	<50.0
MW2	03/13/06	<0.50	<0.50	<0.50	28	<0.50	<0.50	<100
MW2	06/12/06	<0.50	<0.50	<0.50	40	<0.50	<0.50	<100
MW2	09/08/06	<0.50	<0.50	<0.50	440	<0.50	<0.50	<100
MW2	12/05/06	<0.50	<0.50	<0.50	620	<0.50	0.51	<100
MW2	03/12/07	<0.50	<0.50	<0.50	290	<0.50	<0.50	<100
MW2	05/29/07	<0.500	<0.500	<0.500	235	<0.500	<0.500	<50.0
MW2	08/29/07	<0.50	<0.50	<0.50	900	<0.50	0.50	<100
MW2	11/29/07	<0.50	<0.50	<0.50	1,300	<0.50	0.66	<100
MW2	02/27/08	<0.50	<0.50	<0.50	83	<0.50	<0.50	<100
MW2	05/28/08	<0.500	<0.500	<0.500	60.6	<0.500	<0.500	<50.0
MW2	08/27/08	<0.50	<0.50	<0.50	66	<0.50	<0.50	<50
MW2	11/25/08	<0.50	<0.50	<0.50	69	<0.50	<0.50	<50
MW2	02/25/09	<0.50	<0.50	<0.50	46	<0.50	<0.50	<50
MW2	05/27/09	<0.50	<0.50	<0.50	47	<0.50	<0.50	<50
MW3	09/12/94 - 04/14/00	Not analyzed for these analytes.						
MW3	06/16/00	Property transferred to Valero Refining Company.						
MW3	07/05/00 - 02/04/02	Not analyzed for these analytes.						
MW3	05/06/02	<0.50	<0.50	<0.50	194.0	<0.50	<0.50	---
MW3	08/22/02 - 11/14/03	Not analyzed for these analytes.						
MW3	03/01/04	<0.50	<0.50	<0.50	3550.0	<0.50	<0.50	---
MW3	06/15/04	---	---	---	---	---	---	<100
MW3	09/13/04	---	---	---	---	---	---	---
MW3	12/22/04	---	---	---	---	---	---	---
MW3	03/24/05	<0.50	<0.50	<0.50	12,600	<0.50	<0.50	<50.0
MW3	06/14/05	<0.50	<0.50	<0.50	10,500	<0.50	<0.50	<50.0
MW3	09/12/05	<0.500	10.4	<0.500	16,100	<0.500	<0.500	<50.0
MW3	12/13/05	<0.500	5.04	<0.500	3,530h	<0.500	<0.500	<50.0
MW3	03/13/06	<0.50	<0.50	<0.50	12,000h	<0.50	<0.50	<100
MW3	06/12/06	<5.0	<5.0	<5.0	8,000	<5.0	<5.0	<1,000
MW3	09/08/06	<2.5	<2.5	<2.5	6,700	<2.5	<2.5	<500
MW3	12/05/06	<2.5	<2.5	<2.5	6,700	<2.5	<2.5	<500
MW3	03/12/07	<2.5	<2.5	<2.5	5,900	<2.5	<2.5	<500
MW3	05/29/07	<0.500	<0.500	<0.500	4,330	<0.500	<0.500	<50.0
MW3	08/29/07	<1.0	<1.0	<1.0	2,800	<1.0	<1.0	<200
MW3	11/29/07	<1.0	<1.0	<1.0	3,700	<1.0	<1.0	<200
MW3	02/27/08	<5.0	<5.0	<5.0	4,300	<5.0	<5.0	<1,000
MW3	05/28/08	<0.500	<0.500	<0.500	920	<0.500	<0.500	<50.0
MW3	08/27/08	<0.50	<0.50	<0.50	450	<0.50	<0.50	<50

**TABLE 1B
ADDITIONAL CUMULATIVE GROUNDWATER MONITORING AND SAMPLING DATA**

Former Exxon Service Station 70104
1725 Park Street
Alameda, California

Well ID	Sampling Date	EDB (µg/L)	1,2-DCA (µg/L)	TAME (µg/L)	TBA (µg/L)	ETBE (µg/L)	DIPE (µg/L)	Ethanol (µg/L)
MW3	11/25/08	<2.5	<2.5	<2.5	230	<2.5	<2.5	<250
MW3	02/25/09	<2.5	<2.5	<2.5	460	<2.5	<2.5	<250
MW3	05/27/09	<2.5	<2.5	<2.5	220	<2.5	<2.5	<250
MW4	09/12/94 - 04/14/00	Not analyzed for these analytes.						
MW4	06/16/00	Property transferred to Valero Refining Company.						
MW4	07/05/00 - 02/04/02	Not analyzed for these analytes.						
MW4	05/06/02	<0.50	<0.50	<0.50	499.0	0.8	<0.50	---
MW4	08/22/02 - 11/14/03	Not analyzed for these analytes.						
MW4	03/01/04	<0.50	<0.50	<0.50	1,780	<0.50	<0.50	---
MW4	06/15/04	---	---	---	---	---	---	<100
MW4	09/13/04	---	---	---	---	---	---	---
MW4	12/22/04	---	---	---	---	---	---	---
MW4	03/24/05	<0.50	<0.50	<0.50	8,860	<0.50	<0.50	<50.0
MW4	06/14/05	<0.50	2.20	<0.50	5,890	<0.50	<0.50	<50.0
MW4	09/12/05	<0.500	<0.500	<0.500	7,230	<0.500	<0.500	<50.0
MW4	12/13/05	<0.500	3.49	<0.500	3,750g	<0.500	<0.500	<50.0
MW4	03/13/06	<0.50	<0.50	<0.50	2,000	<0.50	<0.50	<100
MW4	06/12/06	<0.50	<0.50	<0.50	740	<0.50	<0.50	<100
MW4	09/08/06	<0.50	<0.50	<0.50	2,800	<0.50	<0.50	<100
MW4	12/05/06	<0.50	<0.50	<0.50	3,900	<0.50	<0.50	<100
MW4	03/12/07	<1.0	<1.0	<1.0	2,800	<1.0	<1.0	<200
MW4	05/29/07	<0.500	<0.500	<0.500	1,350	<0.500	<0.500	<50.0
MW4	08/29/07	<0.50	<0.50	<0.50	940	<0.50	<0.50	<100
MW4	11/29/07	<0.50	<0.50	<0.50	810	<0.50	<0.50	<100
MW4	02/27/08	<0.50	<0.50	<0.50	220	<0.50	<0.50	<100
MW4	05/28/08	<0.500	<0.500	<0.500	107	<0.500	<0.500	<50.0
MW4	08/27/08	<0.50	<0.50	<0.50	130	<0.50	<0.50	<50
MW4	11/25/08	<0.50	<0.50	<0.50	69	<0.50	<0.50	<50
MW4	02/25/09	<2.5	<2.5	<2.5	46	<2.5	<2.5	<250
MW4	05/27/09	<2.5k	<2.5k	<2.5k	<25k	<2.5k	<2.5k	<250k
MW5	09/12/94 - 04/14/00	Not analyzed for these analytes.						
MW5	06/16/00	Property transferred to Valero Refining Company.						
MW5	07/05/00 - 02/04/02	Not analyzed for these analytes.						
MW5	05/06/02	<0.50	<0.50	<0.50	306	<0.50	3	---
MW5	08/22/02 - 11/14/03	Not analyzed for these analytes.						
MW5	03/01/04	<0.50	<0.50	<0.50	528	<0.50	1	---
MW5	06/15/04	---	---	---	---	---	---	<100
MW5	09/13/04	---	---	---	---	---	---	---
MW5	12/22/04	---	---	---	---	---	---	---
MW5	03/24/05	<0.50	<0.50	<0.50	1,560	<0.50	1.30	<50.0
MW5	06/14/05	<0.50	<0.50	<0.50	908	<0.50	1.70	<50.0

**TABLE 1B
ADDITIONAL CUMULATIVE GROUNDWATER MONITORING AND SAMPLING DATA**

Former Exxon Service Station 70104
1725 Park Street
Alameda, California

Well ID	Sampling Date	EDB (µg/L)	1,2-DCA (µg/L)	TAME (µg/L)	TBA (µg/L)	ETBE (µg/L)	DIPE (µg/L)	Ethanol (µg/L)	
MW5	09/12/05	<0.500	13.6	<0.500	1,130	<0.500	<0.500	<50.0	
MW5	12/13/05	<0.500	16.5	<0.500	878	<0.500	1.01	<50.0	
MW5	03/13/06	<0.50	<0.50	<0.50	1,800h	<0.50	<0.50	<100	
MW5	06/12/06	<2.5	<2.5	<2.5	800	<2.5	<2.5	<500	
MW5	09/08/06	<2.5	<2.5	<2.5	79	<2.5	<2.5	<500	
MW5	12/05/06	<0.50	<0.50	<0.50	230	<0.50	<0.50	<100	
MW5	03/12/07	<0.50	<0.50	<0.50	290	<0.50	<0.50	<100	
MW5	05/29/07	<0.500	<0.500	<0.500	171	<0.500	<0.500	<50.0	
MW5	08/29/07	<0.50	<0.50	<0.50	190	<0.50	<0.50	<100	
MW5	11/29/07	<0.50	<0.50	<0.50	110	<0.50	<0.50	<100	
MW5	02/27/08	<0.50	<0.50	<0.50	78	<0.50	<0.50	<100	
MW5	05/28/08	<0.500	<0.500	<0.500	68.3	<0.500	<0.500	<50.0	
MW5	08/27/08	<5.0	<5.0	<5.0	<50	<5.0	<5.0	<500	
MW5	11/25/08	<5.0	<5.0	<5.0	51	<5.0	<5.0	<500	
MW5	02/25/09	<5.0k	<5.0k	<5.0k	<50k	<5.0k	<5.0k	<500k	
MW5	05/27/09	<5.0k	<5.0k	<5.0k	<50k	<5.0k	<5.0k	<500k	
MW6	09/12/94 - 04/14/00	Not analyzed for these analytes.							
MW6	06/16/00	Property transferred to Valero Refining Company.							
MW6	07/05/00 - 02/04/02	Not analyzed for these analytes.							
MW6	05/06/02	<0.50	<0.50	<0.50	32	<0.50	<0.50	---	
MW6	08/22/02 - 11/14/03	Not analyzed for these analytes.							
MW6	03/01/04	<0.50	<0.50	<0.50	2,000	<0.50	<0.50	---	
MW6	06/15/04	---	---	---	---	---	---	<100	
MW6	09/13/04	---	---	---	---	---	---	---	
MW6	12/22/04	---	---	---	---	---	---	---	
MW6	03/24/05	<0.50	<0.50	<0.50	14,700	<0.50	<0.50	<50.0	
MW6	06/14/05	<0.50	<0.50	<0.50	22,800	<0.50	<0.50	<50.0	
MW6	09/12/05	<0.500	<0.500	<0.500	15,400	<0.500	<0.500	<50.0	
MW6	12/13/05	<0.500	<0.500	<0.500	5,640g	<0.500	<0.500	<50.0	
MW6	03/13/06	<5.0	<5.0	<5.0	11,000	<5.0	<5.0	<1,000	
MW6	06/12/06	<5.0	<5.0	<5.0	7,700	<5.0	<5.0	<1,000	
MW6	09/08/06	<5.0	<5.0	<5.0	6,000	<5.0	<5.0	<1,000	
MW6	12/05/06	<2.5	<2.5	<2.5	11,000	<2.5	<2.5	<500	
MW6	03/12/07	<2.5	<2.5	<2.5	5,200	<2.5	<2.5	<500	
MW6	05/29/07	<0.500	<0.500	<0.500	3,640	<0.500	<0.500	<50.0	
MW6	08/29/07	<2.5	<2.5	<2.5	4,400	<2.5	<2.5	<500	
MW6	11/29/07	<2.5	<2.5	<2.5	7,800	<2.5	<2.5	<500	
MW6	02/27/08	<25	<25	<25	2,600	<25	<25	<5,000	
MW6	05/28/08	<0.500	<0.500	<0.500	156	<0.500	<0.500	<50.0	
MW6	08/27/08	<50	<50	<50	<500	<50	<50	<5,000	
MW6	11/25/08	<50	<50	<50	890	<50	<50	<5,000	
MW6	02/25/09	<50	<50	<50	580	<50	<50	<5,000	
MW6	05/27/09	<10	<10	<10	860	<10	<10	<1,000	

**TABLE 1B
ADDITIONAL CUMULATIVE GROUNDWATER MONITORING AND SAMPLING DATA**

Former Exxon Service Station 70104
1725 Park Street
Alameda, California

Well ID	Sampling Date	EDB (µg/L)	1,2-DCA (µg/L)	TAME (µg/L)	TBA (µg/L)	ETBE (µg/L)	DIPE (µg/L)	Ethanol (µg/L)
MW7	09/12/94 - 04/14/00	Not analyzed for these analytes.						
MW7	06/16/00	Property transferred to Valero Refining Company.						
MW7	07/05/00 - 02/04/02	Not analyzed for these analytes.						
MW7	05/06/02	<0.50	<0.50	<0.50	144	<0.50	<0.50	---
MW7	08/22/02 - 11/14/03	Not analyzed for these analytes.						
MW7	03/01/04	<0.50	<0.50	<0.50	295	<0.50	<0.50	---
MW7	06/15/04	---	---	---	---	---	---	<100
MW7	09/13/04	---	---	---	---	---	---	---
MW7	12/22/04	---	---	---	---	---	---	---
MW7	03/24/05	<0.50	<0.50	<0.50	163	<0.50	<0.50	<50.0
MW7	06/14/05	<0.50	<0.50	<0.50	878	<0.50	<0.50	<50.0
MW7	09/12/05	<0.500	<0.500	<0.500	6,910	<0.500	<0.500	<50.0
MW7	12/13/05	<0.500	<0.500	<0.500	683	<0.500	<0.500	<50.0
MW7	03/13/06	<0.50	<0.50	<0.50	120	<0.50	<0.50	<100
MW7	06/12/06	<0.50	<0.50	<0.50	31	<0.50	<0.50	<100
MW7	09/08/06	<0.50	<0.50	<0.50	550	<0.50	<0.50	<100
MW7	12/05/06	<0.50	<0.50	<0.50	200	<0.50	<0.50	<100
MW7	03/12/07	<0.50	<0.50	<0.50	370	<0.50	<0.50	<100
MW7	05/29/07	<0.500	<0.500	<0.500	270	<0.500	<0.500	<50.0
MW7	08/29/07	<0.50	<0.50	<0.50	150	<0.50	<0.50	<100
MW7	11/29/07	<0.50	<0.50	<0.50	98	<0.50	<0.50	<100
MW7	02/27/08	<0.50	<0.50	<0.50	49	<0.50	<0.50	<100
MW7	05/28/08	<0.500	<0.500	<0.500	<10.0	<0.500	<0.500	<50.0
MW7	08/27/08	<0.50	<0.50	<0.50	7.9	<0.50	<0.50	<50
MW7	11/25/08	<0.50	<0.50	<0.50	19	<0.50	<0.50	<50
MW7	02/25/09	<0.50	<0.50	<0.50	<5.0	<0.50	<0.50	<50
MW7	05/27/09	<0.50	<0.50	<0.50	<5.0	<0.50	<0.50	<50
MW8	09/12/94 - 01/13/99	Not analyzed for these analytes.						
MW8	04/28/99	<0.50	<0.50	<0.50	<10.0	<0.50	<0.50	---
MW8	07/09/99 - 04/14/00	Not analyzed for these analytes.						
MW8	06/16/00	Property transferred to Valero Refining Company.						
MW8	07/05/00 - 02/04/02	Not analyzed for these analytes.						
MW8	05/06/02	<0.50	<0.50	<0.50	<10.0	<0.50	<0.50	---
MW8	08/22/02 - 11/14/03	Not analyzed for these analytes.						
MW8	03/01/04	<0.50	<0.50	<0.50	<10.0	<0.50	<0.50	---
MW8	06/15/04	---	---	---	---	---	---	<100
MW8	09/13/04	---	---	---	---	---	---	---
MW8	12/22/04	---	---	---	---	---	---	---
MW8	03/24/05	<0.50	<0.50	<0.50	<10.0	<0.50	<0.50	<50.0
MW8	06/14/05	<0.50	<0.50	<0.50	<10.0	<0.50	<0.50	<50.0
MW8	09/12/05	<0.500	<0.500	<0.500	46.2	<0.500	<0.500	<50.0

**TABLE 1B
ADDITIONAL CUMULATIVE GROUNDWATER MONITORING AND SAMPLING DATA**

Former Exxon Service Station 70104
1725 Park Street
Alameda, California

Well ID	Sampling Date	EDB (µg/L)	1,2-DCA (µg/L)	TAME (µg/L)	TBA (µg/L)	ETBE (µg/L)	DIPE (µg/L)	Ethanol (µg/L)	
MW8	12/13/05	<0.500	<0.500	<0.500	<10.0	<0.500	<0.500	<50.0	
MW8	03/13/06	<0.50	<0.50	<0.50	<5.0	<0.50	<0.50	---	
MW8	06/12/06	<0.50	<0.50	<0.50	<5.0	<0.50	<0.50	---	
MW8	09/08/06	<0.50	<0.50	<0.50	6.9	<0.50	<0.50	---	
MW8	12/05/06	<0.50	<0.50	<0.50	<5.0	<0.50	<0.50	---	
MW8	03/12/07	<0.50	<0.50	<0.50	<5.0	<0.50	<0.50	---	
MW8	05/29/07	<0.500	<0.500	<0.500	<10.0	<0.500	<0.500	---	
MW8	08/29/07	<0.50	<0.50	<0.50	<10	<0.50	<0.50	---	
MW8	11/29/07	<0.50	<0.50	<0.50	<10	<0.50	<0.50	---	
MW8	02/27/08	<0.50	<0.50	<0.50	<5.0	<0.50	<0.50	---	
MW8	05/28/08	<0.500	<0.500	<0.500	<10.0	<0.500	<0.500	---	
MW8	08/27/08	<0.50	<0.50	<0.50	<5.0	<0.50	<0.50	<50	
MW8	11/25/08	<0.50	<0.50	<0.50	<5.0	<0.50	<0.50	<50	
MW8	02/25/09	<0.50	<0.50	<0.50	<5.0	<0.50	<0.50	---	
MW8	05/27/09	<0.50	<0.50	<0.50	<5.0	<0.50	<0.50	---	
MW9	09/12/94 - 04/14/00	Not analyzed for these analytes.							
MW9	06/16/00	Property transferred to Valero Refining Company.							
MW9	07/05/00 - 02/04/02	Not analyzed for these analytes.							
MW9	05/06/02	<0.50	<0.50	<0.50	<10.0	<0.50	<0.50	---	
MW9	08/22/02 - 11/14/03	Not analyzed for these analytes.							
MW9	03/01/04	<0.50	<0.50	<0.50	<10.0	<0.50	<0.50	---	
MW9	06/15/04	---	---	---	---	---	---	<100	
MW9	09/13/04	---	---	---	---	---	---	---	
MW9	12/22/04	---	---	---	---	---	---	---	
MW9	03/24/05	<0.50	<0.50	<0.50	<10.0	<0.50	<0.50	<50.0	
MW9	06/14/05	<0.50	<0.50	<0.50	<10.0	<0.50	<0.50	<50.0	
MW9	09/12/05	<0.500	<0.500	<0.500	<10.0	<0.500	<0.500	<50.0	
MW9	12/13/05	<0.500	<0.500	<0.500	<10.0	<0.500	<0.500	<50.0	
MW9	03/13/06	<0.50	<0.50	<0.50	<5.0	<0.50	<0.50	---	
MW9	06/12/06	<0.50	<0.50	<0.50	<5.0	<0.50	<0.50	---	
MW9	09/08/06	<0.50	<0.50	<0.50	<5.0	<0.50	<0.50	---	
MW9	12/05/06	<0.50	<0.50	<0.50	<5.0	<0.50	<0.50	---	
MW9	03/12/07	<0.50	<0.50	<0.50	<5.0	<0.50	<0.50	---	
MW9	05/29/07	<0.500	<0.500	<0.500	<10.0	<0.500	<0.500	---	
MW9	08/29/07	<0.50	<0.50	<0.50	<10	<0.50	<0.50	---	
MW9	11/29/07	<0.50	<0.50	<0.50	<10	<0.50	<0.50	---	
MW9	02/27/08	<0.50	<0.50	<0.50	<5.0	<0.50	<0.50	---	
MW9	05/28/08	<0.500	<0.500	<0.500	<10.0	<0.500	<0.500	---	
MW9	08/27/08	<0.50	<0.50	<0.50	<5.0	<0.50	<0.50	<50	
MW9	11/25/08	<0.50	<0.50	<0.50	<5.0	<0.50	<0.50	<50	
MW9	02/25/09	<0.50	<0.50	<0.50	<5.0	<0.50	<0.50	---	
MW9	05/27/09	<0.50	<0.50	<0.50	<5.0	<0.50	<0.50	---	

**TABLE 1B
ADDITIONAL CUMULATIVE GROUNDWATER MONITORING AND SAMPLING DATA**

Former Exxon Service Station 70104
1725 Park Street
Alameda, California

Well ID	Sampling Date	EDB (µg/L)	1,2-DCA (µg/L)	TAME (µg/L)	TBA (µg/L)	ETBE (µg/L)	DIPE (µg/L)	Ethanol (µg/L)
MW10	09/12/94 - 10/08/97	Not analyzed for these analytes.						
MW10	12/12/97	Well destroyed.						
MW11	09/12/94 - 04/14/00	Not analyzed for these analytes.						
MW11	06/16/00	Property transferred to Valero Refining Company.						
MW11	07/05/00 - 02/04/02	Not analyzed for these analytes.						
MW11	05/06/02	<0.50	<0.50	<0.50	311	1.00	<0.50	---
MW11	08/22/02 - 11/14/03	Not analyzed for these analytes.						
MW11	03/01/04	<0.50	<0.50	<0.50	21	<0.50	<0.50	---
MW11	06/15/04	---	---	---	---	---	---	<100
MW11	09/13/04	---	---	---	---	---	---	---
MW11	12/22/04	---	---	---	---	---	---	---
MW11	03/24/05	<0.50	<0.50	<0.50	<10.0	<0.50	<0.50	<50.0
MW11	06/14/05	<0.50	<0.50	<0.50	49.0	<0.50	<0.50	<50.0
MW11	09/12/05	<0.500	<0.500	<0.500	24.2	<0.500	<0.500	<50.0
MW11	12/13/05	<0.500	<0.500	<0.500	70.8	<0.500	<0.500	<50.0
MW11	03/13/06	<0.50	<0.50	<0.50	<5.0	<0.50	<0.50	---
MW11	06/12/06	<0.50	<0.50	<0.50	56	<0.50	<0.50	---
MW11	09/08/06	<0.50	<0.50	<0.50	<5.0	<0.50	<0.50	---
MW11	12/05/06	<0.50	<0.50	<0.50	<5.0	<0.50	<0.50	---
MW11	03/12/07	<0.50	<0.50	<0.50	45	<0.50	<0.50	---
MW11	05/29/07	<0.500	<0.500	<0.500	<10.0	<0.500	<0.500	---
MW11	08/29/07	<0.50	<0.50	<0.50	100	<0.50	<0.50	---
MW11	11/29/07	<0.50	<0.50	<0.50	110	<0.50	<0.50	---
MW11	02/27/08	<0.50	<0.50	<0.50	31	<0.50	<0.50	---
MW11	05/28/08	<0.500	<0.500	<0.500	<10.0	<0.500	<0.500	---
MW11	08/27/08	<25	<25	<25	<250	<25	<25	<2,500
MW11	11/25/08	<25	<25	<25	<250	<25	<25	<2,500
MW11	02/25/09	<2.5	<2.5	<2.5	<25	<2.5	<2.5	---
MW11	05/27/09	<10	18	<10	120	<10	<10	---
MW12	10/17/95 - 04/14/00	Not analyzed for these analytes.						
MW12	06/16/00	Property transferred to Valero Refining Company.						
MW12	07/05/00 - Present	Not analyzed for these analytes.						
EW1	09/12/94 - 04/14/00	Not analyzed for these analytes.						
EW1	06/16/00	Property transferred to Valero Refining Company.						
EW1	07/05/00 - Present	Not analyzed for these analytes.						
EW2	09/12/94 - 04/14/00	Not analyzed for these analytes.						

TABLE 1B
ADDITIONAL CUMULATIVE GROUNDWATER MONITORING AND SAMPLING DATA

Former Exxon Service Station 70104
 1725 Park Street
 Alameda, California

Well ID	Sampling Date	EDB (µg/L)	1,2-DCA (µg/L)	TAME (µg/L)	TBA (µg/L)	ETBE (µg/L)	DIPE (µg/L)	Ethanol (µg/L)
EW2	06/16/00	Property transferred to Valero Refining Company.						
EW2	07/05/00 - Present	Not analyzed for these analytes.						
EW3	09/12/94 - 04/14/00	Not analyzed for these analytes.						
EW3	06/16/00	Property transferred to Valero Refining Company.						
EW3	07/05/00 - Present	Not analyzed for these analytes.						
EW4	09/12/94 - 04/14/00	Not analyzed for these analytes.						
EW4	06/16/00	Property transferred to Valero Refining Company.						
EW4	07/05/00 - Present	Not analyzed for these analytes.						
EW5	09/12/94 - 04/14/00	Not analyzed for these analytes.						
EW5	06/16/00	Property transferred to Valero Refining Company.						
EW5	07/05/00 - Present	Not analyzed for these analytes.						

TABLE 1B
ADDITIONAL CUMULATIVE GROUNDWATER MONITORING AND SAMPLING DATA

Former Exxon Service Station 70104
 1725 Park Street
 Alameda, California

Notes:	
TOC Elev.	= Top of well casing elevation; datum is mean sea level.
DTW	= Depth to water.
GW Elev.	= Groundwater elevation; datum is mean sea level.
NAPL	= Non aqueous phase liquid.
TPHd	= Total petroleum hydrocarbons as diesel using EPA Method 5030/8015 (modified).
TPHg	= Total petroleum hydrocarbons as gasoline analyzed using EPA Method 5030/8015B (modified).
MTBE 8021B	= Methyl tertiary butyl ether analyzed using EPA Method 8021B.
MTBE 8260B	= Methyl tertiary butyl ether analyzed using EPA Method 8260B.
BTEX	= Benzene, toluene, ethylbenzene, and total xylenes analyzed using EPA Method 8021B.
EDB	= 1,2-dibromoethane analyzed using EPA Method 8260B.
1,2-DCA	= 1,2-dichloroethane analyzed using EPA Method 8260B.
TAME	= Tertiary amyl methyl ether analyzed using EPA Method 8260B.
TBA	= Tertiary butyl alcohol analyzed using EPA Method 8260B.
ETBE	= Ethyl tertiary butyl ether analyzed using EPA Method 8260B.
DIPE	= Di-isopropyl ether analyzed using EPA Method 8260B.
Ethanol	= Ethanol analyzed using EPA Method 8260B.
µg/L	= Micrograms per liter.
<	= Less than the stated laboratory method reporting limit.
---	= Not measured/Not sampled/Not analyzed.
a	= Total volatile hydrocarbons by DHS /LUFT Manual Method.
b	= Results obtained from a 1:10 dilution analyzed on January 17, 1995.
c	= Diesel-range hydrocarbons reportedly detected in bailer blank; result is suspect.
d	= Hydrocarbon pattern does not resemble the requested fuel.
e	= Well inaccessible.
f	= Analyte detected in laboratory method blank; result is suspect.
g	= Concentration estimated. Analyte exceeded calibration range. Reanalysis not performed due to holding time requirements.
h	= Initial analysis within holding time. Reanalysis for required dilution, confirmation, or QA/QC was past holding time.
i	= Elevated result due to single analyte peak(s) in the quantitation range.
j	= Calibration verification recovery above the method control limit. A high bias may be indicated.
k	= Elevated reporting limit due to high levels of non-target compounds.
l	= Analyte presence not confirmed by second column or GC/MS analysis.

TABLE 2
WELL CONSTRUCTION DETAILS
Former Exxon Service Station 70104
1725 Park Street
Alameda, California

Well ID	Well Installation Date	Well Destruction Date	TOC Elevation (feet)	Borehole Diameter (inches)	Total Depth of Boring (feet bgs)	Well Depth (feet bgs)	Casing Diameter (inches)	Well Casing Material	Screened Interval (feet bgs)	Slot Size (inches)	Filter Pack Interval (feet bgs)	Filter Pack Material
MW1 a	1988	---	17.29	NS	22	NS	4	NS	6-22	NS	NS	NS
MW2 a	1988	---	16.39	NS	16	NS	4	NS	3-15	NS	NS	NS
MW3 a	1988	---	17.02	NS	16	NS	4	NS	4-15	NS	NS	NS
MW4 a	1988	---	17.29	NS	21	NS	4	NS	4-19	NS	NS	NS
MW5 a	1988	---	16.64	NS	21	NS	4	NS	5-20	NS	NS	NS
MW6 a	1988	---	17.31	NS	21	NS	4	NS	5-20	NS	NS	NS
MW7 a	1988	---	17.06	NS	40	NS	4	NS	3-19	NS	NS	NS
MW8	05/05/93	---	16.24	8	21.5	19	2	PVC	5-19	0.020	3.5-19	#3 Sand
MW9	05/05/93	---	15.56	8	19	19	2	PVC	5-19	0.020	3.5-19	#3 Sand
MW10	NS	12/12/97	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS
MW11b	1995	---	17.98	8	20	20	2	PVC	5-20	0.020	4-20	#3 Sand
MW12b	1995	---	16.15	8	20	20	2	PVC	5-20	0.020	4-20	#3 Sand
EW1 a	Dec. 1991	---	16.27	NS	41	NS	4	NS	5-36	NS	NS	NS
EW2 a	Dec. 1991	---	16.07	NS	40	NS	NS	NS	5-35.5	NS	NS	NS
EW3 a	Dec. 1991	---	16.08	NS	40	NS	4	NS	5-35.5	NS	NS	NS
EW4 a	Dec. 1991	---	15.69	NS	40.5	NS	NS	NS	4-35.5	NS	NS	NS
EW5 a	Dec. 1991	---	16.67	NS	41	NS	4	NS	5-40	NS	NS	NS
SW1	11/10/93	---	NS	8	20.5	20	2	PVC	17.5-20	0.010	16-20	Pea Gravel

TABLE 2
WELL CONSTRUCTION DETAILS
Former Exxon Service Station 70104
1725 Park Street
Alameda, California

Well ID	Well Installation Date	Well Destruction Date	TOC Elevation (feet)	Borehole Diameter (inches)	Total Depth of Boring (feet bgs)	Well Depth (feet bgs)	Casing Diameter (inches)	Well Casing Material	Screened Interval (feet bgs)	Slot Size (inches)	Filter Pack Interval (feet bgs)	Filter Pack Material
SM1	11/10/93	---	NS	8	20.5	20	2	PVC	17.5-20	0.010	16-20	Pea Gravel
VW1	11/10/93	---	NS	8	7	7	2	PVC	4.5-7	0.020	4-7	#3 Sand
VW2	11/10/93	---	NS	8	7.5	7	2	PVC	4.5-7	0.020	4-7	#3 Sand

Notes:

- TOC = Top of well casing elevation; datum is mean sea level.
- PVC = Polyvinyl chloride.
- feet bgs = feet below ground surface.
- = Not measured.
- NS = Not specified.
- a = Boring logs unavailable; data obtained by using cross sections from ERI's Site Conceptual Model, dated August 2, 2002.
- b = Boring logs unavailable; data obtained from Delta Environmental's Proposed Additional Hydrogeologic Investigative Work, dated November 15, 1994; data are approximate values.

TABLE 3
OPERATION AND PERFORMANCE DATA FOR AIR SPARGE/SOIL VAPOR EXTRACTION SYSTEM
Former Exxon Service Station 70104
1725 Park Street
Alameda, California

Date	Hour Meter	Total Hours	Hours of Operation	Field Measurements						Laboratory Analytical Results			TPHg Removed		Benzene Removed		MTBE Removed		Benzene Emitted (lbs/day)		
				Temp EFF (deg F)	Pressure ("H2O)	Vacuum ("Hg)	Vacuum (in H2O)	Flow (fpm)	Flow (scfm)	Sample ID	PID (ppmv)	TPHg (mg/M ³)	MTBE (mg/M ³)	Benzene (mg/M ³)	Per Period (pounds)	Cumulative (pounds)	Per Period (pounds)	Cumulative (pounds)		Per Period (pounds)	Cumulative (pounds)
02/16/98	System startup.																				
	0																				
03/24/00	System shutdown pending evaluation.																				
	12,001	0																			
04/01/00	Environmental Resolutions Inc. assumed operation of the system.																				
06/28/00	System upgrades complete. System restarted. System shutdown for carbon changeout, 2 x 500-pounds.																				
	12,008	7	7				26			A-INF	770.0										
										A-INT	18.1										
										A-EFF	13.3										
07/11/00	System down on arrival; restart.																				
	12,011	10	3	86			8	4,000	85	A-INF	207.0	51	--	<1.0	0.16	<60.96	0.00	0.00			<0.01
										A-INT	9.1	<10	--	<1.0							
										A-EFF	0.0	<10	--	<1.0							
07/20/00	System running on arrival (vapor extraction system only). System running on departure.																				
	12,226	225	215	78			9	4,500	97	A-INF	42.3										
										A-INT	2.4										
										A-EFF	0.0										
07/31/00	System down on departure for carbon changeout (2x500-pounds).																				
	12,493	492	267	87			9	4,500	95	A-INF	266.0										
										A-INT	73.0										
										A-EFF	41.2										
08/10/00	System down on arrival for carbon changeout. System running on departure.																				
	12,733	732	0	80			30	800	17	A-INF	53.5	43	--	<1	6.46	<67.42	<0.14	0.13			<0.001
										A-INT	0.0	<10	--	<1							
										A-EFF	0.0	<10	--	<1							
08/16/00	12,874	873	141	84			31.5	250	5	A-INF	164.1										
										A-INT	0.0										
										A-EFF	0.0										
08/24/00	System down on departure for carbon changeout.																				
	13,055	1,064	191	76			20	2,400	52	A-INF	294.0										
										A-INT	23.7										
										A-EFF	2.4										
09/12/00	System down on arrival for carbon changeout. System running on departure.																				
	13,070	1,069	5	74			20	2,600	56	A-INF	247.5	190	--	2.5	5.39	<72.48	0.08	<0.21			<0.00
										A-INT	0.0	<10	--	<1.0							
										A-EFF	0.0	<10	--	<1.0							
09/26/00	13,406	1,405	336	80			22	2,450	52	A-INF	448.7										
										A-INT	10.7										
										A-EFF	0.0										
10/12/00	System running on arrival and down on departure for carbon changeout. Samples taken.																				
	13,786	1,785	380	67			24	2,400	53	A-INF	96.4	55	--	<1.0	17.86	<90.66	<0.26	<0.46			<0.004
										A-INT	72.3	21	--	<1.0							
										A-EFF	9.0	<10	--	<1.0							
10/30/00	System down on arrival for carbon changeout. System running on departure.																				
	13,788	1,787	2	56			24	2,450	55	A-INF	10,024	1,700	--	15	0.35	<91.01	0.00	<0.47			<0.005
										A-INT	59.1	<10	--	<1.0							
										A-EFF	0.0	<10	--	<1.0							

TABLE 3
OPERATION AND PERFORMANCE DATA FOR AIR SPARGE/SOIL VAPOR EXTRACTION SYSTEM
Former Exxon Service Station 70104
1725 Park Street
Alameda, California

Date	Field Measurements										Laboratory Analytical Results			TPHg Removed		Benzene Removed		MTBE Removed		Benzene Emitted (lbs/day)		
	Hour Meter	Total Hours	Hours of Operation	Temp EFF (deg F)	Pressure ("H2O)	Vacuum ("Hg)	Vacuum (in H2O)	Flow (fpm)	Flow (scfm)	Sample ID	PID (ppmv)	TPHg (mg/M ³)	MTBE (mg/M ³)	Benzene (mg/M ³)	Per Period (pounds)	Cumulative (pounds)	Per Period (pounds)	Cumulative (pounds)	Per Period (pounds)		Cumulative (pounds)	
11/08/00	14,008	2,007	220	60	--	--	25	2,300	51	A-INF A-INT A-EFF	102.6 41.8 0.0	29 <10 <10	-- -- --	<1.0 <1.0 <1.0	37.69	<128.70	<0.35	<0.81	--	--	<0.004	
11/21/00	System running on arrival, System down on departure for carbon changeout.																					
	14,314	2,313	306	68	--	--	25	2,300	50	A-INF A-INT A-EFF	322.0 32.3 42.9											
12/06/00	System down on arrival for carbon changeout, System down on departure for carbon changeout.																					
12/11/00	System down on arrival due to carbon changeout, System running on departure.																					
	14,316	2,315	2	52	--	--	24	2,400	54	A-INF A-INT A-EFF	957 1.2 3.1	240 <10 <10	-- -- --	2.1 <1.0 <1.0	8.15	<136.86	0.09	<0.91	--	--	<0.005	
12/27/00	14,697	2,696	381	56	--	--	26	2,600	58	A-INF A-INT A-EFF	192.1 4.8 0.0											
01/09/01	15,012	3,011	315	56	--	--	25	2,400	54	A-INF A-INT A-EFF	82.4 23.2 0.0	32 <10 <10	-- -- --	<1.0 <1.0 <1.0	19.10	<155.95	<0.22	<1.12	--	--	<0.005	
01/23/01	System down on departure for carbon changeout.																					
	15,353	3,352	341	60	--	--	26	2,300	51	A-INF A-INT A-EFF	485.0 35.2 20.7											
01/31/01	15,355	3,354	2	45	--	--	33	1,500	34	A-INF A-INT A-EFF	10,000 0 0											
02/13/01	15,669	3,668	314	56	--	--	12	4,000	90	A-INF A-INT A-EFF	37.8 29.5 0	31 <10 <10	-- -- --	<1.0 <1.0 <1.0	5.55	<161.50	<0.18	<1.31	--	--	<0.008	
02/27/01	System down on departure for changeout.																					
	15,999	3,998	330	70	--	--	8	4,000	87	A-INF A-INT A-EFF	316 37.5 73.6											
03/13/01	System down on arrival for changeout and running on departure, Monthly samples taken.																					
	16,002	4,001	3	65	--	--	9	4,000	88	A-INF A-INT A-EFF	5,833 190.4 0	1,300 16 11	-- -- --	6.1 <1.0 <1.0	73.60	<235.10	0.39	<1.69	--	--	<0.008	
03/27/01	System running on arrival and departure.																					
	16,336	4,335	334	62	--	--	10	4,000	89	A-INF A-INT A-EFF	182.6 16.8 0											
04/12/01	System running on arrival and departure.																					
	16,725	4,724	389	72	--	--	8	4,000	87	A-INF A-INT A-EFF	4.8 2.6 0											

TABLE 3
OPERATION AND PERFORMANCE DATA FOR AIR SPARGE/SOIL VAPOR EXTRACTION SYSTEM
Former Exxon Service Station 70104
1725 Park Street
Alameda, California

Date	Field Measurements										Laboratory Analytical Results			TPHg Removed		Benzene Removed		MTBE Removed		Benzene Emitted (lbs/day)	
	Hour Meter	Total Hours	Hours of Operation	Temp EFF (deg F)	Pressure ("H2O)	Vacuum ("Hg)	Vacuum (in H2O)	Flow (fpm)	Flow (scfm)	Sample ID	PID (ppmv)	TPHg (mg/M ³)	MTBE (mg/M ³)	Benzene (mg/M ³)	Per Period (pounds)	Cumulative (pounds)	Per Period (pounds)	Cumulative (pounds)	Per Period (pounds)		Cumulative (pounds)
04/25/01	System running on arrival and departure.																				
	17,034	5,033	309	80	--	--	9	4,000	86	A-INF	18.6	<10	--	<1.0	<219.46	<454.56	<1.19	<2.86	--	--	<0.008
										A-INT	9.5	<10	--	<1.0							
										A-EFF	0	26	--	<1.0							
05/09/01	System running on arrival and departure.																				
	17,371	5,370	337	86	--	--	10	4,000	85	A-INF	11.3	<10	--	<1.0	<1.07	<455.64	<0.11	<2.99	--	--	<0.007
										A-INT	3.6	<10	--	<1.0							
										A-EFF	5.9	<10	--	<1.0							
05/24/01	System running on arrival and departure.																				
	17,734	5,733	363	86	--	--	20	3,050	65	A-INF	6.2										
										A-INT	1.6										
										A-EFF	3.1										
06/04/01	System running on arrival and departure.																				
	17,992	5,991	258	80	--	--	40	500	11	A-INF	496	280	--	<1.0	16.05	<471.69	<0.11	<3.11	--	--	<0.001
										A-INT	19.7	<10	--	<1.0							
										A-EFF	3.2	<10	--	<1.0							
06/19/01	System running on arrival and departure.																				
	18,353	6,352	361	80	--	--	38	500	11	A-INF	140										
										A-INT	6.4										
										A-EFF	3.0										
07/02/01	System running on arrival and departure.																				
	18,660	6,659	307	80	--	--	38	500	11	A-INF	7.2										
										A-INT	0.0										
										A-EFF	0.0										
07/17/01	System running on arrival and departure.																				
	19,028	7,027	368	75	--	--	10	4,000	86	A-INF	0.0	<10	--	<1.0	<27.27	<498.96	<0.19	<3.29	--	--	<0.008
										A-INT	0.0	<10	--	<1.0							
										A-EFF	0.0	<10	--	<1.0							
08/07/01	System running on arrival and shut down on departure for blower failure.																				
					--	--	--	--	--	A-INF											
										A-INT											
08/13/01	System down on arrival; blower removed awaiting replacement.																				
08/27/01	System down awaiting blower replacement.																				
09/10/01	System down awaiting blower replacement.																				
10/18/01	System down on arrival, installed blower, and running on departure.																				
	19,534	7,533	506	120	--	--	31	4,000	80	A-INF	568.0										
										A-INT	3.0										
										A-EFF	2.0										
10/24/01	System running on arrival and departure.																				
	19,673	7,672	139	80	--	--	41	3,300	71	A-INF	93.1	72	--	<1.0	7.76	<506.73	<0.19	<3.48	--	--	<0.006
										A-INT	7.3	<10	--	<1.0							
										A-EFF	5	<10	--	<1.0							
11/07/01	System running on arrival and down on departure for carbon changeout.																				
	20,012	8,011	339	74	--	--	45	3,000	65	A-INF	230.0	55	--	<1.0	5.46	<512.18	<0.09	<3.57	--	--	<0.005
										A-INT	27.0	<10	--	<1.0							
										A-EFF	5.1	<10	--	<1.0							

TABLE 3
OPERATION AND PERFORMANCE DATA FOR AIR SPARGE/SOIL VAPOR EXTRACTION SYSTEM
Former Exxon Service Station 70104
1725 Park Street
Alameda, California

Date	Field Measurements											Laboratory Analytical Results			TPHg Removed		Benzene Removed		MTBE Removed		Benzene Emitted (lbs/day)	
	Hour Meter	Total Hours	Hours of Operation	Temp EFF (deg F)	Pressure ("H2O)	Vacuum ("Hg)	Vacuum (in H2O)	Flow (fpm)	Flow (scfm)	Sample ID	PID (ppmv)	TPHg (mg/M ³)	MTBE (mg/M ³)	Benzene (mg/M ³)	Per Period (pounds)	Cumulative (pounds)	Per Period (pounds)	Cumulative (pounds)	Per Period (pounds)	Cumulative (pounds)		
11/21/01	System running on arrival and down on departure for carbon changeout. Samples taken.																					
	20,012	8,011	0	150	--	--	45	3,000	57	A-INF	373.0											
										A-INT	0.0											
										A-EFF	0											
12/12/01	System down on arrival, knockout tank High/High (H/H), and running on departure.																					
	20,361	8,360	349	142	--	--	46	3,000	58	A-INF	98.1	45	--	1.3	4.00	<516.18	0.09	<3.66	--	--	<0.005	
										A-INT	1.0	<10	--	<1.0								
										A-EFF	2.7	<10	--	<1.0								
12/27/01	System down on arrival and running on departure.																					
	20,508	8,507	147	142	--	--	44	2,400	46	A-INF	2,396											
										A-INT	2.4											
										A-EFF	0											
01/09/02	System down on arrival, knockout tank H/H, and running on departure.																					
	20,541	8,540	33	148	--	--	42	2,700	51	A-INF	794.5	670	--	8.0	13.10	<529.28	0.17	<3.82	--	--	<0.004	
										A-INT	36.2	<10	--	<1.0								
										A-EFF	2	<10	--	<1.0								
01/23/02	System running on arrival and down on departure for carbon changeout																					
	20,876	8,875	335	136	--	--	45	3,800	74	A-INF	41.2											
										A-INT	8.3											
										A-EFF	7.2											
02/06/02	System down on arrival and running on departure.																					
	20,877	8,876	1	50	--	--	50	3,000	68	A-INF	260	458	--	24.5	42.27	<571.55	1.22	<4.92	--	--	<0.003	
										A-INT	4.9	<5.00	--	<0.500								
										A-EFF	0.1	<5.00	--	<0.500								
02/21/02	System running on arrival and on departure.																					
	21,237	9,236	360	158	--	--	50	2,600	49	A-INF	189.8											
										A-INT	4.7											
										A-EFF	0.0											
03/06/02	System running on arrival and on departure.																					
	21,549	9,548	312	152	--	--	45	2,800	53	A-INF	185.2	82.3	--	2.90	41.02	<612.57	2.08	<6.90	--	--	<0.002	
										A-INT	14.2	15.1	--	<0.500								
										A-EFF	1.4	16.0	--	<0.500								
03/21/02	System running on arrival and departure. Installed pressure gauge for field reading.																					
	21,913	9,912	364	146	--	--	38	3,200	61	A-INF	96.3											
										A-INT	1.5											
										A-EFF	1.7											
04/10/02	System running on arrival and down on departure.																					
	22,393	10,392	480	76	--	--	45	3,200	69	A-INF	64.3	12.0	--	0.16	9.07	<621.64	0.29	<7.40	--	--	<0.001	
										A-INT	19.6	<10	--	<0.10								
										A-EFF	6	<10	--	<0.10								
05/08/02	System down on arrival and running on departure.																					
	22,394	10,393	1	109	--	--	37	3,000	61	A-INF	354.1	440.0	--	3.2	0.05	<621.69	0.00	<7.43	--	--	<0.000	
										A-INT	16.7	<10	--	<0.10								
										A-EFF	11.9	10	--	<0.10								
05/16/02	System running on arrival and on departure.																					
	22,592	10,591	198	118	7	--	41	2,800	57	A-INF	98.1											
										A-INT	3.9											
										A-EFF	3.9											

TABLE 3
OPERATION AND PERFORMANCE DATA FOR AIR SPARGE/SOIL VAPOR EXTRACTION SYSTEM
Former Exxon Service Station 70104
1725 Park Street
Alameda, California

Date	Hour Meter	Total Hours	Hours of Operation	Temp EFF (deg F)	Field Measurements				Flow (fpm)	Flow (scfm)	Sample ID	PID (ppmv)	Laboratory Analytical Results			TPHg Removed		Benzene Removed		MTBE Removed		Benzene Emitted (lbs/day)	
					Pressure ("H2O)	Vacuum ("Hg)	Vacuum (in H2O)	TPHg (mg/M ³)					MTBE (mg/M ³)	Benzene (mg/M ³)	Per Period (pounds)	Cumulative (pounds)	Per Period (pounds)	Cumulative (pounds)	Per Period (pounds)	Cumulative (pounds)			
05/22/02	System running on arrival and on departure.																						
	22,731	10,730	139	118	7	--	38	2,800	57	A-INF	98.1												
										A-INT	3.9												
										A-EFF	3.9												
06/05/02	System running on arrival and down on departure for carbon changeout																						
	23,068	11,067	337	118	--	--	38	3,000	60	A-INF	101.1												
										A-INT	10.1												
										A-EFF	18.2												
06/19/02	System down on arrival and running on departure																						
	23,068	11,067	0	76	--	--	9	3,000	65	A-INF	178.8	120.0	--	0.83	44.32	<666.01	0.32	<7.73	--	--	<0.001		
										A-INT	0.0	<10	--	<0.10									
										A-EFF	0.0	<10	--	<0.10									
07/03/02	System running on arrival and departure.																						
	23,409	11,408	341	112	--	--	25	3,000	61	A-INF	62.2	33	--	0.25	6.11	<672.12	0.04	<7.79	--	--	<0.001		
										A-INT	0.0	<10	--	<0.10									
										A-EFF	0.0	<10	--	<0.10									
07/17/02	System down on arrival and running on departure.																						
	23,434	11,433	25	109	--	--	70	3,000	61	A-INF	82.2												
										A-INT	0.0												
										A-EFF	0.0												
07/31/02	System running on arrival and departure.																						
	23,764	11,763	330	110	--	--	21	3,000	61	A-INF	16.4												
										A-INT	0.0												
										A-EFF	0.0												
08/14/02	System running on arrival and departure.																						
	24,103	12,102	339	112	--	--	16	3,000	61	A-INF	9.8	19	--	0.21	4.09	<676.21	0.04	<7.83	--	--	<0.001		
										A-INT	0.0	<10	--	<0.10									
										A-EFF	0.0	<10	--	<0.10									
08/28/02	System running on arrival and down departure.																						
	24,414	12,413	311	110	--	--	16	3,000	61	A-INF	16.0												
										A-INT	0.0												
										A-EFF	0.0												
11/06/02	System down on arrival and running departure																						
	24,415	12,414	1	106	--	--	26	3,000	61	A-INF	1282	1,300	--	12	46.88	<723.10	0.43	<6.24	--	--	<0.001		
										A-INT	0.0	<10	--	<0.10									
										A-EFF	0.0	<10	--	<0.10									
11/20/02	System running on arrival and departure.																						
	24,754	12,753	339	122	--	--	36	3,300	66	A-INF	67.6												
										A-INT	1.1												
										A-EFF	0.0												
12/04/02	System running on arrival and departure.																						
	25,084	13,083	330	112	--	--	46	3,200	65	A-INF	47.5	<500	--	<5.0	<141.73	<864.83	<1.34	<9.48	--	--	<0.005		
										A-INT	0.2	<100	--	<1.0									
										A-EFF	0.0	<100	--	<1.0									
12/18/02	System running on arrival and departure. Carbon changeout performed.																						
	25,422	13,421	668	112	7	--	46	3,000	62	A-INF	76.1												
										A-INT	2.1												
										A-EFF	0.0												

TABLE 3
OPERATION AND PERFORMANCE DATA FOR AIR SPARGE/SOIL VAPOR EXTRACTION SYSTEM
Former Exxon Service Station 70104
1725 Park Street
Alameda, California

Date	Field Measurements										Laboratory Analytical Results			TPHg Removed		Benzene Removed		MTBE Removed		Benzene Emitted (lbs/day)		
	Hour Meter	Total Hours	Hours of Operation	Temp EFF (deg F)	Pressure ("H2O)	Vacuum ("Hg)	Vacuum (in H2O)	Flow (fpm)	Flow (scfm)	Sample ID	PID (ppmv)	TPHg (mg/M ³)	MTBE (mg/M ³)	Benzene (mg/M ³)	Per Period (pounds)	Cumulative (pounds)	Per Period (pounds)	Cumulative (pounds)	Per Period (pounds)		Cumulative (pounds)	
01/06/03	System running on arrival and on departure for carbon changeout.																					
	25,875	13,874	453	—	—	—	35	3200	80	A-INF	372.0											
										A-INT	602.0											
										A-EFF	604.0											
01/15/03	System down on arrival and running on departure.																					
	25,875	13,874	0	112	--	--	45	2,800	57	A-INF	134.0	110	--	1.4	54.68	<919.51	0.57	<10.11	--	--	<0.001	
										A-INT	1.3	22	--	<0.20								
										A-EFF	0.0	<20	--	<0.20								
01/29/03	System running on arrival and departure.																					
	26,210	14,209	335	114	--	--	45	2,700	54	A-INF	56.9											
										A-INT	0.0											
										A-EFF	0.0											
02/12/03	System running on arrival and departure.																					
	26,548	14,547	338	110	--	--	44	2,800	57	A-INF	50.6	24	--	0.27	9.55	<929.06	0.12	<10.28	--	--	<0.000	
										A-INT	3.4	90	--	1.1								
										A-EFF	0.0	<10	--	<0.10								
02/26/03	System running on arrival and departure. Carbon changeout performed																					
	26,884	14,883	336	112	--	--	44	2,300	46	A-INF	122.9											
										A-INT	1.9											
										A-EFF	0.0											
03/12/03	System running on arrival and departure. Carbon changeout performed																					
	27,218	15,217	334	120	--	--	43	2,600	52	A-INF	30.4	59	--	0.81	5.64	<934.71	0.07	<10.36	--	--	<0.000	
										A-INT	0.6	<10	--	<0.10								
										A-EFF	0.1	<10	--	<0.10								
03/26/03	System running on arrival and departure.																					
	27,555	15,554	337	116	--	--	40	2,700	54	A-INF	12.4											
										A-INT	2.5											
										A-EFF	0.1											
04/09/03	System running on arrival and departure.																					
	27,889	15,888	334	120	--	--	40	2,800	56	A-INF	36.0	57	--	0.36	7.83	<942.53	0.08	<10.45	--	--	<0.001	
										A-INT	2.4	<10	--	<0.10								
										A-EFF	1.0	<10	--	<0.10								
04/23/03	System running on arrival and departure.																					
	28,227	16,226	338	113	--	--	39	2,400	48	A-INF	54.7											
										A-INT	4.0											
										A-EFF	3.7											
05/07/03	System running on arrival and departure.																					
	28,563	16,562	336	118	--	--	40	2,500	50	A-INF	8.5	14	--	0.34	4.73	<947.27	0.05	<10.49	--	--	<0.000	
										A-INT	1.8	<10	--	<0.10								
										A-EFF	2.2	<10	--	<0.10								
05/21/03	System running on arrival and departure.																					
	28,900	16,899	337	127	--	--	38	2,750	54	A-INF	15.8											
										A-INT	2.4											
										A-EFF	1.3											
06/04/03	System running on arrival. System down on departure for carbon changeout.																					
	29,234	17,233	334	121	--	--	39	2,900	58	A-INF	81.2											
										A-INT	90.7											
										A-EFF	70.2											

TABLE 3
OPERATION AND PERFORMANCE DATA FOR AIR SPARGE/SOIL VAPOR EXTRACTION SYSTEM
Former Exxon Service Station 70104
1725 Park Street
Alameda, California

Date	Hour Meter	Total Hours	Hours of Operation	Temp EFF (deg F)	Field Measurements					Laboratory Analytical Results			TPHg Removed		Benzene Removed		MTBE Removed		Benzene Emitted (lbs/day)		
					Pressure ("H2O)	Vacuum ("Hg)	Vacuum (in H2O)	Flow (fpm)	Flow (scfm)	Sample ID	PID (ppmv)	TPHg (mg/M³)	MTBE (mg/M³)	Benzene (mg/M³)	Per Period (pounds)	Cumulative (pounds)	Per Period (pounds)	Cumulative (pounds)		Per Period (pounds)	Cumulative (pounds)
06/18/03	System down on arrival for changeout, System running on departure																				
	29,237	17,236	3	120	--	--	39	2,800	56	A-INF	120.0	790	--	12	53.58	<1,000.85	0.82	<11.32	--	--	<0.001
										A-INT	0.1	<10	--	0.13							
										A-EFF	0.1	<10	--	<0.10							
07/02/03	System running on arrival and departure																				
	29,576	17,575	339	120	--	--	38	3,200	64	A-INF	91.0	70	--	1.1	32.58	<1,033.43	0.50	<11.81	--	--	<0.001
										A-INT	0.0	<10	--	<0.10							
										A-EFF	0.1	<10	--	<0.10							
07/16/03	System running on arrival and departure																				
	29,910	17,909	334	129	--	--	39	3,150	62	A-INF	95.0										
										A-INT	6.6										
										A-EFF	2.5										
07/30/03	System running on arrival, Shut down for carbon changeout, Down on departure																				
	30,241	18,240	331	118	--	--	40	3,050	61	A-INF	51.7										
										A-INT	22.6										
										A-EFF	0.0										
08/13/03	System down on arrival, Restarted, Running on departure																				
	30,244	18,243	3	125	--	--	39	3,100	61	A-INF	321.0	110	--	1.9	14.05	<1,047.48	0.23	<12.05	--	--	<0.001
										A-INT	5.7	<10	--	<0.10							
										A-EFF	6.8	10	--	0.26							
08/27/03	System running on arrival and departure																				
	30,501	18,500	257	121	--	--	39	2,900	58	A-INF	122.6										
										A-INT	2.6										
										A-EFF	1.5										
09/10/03	System running on arrival and departure																				
	30,919	18,918	418	126	--	--	40	2,650	52	A-INF	117.0	93	--	2.4	14.54	<1,062.02	0.31	<12.35	--	--	<0.0005
										A-INT	6.4	<10	--	<0.10							
										A-EFF	3.0	<10	--	<0.10							
09/24/03	System running on arrival and departure																				
	31,256	19,255	337	120	--	--	38.5	3,150	63	A-INF	96.0										
										A-INT	17.0										
										A-EFF	0.6										
10/08/03	System running on arrival and departure																				
	31,587	19,586	331	120	--	--	38	3,000	60	A-INF	31.0	33	--	0.52	8.82	<1,070.84	0.20	<12.56	--	--	<0.0005
										A-INT	1.9	<10	--	<0.10							
										A-EFF	0.0	<10	--	<0.10							
10/22/03	System running on arrival, Shut down due to bad motor starter																				
	31,923	19,922	336	--	--	--	41	2,700	66	A-INF	36.0										
										A-INT	3.0										
										A-EFF	2.0										
11/03/03	System down on arrival and departure																				
11/12/03	System down on arrival and departure. Replaced blower motor starter heater assembly																				
11/17/03	System down on arrival, Restarted, Running on departure																				
	31,927	19,926	4	110	--	--	36	3,100	63	A-INF	262.0										
										A-INT	3.1										
										A-EFF	0.2										

TABLE 3
OPERATION AND PERFORMANCE DATA FOR AIR SPARGE/SOIL VAPOR EXTRACTION SYSTEM
Former Exxon Service Station 70104
1725 Park Street
Alameda, California

Date	Hour Meter	Total Hours	Hours of Operation	Temp EFF (deg F)	Field Measurements					Laboratory Analytical Results				TPHg Removed		Benzene Removed		MTBE Removed		Benzene Emitted (lbs/day)						
					Pressure ("H2O)	Vacuum ("Hg)	Vacuum (in H2O)	Flow (fpm)	Flow (scfm)	Sample ID	PID (ppmv)	TPHg (mg/M ³)	MTBE (mg/M ³)	Benzene (mg/M ³)	Per Period (pounds)	Cumulative (pounds)	Per Period (pounds)	Cumulative (pounds)	Per Period (pounds)		Cumulative (pounds)					
12/01/03	System running on arrival and departure				32,263	20,262	336	108	—	—	38	2,800	57	A-INF	25.3	26	—	0.55	4.35	<1,075.19	0.08	<12.64	—	—	<0.0005	
													A-INT	0.0	<10	—	<0.10									
													A-EFF	0.0	<10	—	<0.10									
12/15/03	System running on arrival and departure				32,600	20,599	337	102	10	—	32	3,400	72	A-INF	53.0											
													A-INT	7.0												
													A-EFF	2.7												
12/29/03	System running on arrival and departure				32,932	20,931	332	94	9.5	—	34	3,400	73	A-INF	46.9											
													A-INT	0.0												
													A-EFF	0.0												
01/12/04	System down on arrival, groundwater pump and treat transfer pump failure. System down for knockout drum replacement.																									
01/26/04	System down on arrival and departure, blower not starting (needs troubleshooting).																									
02/09/04	System retrofit complete, commencing startup with new blower and new Bay Area Air Quality Management District (BAAQMD) conditions.																									
06/27/05	Retrofitted system startup				33,268	21,267	336	72	1	—	136.1	3,900	85	A-INF	185.6	124	8.63	11.3	20.00	<1,095.18	1.58	<14.22	0.00	0.00	<0.0039	
													A-INT	0.0	<10.2	<0.508	<0.508									
													A-EFF	0.6	<10.2	<0.508	<0.508									
06/28/05	33,269	21,268	1	72	2	—	88.5	3,400	74	A-INF	34.1															
													A-INT	0.0												
													A-EFF	0.0												
06/29/05	Shut down system on departure for bi-weekly visitation request with the BAAQMD.																									
	33,289	21,288	20	72	1	—	74.9	2,800	61	A-INF	711.0															
													A-INT	0.0												
													A-EFF	0.0												
07/01/05	System down awaiting Bay Area Air Quality Management District permit modification.																									
07/08/05	Restart system with bi-weekly visitation frequency (BAAQMD).																									
	33,291	21,290	2	70	2	—	95.3	3,000	66	A-INF	571.0															
													A-INT	0.0												
													A-EFF	4.7												
07/11/05	Shut down system on departure for vapor-phase carbon (VPC) changeout 3@500-pounds.																									
	33,362	21,361	71	79	1	—	68.1	4,000	86	A-INF	1,683.0															
													A-INT	196.0												
													A-EFF	224.0												
07/15/05	Restarted system post VPC changeout. Added one more 500-pound vessel in series, three total before discharge to atmosphere.																									
	33,363	21,362	1	78	2	—	108.9	3,000	65	A-INF	440.0															
													A-INT1	0.0												
													A-INT2	0.0												
													A-EFF	0.0												
07/22/05	33,363	21,362	0	78	2	—	108.9	3,000	65	A-INF	440.0	799	71.8	72.7	12.27	<1,107.45	1.12	<15.33	1.07	1.07	<0.0029					
													A-INT1	0.0	20.2	4.87	2.03									
													A-INT2	—	—	—	—									
													A-EFF	0.0	<10.2	<609	0.508									
07/24/05	Responded to auto dialer callout. Shut down system, arranging for liquid-phase carbon (LPC) changeout (clogged) 3@500-pounds.																									
	33,462	21,461	99	80	2	—	108.9	2,600	56																	

TABLE 3
OPERATION AND PERFORMANCE DATA FOR AIR SPARGE/SOIL VAPOR EXTRACTION SYSTEM
Former Exxon Service Station 70104
1725 Park Street
Alameda, California

Date	Hour Meter	Total Hours	Hours of Operation	Temp EFF (deg F)	Field Measurements					Laboratory Analytical Results			TPHg Removed		Benzene Removed		MTBE Removed		Benzene Emitted (lbs/day)		
					Pressure ("H2O)	Vacuum ("Hg)	Vacuum (in H2O)	Flow (fpm)	Flow (scfm)	Sample ID	PID (ppmv)	TPHg (mg/M ³)	MTBE (mg/M ³)	Benzene (mg/M ³)	Per Period (pounds)	Cumulative (pounds)	Per Period (pounds)	Cumulative (pounds)		Per Period (pounds)	Cumulative (pounds)
07/29/05	33,462	21,461	0	--	--	--	--	--	--												
08/05/05	33,462	21,461	0	78	2	--	108.9	2,800	60	A-INF A-INT1 A-INT2 A-EFF	16.0 0.0 0.0 0.0	8.64 <5.00 <5.00 <5.00	0.704 <0.500 <0.500 <0.500	0.855 <0.500 <0.500 <0.500	9.36	<1,116.81	0.85	<16.19	0.84	1.91	<0.0027
08/12/05	33,470	21,469	8	78	2	--	108.9	2,600	56	A-INF A-INT1 A-INT2 A-EFF	56.0 46.0 6.0 0.0										
08/19/05	33,638	21,637	168	70	2	--	108.9	2,600	57	A-INF A-INT A-EFF	18.0 8.1 7.6										
08/26/05	33,638	21,637	0	70	2	--	108.9	2,600	57	A-INF A-INT1 A-INT2 A-EFF	56.0 0.0 0.0 0.0										
09/02/05	33,806	21,805	168	70	2	--	122.5	3,000	66	A-INF A-INT1 A-INT2 A-EFF	58.3 0.0 0.0 0.0										
09/09/05	33,974	21,973	168	70	2	--	122.5	2,600	57	A-INF A-INT1 A-INT2 A-EFF	58.3 0.0 0.0 0.0	14.4 <5.00 <5.00 <5.00	<0.500 <0.500 <0.500 <0.500	0.520 <0.500 <0.500 <0.500	1.29	<1,118.11	0.08	<16.26	<0.07	<1.98	<0.0025
09/16/05	34,142	22,141	168	70	2	--	108.9	3,600	79	A-INF A-INT1 A-INT2 A-EFF	168.0 3.0 0.0 0.0										
09/19/05	34,208	22,207	66	70	2	--	108.9	3,600	79	A-INF A-INT1 A-INT2 A-EFF	-- -- -- --										
10/07/05	34,208	22,207	0	70	2	--	108.9	3,600	78	A-INF A-INT1 A-INT2 A-EFF	6.0 21.0 0.0 0.0										

TABLE 3
OPERATION AND PERFORMANCE DATA FOR AIR SPARGE/SOIL VAPOR EXTRACTION SYSTEM
Former Exxon Service Station 70104
1725 Park Street
Alameda, California

Date	Hour Meter	Total Hours	Hours of Operation	Field Measurements								Laboratory Analytical Results			TPHg Removed		Benzene Removed		MTBE Removed		Benzene Emitted (lbs/day)
				Temp EFF (deg F)	Pressure ("H2O)	Vacuum ("Hg)	Vacuum (in H2O)	Flow (fpm)	Flow (scfm)	Sample ID	PID (ppmv)	TPHg (mg/M ³)	MTBE (mg/M ³)	Benzene (mg/M ³)	Per Period (pounds)	Cumulative (pounds)	Per Period (pounds)	Cumulative (pounds)	Per Period (pounds)	Cumulative (pounds)	
10/14/05	System shut down for blower repair and vapor piping size increase.																				
	34,335	22,334	127	—	—	—	—	—	—	—	A-INF	—									
											A-INT1	—									
											A-INT2	—									
											A-EFF	—									
02/23/06	System down on arrival. Retrofit complete. Restarted. Running on departure.																				
	3	34,338	3	69	—	—	122.5	3,000	147	A-INF	12.2										
										A-INT1	12.1										
										A-INT2	0.8										
										A-EFF	0.4										
02/24/06	System running on arrival and departure.																				
	24	34,359	21	70	2	—	136	1,600	79	A-INF	0.0	<5.00	<0.500	<0.500	<0.95	<1,119.06	<0.05	<16.31	<0.05	<2.03	<0.0035
										A-INT1	0.0	27.3	3.24	<0.500							
										A-INT2	0.0	<5.00	<0.500	<0.500							
										A-EFF	0.0	<5.00	<0.500	<0.500							
03/03/06	System running on arrival and departure.																				
	191	34,526	167	70	2	—	136	1,600	79	A-INF	0.0	24.5a	<0.500	<0.500	<0.73	<1,119.78	<0.02	<16.34	<0.02	<2.05	<0.0035
										A-INT1	0.0	58.9 a	<0.500	<0.500							
										A-INT2	0.0	5.00	<0.500	<0.500							
										A-EFF	0.0	5.00	<0.500	<0.500							
03/10/06	System running on arrival and departure.																				
	277	34,612	86	70	2	—	136	1,600	79	A-INF	0.0										
										A-INT1	0.0										
										A-INT2	0.0										
										A-EFF	0.0										
03/17/06	System down on arrival (well box high level). Restarted. Running on departure.																				
	375	34,710	98	70	2	—	136	1,200	59	A-INF	0.0										
										A-INT1	0.0										
										A-INT2	0.0										
										A-EFF	0.0										
03/24/06	System running on arrival and departure.																				
	510	34,845	135	70	2	—	136	1,400	69	A-INF	0.0										
										A-INT1	0.0										
										A-INT2	0.0										
										A-EFF	0.0										
03/31/06	System down on arrival (well box high level). Restarted. Running on departure.																				
	527	34,862	17	70	2	—	149.71	1,500	74	A-INF	0.0										
										A-INT1	0.0										
										A-INT2	0.0										
										A-EFF	0.0										
04/07/06	System running on arrival and departure.																				
	696	35,031	169	70	2	—	135.9	1,400	69	A-INF	0.0	<50.0	<0.500	0.535	<5.20	<1,124.98	<0.07	<16.41	<0.07	<2.12	<0.0031
										A-INT1	0.0	<50.0	0.571	<0.500							
										A-INT2	0.0	70.8 a	<0.500	<0.500							
										A-EFF	0.0	84.9 a	<0.500	<0.500							
04/13/06	System running on arrival, down on departure for carbon changeout.																				
	837	35,172	141	76	2	—	135.9	2,200	107	A-INF	1.5										
										A-INT1	43.9										
										A-INT2	30.3										
										A-EFF	26.0										

TABLE 3
OPERATION AND PERFORMANCE DATA FOR AIR SPARGE/SOIL VAPOR EXTRACTION SYSTEM
Former Exxon Service Station 70104
1725 Park Street
Alameda, California

Date	Hour Meter	Total Hours	Hours of Operation	Temp EFF (deg F)	Field Measurements					Laboratory Analytical Results			TPHg Removed		Benzene Removed		MTBE Removed		Benzene Emitted (lbs/day)		
					Pressure ("H2O)	Vacuum ("Hg)	Vacuum (in H2O)	Flow (fpm)	Flow (scfm)	Sample ID	PID (ppmv)	TPHg (mg/M ³)	MTBE (mg/M ³)	Benzene (mg/M ³)	Per Period (pounds)	Cumulative (pounds)	Per Period (pounds)	Cumulative (pounds)		Per Period (pounds)	Cumulative (pounds)
04/28/06	System down on arrival and running on departure (carbon changeout 3@500 lbs.)																				
	837	23,171	0	76	2	—	135.9	1,400	67	A-INF	0.0										
										A-INT1	0.0										
										A-INT2	0.0										
										A-EFF	0.0										
05/05/06	System running on arrival and departure.																				
	1,006	23,340	169	70	2	—	108.7	1,500	74	A-INF	0.0	b	b	b							
										A-INT1	0.0	b	b	b							
										A-INT2	0.0	<50.0	<0.500	<0.500							
										A-EFF	0.0	<50.0	<0.500	<0.500							
05/12/06	System running on arrival and departure.																				
	1,172	23,506	166	70	2	—	122.3	1,500	74	A-INF	0.0	<50.0	<0.500	<0.500	<6.36	<1,131.33	<0.07	<16.48	<0.06	<2.16	<0.0033
										A-INT1	0.0	<50.0	<0.500	<0.500							
										A-INT2	0.0	<50.0	<0.500	<0.500							
										A-EFF	0.0	<50.0	<0.500	<0.500							
05/19/06	System running on arrival and departure.																				
	1,339	23,673	167	70	2	—	135.9	1,600	79	A-INF	0.0										
										A-INT1	0.0										
										A-INT2	0.0										
										A-EFF	0.0										
05/25/06	System running on arrival and departure.																				
	1,485	23,819	146	70	2	—	135.9	1,600	79	A-INF	0.0										
										A-INT1	0.0										
										A-INT2	0.0										
										A-EFF	0.0										
06/02/06	System running on arrival and departure.																				
	1,676	24,010	191	70	2	—	135.9	1,500	79	A-INF	0.0										
										A-INT1	0.0										
										A-INT2	0.0										
										A-EFF	0.0										
06/09/06	System running on arrival and departure.																				
	1,846	24,180	170	70	2	—	135.9	1,499	74	A-INF	0.0										
										A-INT1	0.0										
										A-INT2	0.0										
										A-EFF	0.0										
06/16/06	System down on arrival and running on departure.																				
	1,967	24,301	121	70	2	—	135.9	1,400	69	A-INF	0.0	<50.0	2.73	<0.500	<10.61	<1,141.95	<0.11	<16.58	<0.34	<2.53	<0.0031
										A-INT1	0.0	—	—	—							
										A-INT2	0.0	<50.0	<0.500	<0.500							
										A-EFF	0.0	<50.0	<0.500	<0.500							
06/23/06	System running on arrival and departure.																				
	2,134	24,468	167	70	2	—	135.9	1,450	71	A-INF	0.0										
										A-INT1	0.0										
										A-INT2	0.0										
										A-EFF	0.0										
06/30/06	System running on arrival and departure.																				
	2,300	24,634	166	70	2	—	135.9	1,400	69	A-INF	0.0										
										A-INT1	0.0										
										A-INT2	0.0										
										A-EFF	0.0										

TABLE 3
OPERATION AND PERFORMANCE DATA FOR AIR SPARGE/SOIL VAPOR EXTRACTION SYSTEM
Former Exxon Service Station 70104
1725 Park Street
Alameda, California

Date	Field Measurements											Laboratory Analytical Results			TPHg Removed		Benzene Removed		MTBE Removed		Benzene Emitted (lbs/day)	
	Hour Meter	Total Hours	Hours of Operation	Temp EFF (deg F)	Pressure ("H2O)	Vacuum ("Hg)	Vacuum (in H2O)	Flow (fpm)	Flow (scfm)	Sample ID	PID (ppmv)	TPHg (mg/M ³)	MTBE (mg/M ³)	Benzene (mg/M ³)	Per Period (pounds)	Cumulative (pounds)	Per Period (pounds)	Cumulative (pounds)	Per Period (pounds)	Cumulative (pounds)		
07/05/06	System running on arrival and departure.																					
	2,424	24,758	124	70	2	—	135.9	2,000	98	A-INF	15.7	<50.0	<0.500	<0.500	<7.15	<1,149.10	<0.07	<16.65	<0.23	<2.76	<0.0044	
										A-INT1	0.0	<50.0	<0.500	<0.500								
										A-INT2	0.0	<50.0	<0.500	<0.500								
07/14/06	System running on arrival and departure.																					
	2,644	24,978	220	70	2	—	135.9	2,000	98	A-INF	240.0	<50.0	<0.500	<0.500								
										A-INT1	3.2	<50.0	<0.500	<0.500								
										A-INT2	0.0	<50.0	<0.500	<0.500								
07/20/06	System running on arrival and departure.																					
	2,804	25,138	160	70	2	—	135.9	1,800	89	A-INF	61.0	<50.0	<0.500	<0.500								
										A-INT1	0.0	<50.0	<0.500	<0.500								
										A-INT2	0.0	<50.0	<0.500	<0.500								
07/28/05	System running on arrival and departure.																					
	2,973	25,307	169	70	2	—	135.9	1,800	89	A-INF	56.0	<50.0	<0.500	<0.500								
										A-INT1	0.0	<50.0	<0.500	<0.500								
										A-INT2	0.0	<50.0	<0.500	<0.500								
08/04/06	System running on arrival and departure.																					
	3,144	25,478	171	70	2	—	135.9	1,800	89	A-INF	96.0	147	1.30	1.71	<24.82	<1,173.92	<0.28	<16.93	<0.23	<2.98	<0.0039	
										A-INT1	0.0	<50.0	<0.500	<0.500								
										A-INT2	0.0	<50.0	<0.500	<0.500								
08/11/06	System running on arrival and departure.																					
	3,308	25,642	164	70	2	—	135.9	2,200	108	A-INF	65.0	<50.0	<0.500	<0.500								
										A-INT1	0.0	<50.0	<0.500	<0.500								
										A-INT2	0.0	<50.0	<0.500	<0.500								
08/18/06	System running on arrival and departure.																					
	3,483	25,817	175	70	2	—	135.9	2,500	123	A-INF	60.0	<50.0	<0.500	<0.500								
										A-INT1	0.0	<50.0	<0.500	<0.500								
										A-INT2	0.0	<50.0	<0.500	<0.500								
08/25/06	System down on arrival (H/H moisture separator), restarted system.																					
	3,486	25,820	3	70	2	—	135.9	2,500	123	A-INF	56.0	<50.0	<0.500	<0.500								
										A-INT1	0.0	<50.0	<0.500	<0.500								
										A-INT2	0.0	<50.0	<0.500	<0.500								
09/01/06	System running on arrival and down for LPC changeout on departure.																					
	3,654	25,988	168	70	2	—	135.9	2,500	123	A-INF	27.0	<50.0	<0.500	<0.500								
										A-INT1	0.0	<50.0	<0.500	<0.500								
										A-INT2	0.0	<50.0	<0.500	<0.500								
09/15/06	System down on arrival, (carbon changeout completed), restarted system.																					
	3,657	25,991	3	70	2	—	135.9	2,500	123	A-INF	0.0	<50.0	<0.500	<0.500								
										A-INT1	0.0	<50.0	<0.500	<0.500								
										A-INT2	0.0	<50.0	<0.500	<0.500								

TABLE 3
OPERATION AND PERFORMANCE DATA FOR AIR SPARGE/SOIL VAPOR EXTRACTION SYSTEM
Former Exxon Service Station 70104
1725 Park Street
Alameda, California

Date	Hour Meter	Total Hours	Hours of Operation	Field Measurements								Laboratory Analytical Results			TPHg Removed		Benzene Removed		MTBE Removed		Benzene Emitted (lbs/day)
				Temp EFF (deg F)	Pressure ("H2O)	Vacuum ("Hg)	Vacuum (in H2O)	Flow (fpm)	Flow (scfm)	Sample ID	PID (ppmv)	TPHg (mg/M ³)	MTBE (mg/M ³)	Benzene (mg/M ³)	Per Period (pounds)	Cumulative (pounds)	Per Period (pounds)	Cumulative (pounds)	Per Period (pounds)	Cumulative (pounds)	
09/22/06	System down on arrival, locked out/lagged out system for repair																				
10/06/06	3,734	26,068	77	70	2	—	136.1	2,500	123	A-INF A-INT1 A-INT2 A-EFF	30.0 0.0 0.0 0.0										
10/13/06	3,742	26,076	8	70	2	—	136.1	2,500	123	A-INF A-INT1 A-INT2 A-EFF	60.0 0.0 0.0 0.0										
10/20/06	System down on arrival. System shut down for carbon changeout.																				
	3,744	26,078	2	70	2	—	—	—	—	A-INF A-INT1 A-INT2	— — —										
10/27/06	System down on arrival for carbon changeout. System running on departure.																				
	3,744	26,078	0	70	2	—	136.1	2,500	123	A-INF A-INT1 A-INT2 A-EFF	204.0 1.0 0.0 0.0	<50.0 <50.0 <50.0 <50.0	<0.500 2.08 <0.500 <0.500	<23.40 <1,197.32	<0.26 <17.19	<0.21 <3.20	<0.0055				
11/03/06	System running on arrival and departure.																				
	3,915	26,249	171	70	0	—	136.1	2,500	122	A-INF A-INT1 A-INT2 A-EFF	10.0 0.0 0.0 0.0										
11/10/06	System running on arrival and departure.																				
	4,079	26,413	164	100	2	—	136.1	2,500	117	A-INF A-INT1 A-INT2 A-EFF	72.0 2.0 0.0 0.0	141 65.4 <50.0 <50.0	2.68 3.46 1.31 0.686	<14.34 <1,211.65	<0.25 <17.45	<0.24 <3.44	<0.0120				
11/14/06	System running on arrival and departure.																				
	4,135	26,469	56	110	1	—	149.7	2,500	114	A-INF A-INT1 A-INT2 A-EFF	53.0 1.0 0.0 0.0										
11/20/06	System running on arrival and departure.																				
	4,321	26,655	186	110	1	—	149.7	2,500	114	A-INF A-INT1 A-INT2 A-EFF	63.0 0.0 0.0 0.0										
11/27/06	System running on arrival and departure.																				
	4,487	26,821	166	110	1	—	136.1	2,500	114	A-INF A-INT1 A-INT2 A-EFF	63.0 0.0 0.0 0.0										

TABLE 3
OPERATION AND PERFORMANCE DATA FOR AIR SPARGE/SOIL VAPOR EXTRACTION SYSTEM
Former Exxon Service Station 70104
1725 Park Street
Alameda, California

Date	Hour Meter	Total Hours	Hours of Operation	Temp EFF (deg F)	Field Measurements					Laboratory Analytical Results			TPHg Removed		Benzene Removed		MTBE Removed		Benzene Emitted (lbs/day)																									
					Pressure ("H2O)	Vacuum ("Hg)	Vacuum (in H2O)	Flow (fpm)	Flow (scfm)	Sample ID	PID (ppmv)	TPHg (mg/M³)	MTBE (mg/M³)	Benzene (mg/M³)	Per Period (pounds)	Cumulative (pounds)	Per Period (pounds)	Cumulative (pounds)		Per Period (pounds)	Cumulative (pounds)																							
12/05/06	System running on arrival and departure.				100	1	10	136.1	2,600	121	A-INF	10.0	<50.0	<0.500	<0.500	<25.35	<1,237.00	<0.45	<17.89	<0.42	<3.86	<0.0054																						
	4,677	27,011	190																																									
12/15/06	System down on arrival and running on departure.				110	1	---	136.1	2,500	114	A-INF	16.0	<50.0	<0.500	<0.500																													
	4,784	27,118	107																																									
12/21/06	System running on arrival and departure.				100	10	---	136.1	2,500	119	A-INF	46.0	<50.0	<0.500	<0.500																													
	4,952	27,286	168																																									
12/27/06	System down on arrival and running on departure.				120	10	11	149.7	2,250	103	A-INF	0.0	<50.0	<0.500	<0.500																													
	5,039	27,373	87																																									
01/05/07	System down on arrival and running on departure.				110	10	10	136.1	2,400	112	A-INF	0.0	<50.0	<0.500	<0.500																													
	5,137	27,471	98																																									
01/12/07	System running on arrival and departure.				110	10	10	136.1	2,400	112	A-INF	10.0	<50.0	<0.500	<0.500	<13.50	<1,250.51	<0.14	<18.03	<0.14	<3.99	<0.0050																						
	5,297	27,631	160																																									
01/19/07	System down on arrival and running on departure.				110	10	10	136.1	2,400	112	A-INF	6.0	<50.0	<0.500	<0.500																													
	5,370	27,704	73																																									
01/28/07	System running on arrival and departure.				110	10	8	108.8	2,600	121	A-INF	6.0	<50.0	<0.500	<0.500																													
	5,528	27,862	158																																									
02/02/07	System running on arrival and departure.				90	9	8	108.8	2,400	116	A-INF	8.0	<50.0	<0.500	<0.500	<8.50	<1,259.01	<0.09	<18.11	<0.09	<4.08	<0.0052																						
	5,696	28,030	168																																									
02/09/07	System running on arrival and departure.				90	9	9	122.5	2,400	116	A-INF	9.0	<50.0	<0.500	<0.500																													
	5,865	28,199	169																																									

TABLE 3
OPERATION AND PERFORMANCE DATA FOR AIR SPARGE/SOIL VAPOR EXTRACTION SYSTEM
Former Exxon Service Station 70104
1725 Park Street
Alameda, California

Date	Hour Meter	Total Hours	Hours of Operation	Field Measurements					Laboratory Analytical Results			TPHg Removed		Benzene Removed		MTBE Removed		Benzene Emitted (lbs/day)			
				Temp EFF (deg F)	Pressure ("H2O)	Vacuum ("Hg)	Vacuum (in H2O)	Flow (fpm)	Flow (scfm)	Sample ID	PID (ppmv)	TPHg (mg/M ³)	MTBE (mg/M ³)	Benzene (mg/M ³)	Per Period (pounds)	Cumulative (pounds)	Per Period (pounds)		Cumulative (pounds)	Per Period (pounds)	Cumulative (pounds)
02/16/07	System running on arrival and locked out/tagged out on departure.																				
	6,033	28,367	168	110	0	9	122.5	2,400	109	A-INF	9.0										
										A-INT1	0.0										
										A-INT2	0.0										
										A-EFF	0.0										
02/23/07	System locked out/tagged out on arrival and departure.																				
03/02/07	System locked out/tagged out on arrival and departure.																				
03/09/07	System locked out/tagged out on arrival and departure.																				
04/03/07	System locked out/tagged out on arrival, restarted, and running on departure.																				
	6,033	28,367	0	110	0	9	122.45	2,600	118	A-INF	2.0										
										A-INT1	0.0										
										A-INT2	0.0										
										A-EFF	0.0										
04/12/07	System running on arrival and departure.																				
	6,240	28,574	207	90	0	9	122.45	2,600	123	A-INF	2.0	<50.0	<0.500	<0.500	<12.14	<1,271.14	<0.12	<18.23	<0.12	<4.20	<0.0055
										A-INT1	0.0	<50.0	0.703	0.888							
										A-INT2	0.0	<50.0	0.646	<0.500							
										A-EFF	0.0	<50.0	<0.500	<0.500							
04/20/07	System running on arrival and departure.																				
	6,430	28,764	190	110	0	8	108.84	2,600	118	A-INF	3.0										
										A-INT1	0.0										
										A-INT2	0.0										
										A-EFF	0.0										
04/25/07	System down on arrival and running on departure.																				
	6,475	28,809	45	110	0	8	108.84	2,600	118	A-INF	4.0										
										A-INT1	0.0										
										A-INT2	0.0										
										A-EFF	0.0										
05/04/07	System down on arrival and running on departure.																				
	6,491	28,825	16	110	0	8	108.84	2,600	118	A-INF	2.0										
										A-INT1	0.0										
										A-INT2	0.0										
										A-EFF	0.0										
05/11/07	System down on arrival and running on departure.																				
	6,647	28,981	156	120	0	8	108.84	2,600	116	A-INF	4.0	<50.0	<0.500	<0.500	<9.10	<1,280.25	<0.09	<18.32	<0.09	<4.29	<0.0052
										A-INT1	0.0	<50.0	0.973	<0.500							
										A-INT2	0.0	<50.0	<0.500	<0.500							
										A-EFF	0.0	<50.0	<0.500	<0.500							
05/17/07	System down on arrival and running on departure.																				
	6,760	29,094	113	100	0	6	81.63	2,600	121	A-INF	3.0										
										A-INT1	0.0										
										A-INT2	0.0										
										A-EFF	0.0										
05/25/07	System running on arrival and departure.																				
	6,930	29,264	170	100	0	6	81.63	2,600	121	A-INF	2.0										
										A-INT1	0.0										
										A-INT2	0.0										
										A-EFF	0.0										

TABLE 3
OPERATION AND PERFORMANCE DATA FOR AIR SPARGE/SOIL VAPOR EXTRACTION SYSTEM
Former Exxon Service Station 70104
1725 Park Street
Alameda, California

Date	Hour Meter	Total Hours	Hours of Operation	Temp EFF (deg F)	Field Measurements					Laboratory Analytical Results			TPHg Removed		Benzene Removed		MTBE Removed		Benzene Emitted (lbs/day)		
					Pressure ("H2O)	Vacuum ("Hg)	Vacuum (in H2O)	Flow (fpm)	Flow (scfm)	Sample ID	PID (ppmv)	TPHg (mg/M ³)	MTBE (mg/M ³)	Benzene (mg/M ³)	Per Period (pounds)	Cumulative (pounds)	Per Period (pounds)	Cumulative (pounds)		Per Period (pounds)	Cumulative (pounds)
06/08/07	System running on arrival and shut down on departure.																				
	7,284	29,618	354	100	0	6	81.63	2,600	121	A-INF	4.0										
										A-INT1	0.0										
										A-INT2	0.0										
										A-EFF	0.0										
06/21/07	System down on arrival and running on departure.																				
	7,428	29,762	144	100	0	8	108.84	2,600	121	A-INF	1.0	b	b	b							
										A-INT1	0.0	<50.0	<0.500	<0.500							
										A-INT2	0.0	<50.0	1.17	<0.500							
										A-EFF	0.0	<50.0	<0.500	<0.500							
06/29/07	System down on arrival and running on departure.																				
	7,615	29,949	187	150	0	8	108.84	2,600	111	A-INF	1.0	<50.0	<0.500	<0.500	<20.56	<1,300.80	<0.21	<18.53	<0.21	<4.50	<0.0050
										A-INT1	0.0	<50.0	<0.500	0.753							
										A-INT2	0.0	<50.0	1.81	<0.500							
										A-EFF	0.0	<50.0	<0.500	<0.500							
07/06/07	System down on arrival and running on departure.																				
	7,660	29,994	45	150	0	7	95.24	2,400	102	A-INF	0.0										
										A-INT1	0.0										
										A-INT2	0.0										
										A-EFF	0.0										
07/11/07	System down on arrival and running on departure.																				
	7,703	30,037	43	110	0	8	108.84	2,600	118	A-INF	1.0										
										A-INT1	0.0										
										A-INT2	0.0										
										A-EFF	0.0										
07/18/07	System down on arrival and running on departure.																				
	7,819	30,153	116	80	0	6	81.63	3,000	144	A-INF	1.0										
										A-INT1	0.0										
										A-INT2	0.0										
										A-EFF	0.0										
07/20/07	System down on arrival and running on departure.																				
	7,858	30,192	39	--	--	--	--	--	--	A-INF	--										
										A-INT1	--										
										A-INT2	--										
										A-EFF	--										
07/24/07	System running on arrival and departure.																				
	7,952	30,286	94	70	0	6	81.63	3,200	157	A-INF	1.0										
										A-INT1	0.0										
										A-INT2	0.0										
										A-EFF	0.0										
07/31/07	System running on arrival and departure.																				
	8,120	30,454	168	70	0	6	81.63	3,400	167	A-INF	1.0	<50.0	<0.500	<0.500	<13.09	<1,313.90	<0.13	<18.66	<0.13	<4.63	--
										A-INT1	0.0	<50.0	<0.500	<0.500							
										A-INT2	0.0	<50.0	<0.500	<0.500							
										A-EFF	0.0	b	b	b							
08/09/07	System running on arrival and departure.																				
	8,337	30,671	217	80	0	6	81.63	3,400	164	A-INF	0.0	1,100	27.5	29.7	<77.03	<1,390.92	<2.02	<20.68	<1.88	<6.50	<0.0073
										A-INT1	0.0	<50.0	<0.500	<0.500							
										A-INT2	0.0	<50.0	<0.500	<0.500							
										A-EFF	0.0	<50.0	<0.500	<0.500							

TABLE 3
OPERATION AND PERFORMANCE DATA FOR AIR SPARGE/SOIL VAPOR EXTRACTION SYSTEM
Former Exxon Service Station 70104
1725 Park Street
Alameda, California

Date	Hour Meter	Total Hours	Hours of Operation	Temp EFF (deg F)	Field Measurements							Laboratory Analytical Results			TPHg Removed		Benzene Removed		MTBE Removed		Benzene Emitted (lbs/day)		
					Pressure ("H2O)	Vacuum ("Hg)	Vacuum (in H2O)	Flow (fpm)	Flow (scfm)	Sample ID	PID (ppmv)	TPHg (mg/M ³)	MTBE (mg/M ³)	Benzene (mg/M ³)	Per Period (pounds)	Cumulative (pounds)	Per Period (pounds)	Cumulative (pounds)	Per Period (pounds)	Cumulative (pounds)			
12/19/07	System down on arrival and running on departure.																						
	11,262	33,596	1	160	0	6.5	88.44	2,800	117	A-INF	0.0												
										A-INT1	0.0												
										A-INT2	0.0												
										A-EFF	0.0												
12/21/07	System running on arrival and departure.																						
	11,303	33,637	41	160	0	6.5	88.44	2,800	117	A-INF	0.0												
										A-INT1	0.0												
										A-INT2	0.0												
										A-EFF	0.0												
12/27/07	System running on arrival and departure.																						
	11,470	33,804	167	160	0	6.5	88.44	2,800	117	A-INF	0.0												
										A-INT1	0.0												
										A-INT2	0.0												
										A-EFF	0.0												
01/04/08	System down on arrival and departure.																						
	11,636	33,970	166	160	0																		
01/07/08	System down on arrival and running on departure.																						
	11,636	33,970	0	160	0	6	81.63	2,800	117	A-INF	0.0												
										A-INT1	0.0												
										A-INT2	0.0												
										A-EFF	0.0												
01/18/08	System running on arrival and departure.																						
	11,904	34,238	268	160	0	6	81.63	2,800	117	A-INF	0.0	<11d	<0.0072d	<0.0016d	<4.22	<1,668.67	<0.00	<27.69	<0.02	<13.44	0.000		
										A-INT1	0.0	<11d	0.20d	0.015d									
										A-INT2	0.0	<11d	0.31d	<0.0016d									
										A-EFF	0.0	<11d	0.044d	0.0028d									
01/25/08	System down on arrival and running on departure.																						
	12,045	34,379	141	135	0	6	81.63	3,100	135	A-INF	0.0												
										A-INT1	0.0												
										A-INT2	0.0												
										A-EFF	0.0												
01/27/08	System down on arrival and running on departure.																						
	12,052	34,386	7	145	0	6	81.63	3,000	129	A-INF	—												
										A-INT1	—												
										A-INT2	—												
										A-EFF	—												
01/31/08	System down on arrival and running on departure.																						
	12,140	34,474	88	160	0	7	95.24	2,600	109	A-INF	0.0												
										A-INT1	0.0												
										A-INT2	0.0												
										A-EFF	0.0												
02/08/08	System running on arrival and departure.																						
	12,261	34,595	121	165	0	7.5	102.04	2,500	104	A-INF	0.0												
										A-INT1	0.0												
										A-INT2	0.0												
										A-EFF	0.0												

TABLE 3
OPERATION AND PERFORMANCE DATA FOR AIR SPARGE/SOIL VAPOR EXTRACTION SYSTEM
Former Exxon Service Station 70104
1725 Park Street
Alameda, California

Date	Hour Meter	Total Hours	Hours of Operation	Temp EFF (deg F)	Field Measurements					Laboratory Analytical Results			TPHg Removed		Benzene Removed		MTBE Removed		Benzene Emitted (lbs/day)		
					Pressure ("H2O)	Vacuum ("Hg)	Vacuum (in H2O)	Flow (fpm)	Flow (scfm)	Sample ID	PID (ppmv)	TPHg (mg/M ³)	MTBE (mg/M ³)	Benzene (mg/M ³)	Per Period (pounds)	Cumulative (pounds)	Per Period (pounds)	Cumulative (pounds)		Per Period (pounds)	Cumulative (pounds)
02/15/08	System running on arrival and departure.				0	5	68.03	2,800	119	A-INF	0.0	<11d	0.12d	<0.0016d	<2.81	<1,671.48	<0.00	<27.69	<0.02	<13.46	<0.0004
	A-INT1	0.0	<11 d	0.078 d						0.0059 d											
	A-INT2	0.0	<11 d	0.22 d						<0.0016 d											
	A-EFF	0.0	<11 d	<0.0072 d						<0.0016 d											
02/22/08	System running on arrival and departure.				0	5.5	74.83	2,800	119	A-INF	0.8										
	A-INT1	1.4																			
	A-INT2	0.8																			
	A-EFF	0.0																			
02/26/08	System running on arrival and departure.				0	5.5	74.83	2,800	118	A-INF	0.0										
	A-INT1	0.0																			
	A-INT2	0.0																			
	A-EFF	0.0																			
03/06/08	System running on arrival and departure.				0	5.5	74.83	2,600	109	A-INF	3.7										
	A-INT1	3.7																			
	A-INT2	2.2																			
	A-EFF	0.7																			
03/14/08	System running on arrival and departure.				0	5.5	74.83	2,600	109	A-INF	0.0										
	A-INT1	0.0																			
	A-INT2	0.0																			
	A-EFF	0.0																			
03/21/08	System running on arrival and departure.				0	6.0	81.63	3,000	125	A-INF	0.0										
	A-INT1	0.0																			
	A-INT2	0.0																			
	A-EFF	0.0																			
03/28/08	System running on arrival and departure.				0	5.5	74.83	2,600	109	A-INF	0.0	<11d	0.059d	<0.0016d	<4.74	<1,676.22	<0.00	<27.69	0.04	<13.50	<0.000
	A-INT1	0.0	<11d	0.13d						0.0043d											
	A-INT2	0.0	<11d	0.17d						<0.0016d											
	A-EFF	0.0	<11d	<0.0072d						<0.0016d											
04/05/08	System running on arrival and departure.				0	5.5	74.83	2,600	110	A-INF	0.0										
	A-INT1	0.0																			
	A-INT2	0.0																			
	A-EFF	0.0																			
04/11/08	System running on arrival and down on departure.				0	5.5	74.83	2,600	110	A-INF	0.0	<11	0.037	0.0030	<1.50	<1,677.72	<0.00	<27.69	0.01	<13.50	<0.0000
	A-INT1	0.0	<11	0.11						0.0056											
	A-INT2	0.0	<11	0.14						<0.0016											
	A-EFF	0.0	<11	<0.0072						<0.0016											
04/15/08	System down on arrival and running on departure.				0	5.5	74.83	2,600	109	A-INF	0.0										
	A-INT1	0.0																			
	A-INT2	0.0																			
	A-EFF	0.0																			

TABLE 3
OPERATION AND PERFORMANCE DATA FOR AIR SPARGE/SOIL VAPOR EXTRACTION SYSTEM
Former Exxon Service Station 70104
1725 Park Street
Alameda, California

Date	Hour Meter	Total Hours	Hours of Operation	Temp EFF (deg F)	Field Measurements					Laboratory Analytical Results			TPHg Removed		Benzene Removed		MTBE Removed		Benzene Emitted (lbs/day)		
					Pressure ("H2O)	Vacuum ("Hg)	Vacuum (in H2O)	Flow (fpm)	Flow (scfm)	Sample ID	PID (ppmv)	TPHg (mg/M ³)	MTBE (mg/M ³)	Benzene (mg/M ³)	Per Period (pounds)	Cumulative (pounds)	Per Period (pounds)	Cumulative (pounds)		Per Period (pounds)	Cumulative (pounds)
04/22/08	System running on arrival and departure, 14,085 36,419 167 160				0	5.5	74.83	2,600	109	A-INF	0.0										
										A-INT1	0.0										
										A-INT2	0.0										
										A-EFF	0.0										
05/02/08	System running on arrival and departure, 14,326 36,660 241 160				0	5.0	68.03	2,600	109	A-INF	0.0										
										A-INT1	0.0										
										A-INT2	0.0										
										A-EFF	0.0										
05/06/08	System running on arrival and departure, 14,413 36,747 87 160				0	5.0	68.03	2,600	109	A-INF	0.0	<11	0.21	<0.0016	<2.65	<1,680.37	<0.00	<27.69	0.03	<13.53	<0.0000
										A-INT1	0.0	<11	0.066	0.0035							
										A-INT2	0.0	<11	0.093	<0.0016							
										A-EFF	0.0	<11	<0.0072	<0.0016							
05/16/08	System running on arrival and departure, 14,650 36,984 237 160				0	5.0	68.03	2,800	117	A-INF	0.0										
										A-INT1	0.0										
										A-INT2	0.0										
										A-EFF	0.0										
05/23/08	System running on arrival and departure, 14,819 37,153 169 160				0	5.0	68.03	2,800	117	A-INF	0.0										
										A-INT1	0.0										
										A-INT2	0.0										
										A-EFF	0.0										
05/28/08	System running on arrival and departure, 14,940 37,274 121 160				0	5.0	68.03	2,800	117	A-INF	0.0										
										A-INT1	0.0										
										A-INT2	0.0										
										A-EFF	0.0										
06/03/08	System running on arrival and departure, 15,083 37,417 143 150				0	5.0	68.03	2,800	119	A-INF	0.0										
										A-INT1	0.0										
										A-INT2	0.0										
										A-EFF	0.0										
06/13/08	System running on arrival and departure, 15,323 37,657 240 160				0	5.0	68.03	2,800	117	A-INF	0.0	<11	0.080	<0.0016	<4.23	<1,684.60	<0.00	<27.70	0.06	<13.59	<0.0000
										A-INT1	0.0	<11	0.27	0.0094							
										A-INT2	0.0	<11	0.25	<0.0016							
										A-EFF	0.0	<11	<0.0072	<0.0016							
06/17/08	System running on arrival and departure, 15,418 37,752 95 100				0	5.0	68.03	2,800	130	A-INF	0.0										
										A-INT1	0.0										
										A-INT2	0.0										
										A-EFF	0.0										
06/23/08	System running on arrival and departure, 15,565 37,899 147 100				0	5.5	74.83	2,800	130	A-INF	0.0										
										A-INT1	0.0										
										A-INT2	0.0										
										A-EFF	0.0										

TABLE 3
OPERATION AND PERFORMANCE DATA FOR AIR SPARGE/SOIL VAPOR EXTRACTION SYSTEM
Former Exxon Service Station 70104
1725 Park Street
Alameda, California

Date	Hour Meter	Total Hours	Hours of Operation	Temp EFF (deg F)	Field Measurements					Laboratory Analytical Results			TPHg Removed		Benzene Removed		MTBE Removed		Benzene Emitted (lbs/day)		
					Pressure ("H2O)	Vacuum ("Hg)	Vacuum (in H2O)	Flow (fpm)	Flow (scfm)	Sample ID	PID (ppmv)	TPHg (mg/M ³)	MTBE (mg/M ³)	Benzene (mg/M ³)	Per Period (pounds)	Cumulative (pounds)	Per Period (pounds)	Cumulative (pounds)		Per Period (pounds)	Cumulative (pounds)
07/03/08	System running on arrival and departure.																				
	15,802	38,136	237	100	0	5.5	74.83	2,800	130	A-INF	0.0										
										A-INT1	0.0										
										A-INT2	0.0										
										A-EFF	0.0										
07/08/08	System running on arrival and departure.																				
	15,920	38,254	118	120	0	5.5	74.83	2,800	125	A-INF	0.0	<11	0.047	0.0023	<2.98	<1,687.58	<0.00	<27.70	0.02	<13.61	<0.0000
										A-INT1	0.0	<11	0.17	0.0051							
										A-INT2	0.0	<11	0.28	<0.0016							
										A-EFF	0.0	<11	0.014	<0.0016							
07/14/08	System Lock out/tag out for LPC carbon changeout.																				
07/15/08	System running on arrival and departure.																				
	16,061	38,395	141	120	0	5.5	74.83	2,800	125	A-INF	0.0	<11	0.16	0.018	<0.73	<1,688.31	0.00	<27.70	0.01	<13.61	<0.0000
										A-INT1	0.0	<11	0.024	<0.0016							
										A-INT2	0.0	<11	0.077	<0.0016							
										A-EFF	0.0	<11	<0.0072	<0.0016							
07/21/08	System running on arrival and departure.																				
	16,205	38,539	144	120	0	5.5	74.83	2,800	125	A-INF	0.0										
										A-INT1	0.0										
										A-INT2	0.0										
										A-EFF	0.0										
07/29/08	System running on arrival and departure.																				
	16,395	38,729	190	120	0	5.5	74.83	2,800	125	A-INF	0.0										
										A-INT1	0.0										
										A-INT2	0.0										
										A-EFF	0.0										
08/08/08	System running on arrival and departure.																				
	16,632	38,966	237	120	0	5.5	74.83	2,800	125	A-INF	0.0										
										A-INT1	0.0										
										A-INT2	0.0										
										A-EFF	0.0										
08/15/08	System running on arrival and departure.																				
	16,806	39,140	174	175	0	7.0	95.24	2,000	82	A-INF	0.0										
										A-INT1	0.0										
										A-INT2	0.0										
										A-EFF	0.0										
08/22/08	System running on arrival and departure.																				
	16,971	39,305	165	200	0	7.0	95.24	2,600	102	A-INF	0.0	<11 d	0.062 d	0.0067 d	<4.26	<1,692.57	0.00	<27.70	0.04	<13.66	<0.0000
										A-INT1	0.0	<11 d	0.099 d	0.018 d							
										A-INT2	0.0	<11 d	0.0075 d	0.0098 d							
										A-EFF	0.0	<11 d	0.023 d	0.0039 d							
08/29/08	System running on arrival and departure.																				
	17,137	39,471	166	100	0	7.0	95.24	2,500	116	A-INF	0.0										
										A-INT1	0.0										
										A-INT2	0.0										
										A-EFF	0.0										

TABLE 3
OPERATION AND PERFORMANCE DATA FOR AIR SPARGE/SOIL VAPOR EXTRACTION SYSTEM
Former Exxon Service Station 70104
1725 Park Street
Alameda, California

Date	Field Measurements											Laboratory Analytical Results			TPHg Removed		Benzene Removed		MTBE Removed		Benzene Emitted (lbs/day)													
	Hour Meter	Total Hours	Hours of Operation	Temp EFF (deg F)	Pressure ("H2O)	Vacuum ("Hg)	Vacuum (in H2O)	Flow (fpm)	Flow (scfm)	Sample ID	PID (ppmv)	TPHg (mg/M ³)	MTBE (mg/M ³)	Benzene (mg/M ³)	Per Period (pounds)	Cumulative (pounds)	Per Period (pounds)	Cumulative (pounds)	Per Period (pounds)	Cumulative (pounds)														
11/17/08	System running on arrival and departure.																																	
	18,992	41,326	19	105	0	6.0	81.63	2,700	124	A-INF	0.0													<11	0.19	0.0046	<4.49	<1,702.76	<0.00	<27.70	0.10	<13.81	<0.0004	
										A-INT1	0.0													<11	0.20	0.0023								
										A-INT2	0.0													<11	0.092	<0.0016								
11/25/08	System running on arrival and departure.																																	
	19,156	41,490	164	100	0	5.0	68.03	2,800	130	A-INF	0.0																							
										A-INT1	0.0																							
										A-INT2	0.0																							
12/05/08	System running on arrival and departure.																																	
	19,395	41,729	239	100	0	5.0	68.03c	2,800	130	A-INF	0.0																							
										A-INT1	0.0																							
										A-INT2	0.0																							
12/12/08	System running on arrival and departure.																																	
	19,397	41,731	2	100	0	5.0	68.03c	2,700	125	A-INF	0.0													<5.7	0.14	0.0046	<1.58	<1,704.34	0.00	<27.71	0.03	<13.84	<0.0004	
										A-INT1	0.0													<5.7	0.15	0.0018								
										A-INT2	0.0													<5.7	0.098	<0.0016								
12/16/08	System running on arrival and departure.																																	
	19,492	41,826	95	100	0	5.0	68.03	2,800	130	A-INF	0.0																							
										A-INT1	0.0																							
										A-INT2	0.0																							
12/24/08	System running on arrival and departure.																																	
	19,689	42,023	197	110	--	5.0	68.03	2,800	128	A-INF	4.0																							
										A-INT1	0.0																							
										A-INT2	0.0																							
01/02/09	System running on arrival and departure.																																	
	19,899	42,233	210	110	--	5.0	68.03	2,900	132	A-INF	3.5																							
										A-INT1	0.0																							
										A-INT2	0.0																							
01/09/09	System running on arrival and departure.																																	
	20,067	42,401	168	110	--	5.0	68.03	2,900	132	A-INF	0.0													<5.7	0.13	<0.0016	<1.84	<1,706.17	<0.00	<27.71	0.04	<13.89	<0.0004	
										A-INT1	0.0													<5.7	0.18	0.0021								
										A-INT2	0.0													<5.7	0.079	<0.0016								
01/16/09	System running on arrival and departure.																																	
	20,234	42,568	167	110	--	5.0	68.03	2,900	132	A-INF	0.0																							
										A-INT1	0.0																							
										A-INT2	0.0																							
01/20/09	System running on arrival and departure.																																	
	20,331	42,665	97	110	--	5.0	68.03	2,900	132	A-INF	0.0																							
										A-INT1	0.0																							
										A-INT2	0.0																							
									A-EFF	0.0																								

TABLE 3
OPERATION AND PERFORMANCE DATA FOR AIR SPARGE/SOIL VAPOR EXTRACTION SYSTEM
Former Exxon Service Station 70104
1725 Park Street
Alameda, California

Date	Field Measurements											Laboratory Analytical Results			TPHg Removed		Benzene Removed		MTBE Removed		Benzene Emitted (lbs/day)	
	Hour Meter	Total Hours	Hours of Operation	Temp EFF (deg F)	Pressure ("H2O)	Vacuum ("Hg)	Vacuum (in H2O)	Flow (fpm)	Flow (scfm)	Sample ID	PID (ppmv)	TPHg (mg/M³)	MTBE (mg/M³)	Benzene (mg/M³)	Per Period (pounds)	Cumulative (pounds)	Per Period (pounds)	Cumulative (pounds)	Per Period (pounds)	Cumulative (pounds)		
01/30/09	System running on arrival and departure.																					
	20,572	42,906	241	110	--	5.0	68.03	2,900	132	A-INF	0.0											
										A-INT1	0.0											
										A-INT2	0.0											
										A-EFF	0.0											
02/06/09	System running on arrival and departure.																					
	20,738	43,072	166	110	--	5.0	68.03	2,400	109	A-INF	0.0											
										A-INT1	0.0											
										A-INT2	0.0											
										A-EFF	0.0											
02/13/09	System running on arrival and departure.																					
	20,904	43,238	166	110	--	5.0	68.03	2,800	128	A-INF	0.0	<5.7	0.15	0.0050	<2.32	<1,708.49	<0.00	<27.71	0.06	<13.95	<0.0004	
										A-INT1	0.0	<5.7	0.13	0.0024								
										A-INT2	0.0	<5.7	0.061	<0.0016								
										A-EFF	0.0	<5.7	0.20	<0.0016								
02/20/09	System running on arrival and departure.																					
	21,072	43,406	168	110	--	5.0	68.03	2,800	128	A-INF	0.0											
										A-INT1	0.0											
										A-INT2	0.0											
										A-EFF	0.0											
02/27/09	System running on arrival and departure.																					
	21,240	43,574	168	110	--	5.0	68.03	3,100	141	A-INF	0.0											
										A-INT1	0.0											
										A-INT2	0.0											
										A-EFF	0.0											
03/06/09	System running on arrival and departure.																					
	21,406	43,740	166	110	--	5.0	68.03	3,100	141	A-INF	0.0											
										A-INT1	0.0											
										A-INT2	0.0											
										A-EFF	0.0											
03/13/09	System running on arrival and departure.																					
	21,574	43,908	168	110	--	5.0	68.03	3,100	141	A-INF	0.0	<5.7	0.078	0.0023	<1.92	<1,710.41	0.00	<27.71	0.04	<13.98	<0.0004	
										A-INT1	0.0	<5.7	0.27	0.0019								
										A-INT2	0.0	<5.7	0.069	<0.0016								
										A-EFF	0.0	<5.7	0.11	<0.0016								
03/20/09	System running on arrival and departure.																					
	21,740	44,074	166	120	--	5.0	68.03	3,000	134	A-INF	0.0											
										A-INT1	0.0											
										A-INT2	0.0											
										A-EFF	0.0											
03/23/09	System running on arrival and departure.																					
	21,830	44,164	90	125	--	5.0	68.03	3,000	133	A-INF	0.0											
										A-INT1	0.0											
										A-INT2	0.0											
										A-EFF	0.0											
03/31/09	System running on arrival and departure.																					
	22,003	44,337	173	100	--	5.0	68.03	2,600	121	A-INF	0.0											
										A-INT1	0.0											
										A-INT2	0.0											
										A-EFF	0.0											

TABLE 3
OPERATION AND PERFORMANCE DATA FOR AIR SPARGE/SOIL VAPOR EXTRACTION SYSTEM
Former Exxon Service Station 70104
1725 Park Street
Alameda, California

Date	Hour Meter	Total Hours	Hours of Operation	Temp EFF (deg F)	Field Measurements				Laboratory Analytical Results			TPHg Removed		Benzene Removed		MTBE Removed		Benzene Emitted (lbs/day)				
					Pressure ("H2O)	Vacuum ("Hg)	Vacuum (in H2O)	Flow (fpm)	Flow (scfm)	Sample ID	PID (ppmv)	TPHg (mg/M³)	MTBE (mg/M³)	Benzene (mg/M³)	Per Period (pounds)	Cumulative (pounds)	Per Period (pounds)		Cumulative (pounds)	Per Period (pounds)	Cumulative (pounds)	
04/07/09	System running on arrival and departure				100	---	5.0	68.03	2,600	121	A-INF	0.0	<5.7	0.26	<0.0016	<1.68	<1,712.09	<0.00	<27.71	0.05	<14.03	<0.0004
	A-INT1	0.0	<5.7	0.21							0.0018											
	A-INT2	0.0	<5.7	0.051							<0.0016											
	A-EFF	0.0	<5.7	0.13							<0.0016											
04/17/09	System running on arrival and departure				100	---	5.0	68.03	2,600	121	A-INF	0.0										
	A-INT1	0.0																				
	A-INT2	0.0																				
	A-EFF	0.0																				
04/24/09	System running on arrival and departure				110	---	5.0	68.03	2,600	118	A-INF	0.0										
	A-INT1	0.0																				
	A-INT2	0.0																				
	A-EFF	0.0																				
05/01/09	System running on arrival and departure				100	---	5.0	68.03	2,600	121	A-INF	0.0										
	A-INT1	0.0																				
	A-INT2	0.0																				
	A-EFF	0.0																				
05/08/09	System running on arrival and departure				100	---	5.0	68.03	2,600	121	A-INF	0.0										
	A-INT1	0.0																				
	A-INT2	0.0																				
	A-EFF	0.0																				
05/15/09	System running on arrival and departure				100	---	5.0	68.03	2,000	93	A-INF	0.0	<5.7	0.34	<0.0016	<2.13	<1,714.21	<0.00	<27.71	0.11	<14.15	<0.0003
	A-INT1	0.0	<5.7	0.44							0.0042											
	A-INT2	0.0	<5.7	0.12							<0.0016											
	A-EFF	0.0	<5.7	0.40							<0.0016											
05/22/09	System down on arrival and running on departure				110	---	5.0	68.03	2,800	128	A-INF	0.0										
	A-INT1	0.0																				
	A-INT2	0.0																				
	A-EFF	0.0																				
05/29/09	System running on arrival and departure				120	---	5.0	68.03	2,600	116	A-INF	0.0										
	A-INT1	0.0																				
	A-INT2	0.0																				
	A-EFF	0.0																				
06/05/09	System down on arrival and running on departure				120	---	5.0	68.03	2,600	116	A-INF	0.0										
	A-INT1	0.0																				
	A-INT2	0.0																				
	A-EFF	0.0																				
06/11/09	System running on arrival and departure				110	---	5.0	68.03	2,600	118	A-INF	0.0	<5.7	0.87	0.0022	<1.23	<1,715.45	<0.00	<27.71	0.13	<14.28	<0.0004
	A-INT1	0.0	<5.7	0.38							0.0025											
	A-INT2	0.0	<5.7	0.15							<0.0016											
	A-EFF	0.0	<5.7	0.72							<0.0016											

TABLE 3
OPERATION AND PERFORMANCE DATA FOR AIR SPARGE/SOIL VAPOR EXTRACTION SYSTEM
Former Exxon Service Station 70104
1725 Park Street
Alameda, California

Notes:	Removal rates are calculated using ERI SOP-25: "Hydrocarbons removed from a Vadose Well" Data prior to April 1, 2000, provided by Delta Environmental Consultants, Inc.
A-INF	= Influent vapor sample collected prior to biofilters.
A-INT1	= Vapor sample collected after 1st carbon vessel.
A-INT2	= Vapor sample collected after 2nd carbon vessel.
A-EFF	= Vapor sample collected from effluent sample port.
TPHg	= Total petroleum hydrocarbons as gasoline using EPA Method T0-3M; on and prior to 08/09/07, analyzed using EPA Method 18M.
MTBE	= Methyl tertiary butyl ether analyzed using EPA Method T0-15M; on and prior to 08/09/07, analyzed using EPA Method 18M.
Benzene	= Benzene analyzed using EPA Method T0-15M; on and prior to 08/09/07, analyzed using EPA Method 18M.
Temp EFF	= Temperature effluent.
deg F	= Degrees Fahrenheit.
In H2O	= Inches of water column.
In Hg	= Inches of mercury vacuum.
scfm	= Standard cubic feet per minute.
fpm	= Feet per minute.
lbs/day	= Pounds per day.
ppmv	= Parts per million by volume.
mg/M ³	= Milligrams per cubic meter.
---	= Not sampled/Not measured/Not analyzed/Not calculated.
a	= Analyte was detected in the associated Method Blank.
b	= Tedlar Bag deflated, sample could not be analyzed.
c	= Concentration exceeds the calibration range.
d	= Sample analyzed past recommended holding time.

TABLE 4
OPERATION AND PERFORMANCE DATA FOR GROUNDWATER PUMP AND TREAT SYSTEM
Former Exxon Service Station 70104
1725 Park Street
Alameda, California

Date	Total Flow (gallons)	Average Flow Rate (gpm)	Sample ID	Laboratory Analytical Results						TPHg Removed		Benzene Removed		MTBE Removed		
				TPHg (µg/l)	B (µg/l)	T (µg/l)	E (µg/l)	X (µg/l)	MTBE (µg/l)	Per Period (lbs)	Cumulative (lbs)	Per Period (lbs)	Cumulative (lbs)	Per Period (lbs)	Cumulative (lbs)	
10/10/94	1,331,420	---	W-INF	<50	<0.5	<0.5	<0.5	<0.5	---	---	---	---	---	---	---	---
			W-EFF	<50	<0.5	<0.5	<0.5	<0.5	---	---	---	---	---	---	---	---
12/02/94	1,392,010	0.8	W-INF	65	1.9	0.9	<0.5	2.4	---	<0.029	<0.0	<0.0006	<0.001	---	---	
			W-EFF	<50	<0.5	<0.5	<0.5	<0.5	---	---	---	---	---	---	---	---
01/13/95	1,415,980	0.4	W-INF	1,000	<0.5	<0.5	<0.5	<0.5	---	0.106	<0.1	<0.0002	<0.001	---	---	
			W-INT1	<50	<0.5	<0.5	<0.5	<0.5	---	---	---	---	---	---	---	
			W-EFF	<50	<0.5	<0.5	<0.5	<0.5	---	---	---	---	---	---	---	---
02/23/95	1,494,030	1.3	W-INF	57	<0.5	<0.5	<0.5	2.7	---	0.344	<0.5	<0.0003	<0.001	---	---	
			W-INT1	<50	<0.5	<0.5	<0.5	<0.5	---	---	---	---	---	---	---	
			W-EFF	<50	<0.5	<0.5	<0.5	<0.5	---	---	---	---	---	---	---	---
03/14/95	---	---	W-INF	<50	<0.5	<0.5	<0.5	<0.5	---	---	---	---	---	---	---	
			W-INT1	<50	<0.5	<0.5	<0.5	<0.5	---	---	---	---	---	---	---	
			W-EFF	<50	<0.5	<0.5	<0.5	<0.5	---	---	---	---	---	---	---	---
04/14/95	1,513,240	0.3	W-INF	<50	<0.5	<0.5	<0.5	<0.5	---	<0.009	<0.5	<0.0001	<0.001	---	---	
			W-INT1	<50	<0.5	<0.5	<0.5	<0.5	---	---	---	---	---	---	---	
			W-EFF	<50	<0.5	<0.5	<0.5	<0.5	---	---	---	---	---	---	---	---
05/18/95	1,714,850	4.1	W-INF	---	---	---	---	---	---	---	---	---	---	---	---	
06/30/95	1,847,330	2.1	W-INF	1,700	480	23	66	180	---	<2.439	<2.9	0.6685	<0.670	---	---	
			W-INT1	<50	<0.5	<0.5	<0.5	<0.5	---	---	---	---	---	---	---	
			W-EFF	<50	<0.5	<0.5	<0.5	<0.5	---	---	---	---	---	---	---	---
07/12/95	1,908,730	3.6	W-INF	290	68	<2.0	2.4	5.6	---	0.510	<3.4	0.1128	<0.783	---	---	
			W-INT1	<50	<0.5	<0.5	<0.5	<0.5	---	---	---	---	---	---	---	
			W-EFF	<50	<0.5	<0.5	<0.5	<0.5	---	---	---	---	---	---	---	---
08/09/95	2,027,830	3.0	W-INF	6,600	1,700	260	370	550	---	3.423	<6.9	0.8768	<1.659	---	---	
			W-INT1	<50	<0.5	<0.5	<0.5	<0.5	---	---	---	---	---	---	---	
			W-EFF	<50	<0.5	<0.5	<0.5	<0.5	---	---	---	---	---	---	---	---
09/06/95	2,158,260	3.2	W-INF	120	17	0.84	1.0	3.0	---	3.650	<10.5	0.9325	<2.592	---	---	
			W-INT1	<50	<0.5	<0.5	<0.5	<0.5	---	---	---	---	---	---	---	
			W-EFF	<50	<0.5	<0.5	<0.5	<0.5	---	---	---	---	---	---	---	---
10/11/95	2,215,310	1.1	W-INF	160	22	0.97	1.2	4.0	---	0.067	<10.6	0.0093	<2.601	---	---	
			W-INT1	<50	<0.5	<0.5	<0.5	<0.5	---	---	---	---	---	---	---	
			W-EFF	<50	<0.5	<0.5	<0.5	<0.5	---	---	---	---	---	---	---	---
11/16/95	2,384,880	3.3	W-INF	120	4.9	<0.5	<0.5	5.9	---	0.198	<10.8	0.0190	<2.620	---	---	
			W-INT1	<50	<0.5	<0.5	<0.5	<0.5	---	---	---	---	---	---	---	
			W-EFF	<50	<0.5	<0.5	<0.5	<0.5	---	---	---	---	---	---	---	---
12/14/95	2,453,200	1.7	W-INF	450	46	16	4.6	65	---	0.162	<10.9	0.0145	<2.635	---	---	
			W-INT1	<50	<0.5	<0.5	<0.5	<0.5	---	---	---	---	---	---	---	
			W-EFF	<50	<0.5	<0.5	<0.5	<0.5	---	---	---	---	---	---	---	---
01/05/96	2,516,900	2.0	W-INF	240	26	2.4	1.2	20	---	0.183	<11.1	0.0191	<2.654	---	---	
			W-INT1	<50	<0.5	<0.5	<0.5	<0.5	---	---	---	---	---	---	---	
			W-EFF	<50	<0.5	<0.5	<0.5	<0.5	---	---	---	---	---	---	---	---

TABLE 4
OPERATION AND PERFORMANCE DATA FOR GROUNDWATER PUMP AND TREAT SYSTEM
Former Exxon Service Station 70104
1725 Park Street
Alameda, California

Date	Total Flow (gallons)	Average Flow Rate (gpm)	Sample ID	Laboratory Analytical Results						TPHg Removed		Benzene Removed		MTBE Removed	
				TPHg (µg/l)	B (µg/l)	T (µg/l)	E (µg/l)	X (µg/l)	MTBE (µg/l)	Per Period (lbs)	Cumulative (lbs)	Per Period (lbs)	Cumulative (lbs)	Per Period (lbs)	Cumulative (lbs)
02/14/96	2,680,160	2.8	W-INF	470	43	5.5	<0.5	55	---	0.483	<11.6	0.0469	<2.701	---	---
			W-INT1	<50	<0.5	<0.5	<0.5	<0.5	---						
			W-EFF	<50	<0.5	<0.5	<0.5	<0.5	---						
03/12/96	2,767,820	2.3	W-INF	620	60	9.8	3.9	70	---	0.398	<12.0	0.0376	<2.738	---	---
			W-INT1	<50	<0.5	<0.5	<0.5	<0.5	---						
			W-EFF	<50	<0.5	<0.5	<0.5	<0.5	---						
04/16/96	2,927,390	3.2	W-INF	790	120	27	8.8	120	---	0.937	<12.9	0.1196	<2.858	---	---
			W-INT1	<50	<0.5	<0.5	<0.5	<0.5	---						
			W-EFF	<50	<0.5	<0.5	<0.5	<0.5	---						
05/07/96	2,971,100	1.4	W-INF	430	66	2.7	5	32	---	0.222	<13.2	0.0339	<2.892	---	---
			W-INT1	<50	<0.5	<0.5	<0.5	<0.5	---						
			W-EFF	<50	<0.5	<0.5	<0.5	<0.5	---						
06/11/96	3,109,730	2.8	W-INF	2,900	470	120	19	410	---	1.922	<15.1	0.3094	<3.201	---	---
			W-INT1	<50	<0.5	<0.5	<0.5	<0.5	---						
			W-EFF	<50	<0.5	<0.5	<0.5	<0.5	---						
07/09/96	3,232,330	3.0	W-INF	490	55	6.2	<0.5	110	---	1.731	<16.8	0.2680	<3.469	---	---
			W-INT1	<50	<0.5	<0.5	<0.5	<0.5	---						
			W-EFF	<50	<0.5	<0.5	<0.5	<0.5	---						
08/08/96	3,365,060	3.1	W-INF	580	49	4.6	<1.0	75	---	0.591	<17.4	0.0575	<3.527	---	---
			W-INT1	<50	<0.5	<0.5	<0.5	<0.5	---						
			W-EFF	<50	<0.5	<0.5	<0.5	<0.5	---						
09/05/96	---	---	W-INF	740	67	19	10	72	---	---	---	---	---	---	---
			W-INT1	<50	<0.5	<0.5	<0.5	<0.5	---						
			W-EFF	<50	<0.5	<0.5	<0.5	<0.5	---						
10/02/96	3,530,230	2.1	W-INF	980	130	39	7.8	130	---	1.073	<18.5	0.1231	<3.650	---	---
			W-INT1	<50	<0.5	<0.5	<0.5	<0.5	---						
			W-EFF	<50	<0.5	<0.5	<0.5	<0.5	---						
11/08/96	3,657,370	2.4	W-INF	480	42	7.1	0.69	79	---	0.774	<19.2	0.0912	<3.741	---	---
			W-INT1	<50	<0.5	<0.5	<0.5	<0.5	---						
			W-EFF	<50	<0.5	<0.5	<0.5	<0.5	---						
12/09/96	3,735,650	1.8	W-INF	<50	<0.5	<0.5	<0.5	<0.5	---	<0.173	<19.4	0.0139	<3.755	---	---
			W-INT1	<50	<0.5	<0.5	<0.5	<0.5	---						
			W-EFF	<50	<0.5	<0.5	<0.5	<0.5	---						
01/21/97	3,735,730	0.0	W-INF	690	69	20	20	91	---	<0.000	<19.4	0.0000	<3.755	---	---
			W-INT1	<50	<0.5	<0.5	<0.5	<0.5	---						
			W-EFF	<50	<0.5	<0.5	<0.5	<0.5	---						
02/10/97	3,735,360	0.0	W-INF	860	100	24	1.4	160	---	---	---	---	---	---	---
			W-INT1	<50	<0.5	<0.5	<0.5	<0.5	---						
			W-EFF	<50	<0.5	<0.5	<0.5	<0.5	---						
03/20/97	3,843,430	2.0	W-INF	86	<0.5	<0.5	<0.5	5.1	---	0.426	<19.9	<0.0453	<3.800	---	---
			W-INT1	<50	<0.5	<0.5	<0.5	<0.5	---						
			W-EFF	<50	<0.5	<0.5	<0.5	<0.5	---						

TABLE 4
OPERATION AND PERFORMANCE DATA FOR GROUNDWATER PUMP AND TREAT SYSTEM
Former Exxon Service Station 70104
1725 Park Street
Alameda, California

Date	Total Flow (gallons)	Average Flow Rate (gpm)	Sample ID	Laboratory Analytical Results						TPHg Removed		Benzene Removed		MTBE Removed	
				TPHg (µg/l)	B (µg/l)	T (µg/l)	E (µg/l)	X (µg/l)	MTBE (µg/l)	Per Period (lbs)	Cumulative (lbs)	Per Period (lbs)	Cumulative (lbs)	Per Period (lbs)	Cumulative (lbs)
04/03/97	3,918,650	3.7	W-INF	690	31	6.1	<5.0	89	---	0.244	<20.1	0.0099	<3.810	---	---
			W-INT1	<1,000	<10	<10	<10	<10	---						
			W-EFF	<50	<0.5	<0.5	<0.5	<0.5	---						
05/07/97	4,092,720	3.6	W-INF	1,000	57	29	11	110	---	1.227	<21.3	0.0639	<3.874	---	---
			W-INT1	<50	1.1	<0.5	<0.5	<0.5	---						
			W-EFF	<50	<0.5	<0.5	<0.5	<0.5	---						
06/11/97	4,144,600	1.0	W-INF	570	66	14	4.7	75	---	0.340	<21.7	0.0266	<3.901	---	---
			W-INT1	<50	0.57	<0.5	<0.5	<0.5	---						
			W-EFF	<50	<0.5	<0.5	<0.5	<0.5	---						
06/25/97	4,273,310	6.4	W-EFF	<50	<0.5	<0.5	<0.5	<0.5	---						
07/24/97	4,363,090	2.2	W-INF	470	25	8.8	3.7	49	---	0.948	<22.6	0.0829	<3.984	---	---
			W-INT1	<50	<0.5	<0.5	<0.5	<0.5	---						
			W-EFF	<50	<0.5	<0.5	<0.5	<0.5	---						
08/04/97	4,408,100	2.8	W-INF	610	48	18	6.2	69	---	0.203	<22.8	0.0137	<3.997	---	---
			W-INT1	<50	0.76	<0.5	<0.5	<0.5	---						
			W-EFF	<50	<0.5	<0.5	<0.5	<0.5	---						
10/21/97	4,496,810	0.8	W-INF	250	16	5.4	2.3	29	---	0.318	<23.1	0.0237	<4.021	---	---
			W-INT1	<50	<0.5	<0.5	<0.5	<0.5	---						
			W-EFF	<50	<0.5	<0.5	<0.5	<0.5	---						
11/04/97	4,553,090	2.8	W-INF	510	22	9.8	13	60	---	0.178	<23.3	0.0089	<4.030	---	---
			W-INT1	<50	0.82	<0.5	<0.5	0.5	---						
			W-EFF	<50	<0.5	<0.5	<0.5	<0.5	---						
12/05/97	4,588,340	0.8	W-INF	79	1.5	<0.5	<0.5	53	---	0.087	<23.4	0.0035	<4.033	---	---
			W-INT1	<50	<0.5	<0.5	<0.5	<0.5	---						
			W-EFF	<50	<0.5	<0.5	<0.5	<0.5	---						
01/08/98	4,625,400	0.8	W-INF	83	2.6	0.74	<0.5	5.4	---	0.025	<23.4	0.0006	<4.034	---	---
			W-INT1	<50	<0.5	<0.5	<0.5	<0.5	---						
			W-EFF	<50	0.58	<0.5	0.81	1.5	---						
03/03/98	4,662,470	0.5	W-INF	<50	0.54	<0.5	<0.5	0.88	---	<0.021	<23.4	0.0005	<4.034	---	---
			W-INT1	<50	<0.5	<0.5	<0.5	0.5	---						
			W-EFF	<50	<0.5	<0.5	<0.5	<0.5	---						
04/02/98	4,702,760	0.9	W-INF	1,100	170	32	12	160	---	0.193	<23.6	0.0287	<4.063	---	---
			W-INT1	<50	<0.5	<0.5	<0.5	<0.5	---						
			W-EFF	<50	<0.5	<0.5	<0.5	<0.5	---						
05/04/98	4,786,330	1.8	W-INF	1,000	140	23	8.5	150	---	0.732	<24.4	0.1081	<4.171	---	---
			W-INT1	<50	<0.5	<0.5	<0.5	0.5	---						
			W-EFF	<50	<0.5	<0.5	<0.5	<0.5	---						
06/10/98	4,852,030	1.2	W-INF	670	110	16	7.6	74	---	0.458	<24.8	0.0685	<4.240	---	---
			W-INT1	<50	<0.5	<0.5	<0.5	<0.5	---						
			W-EFF	<50	<0.5	<0.5	<0.5	<0.5	---						

TABLE 4
OPERATION AND PERFORMANCE DATA FOR GROUNDWATER PUMP AND TREAT SYSTEM
Former Exxon Service Station 70104
1725 Park Street
Alameda, California

Date	Total Flow (gallons)	Average Flow Rate (gpm)	Sample ID	Laboratory Analytical Results						TPHg Removed		Benzene Removed		MTBE Removed	
				TPHg (µg/l)	B (µg/l)	T (µg/l)	E (µg/l)	X (µg/l)	MTBE (µg/l)	Per Period (lbs)	Cumulative (lbs)	Per Period (lbs)	Cumulative (lbs)	Per Period (lbs)	Cumulative (lbs)
07/07/98	4,951,910	2.6	W-INF	690	91	13	6.3	55	---	0.567	<25.4	0.0838	<4.323	---	---
			W-INT1	<200	<2.0	<2.0	<2.0	<2.0	---						
			W-EFF	<50	<0.5	<0.5	<0.5	<0.5	---						
08/04/98	5,039,980	2.2	W-INF	230	36	6.4	2.5	17	---	0.338	<25.7	0.0467	<4.370	---	---
			W-INT1	<50	<0.5	<0.5	<0.5	<0.5	---						
			W-EFF	<50	<0.5	<0.5	<0.5	<0.5	---						
09/03/98	5,080,850	1.0	W-INF	280	13	2.0	6.4	21	---	0.087	<25.8	0.0084	<4.378	---	---
			W-INT1	<50	<0.5	<0.5	<0.5	<0.5	---						
			W-EFF	<50	<0.5	<0.5	<0.5	<0.5	---						
10/20/98	---	---	W-INF	740	43	54	25	110	---	---	---	---	---	---	
			W-INT1	<50	<0.5	<0.5	<0.5	<0.5	---						
			W-EFF	<50	<0.5	<0.5	<0.5	<0.5	---						
11/09/98	5,232,360	1.6	W-INF	300	37	10	8.4	43	---	0.367	<26.2	0.0316	<4.410	---	---
			W-INT1	<50	<0.5	<0.5	<0.5	<0.5	---						
			W-EFF	<50	<0.5	<0.5	<0.5	<0.5	---						
12/08/98	5,284,180	1.2	W-INF	700	82	25	13	100	---	0.216	<26.4	0.0257	<4.436	---	---
			W-INT1	<50	<0.5	<0.5	<0.5	<0.5	---						
			W-EFF	<50	<0.5	<0.5	<0.5	<0.5	---						
01/13/99	5,377,930	1.8	W-INF	1,030	155	46.5	52.7	73.3	---	0.677	<27.1	0.0927	<4.528	---	---
			W-INT1	<500	<5.0	<5.0	<5.0	<5.0	---						
			W-EFF	<500	<5.0	<5.0	<5.0	<5.0	---						
02/08/99	5,441,820	1.7	W-INF	260	31	9.0	2.4	33	---	0.344	<27.4	0.0496	<4.578	---	---
			W-INT1	<50	<0.5	<0.5	<0.5	<0.5	---						
			W-EFF	<50	<0.5	<0.5	<0.5	<0.5	---						
03/08/99	5,509,090	1.7	W-INF	800	87	16	8.5	140	---	0.297	<27.7	0.0331	<4.611	---	---
			W-INT1	<50	<0.5	<0.5	<0.5	<0.5	---						
			W-EFF	<50	<0.5	<0.5	<0.5	<0.5	---						
04/05/99	5,571,890	1.6	W-INF	<500	36.6	12.2	5.84	20.9	---	<0.341	<28.1	0.0324	<4.644	---	---
			W-INT1	<500	<5.0	<5.0	<5.0	<5.0	---						
			W-EFF	<500	<5.0	<5.0	<5.0	<5.0	---						
05/06/99	5,621,560	1.1	W-INF	310	45	6.0	0.86	41	---	0.168	<28.2	0.0169	<4.660	---	---
			W-INT1	<50	<0.5	<0.5	<0.5	<0.5	---						
			W-EFF	<50	<0.5	<0.5	<0.5	<0.5	---						
06/07/99	5,706,250	1.8	W-INF	<250	24.8	<2.5	<2.5	8.74	---	<0.198	<28.4	0.0247	<4.685	---	---
			W-INT1	<100	<1.0	<1.0	<1.0	<1.0	---						
			W-EFF	<250	<2.5	<2.5	<2.5	<2.5	---						
07/28/99	5,805,010	1.3	W-INF	<100	7.00	<1.0	2.40	6.40	---	<0.144	<28.6	0.0131	<4.698	---	---
			W-INT1	<50	<0.5	<0.5	<0.5	<0.5	---						
			W-EFF	<50	<0.5	<0.5	<0.5	<0.5	---						
08/09/99	5,849,280	2.6	W-INF	<500	17.1	5.88	<5.0	26.8	---	<0.111	<28.7	0.0045	<4.703	---	---
			W-INT1	<250	<2.5	<2.5	<2.5	<2.5	---						
			W-EFF	<250	<2.5	<2.5	<2.5	<2.5	---						

TABLE 4
OPERATION AND PERFORMANCE DATA FOR GROUNDWATER PUMP AND TREAT SYSTEM
Former Exxon Service Station 70104
1725 Park Street
Alameda, California

Date	Total Flow (gallons)	Average Flow Rate (gpm)	Sample ID	Laboratory Analytical Results						TPHg Removed		Benzene Removed		MTBE Removed	
				TPHg (µg/l)	B (µg/l)	T (µg/l)	E (µg/l)	X (µg/l)	MTBE (µg/l)	Per Period (lbs)	Cumulative (lbs)	Per Period (lbs)	Cumulative (lbs)	Per Period (lbs)	Cumulative (lbs)
09/07/99	5,880,860	0.8	W-INF	<500	20.4	<5.0	<5.0	31.1	---	<0.132	<28.8	0.0049	<4.708	---	---
			W-INT1	<50	<0.5	<0.5	<0.5	<0.5	---						
			W-EFF	<50	<0.5	<0.5	<0.5	<0.5	---						
10/12/99	5,966,690	1.7	W-INF	100	2	<1.0	<1.0	<1.0	---	0.215	<29.0	0.0080	<4.716	---	---
			W-INT1	<50	<1.0	<1.0	<1.0	<1.0	---						
			W-EFF	<50	<1.0	<1.0	<1.0	<1.0	---						
11/18/99	5,971,540	0.1	W-INF	660	66	7.8	5.6	57	---	0.015	<29.0	0.0014	<4.717	---	---
			W-INT1	<50	<1.0	<1.0	<1.0	<1.0	---						
			W-EFF	<50	<1.0	<1.0	<1.0	<1.0	---						
12/09/99	5,992,780	0.7	W-INF	200	28	3.2	2.2	22.4	---	0.076	<29.1	0.0083	<4.725	---	---
			W-INT1	<50	<1.0	<1.0	<1.0	<1.0	---						
			W-EFF	<50	<1.0	<1.0	<1.0	<1.0	---						
01/10/00	6,035,690	0.9	W-INF	120	11	1.5	1.8	14.5	---	0.057	<29.2	0.0070	<4.732	---	---
			W-INT1	<50	<1.0	<1.0	<1.0	<1.0	---						
			W-EFF	<50	<1.0	<1.0	<1.0	<1.0	---						
02/08/00	6,055,000	0.5	W-INF	130	14	<1.0	<1.0	11.9	---	0.020	<29.2	0.0020	<4.734	---	---
			W-INT2	<50	<1.0	<1.0	<1.0	<1.0	---						
			W-EFF	<50	<1.0	<1.0	<1.0	<1.0	---						
03/24/00	System shut down pending evaluation.														
	6,080,125	0.4													
03/28/00	System shut down upon departure.														
	6,080,360	0.0	W-INF	<50	<1.0	<1.0	<1.0	<1.0	---	<0.019	<29.2	<0.0016	<4.736	---	---
			W-INT1	<50	<1.0	<1.0	<1.0	<1.0	---						
			W-INT2	<50	<1.0	<1.0	<1.0	<1.0	---						
		W-EFF	<67	<1.0	<1.0	<1.0	<1.0	---							
04/01/00	Environmental Resolutions, Inc. assumed operation of the remediation system.														
06/05/02	System down on arrival and running on departure. Startup. Water samples collected for startup.														
	10	0.0	W-INF	<50	<0.5	<0.5	<0.5	<0.5	---	<0.000	<29.2	<0.0000	<4.736	---	---
			W-INT1	<50	<0.5	<0.5	<0.5	<0.5	---						
			W-INT2	<50	<0.5	<0.5	<0.5	<0.5	---						
		W-EFF	<50	<0.5	<0.5	<0.5	<0.5	---							
06/19/02	System running on arrival and departure.														
	47,370	2.4													
07/03/02	System running on arrival and departure.														
	114,030	3.3	W-INF	270	<2.5	<2.5	<2.5	<2.5	1,300	0.152	<29.4	<0.0014	<4.737	2.473	2.473
			W-INT1	<50	<0.5	<0.5	<0.5	<0.5	46						
			W-INT2	<50	<0.5	<0.5	<0.5	<0.5	<2.5						
		W-EFF	<50	<0.5	<0.5	<0.5	<0.5	<2.5							
07/17/02	System down on arrival and running on departure.														
	114,230	0.0													
07/31/02	System running on arrival and down on departure.														
	179,580	3.2													

TABLE 4
OPERATION AND PERFORMANCE DATA FOR GROUNDWATER PUMP AND TREAT SYSTEM
Former Exxon Service Station 70104
1725 Park Street
Alameda, California

Date	Total Flow (gallons)	Average Flow Rate (gpm)	Sample ID	Laboratory Analytical Results						TPHg Removed		Benzene Removed		MTBE Removed	
				TPHg (µg/l)	B (µg/l)	T (µg/l)	E (µg/l)	X (µg/l)	MTBE (µg/l)	Per Period (lbs)	Cumulative (lbs)	Per Period (lbs)	Cumulative (lbs)	Per Period (lbs)	Cumulative (lbs)
08/14/02	System down on arrival and running on departure.														
	179,930	0.0	W-INF	620	4.1	<2.5	<2.5	<2.5	1,400	0.245	<29.6	0.0018	<4.739	0.742	3.216
			W-INT1	<50	<0.50	<0.50	<0.50	<0.5	150						
			W-INT2	<50	<0.50	<0.50	<0.50	<0.5	<2.5						
			W-EFF	<50	<0.50	<0.50	<0.50	<0.50	<2.5						
08/28/02	System running on arrival and down on departure.														
	222,900	2.1													
11/06/02	System down on arrival and running on departure.														
	223,080	0.0	W-INF	660	<5.0	<5.0	<5.0	<5.0	1,700	0.230	<29.8	<0.0016	<4.741	0.558	3.774
			W-INT1	100	3.9	<0.5	<0.5	1.4	150						
			W-INT2	<50	<0.5	<0.5	<0.5	<0.5	<2.5						
			W-EFF	<50	<0.5	<0.5	<0.5	<0.5	<2.5						
11/20/02	System down on arrival and departure.														
12/04/02	System down on arrival and departure.														
12/18/02	System down on arrival and departure.														
01/03/03	System down on arrival and departure.														
	224,032	0.0													
01/06/03	System down on arrival and departure.														
01/15/03	System down on arrival and running on departure.														
	224,360	0.0	W-INF	730	<5.0	<5.0	<5.0	<5.0	1,200	0.007	<29.8	<0.0001	<4.741	0.015	3.789
			W-INT1	71	<0.50	<0.50	<0.50	<0.50	110						
			W-INT2	--	--	--	--	--	--						
			W-EFF	<50	<0.50	<0.50	<0.50	<0.50	<2.5						
01/29/03	System running on arrival and departure.														
	283,830	3.0													
02/12/03	System running on arrival and departure.														
	321,540	1.9	W-INF	<500	<5.0	<5.0	<5.0	<5.0	500	<0.499	<30.3	<0.0041	<4.745	0.689	4.478
			W-INT1	<500	<5.0	<5.0	<5.0	<5.0	500						
			W-INT2	<250	<2.5	<2.5	<2.5	<2.5	330						
			W-EFF	<50	<0.50	<0.50	<0.50	<0.50	<2.5						
02/26/03	System running on arrival and departure.														
	383,280	3.1													
03/12/03	System running on arrival and departure.														
	439,050	2.8	W-INF	190	<10	<10	<10	<10	1,200	0.338	<30.7	<0.0074	<4.752	0.833	5.312
			W-INT1	86	<2.5	<2.5	<2.5	<2.5	150						
			W-INT2	<50	<0.50	<0.50	<0.50	<0.50	1.5						
			W-EFF	<50	<0.50	<0.50	<0.50	<0.50	<0.5						
03/26/03	System running on arrival and departure.														
	489,680	2.5													
04/09/03	System running on arrival and departure.														
	537,030	2.4	W-INF	<500	<25	<25	<25	<25	930	<0.282	<31.0	<0.0143	<4.767	0.871	6.182
			W-INT1	50	<2.5	<2.5	<2.5	<2.5	91						
			W-INT2	<50	<0.50	<0.50	<0.50	<0.50	8.7						
			W-EFF	<50	<0.50	<0.50	<0.50	<0.50	<0.5						

TABLE 4
OPERATION AND PERFORMANCE DATA FOR GROUNDWATER PUMP AND TREAT SYSTEM
Former Exxon Service Station 70104
1725 Park Street
Alameda, California

Date	Total Flow (gallons)	Average Flow Rate (gpm)	Sample ID	Laboratory Analytical Results						TPHg Removed		Benzene Removed		MTBE Removed		
				TPHg (µg/l)	B (µg/l)	T (µg/l)	E (µg/l)	X (µg/l)	MTBE (µg/l)	Per Period (lbs)	Cumulative (lbs)	Per Period (lbs)	Cumulative (lbs)	Per Period (lbs)	Cumulative (lbs)	
04/23/03	System running on arrival and departure. 584,410 2.4															
05/07/03	System running on arrival and departure. 613,620 1.5			W-INF	180	<5.0	<5.0	<5.0	<5.0	430	0.217	<31.2	<0.0096	<4.776	0.435	6.617
			W-INT1	110	<0.50	<0.50	<0.50	<0.50	<0.50	99						
			W-INT2	<50	<0.50	<0.50	<0.50	<0.50	<0.50	18						
			W-EFF	<50	<0.50	<0.50	<0.50	<0.50	<0.50	<0.50						
05/21/03	System running on arrival and departure. 646,410 1.6															
06/04/03	System running on arrival, down on departure for carbon changeout. 723,100 3.8															
06/18/03	System down on arrival, running on departure, monthly samples taken. 723,320 0.0			W-INF	<250	<2.5	<2.5	<2.5	<2.5	410	<0.197	<31.4	<0.0034	<4.780	0.384	7.001
			W-INT1	<50	<0.50	<0.50	<0.50	<0.50	<0.50	<2.5						
			W-INT2	<50	<0.50	<0.50	<0.50	<0.50	<0.50	<2.5						
			W-EFF	<50	<0.50	<0.50	<0.50	<0.50	<0.50	<2.5						
07/02/03	System running on arrival and departure. 751,630 1.4			W-INF	120	<25	<25	<25	29	560	0.044	<31.4	<0.0032	<4.783	0.115	7.116
			W-INT1	<50	<0.50	<0.50	<0.50	<0.50	<0.50	<0.50						
			W-INT2	<50	<0.50	<0.50	<0.50	<0.50	<0.50	<0.50						
			W-EFF	<50	<0.50	<0.50	<0.50	<0.50	<0.50	<0.50						
07/16/03	System running on arrival and departure. 778,100 1.3															
07/30/03	System running on arrival and departure. 805,390 1.4															
08/13/03	System running on arrival and departure. 828,920 1.2			W-INF	390	<10	<10	<10	<10	620	0.164	<31.6	<0.0113	<4.794	0.380	7.496
			W-INT1	<50	<0.50	<0.50	<0.50	<0.50	<0.50	0.90						
			W-INT2	<50	<0.50	<0.50	<0.50	<0.50	<0.50	<0.50						
			W-EFF	<50	<0.50	<0.50	<0.50	<0.50	<0.50	<0.50						
08/27/03	System running on arrival and departure. 854,560 1.3															
09/10/03	System down on arrival, running on departure. 854,800 0.0			W-INF	89	<5.0	<5.0	<5.0	<5.0	140	0.052	<31.6	<0.0016	<4.796	0.082	7.578
			W-INT1	<50	<0.50	<0.50	<0.50	<0.50	<0.50	0.81						
			W-INT2	<50	<0.50	<0.50	<0.50	<0.50	<0.50	<0.50						
			W-EFF	<50	<0.50	<0.50	<0.50	<0.50	<0.50	<0.50						
09/24/03	System running on arrival and departure. 879,920 1.3															
10/08/03	System running on arrival and departure. 903,850 1.2			W-INF	330	<10	<10	<10	<10	540	0.086	<31.7	<0.0031	<4.799	0.139	7.718
			W-INT1	<50	<0.50	<0.50	<0.50	<0.50	<0.50	1.5						
			W-INT2	<50	<0.50	<0.50	<0.50	<0.50	<0.50	<0.50						
			W-EFF	<50	<0.50	<0.50	<0.50	<0.50	<0.50	<0.50						

TABLE 4
OPERATION AND PERFORMANCE DATA FOR GROUNDWATER PUMP AND TREAT SYSTEM
Former Exxon Service Station 70104
1725 Park Street
Alameda, California

Date	Total Flow (gallons)	Average Flow Rate (gpm)	Sample ID	Laboratory Analytical Results						TPHg Removed		Benzene Removed		MTBE Removed		
				TPHg (µg/l)	B (µg/l)	T (µg/l)	E (µg/l)	X (µg/l)	MTBE (µg/l)	Per Period (lbs)	Cumulative (lbs)	Per Period (lbs)	Cumulative (lbs)	Per Period (lbs)	Cumulative (lbs)	
10/22/03	System running on arrival and departure. 927,460															
		1.2														
11/03/03	System running on arrival and departure. 947,710															
		1.2	W-INF	530	<10	<10	<10	<10	810	0.157	<31.9	<0.0037	<4.802	0.247	7.965	
			W-INT1	<50	<0.50	<0.50	<0.50	<0.50	4.4							
			W-INT2	<50	<0.50	<0.50	<0.50	<0.50	<0.50							
			W-EFF	<50	<0.50	<0.50	<0.50	<0.50	<0.50							
11/17/03	System down on arrival. Restarted. Running on departure. 964,770															
		0.9														
12/01/03	System running on arrival and departure. 992,510															
		1.4	W-INF	410	<250	<250	<250	<250	820	0.176	<32.1	<0.0486	<4.851	0.305	8.269	
			W-INT1	<50	<0.50	<0.50	<0.50	<0.50	4.2							
			W-INT2	<50	<0.50	<0.50	<0.50	<0.50	<0.50							
			W-EFF	<50	<0.50	<0.50	<0.50	<0.50	<0.50							
12/15/03	System running on arrival and departure. 1,021,420															
		1.4														
12/29/03	System running on arrival and departure. 1,051,220															
		1.5														
01/12/04	System down on arrival High/High ([H/H] holding tank), transfer pump failure. 1,062,140															
		0.5														
01/26/04	System shut down on arrival, replaced transfer pump restarted system. Collected monthly samples. 1,062,440															
		0.0	W-INF	300	<5.0	<5.0	<5.0	<5.0	770	0.207	<32.3	<0.0744	<4.925	0.464	8.733	
			W-INT1	<50	<0.50	<0.50	<0.50	<0.50	5.7							
			W-INT2	<50	<0.50	<0.50	<0.50	<0.50	<0.50							
			W-EFF	<50	<0.50	<0.50	<0.50	<0.50	<0.50							
02/09/04	System down on arrival (H/H holding tank, transfer pump appears to have failed). System shut down on departure. 1,062,450															
		0.0														
04/08/05	Started system and ran water through system into holding tank (did not discharge). Approximately 400 gallons. 1,064,739															
		0.0	W-INF	600	<0.50	<0.5	<0.5	<0.5	748	0.009	<32.3	<0.0001	<4.925	0.015	8.748	
			W-INT1	<50.0	<0.50	<0.5	<0.5	<0.5	2.9							
			W-INT2	<50.0	<0.50	<0.5	<0.5	<0.5	<0.5							
			W-EFF	<50.0	<0.50	<0.5	<0.5	<0.5	<0.5							
06/27/05	1,065,780	0.0														
06/28/05	1,066,510	0.5														
06/29/05	1,075,770	6.4														
07/01/05	1,093,250	6.1														
07/08/05	1,146,060	5.2														
07/15/05	1,201,070	5.5														
07/22/05	1,257,570	5.6	W-INF	844	8.80	2.3	0.7	30.9	707	1.162	<33.4	0.0075	<4.933	1.170	9.918	
			W-INT1	151	<0.50	<0.5	<0.5	<0.5	151							
			W-INT2	<50.0	<0.50	<0.5	<0.5	<0.5	1.9							
			W-EFF	<50.0	<0.50	<0.5	<0.5	<0.5	<0.5							
07/24/05	1,271,470	4.8														

TABLE 4
OPERATION AND PERFORMANCE DATA FOR GROUNDWATER PUMP AND TREAT SYSTEM
Former Exxon Service Station 70104
1725 Park Street
Alameda, California

Date	Total Flow (gallons)	Average Flow Rate (gpm)	Sample ID	Laboratory Analytical Results						TPHg Removed		Benzene Removed		MTBE Removed	
				TPHg (µg/l)	B (µg/l)	T (µg/l)	E (µg/l)	X (µg/l)	MTBE (µg/l)	Per Period (lbs)	Cumulative (lbs)	Per Period (lbs)	Cumulative (lbs)	Per Period (lbs)	Cumulative (lbs)
07/29/05	1,272,030	0.1													
08/05/05	1,272,630	0.1	W-INF	713	6.01	<0.500	0.569	9.69	647	0.098	<33.5	0.0009	<4.934	0.085	10.003
			W-INT1	<50.0	<0.500	<0.500	<0.500	<0.500	0.698						
			W-INT2	<50.0	<0.500	<0.500	<0.500	<0.500	<0.500						
			W-EFF	<50.0	<0.500	<0.500	<0.500	<0.500	<0.500						
08/12/05	1,326,820	5.4													
08/19/05	1,330,450	0.4													
08/26/05	1,346,130	1.6													
09/02/05	1,384,160	3.8													
09/09/05	1,436,360	5.2	W-INF	681	0.96	<0.50	<0.50	<0.50	664	0.952	<34.5	0.0048	<4.939	0.895	10.899
			W-INT1	<50.0	<0.50	<0.50	<0.50	<0.50	<0.50						
			W-INT2	<50.0	<0.50	<0.50	<0.50	<0.50	<0.50						
			W-EFF	<50.0	<0.50	<0.50	<0.50	<0.50	<0.50						
09/16/05	1,488,660	5.2													
09/19/05	1,507,200	4.3													
10/07/05	1,507,820	0.0													
10/14/05	1,550,690	4.3													
10/21/05	1,563,060	1.2													
10/28/05	1,578,720	1.6													
11/04/05	1,634,790	5.6													
11/11/05	1,670,990	3.6	W-INF	858	0.86	<0.50	<0.50	<0.50	695	1.506	<36.0	0.0018	<4.940	1.330	12.229
			W-INT1	<50.0	<0.50	<0.50	<0.50	<0.50	3.25						
			W-INT2	<50.0	<0.50	<0.50	<0.50	<0.50	0.53						
			W-EFF	<50.0	<0.50	<0.50	<0.50	<0.50	<0.50						
11/18/05	1,706,440	3.5													
11/21/05	1,715,550	2.1													
12/02/05	1,772,310	3.6													
12/09/05	1,786,420	1.4	W-INF	1,060	<0.50	<0.50	<0.50	<0.50	821	0.924	<36.9	<0.0007	<4.941	0.730	12.959
			W-INT1	<50.0	<0.50	<0.50	<0.50	<0.50	16.0						
			W-INT2	<50.0	<0.50	<0.50	<0.50	<0.50	<0.50						
			W-EFF	<50.0	<0.50	<0.50	<0.50	<0.50	<0.50						
12/16/05	1,800,240	1.4													
12/22/05	1,804,140	0.5													
12/30/05	1,804,160	0.0													
01/06/06	1,823,487	1.9	W-INF	3,210c	<0.50	<0.50	<0.50	<0.50	1,240	0.660	<37.6	<0.0002	<4.941	0.319	13.277
			W-INT1	<50.0	<0.50	<0.50	<0.50	<0.50	28.8						
			W-INT2	<50.0	<0.50	<0.50	<0.50	<0.50	<0.50						
			W-EFF	<50.0	<0.50	<0.50	<0.50	<0.50	<0.50						
01/13/06	1,840,520	1.7													
01/20/06	1,853,860	1.3													
01/27/06	1,870,720	1.7													

TABLE 4
OPERATION AND PERFORMANCE DATA FOR GROUNDWATER PUMP AND TREAT SYSTEM
Former Exxon Service Station 70104
1725 Park Street
Alameda, California

Date	Total Flow (gallons)	Average Flow Rate (gpm)	Sample ID	Laboratory Analytical Results						TPHg Removed		Benzene Removed		MTBE Removed	
				TPHg (µg/l)	B (µg/l)	T (µg/l)	E (µg/l)	X (µg/l)	MTBE (µg/l)	Per Period (lbs)	Cumulative (lbs)	Per Period (lbs)	Cumulative (lbs)	Per Period (lbs)	Cumulative (lbs)
02/03/06	1,887,390	1.7	W-INF	1,700d	<10	<10	<10	<10	1,700	1.309	<38.9	<0.0028	<4.944	0.784	14.061
			W-INT1	<50	<0.50	<0.50	<0.50	<0.50	35						
			W-INT2	<50	<0.50	<0.50	<0.50	<0.50	<2.5						
			W-EFF	<50	<0.50	<0.50	<0.50	<0.50	<2.5						
02/10/06	System running on arrival and departure.														
	1,904,310	1.7													
02/17/06	System running on arrival and departure.														
	1,921,860	1.7													
02/23/06	System running on arrival and departure.														
	1,936,920	1.7													
02/24/06	System running on arrival and departure.														
	1,941,290	3.0													
03/03/06	System running on arrival and departure.														
	1,972,060	3.1	W-INF	<2,500	<25	<25	<25	<25	1,700	<1.484	<40.4	<0.0124	<4.956	1.201	15.262
			W-INT1	<500	<5.0	<5.0	<5.0	<5.0	250						
			W-INT2	<50	<0.50	<0.50	<0.50	<0.50	<2.5						
			W-EFF	<50	<0.50	<0.50	<0.50	<0.50	<2.5						
03/10/06	System running on arrival and departure.														
	1,989,680	1.8													
03/17/06	System down on arrival (moisture separator tank [MST] high level). Restarted. Running on departure.														
	2,002,980	1.3													
03/24/06	System running on arrival and departure.														
	2,038,840	3.6													
03/31/06	System down on arrival. Restarted. Running on departure.														
	2,042,050	0.3													
04/07/06	System running on arrival and departure.														
	2,079,030	3.7	W-INF	<2,500	<25	<25	<25	<25	1,800	<2.231	<42.6	<0.0223	<4.979	1.562	16.824
			W-INT1	400 d	<2.5	<2.5	<2.5	<2.5	440						
			W-INT2	<50	<0.50	<0.50	<0.50	<0.50	<2.5						
			W-EFF	<50	<0.50	<0.50	<0.50	<0.50	<2.5						
04/13/06	System running on arrival and departure.														
	2,109,320	3.5													
04/28/06	System running on arrival and departure.														
	2,145,290	1.7													
05/05/06	System running on arrival and departure.														
	2,180,750	3.5	W-INF	<2,500	<25	<25	<25	<25	1,800	<2.122	<44.7	<0.0212	<5.000	1.528	18.352
			W-INT1	650 d	<5.0	<5.0	<5.0	<5.0	800						
			W-INT2	<50	<0.50	<0.50	<0.50	<0.50	<2.5						
			W-EFF	<50	<0.50	<0.50	<0.50	<0.50	<2.5						
05/12/06	System running on arrival and departure.														
	2,213,710	3.3													
05/19/06	System running on arrival and departure.														
	2,245,730	3.2													

TABLE 4
OPERATION AND PERFORMANCE DATA FOR GROUNDWATER PUMP AND TREAT SYSTEM
Former Exxon Service Station 70104
1725 Park Street
Alameda, California

Date	Total Flow (gallons)	Average Flow Rate (gpm)	Sample ID	Laboratory Analytical Results						TPHg Removed		Benzene Removed		MTBE Removed		
				TPHg (µg/l)	B (µg/l)	T (µg/l)	E (µg/l)	X (µg/l)	MTBE (µg/l)	Per Period (lbs)	Cumulative (lbs)	Per Period (lbs)	Cumulative (lbs)	Per Period (lbs)	Cumulative (lbs)	
05/25/06	System running on arrival and departure. 2,272,150															
		3.1														
06/02/06	System running on arrival and departure. 2,305,800															
		2.9														
06/09/06	System running on arrival and departure. 2,334,660															
		2.9	W-INF	<2,500	<25	<25	<25	<25	2,100	<3.210	<47.9	<0.0321	<5.032	2.504	20.856	
			W-INT1	1,200 d	15	<10	<10	<10	1,100							
			W-INT2	<50	<0.50	<0.50	<0.50	<0.50	9.6							
			W-EFF	<50	<0.50	<0.50	<0.50	<0.50	<2.5							
06/16/06	System down on arrival and running on departure. 2,354,230															
		1.9														
06/23/06	System running on arrival and departure. 2,364,230															
		1.0														
06/30/06	System running on arrival and departure. 2,373,900															
		1.0														
07/05/06	System running on arrival and departure. 2,381,000															
		1.0	W-INF	113	<0.50	<0.50	<0.50	<0.50	169	0.505	<48.4	<0.0049	<5.037	0.439	21.294	
			W-INT1	<50.0	<0.50	<0.50	<0.50	<0.50	9.86							
			W-INT2	<50.0	<0.50	<0.50	<0.50	<0.50	<0.50							
			W-EFF	<50.0	<0.50	<0.50	<0.50	<0.50	<0.50							
07/14/06	System running on arrival and departure. 2,435,000															
		4.2														
07/21/06	System running on arrival and departure. 2,471,700															
		3.6														
07/28/06	System running on arrival and departure. 2,505,700															
		3.4														
08/04/06	System running on arrival and departure. 2,541,520															
		3.6	W-INF	1,800	1.97	<0.50	<0.50	2.27	2,220	1.281	<49.7	0.0017	<5.039	1.600	22.894	
			W-INT1	619	<0.50	<0.50	<0.50	<0.50	646							
			W-INT2	<50.0	<0.50	<0.50	<0.50	0.64	<0.50							
			W-EFF	<50.0	<0.50	<0.50	<0.50	<0.50	<0.50							
08/11/06	System running on arrival and departure. 2,578,290															
		3.7														
08/18/06	System running on arrival and departure. 2,614,050															
		3.6														
08/25/06	System running on arrival and departure. 2,614,100															
		0.0														
09/01/06	System running on arrival and shut down on departure for carbon changeout. 2,651,170															
		3.7														
09/15/06	Carbon changeout complete. Restart system. 2,651,170															
		0.0														

TABLE 4
OPERATION AND PERFORMANCE DATA FOR GROUNDWATER PUMP AND TREAT SYSTEM
Former Exxon Service Station 70104
1725 Park Street
Alameda, California

Date	Total Flow (gallons)	Average Flow Rate (gpm)	Sample ID	Laboratory Analytical Results						TPHg Removed		Benzene Removed		MTBE Removed		
				TPHg (µg/l)	B (µg/l)	T (µg/l)	E (µg/l)	X (µg/l)	MTBE (µg/l)	Per Period (lbs)	Cumulative (lbs)	Per Period (lbs)	Cumulative (lbs)	Per Period (lbs)	Cumulative (lbs)	
09/22/06	System down on arrival and locked out/tagged out on departure for repairs.															
	2,670,860	2.0	W-INF	861	<0.50	<0.50	<0.50	0.67	924	1.436	<51.2	<0.0013	<5.040	1.696	24.590	
			W-INT1	<50.0	<0.50	<0.50	<0.50	<0.50	6.66							
			W-INT2	<50.0	0.84	<0.50	<0.50	2.98	1.29							
			W-EFF	<50.0	<0.50	<0.50	<0.50	<0.50	<0.50							
10/06/06	System down on arrival and running on departure.															
	2,670,860	0.0														
10/13/06	System down on arrival and departure.															
	2,672,600	0.2														
10/20/06	System down on arrival and locked out/tagged out on departure for carbon changeout.															
	2,672,860	0.0														
10/27/06	System down on arrival and running on departure.															
	2,672,860	0.0	W-INF	<2,500	<25	<25	<25	<25	2,400	<0.028	<51.2	<0.0002	<5.040	0.028	24.618	
			W-INT1	<50	<0.50	<0.50	<0.50	<0.50	<2.5							
			W-INT2	<50	<0.50	<0.50	<0.50	<0.50	<2.5							
			W-EFF	<50	<0.50	<0.50	<0.50	<0.50	<2.5							
11/03/06	System running on arrival and departure.															
	2,710,410	3.7														
11/10/06	System running on arrival and departure.															
	2,751,080	4.0	W-INF	2,700d	<25	<25	<25	<25	2,500	1.697	<52.9	<0.0163	<5.056	1.599	26.217	
			W-INT1	<50	<0.50	<0.50	<0.50	<0.50	<2.5							
			W-INT2	<50	<0.50	<0.50	<0.50	<0.50	<2.5							
			W-EFF	<50	<0.50	<0.50	<0.50	<0.50	<2.5							
11/14/06	System running on arrival and departure.															
	2,775,140	4.2														
11/20/06	System running on arrival and departure.															
	2,808,860	3.9														
11/27/06	System running on arrival and departure.															
	2,845,210	3.6														
12/05/06	System running on arrival and departure.															
	2,885,930	3.5	W-INF	2,500d	<25	<25	<25	<25	2,300	2.925	<55.8	<0.0281	<5.085	2.700	28.917	
			W-INT1	<50	<0.50	<0.50	<0.50	<0.50	38							
			W-INT2	<50	<0.50	<0.50	<0.50	<0.50	<2.5							
			W-EFF	<50	<0.50	<0.50	<0.50	<0.50	<2.5							
12/15/06	System down on arrival and running departure.															
	2,885,930	0.0														
12/21/06	System running on arrival and departure.															
	2,922,240	4.2														
12/26/06	System running on arrival and departure.															
	2,944,490	3.1														
01/05/07	System running on arrival and departure.															
	2,969,800	1.8														

TABLE 4
OPERATION AND PERFORMANCE DATA FOR GROUNDWATER PUMP AND TREAT SYSTEM
Former Exxon Service Station 70104
1725 Park Street
Alameda, California

Date	Total Flow (gallons)	Average Flow Rate (gpm)	Sample ID	Laboratory Analytical Results						TPHg Removed		Benzene Removed		MTBE Removed	
				TPHg (µg/l)	B (µg/l)	T (µg/l)	E (µg/l)	X (µg/l)	MTBE (µg/l)	Per Period (lbs)	Cumulative (lbs)	Per Period (lbs)	Cumulative (lbs)	Per Period (lbs)	Cumulative (lbs)
01/12/07	System running on arrival and departure.														
	3,012,350	4.2	W-INF	1,600d	<12	<12	<12	<12	1,700	2.162	<58.0	<0.0195	<5.104	2.110	31.027
			W-INT1	580 d	<5.0	<5.0	<5.0	<5.0	590						
			W-INT2	<50	<0.50	<0.50	<0.50	<0.50	<2.5						
01/19/07	System running on arrival and departure.														
	3,046,970	3.4	W-EFF	<50	<0.50	<0.50	<0.50	<0.50	<2.5						
01/26/07	System running on arrival and departure.														
	3,090,550	4.3													
02/02/07	System running on arrival and departure.														
	3,129,760	3.9	W-INF	1,400d	<12	<12	<12	<12	2,100	1.469	<59.4	<0.0118	<5.116	1.861	32.888
			W-INT1	1,100 d	<10	<10	<10	<10	1,400						
			W-INT2	<50	<0.50	<0.50	<0.50	<0.50	<2.5						
02/09/07	System running on arrival and departure.														
	3,189,480	3.9	W-EFF	<50	<0.50	<0.50	<0.50	<0.50	<2.5						
02/16/07	System running on arrival and locked out/tagged out on departure for carbon changeout.														
	3,187,150	1.8													
02/23/07	System locked out/tagged out on arrival and departure.														
03/02/07	System locked out/tagged out on arrival and departure.														
03/09/07	System locked out/tagged out on arrival and departure.														
04/03/07	System locked out/tagged out on arrival, restarted, and running on departure.														
	3,187,660	0.0													
04/12/07	System running on arrival and departure.														
	3,223,250	2.8	W-INF	2,700d,e	<25e	<25e	<25e	<25e	3,100e	1.599	<61.0	<0.0144	<5.130	2.028	34.916
			W-INT1	1,600 d,e	<10 e	<10 e	<10 e	<10 e	1,800 e						
			W-INT2	<50e	<0.50 e	<0.50 e	<0.50 e	<0.50 e	<2.5 e						
04/20/07	System running on arrival and departure.														
	3,235,130	1.0	W-EFF	<50 e	<0.50 e	<0.50 e	<0.50 e	<0.50 e	<2.5 e						
04/25/07	System down on arrival and running on departure.														
	3,246,590	1.6													
05/04/07	System down on arrival and running on departure.														
	3,248,650	0.2													
05/11/07	System down on arrival and running on departure.														
	3,255,710	0.7	W-INF	2,200f	<10 f	<10f	<10f	<10f	3,400f	0.664	<61.7	<0.0047	<5.135	0.880	35.796
			W-INT1	1,000 f	<10 f	<10 f	<10 f	<10 f	1,600 f						
			W-INT2	<50f	<0.50 f	<0.50 f	<0.50 f	<0.50 f	<0.50 f						
05/17/07	System down on arrival and running on departure.														
	3,276,990	2.5	W-EFF	<50 f	<0.50 f	<0.50 f	<0.50 f	<0.50 f	2.5 f						
05/25/07	System running on arrival and departure.														
	3,284,770	0.7													

TABLE 4
OPERATION AND PERFORMANCE DATA FOR GROUNDWATER PUMP AND TREAT SYSTEM
Former Exxon Service Station 70104
1725 Park Street
Alameda, California

Date	Total Flow (gallons)	Average Flow Rate (gpm)	Sample ID	Laboratory Analytical Results						TPHg Removed		Benzene Removed		MTBE Removed	
				TPHg (µg/l)	B (µg/l)	T (µg/l)	E (µg/l)	X (µg/l)	MTBE (µg/l)	Per Period (lbs)	Cumulative (lbs)	Per Period (lbs)	Cumulative (lbs)	Per Period (lbs)	Cumulative (lbs)
05/30/07	System running on arrival and departure.														
	3,299,240	2.0													
06/01/07	System down on arrival and running on departure.														
06/08/07	System down on arrival and running on departure.														
	3,338,400	3.0													
06/15/07	System down on arrival and running on departure.														
06/21/07	System down on arrival and running on departure.														
	3,351,600	0.7	W-INF	<2,500	<25	<25	<25	<25	1,600	<1.880	<63.6	<0.0140	<5.149	2.000	37.796
			W-INT1	<50	<0.50	<0.50	<0.50	<0.50	<2.5						
			W-INT2	<50	<0.50	<0.50	<0.50	<0.50	<2.5						
			W-EFF	<50	<0.50	<0.50	<0.50	<0.50	<2.5						
06/29/07	System down on arrival and running on departure.														
	3,374,190	2.0													
07/06/07	System down on arrival and running on departure.														
	3,382,010	0.8													
07/11/07	System down on arrival and running on departure.														
	3,388,110	0.9													
07/18/07	System down on arrival and running on departure.														
	3,409,620	2.1													
07/20/07	System down on arrival and running on departure.														
	3,411,890	0.8													
07/24/07	System running on arrival and departure.														
	3,416,420	0.8													
07/31/07	System running on arrival and departure.														
	3,425,640	0.9	W-INF	1,040	0.86	<0.50	<0.50	<0.50	684	1.093	<64.7	0.0080	<5.157	0.705	38.502
			W-INT1	<50.0	<0.50	<0.50	<0.50	<0.50	<0.50						
			W-INT2	<50.0	<0.50	<0.50	<0.50	<0.50	<0.50						
			W-EFF	<50.0	<0.50	<0.50	<0.50	<0.50	<0.50						
08/09/07	System running on arrival and departure.														
	3,437,380	0.9	W-INF	2,330	<0.50	<0.50	<0.50	<0.50	1,590	0.165	<64.8	<0.0001	<5.157	0.111	38.613
			W-INT1	<50.0	<0.50	<0.50	<0.50	<0.50	0.65						
			W-INT2	<50.0	<0.50	<0.50	<0.50	<0.50	<0.50						
			W-EFF	<50.0	<0.50	<0.50	<0.50	<0.50	<0.50						
08/14/07	System running on arrival and departure.														
	3,446,080	1.2													
08/21/07	System running on arrival and departure.														
	3,456,500	1.0													
08/28/07	System down on arrival and running on departure.														
	3,467,940	1.1													
09/07/07	System running on arrival and departure.														
	3,478,900	0.8													

TABLE 4
OPERATION AND PERFORMANCE DATA FOR GROUNDWATER PUMP AND TREAT SYSTEM
Former Exxon Service Station 70104
1725 Park Street
Alameda, California

Date	Total Flow (gallons)	Average Flow Rate (gpm)	Sample ID	Laboratory Analytical Results						TPHg Removed		Benzene Removed		MTBE Removed	
				TPHg (µg/l)	B (µg/l)	T (µg/l)	E (µg/l)	X (µg/l)	MTBE (µg/l)	Per Period (lbs)	Cumulative (lbs)	Per Period (lbs)	Cumulative (lbs)	Per Period (lbs)	Cumulative (lbs)
09/14/07	System running on arrival and departure.														
	3,485,690	0.7	W-INF	120	<0.50	<0.50	<0.50	<1.0	330	0.494	<65.3	<0.0002	<5.157	0.387	39.000
			W-INT1	<50	<0.50	<0.50	<0.50	<1.0	<5.0						
			W-INT2	<50	<0.50	<0.50	<0.50	<1.0	<5.0						
		W-EFF	79	<0.50	<0.50	<0.50	<1.0	<5.0							
09/21/07	System running on arrival and departure.														
	3,492,210	0.7													
09/28/07	System running on arrival and departure.														
	3,498,950	0.7													
10/02/07	System running on arrival and shut down on departure.														
	3,502,850	0.7													
10/05/07	System shut down on arrival and running on departure.														
	3,502,920	0.0													
10/12/07	System running on arrival and running on departure.														
	3,522,910	2.0	W-INF	1,200	<5.0	<5.0	<5.0	<10	1,900	0.205	<65.5	<0.0009	<5.158	0.346	39.346
			W-INT1	<50	<0.50	<0.50	<0.50	<1.0	<5.0						
			W-INT2	<50	<0.50	<0.50	<0.50	<1.0	<5.0						
		W-EFF	<50	<0.50	<0.50	<0.50	<1.0	<5.0							
10/16/07	System running on arrival and running on departure.														
	3,524,550	0.3													
10/22/07	System running on arrival and running on departure.														
	3,546,660	2.6													
11/02/07	System running on arrival and running on departure.														
	3,556,830	0.6													
11/09/07	System running on arrival and running on departure.														
	3,576,540	2.0	W-INF	550	<2.5	<2.5	<2.5	<5.0	1,700	0.392	<65.9	<0.0017	<5.160	0.805	40.152
			W-INT1	<50	<0.50	<0.50	<0.50	<1.0	<5.0						
			W-INT2	<50	<0.50	<0.50	<0.50	<1.0	<5.0						
		W-EFF	<50	<0.50	<0.50	<0.50	<1.0	<5.0							
11/16/07	System running on arrival and running on departure.														
	3,585,210	0.9													
11/21/07	System running on arrival and running on departure.														
	3,590,160	0.7													
11/26/07	System down on arrival and running on departure.														
	3,595,010	0.7													
12/07/07	System running on arrival and running on departure.														
	3,605,900	0.7	W-INF	250	<2.5	<2.5	<2.5	<5.0	380	0.098	<66.0	<0.0006	<5.160	0.255	40.407
			W-INT1	<50	<0.50	0.50	<0.50	<1.0	<5.0						
			W-INT2	<50	<0.50	<0.50	<0.50	<1.0	<5.0						
		W-EFF	<50	<0.50	<0.50	<0.50	<1.0	<5.0							
12/13/07	System running on arrival and running on departure.														
	3,609,430	0.4													
12/14/07	System shut down on arrival and departure.														
	3,610,550	0.8													

TABLE 4
OPERATION AND PERFORMANCE DATA FOR GROUNDWATER PUMP AND TREAT SYSTEM
Former Exxon Service Station 70104
1725 Park Street
Alameda, California

Date	Total Flow (gallons)	Average Flow Rate (gpm)	Sample ID	Laboratory Analytical Results						TPHg Removed		Benzene Removed		MTBE Removed	
				TPHg (µg/l)	B (µg/l)	T (µg/l)	E (µg/l)	X (µg/l)	MTBE (µg/l)	Per Period (lbs)	Cumulative (lbs)	Per Period (lbs)	Cumulative (lbs)	Per Period (lbs)	Cumulative (lbs)
12/19/07	System down on arrival and running on departure.														
	3,610,960	0.1													
12/21/07	System running on arrival and running on departure.														
	3,617,270	2.2													
12/27/07	System running on arrival and running on departure.														
	3,628,510	1.3													
01/04/08	System down on arrival and down on departure.														
	3,635,950	0.7													
01/07/08	System restarted.														
	3,635,950	0.0													
01/18/08	System running on arrival and departure.														
	3,647,250	0.7	W-INF	360	<1.0	<1.0	<1.0	<2.0	500	0.105	<66.1	<0.0006	<5.161	0.152	40.558
			W-INT1	<50	<0.50	<0.50	<0.50	<1.0	<5.0						
			W-INT2	<50	<0.50	<0.50	<0.50	<1.0	<5.0						
			W-EFF	<50	<0.50	<0.50	<0.50	<1.0	<5.0						
01/25/08	System down on arrival and running on departure.														
	3,653,500	0.6													
01/27/08	System down on arrival and running on departure.														
	3,654,200	0.2													
01/31/08	System down on arrival and running on departure.														
	3,659,910	1.0													
02/08/08	System running on arrival and departure.														
	3,690,670	2.7													
02/15/08	Restart system; running on departure.														
	3,704,620	1.4	W-INF	<50	<10.00	29	<10.00	49	2,400	<0.098	<66.2	<0.0026	<5.164	0.694	41.252
			W-INT1	<50	<0.50	<0.50	<0.50	<1.0	14						
			W-INT2	<50	<0.50	<0.50	<0.50	<1.0	<5.0						
			W-EFF	<50	<0.50	<0.50	<0.50	<1.0	<5.0						
02/22/08	System running on arrival and departure.														
	3,716,980	1.2													
02/26/08	System running on arrival and departure.														
	3,722,530	1.0													
03/06/08	System running on arrival and departure.														
	3,738,110	1.2													
03/14/08	System running on arrival and departure.														
	3,749,150	1.0													
03/21/08	System down on arrival and running on departure.														
	3,757,000	0.8													
03/28/08	System down on arrival and running on departure.														
	3,757,540	0.1	W-INF	120	<0.50	<0.50	<0.50	<1.0	210	0.038	<66.3	<0.0023	<5.166	0.576	41.829
			W-INT1	<50	<0.50	<0.50	<0.50	<1.0	21						
			W-INT2	<50	<0.50	<0.50	<0.50	<1.0	<5.0						
			W-EFF	<50	<0.50	<0.50	<0.50	<1.0	<5.0						

TABLE 4
OPERATION AND PERFORMANCE DATA FOR GROUNDWATER PUMP AND TREAT SYSTEM
Former Exxon Service Station 70104
1725 Park Street
Alameda, California

Date	Total Flow (gallons)	Average Flow Rate (gpm)	Sample ID	Laboratory Analytical Results						TPHg Removed		Benzene Removed		MTBE Removed	
				TPHg (µg/l)	B (µg/l)	T (µg/l)	E (µg/l)	X (µg/l)	MTBE (µg/l)	Per Period (lbs)	Cumulative (lbs)	Per Period (lbs)	Cumulative (lbs)	Per Period (lbs)	Cumulative (lbs)
04/05/08	System running on arrival and departure.														
	3,757,690	0.0													
04/11/08	System running on arrival and down on departure.														
	3,757,750	0.0	W-INF	370	<0.50	<0.50	<0.50	<1.0	270	0.000	<66.3	<0.0000	<5,166	0.000	41.829
			W-INT1	<50	<0.50	<0.50	<0.50	<1.0	24						
			W-INT2	<50	<0.50	<0.50	<0.50	<1.0	<5.0						
			W-EFF	<50	<0.50	<0.50	<0.50	<1.0	<5.0						
04/15/08	System down on arrival and running on departure.														
	3,757,750	0.0													
04/22/08	System running on arrival and departure.														
	3,761,040	0.3													
05/02/08	System running on arrival and departure.														
	3,769,160	0.6													
05/06/08	System running on arrival and departure.														
	3,774,830	1.0	W-INF	870	<2.5	<2.5	<2.5	<5.0	1,300	0.088	<66.4	<0.0002	<5,166	0.112	41.941
			W-INT1	65	<0.50	<0.50	<0.50	<1.0	86						
			W-INT2	<50	<0.50	<0.50	<0.50	<1.0	<5.0						
			W-EFF	<50	<0.50	<0.50	<0.50	<1.0	<5.0						
05/16/08	System running on arrival and departure.														
	3,785,690	0.8													
05/23/08	System running on arrival and departure.														
	3,788,780	0.3													
05/28/08	System running on arrival and departure.														
	3,790,260	0.2													
06/03/08	System running on arrival and departure.														
	3,795,970	0.7	W-INF	630	<1.0	<1.0	<1.0	<2.0	550	0.132	<66.5	<0.0003	<5,167	0.163	42,104
			W-INT1	82	0.56	<1.4	<0.50	<1.0	17						
			W-INT2	<50	0.62	1.5	<0.50	<1.0	<5.0						
			W-EFF	<50	<0.50	<0.50	<0.50	<1.0	<5.0						
06/13/08	System running on arrival and departure.														
	3,796,670	0.1													
06/17/08	System running on arrival and departure.														
	3,797,130	0.1													
06/23/08	System running on arrival and departure.														
	3,797,230	0.0													
07/03/08	System running on arrival and departure.														
	3,797,330	0.0													
07/08/08	System running on arrival and departure.														
	3,797,510	0.0	W-INF	640	<2.5	<2.5	<2.5	<5.0	1,200	0.008	<66.5	<0.0000	<5,167	0.011	42,115
			W-INT1	<50	<0.50	<0.50	<0.50	<1.0	77						
			W-INT2	<50	<0.50	<0.50	<0.50	<1.0	<5.0						
			W-EFF	<50	<0.50	<0.50	<0.50	<1.0	<5.0						

TABLE 4
OPERATION AND PERFORMANCE DATA FOR GROUNDWATER PUMP AND TREAT SYSTEM
Former Exxon Service Station 70104
1725 Park Street
Alameda, California

Date	Total Flow (gallons)	Average Flow Rate (gpm)	Sample ID	Laboratory Analytical Results						TPHg Removed		Benzene Removed		MTBE Removed	
				TPHg (µg/l)	B (µg/l)	T (µg/l)	E (µg/l)	X (µg/l)	MTBE (µg/l)	Per Period (lbs)	Cumulative (lbs)	Per Period (lbs)	Cumulative (lbs)	Per Period (lbs)	Cumulative (lbs)
07/15/08	System running on arrival and departure. 3,797,760	0.0	W-INF	<50	2.0	<0.50	<0.50	<1.0	120	<0.001	<66.5	0.0000	<5.167	0.001	42.117
			W-INT1	<50	<0.50	<0.50	<0.50	<1.0	<5.0						
			W-INT2	<50	<0.50	<0.50	<0.50	<1.0	<5.0						
			W-EFF	<50	<0.50	<0.50	<0.50	<1.0	<5.0						
07/21/08	System running on arrival and departure. 3,799,120	0.2													
07/29/08	System running on arrival and departure. 3,799,560	0.0													
08/08/08	System running on arrival and departure. 3,799,950	0.0													
08/15/08	System running on arrival and departure. 3,800,390	0.0													
08/22/08	System running on arrival and departure. 3,800,440	0.0	W-INF	150	4.0	<0.50	<0.50	<1.0	370	0.002	<66.5	0.0001	<5.167	0.005	42.122
			W-INT1	<50	<0.50	<0.50	<0.50	<1.0	<5.0						
			W-INT2	<50	<0.50	<0.50	<0.50	<1.0	<5.0						
			W-EFF	<50	<0.50	<0.50	<0.50	<1.0	<5.0						
08/29/08	System running on arrival and departure. 3,801,090	0.1													
09/05/08	System running on arrival and departure. 3,801,360	0.0	W-INF	570	5.6	<5.0	<5.0	<10	4,700	0.003	<66.5	0.0000	<5.167	0.019	42.142
			W-INT1	<50	<0.50	<0.50	<0.50	<1.0	<5.0						
			W-INT2	<50	<0.50	<0.50	<0.50	<1.0	<5.0						
			W-EFF	<50	<0.50	<0.50	<0.50	<1.0	<5.0						
09/12/08	System running on arrival and departure. 3,801,700	0.0													
09/19/08	System running on arrival and departure. 3,802,220	0.1													
09/26/08	System running on arrival and departure. 3,821,130	1.9													
10/03/08	System running on arrival and departure. 3,829,660	0.9													
10/10/08	System running on arrival and departure. 3,836,030	0.6	W-INF	410	<1.0	<1.00	<1.00	<2.0	640	0.142	<66.6	<0.0010	<5.168	0.772	42.914
			W-INT1	<50	<0.50	<0.50	<0.50	<1.0	<5.0						
			W-INT2	<50	<0.50	<0.50	<0.50	<1.0	<5.0						
			W-EFF	<50	<0.50	<0.50	<0.50	<1.0	<5.0						
10/17/08	System running on arrival and departure. 3,842,780	0.7													
10/31/08	System running on arrival and departure. 3,859,120	0.8													
11/07/08	System running on arrival and departure. 3,865,290	0.6													

TABLE 4
OPERATION AND PERFORMANCE DATA FOR GROUNDWATER PUMP AND TREAT SYSTEM
Former Exxon Service Station 70104
1725 Park Street
Alameda, California

Date	Total Flow (gallons)	Average Flow Rate (gpm)	Sample ID	Laboratory Analytical Results						TPHg Removed		Benzene Removed		MTBE Removed	
				TPHg (µg/l)	B (µg/l)	T (µg/l)	E (µg/l)	X (µg/l)	MTBE (µg/l)	Per Period (lbs)	Cumulative (lbs)	Per Period (lbs)	Cumulative (lbs)	Per Period (lbs)	Cumulative (lbs)
11/15/08	System running on arrival and departure. 3,871,710 0.6														
11/17/08	System running on arrival and departure. 3,872,707 0.4		W-INF	550	<1.0	<1.0	<1.0	<2.0	940	0.147	<66.8	<0.0003	<5.168	0.242	43,156
			W-INT1	<50	<0.50	<0.50	<0.50	<1.0	<5.0						
			W-INT2	<50	<0.50	<0.50	<0.50	<1.0	<5.0						
			W-EFF	<50	<0.50	<0.50	<0.50	<1.0	<5.0						
11/25/08	System running on arrival and departure. 3,875,830 0.3														
12/05/08	System running on arrival and departure. 3,883,530 0.5														
12/12/08	System running on arrival and departure. 3,887,570 0.4		W-INF	180	<0.50	<0.50	<0.50	<1.0	280	0.045	<66.8	<0.0001	<5.168	0.076	43,231
			W-INT1	<50	<0.50	<0.50	<0.50	<1.0	<5.0						
			W-INT2	<50	<0.50	<0.50	<0.50	<1.0	<5.0						
			W-EFF	<50	<0.50	<0.50	<0.50	<1.0	<5.0						
12/16/08	System running on arrival and departure. 3,891,390 0.7														
12/24/08	System running on arrival and departure. 3,892,540 0.1														
01/02/09	System running on arrival and departure. 3,912,840 1.6														
01/09/09	System running on arrival and departure. 3,921,110 0.8		W-INF	63	<0.50	<0.50	<0.50	<1.0	310	0.034	<66.9	<0.0001	<5.168	0.083	43,314
			W-INT1	<50	<0.50	<0.50	<0.50	<1.0	<5.0						
			W-INT2	<50	<0.50	<0.50	<0.50	<1.0	<5.0						
			W-EFF	<50	<0.50	<0.50	<0.50	<1.0	<5.0						
01/16/09	System running on arrival and departure. 3,923,430 0.2														
01/20/09	System running on arrival and departure. 3,928,540 0.9														
01/30/09	System running on arrival and departure. 3,939,740 0.8														
02/06/09	System running on arrival and departure. 3,947,850 0.8														
02/13/09	System running on arrival and departure. 3,955,300 0.7		W-INF	97	<0.50	<0.50	<0.50	<1.0	400	0.023	<66.9	<0.0001	<5.168	0.101	43,415
			W-INT1	<50	<0.50	<0.50	<0.50	<1.0	<5.0						
			W-INT2	<50	<0.50	<0.50	<0.50	<1.0	<5.0						
			W-EFF	<50	<0.50	<0.50	<0.50	<1.0	<5.0						
02/20/09	System down on arrival and departure. 3,961,760 0.6														
02/27/09	System down on arrival and departure. 3,961,760 0.0														

TABLE 4
OPERATION AND PERFORMANCE DATA FOR GROUNDWATER PUMP AND TREAT SYSTEM
Former Exxon Service Station 70104
1725 Park Street
Alameda, California

Date	Total Flow (gallons)	Average Flow Rate (gpm)	Sample ID	Laboratory Analytical Results						TPHg Removed		Benzene Removed		MTBE Removed	
				TPHg (µg/l)	B (µg/l)	T (µg/l)	E (µg/l)	X (µg/l)	MTBE (µg/l)	Per Period (lbs)	Cumulative (lbs)	Per Period (lbs)	Cumulative (lbs)	Per Period (lbs)	Cumulative (lbs)
03/06/09	System running on arrival and departure. 3,969,890														
		0.8													
03/13/09	System running on arrival and departure. 3,989,370														
		1.9	W-INF	310	1.5	<0.50	<0.50	1.6	410	0.058	<66.9	0.0003	<5,169	0.115	43.530
			W-INT1	<50	<0.50	<0.50	<0.50	<1.0	<5.0						
			W-INT2	<50	<0.50	<0.50	<0.50	<1.0	<5.0						
			W-EFF	<50	<0.50	<0.50	<0.50	<1.0	<5.0						
03/20/09	System running on arrival and departure. 3,999,140														
		1.0													
03/23/09	System running on arrival and departure. 3,999,870														
		0.2													
03/31/09	System running on arrival and departure. 4,009,710														
		0.9													
04/07/09	System running on arrival and departure. 4,015,770														
		0.6	W-INF	360	<0.50	<0.50	<0.50	<1.0	490	0.074	<67.0	<0.0002	<5,169	0.099	43.629
			W-INT1	<50	<0.50	<0.50	<0.50	<1.0	<5.0						
			W-INT2	<50	<0.50	<0.50	<0.50	<1.0	<5.0						
			W-EFF	<50	<0.50	<0.50	<0.50	<1.0	<5.0						
04/17/09	System running on arrival and departure. 4,030,486														
		1.0													
04/29/09	System running on arrival and departure. 4,047,450														
		1.0													
05/01/09	System running on arrival and departure. 4,057,140														
		3.4													
05/08/09	System running on arrival and departure. 4,064,660														
		0.8													
05/15/09	System running on arrival and departure. 4,070,650														
		0.6	W-INF	360	<0.50	<0.50	<0.50	<1.0	470	0.165	<67.2	<0.0002	<5,169	0.220	43.849
			W-INT1	<50	<0.50	<0.50	<0.50	<1.0	<5.0						
			W-INT2	<50	<0.50	<0.50	<0.50	<1.0	<5.0						
			W-EFF	<50	<0.50	<0.50	<0.50	<1.0	<5.0						
05/22/09	System running on arrival and departure. 4,075,430														
		0.5													
05/29/09	System running on arrival and departure. 4,077,470														
		0.2													
06/05/09	System running on arrival and departure. 4,083,490														
		0.6													
06/11/09	System running on arrival and departure. 4,094,140														
		1.2	W-INF	<50	<0.50	<0.50	<0.50	<1.0	700	<0.040	<67.2	<0.0001	<5,169	0.115	43.964
			W-INT1	<50	<0.50	<0.50	<0.50	<1.0	<5.0						
			W-INT2	<50	<0.50	<0.50	<0.50	<1.0	<5.0						
			W-EFF	<50	<0.50	0.69g	<0.50	3.4	<5.0						

TABLE 4
OPERATION AND PERFORMANCE DATA FOR GROUNDWATER PUMP AND TREAT SYSTEM
Former Exxon Service Station 70104
1725 Park Street
Alameda, California

Notes: * If value is below laboratory detection limit, then detection limit value is used for removal calculations.
Data prior to April 1, 2000, provided by Delta Environmental Consultants, Inc.

W- INF	=	Water sample collected at the influent sample port.
W-INT	=	Water sample collected at the intermediate 1 sample port.
W-EFF	=	Water sample collected at the intermediate 2 sample port.
W-PSP#1	=	Water sample collected at the effluent sample port. Also referred to as PSP#1 for reporting purposes.
TPHg	=	Total petroleum hydrocarbons as gasoline analyzed using EPA Method 5030/8015 (modified)/8015B or LUFT GCMS.
BTEX	=	Benzene, toluene, ethylbenzene, and total xylenes analyzed using EPA Method 5030/8021B or 624.
MTBE	=	Methyl tertiary butyl ether analyzed using EPA Method 8020/8021B.
gal	=	Gallons.
gpm	=	Gallons per day.
µg/L	=	Micrograms per liter.
lbs	=	Pounds.
<	=	Less than the stated laboratory method reporting limit.
---	=	Not sampled/Not analyzed/Not recorded/Not measured/Not calculated/Not applicable.
a	=	Incorrect sample date is shown on laboratory report. The correct date is shown on table.
b	=	Estimated value above laboratory equipment calibration range.
c	=	Analyte detected in associated Method Blank.
d	=	The result for this hydrocarbon is elevated due to the presence of single analyte peak(s) in the quantitation range.
e	=	Samples exceeded the EPA recommended temperature for analyses.
f	=	Sample analyzed past EPA recommended hold time.
g	=	Analyte presence was not confirmed by second column or GC/MS analysis.

APPENDIX A
GROUNDWATER SAMPLING PROTOCOL

GROUNDWATER SAMPLING PROTOCOL

The static water level and separate-phase product level, if present, in each well that contained water and/or separate-phase product are measured with a ORS Interface Probe, which is accurate to the nearest 0.01 foot. To calculate groundwater elevations and evaluate groundwater gradient, depth to water (DTW) levels are subtracted from top of casing elevations.

Groundwater samples collected for subjective evaluation are collected by gently lowering approximately half the length of a clean Teflon® or polypropylene bailer past the air-water interface (if possible) and collecting a sample from near the surface of the water in the well. The samples are checked for measurable free-phase hydrocarbons or sheen. If appropriate, free-phase hydrocarbons are removed from the well.

Before water samples are collected from the groundwater monitoring wells, the wells are purged until a minimum of three well casing volumes is purged and stabilization of the temperature, pH, and conductivity is obtained. Water samples from the wells that do not obtain stability of the temperature, pH, and conductivity are considered to be "grab samples." The quantity of water purged from each well is calculated as follows:

1 well casing volume = $\pi r^2 h (7.48)$ where:

r	=	radius of the well casing in feet
h	=	column of water in the well in feet (depth to bottom - depth to water)
7.48	=	conversion constant from cubic feet to gallons
π	=	ratio of the circumference of a circle to its diameter

Gallons of water purged/gallons in 1 well casing volume = well casing volumes removed.


After purging, each well is allowed to recharge to at least 80% of the initial water level. Water samples from wells that do not recover at least 80% (due to slow recharging of the well) between purging and sampling are considered to be "grab samples." Water samples are collected with a new, disposable Teflon® or polypropylene bailer. The groundwater is carefully poured into selected sample containers (40-milliliter [ml] glass vials, 1,000-ml glass amber bottles, etc.), which are filled so as to produce a positive meniscus.

Depending on the required analysis, each sample container is preserved with hydrochloric acid, nitric acid, etc., or it is preservative free. The type of preservative used for each sample is specified on the Chain-of-Custody record.

Each vial and glass amber bottle is sealed with a cap containing a Teflon® septum, and subsequently examined for air bubbles to avoid headspace, which would allow volatilization to occur. The samples are promptly transported in iced storage in a thermally-insulated ice chest, accompanied by a Chain-of-Custody record, to a California state-certified laboratory.

APPENDIX B

**LABORATORY ANALYTICAL REPORTS
AND CHAIN-OF-CUSTODY RECORDS**



June 11, 2009

RECEIVED
JUN 12 2009

Paula Sime
Environmental Resolutions, Inc.
601 North McDowell Blvd.
Petaluma, CA 94954-2312

BY:.....

Subject: **Calscience Work Order No.: 09-05-2483**
Client Reference: **ExxonMobil 70104**

Dear Client:

Enclosed is an analytical report for the above-referenced project. The samples included in this report were received 5/29/2009 and analyzed in accordance with the attached chain-of-custody.

Unless otherwise noted, all analytical testing was accomplished in accordance with the guidelines established in our Quality Systems Manual, applicable standard operating procedures, and other related documentation. The original report of subcontracted analysis, if any, is provided herein, and follows the standard Calscience data package. The results in this analytical report are limited to the samples tested and any reproduction thereof must be made in its entirety.


Note that the Chain-of-Custody Record and Sample Receipt Form are integral parts of this report.


If you have any questions regarding this report, please do not hesitate to contact the undersigned.

Sincerely,

Cecile de Guia

Calscience Environmental
Laboratories, Inc.
Cecile deGuia
Project Manager





Analytical Report



Environmental Resolutions, Inc.
601 North McDowell Blvd.
Petaluma, CA 94954-2312

Date Received: 05/29/09
Work Order No: 09-05-2483
Preparation: EPA 3510C
Method: EPA 8015B (M)

Project: ExxonMobil 70104

Page 1 of 3

Client Sample Number	Lab Sample Number	Date/Time Collected	Matrix	Instrument	Date Prepared	Date/Time Analyzed	QC Batch ID
MW1	09-05-2483-2-G	05/27/09 10:56	Aqueous	GC 46	05/29/09	06/02/09 10:27	090529B22

Comment(s): -The sample extract was subjected to Silica Gel treatment prior to analysis.

Parameter	Result	RL	DF	Qual	Units
TPH as Diesel	100	50	1		ug/L
Surrogates:	REC (%)	Control Limits		Qual	
Decachlorobiphenyl	104	68-140			

MW2	09-05-2483-3-G	05/27/09 10:45	Aqueous	GC 46	05/29/09	06/02/09 10:42	090529B22
-----	----------------	----------------	---------	-------	----------	----------------	-----------

Comment(s): -The sample extract was subjected to Silica Gel treatment prior to analysis.

Parameter	Result	RL	DF	Qual	Units
TPH as Diesel	ND	50	1		ug/L
Surrogates:	REC (%)	Control Limits		Qual	
Decachlorobiphenyl	102	68-140			

MW3	09-05-2483-4-G	05/27/09 11:15	Aqueous	GC 46	05/29/09	06/02/09 11:13	090529B22
-----	----------------	----------------	---------	-------	----------	----------------	-----------

Comment(s): -The sample extract was subjected to Silica Gel treatment prior to analysis.

Parameter	Result	RL	DF	Qual	Units
TPH as Diesel	ND	50	1		ug/L
Surrogates:	REC (%)	Control Limits		Qual	
Decachlorobiphenyl	106	68-140			

MW4	09-05-2483-5-G	05/27/09 10:15	Aqueous	GC 46	05/29/09	06/02/09 11:29	090529B22
-----	----------------	----------------	---------	-------	----------	----------------	-----------

Comment(s): -The sample extract was subjected to Silica Gel treatment prior to analysis.

Parameter	Result	RL	DF	Qual	Units
TPH as Diesel	ND	50	1		ug/L
Surrogates:	REC (%)	Control Limits		Qual	
Decachlorobiphenyl	102	68-140			

RL - Reporting Limit , DF - Dilution Factor , Qual - Qualifiers

Analytical Report



Environmental Resolutions, Inc.
 601 North McDowell Blvd.
 Petaluma, CA 94954-2312

Date Received: 05/29/09
 Work Order No: 09-05-2483
 Preparation: EPA 3510C
 Method: EPA 8015B (M)

Project: ExxonMobil 70104

Page 2 of 3

Client Sample Number	Lab Sample Number	Date/Time Collected	Matrix	Instrument	Date Prepared	Date/Time Analyzed	QC Batch ID
MW5	09-05-2483-6-G	05/27/09 11:00	Aqueous	GC 46	05/29/09	06/02/09 11:44	090529B22

Comment(s): -The sample extract was subjected to Silica Gel treatment prior to analysis.

Parameter	Result	RL	DF	Qual	Units
TPH as Diesel	1600	50	1		ug/L
<u>Surrogates:</u>	<u>REC (%)</u>	<u>Control Limits</u>		<u>Qual</u>	
Decachlorobiphenyl	107	68-140			

Client Sample Number	Lab Sample Number	Date/Time Collected	Matrix	Instrument	Date Prepared	Date/Time Analyzed	QC Batch ID
MW6	09-05-2483-7-G	05/27/09 12:37	Aqueous	GC 46	05/29/09	06/02/09 11:59	090529B22

Comment(s): -The sample extract was subjected to Silica Gel treatment prior to analysis.

Parameter	Result	RL	DF	Qual	Units
TPH as Diesel	88	50	1		ug/L
<u>Surrogates:</u>	<u>REC (%)</u>	<u>Control Limits</u>		<u>Qual</u>	
Decachlorobiphenyl	116	68-140			

Client Sample Number	Lab Sample Number	Date/Time Collected	Matrix	Instrument	Date Prepared	Date/Time Analyzed	QC Batch ID
MW7	09-05-2483-8-G	05/27/09 11:09	Aqueous	GC 46	05/29/09	06/02/09 12:14	090529B22

Comment(s): -The sample extract was subjected to Silica Gel treatment prior to analysis.


Parameter	Result	RL	DF	Qual	Units
TPH as Diesel	ND	50	1		ug/L
<u>Surrogates:</u>	<u>REC (%)</u>	<u>Control Limits</u>		<u>Qual</u>	
Decachlorobiphenyl	97	68-140			

Client Sample Number	Lab Sample Number	Date/Time Collected	Matrix	Instrument	Date Prepared	Date/Time Analyzed	QC Batch ID
MW8	09-05-2483-9-G	05/27/09 09:05	Aqueous	GC 46	05/29/09	06/02/09 12:30	090529B22

Comment(s): -The sample extract was subjected to Silica Gel treatment prior to analysis.

Parameter	Result	RL	DF	Qual	Units
TPH as Diesel	ND	50	1		ug/L
<u>Surrogates:</u>	<u>REC (%)</u>	<u>Control Limits</u>		<u>Qual</u>	
Decachlorobiphenyl	104	68-140			

RL - Reporting Limit , DF - Dilution Factor , Qual - Qualifiers



Analytical Report



Environmental Resolutions, Inc.
601 North McDowell Blvd.
Petaluma, CA 94954-2312

Date Received: 05/29/09
Work Order No: 09-05-2483
Preparation: EPA 3510C
Method: EPA 8015B (M)

Project: ExxonMobil 70104

Page 3 of 3

Client Sample Number	Lab Sample Number	Date/Time Collected	Matrix	Instrument	Date Prepared	Date/Time Analyzed	QC Batch ID
MW9	09-05-2483-10-G	05/27/09 09:42	Aqueous	GC 46	05/29/09	06/02/09 12:45	090529B22

Comment(s): -The sample extract was subjected to Silica Gel treatment prior to analysis.

Parameter	Result	RL	DF	Qual	Units
TPH as Diesel	ND	50	1		ug/L
<u>Surrogates:</u>	<u>REC (%)</u>	<u>Control Limits</u>		<u>Qual</u>	
Decachlorobiphenyl	100	68-140			

Client Sample Number	Lab Sample Number	Date/Time Collected	Matrix	Instrument	Date Prepared	Date/Time Analyzed	QC Batch ID
MW11	09-05-2483-11-G	05/27/09 10:18	Aqueous	GC 46	05/29/09	06/02/09 00:00	090529B22


Comment(s): -The sample extract was subjected to Silica Gel treatment prior to analysis.

Parameter	Result	RL	DF	Qual	Units
TPH as Diesel	ND	50	1		ug/L
<u>Surrogates:</u>	<u>REC (%)</u>	<u>Control Limits</u>		<u>Qual</u>	
Decachlorobiphenyl	91	68-140			

Client Sample Number	Lab Sample Number	Date/Time Collected	Matrix	Instrument	Date Prepared	Date/Time Analyzed	QC Batch ID
Method Blank	099-12-330-1,113	N/A	Aqueous	GC 46	05/29/09	06/02/09 01:11	090529B22

Parameter	Result	RL	DF	Qual	Units
TPH as Diesel	ND	50	1		ug/L
<u>Surrogates:</u>	<u>REC (%)</u>	<u>Control Limits</u>		<u>Qual</u>	
Decachlorobiphenyl	102	68-140			

RL - Reporting Limit , DF - Dilution Factor , Qual - Qualifiers



Analytical Report



Environmental Resolutions, Inc.
601 North McDowell Blvd.
Petaluma, CA 94954-2312

Date Received: 05/29/09
Work Order No: 09-05-2483
Preparation: EPA 5030B
Method: EPA 8015B (M)

Project: ExxonMobil 70104

Page 1 of 3

Table with 9 columns: Client Sample Number, Lab Sample Number, Date/Time Collected, Matrix, Instrument, Date Prepared, Date/Time Analyzed, QC Batch ID. Row 1: MW1, 09-05-2483-2-E, 05/27/09 10:56, Aqueous, GC 29, 06/05/09, 06/06/09 01:43, 090605B01

Table with 6 columns: Parameter, Result, RL, DF, Qual, Units. Rows: TPH as Gasoline (840, 50, 1, ug/L), Surrogates: 1,4-Bromofluorobenzene (84, 38-134)

Table with 9 columns: Client Sample Number, Lab Sample Number, Date/Time Collected, Matrix, Instrument, Date Prepared, Date/Time Analyzed, QC Batch ID. Row 1: MW2, 09-05-2483-3-E, 05/27/09 10:45, Aqueous, GC 29, 06/05/09, 06/06/09 02:17, 090605B01

Table with 6 columns: Parameter, Result, RL, DF, Qual, Units. Rows: TPH as Gasoline (63, 50, 1, ug/L), Surrogates: 1,4-Bromofluorobenzene (81, 38-134)


Table with 9 columns: Client Sample Number, Lab Sample Number, Date/Time Collected, Matrix, Instrument, Date Prepared, Date/Time Analyzed, QC Batch ID. Row 1: MW3, 09-05-2483-4-F, 05/27/09 11:15, Aqueous, GC 29, 06/08/09, 06/08/09 17:45, 090608B01

Table with 6 columns: Parameter, Result, RL, DF, Qual, Units. Rows: TPH as Gasoline (2400, 1000, 20, ug/L), Surrogates: 1,4-Bromofluorobenzene (97, 38-134)

Table with 9 columns: Client Sample Number, Lab Sample Number, Date/Time Collected, Matrix, Instrument, Date Prepared, Date/Time Analyzed, QC Batch ID. Row 1: MW4, 09-05-2483-5-F, 05/27/09 10:15, Aqueous, GC 29, 06/08/09, 06/08/09 18:19, 090608B01

Table with 6 columns: Parameter, Result, RL, DF, Qual, Units. Rows: TPH as Gasoline (1300, 500, 10, ug/L), Surrogates: 1,4-Bromofluorobenzene (99, 38-134)

RL - Reporting Limit , DF - Dilution Factor , Qual - Qualifiers



Analytical Report



Environmental Resolutions, Inc.
 601 North McDowell Blvd.
 Petaluma, CA 94954-2312

Date Received: 05/29/09
 Work Order No: 09-05-2483
 Preparation: EPA 5030B
 Method: EPA 8015B (M)

Project: ExxonMobil 70104

Page 2 of 3

Client Sample Number	Lab Sample Number	Date/Time Collected	Matrix	Instrument	Date Prepared	Date/Time Analyzed	QC Batch ID
MW5	09-05-2483-6-F	05/27/09 11:00	Aqueous	GC 29	06/08/09	06/08/09 19:25	090608B01

Parameter	Result	RL	DF	Qual	Units
TPH as Gasoline	3100	500	10		ug/L
<u>Surrogates:</u>	<u>REC (%)</u>	<u>Control Limits</u>		<u>Qual</u>	
1,4-Bromofluorobenzene	97	38-134			

MW6	09-05-2483-7-F	05/27/09 12:37	Aqueous	GC 29	06/08/09	06/08/09 19:59	090608B01
-----	----------------	-------------------	---------	-------	----------	-------------------	-----------

Parameter	Result	RL	DF	Qual	Units
TPH as Gasoline	5100	500	10		ug/L
<u>Surrogates:</u>	<u>REC (%)</u>	<u>Control Limits</u>		<u>Qual</u>	
1,4-Bromofluorobenzene	111	38-134			


MW7	09-05-2483-8-E	05/27/09 11:09	Aqueous	GC 29	06/05/09	06/06/09 05:04	090605B01
-----	----------------	-------------------	---------	-------	----------	-------------------	-----------

Parameter	Result	RL	DF	Qual	Units
TPH as Gasoline	ND	50	1		ug/L
<u>Surrogates:</u>	<u>REC (%)</u>	<u>Control Limits</u>		<u>Qual</u>	
1,4-Bromofluorobenzene	76	38-134			

MW8	09-05-2483-9-E	05/27/09 09:05	Aqueous	GC 29	06/05/09	06/06/09 05:37	090605B01
-----	----------------	-------------------	---------	-------	----------	-------------------	-----------

Parameter	Result	RL	DF	Qual	Units
TPH as Gasoline	ND	50	1		ug/L
<u>Surrogates:</u>	<u>REC (%)</u>	<u>Control Limits</u>		<u>Qual</u>	
1,4-Bromofluorobenzene	79	38-134			

RL - Reporting Limit , DF - Dilution Factor , Qual - Qualifiers



Analytical Report



Environmental Resolutions, Inc.	Date Received:	05/29/09
601 North McDowell Blvd.	Work Order No:	09-05-2483
Petaluma, CA 94954-2312	Preparation:	EPA 5030B
	Method:	EPA 8015B (M)

Project: ExxonMobil 70104 Page 3 of 3

Client Sample Number	Lab Sample Number	Date/Time Collected	Matrix	Instrument	Date Prepared	Date/Time Analyzed	QC Batch ID
MW9	09-05-2483-10-F	05/27/09 09:42	Aqueous	GC 29	06/05/09	06/06/09 06:10	090605B01

Parameter	Result	RL	DF	Qual	Units
TPH as Gasoline	ND	50	1		ug/L
<u>Surrogates:</u>	<u>REC (%)</u>	<u>Control Limits</u>		<u>Qual</u>	
1,4-Bromofluorobenzene	78	38-134			

MW11	09-05-2483-11-F	05/27/09 10:18	Aqueous	GC 29	06/08/09	06/08/09 20:32	090608B01
------	-----------------	-------------------	---------	-------	----------	-------------------	-----------

Parameter	Result	RL	DF	Qual	Units
TPH as Gasoline	18000	2500	50		ug/L
<u>Surrogates:</u>	<u>REC (%)</u>	<u>Control Limits</u>		<u>Qual</u>	
1,4-Bromofluorobenzene	96	38-134			

Method Blank	099-12-436-3,357	N/A	Aqueous	GC 29	06/05/09	06/05/09 16:16	090605B01
--------------	------------------	-----	---------	-------	----------	-------------------	-----------

Parameter	Result	RL	DF	Qual	Units
TPH as Gasoline	ND	50	1		ug/L
<u>Surrogates:</u>	<u>REC (%)</u>	<u>Control Limits</u>		<u>Qual</u>	
1,4-Bromofluorobenzene	82	38-134			

Method Blank	099-12-436-3,363	N/A	Aqueous	GC 29	06/08/09	06/08/09 10:31	090608B01
--------------	------------------	-----	---------	-------	----------	-------------------	-----------

Parameter	Result	RL	DF	Qual	Units
TPH as Gasoline	ND	50	1		ug/L
<u>Surrogates:</u>	<u>REC (%)</u>	<u>Control Limits</u>		<u>Qual</u>	
1,4-Bromofluorobenzene	94	38-134			

RL - Reporting Limit , DF - Dilution Factor , Qual - Qualifiers

Analytical Report



Environmental Resolutions, Inc.
601 North McDowell Blvd.
Petaluma, CA 94954-2312

Date Received: 05/29/09
Work Order No: 09-05-2483
Preparation: EPA 5030B
Method: EPA 8021B
Units: ug/L

Project: ExxonMobil 70104

Page 1 of 3

Client Sample Number	Lab Sample Number	Date/Time Collected	Matrix	Instrument	Date Prepared	Date/Time Analyzed	QC Batch ID
MW1	09-05-2483-2-D	05/27/09 10:56	Aqueous	GC 8	06/01/09	06/01/09 20:18	090601B02

Parameter	Result	RL	DF	Qual	Parameter	Result	RL	DF	Qual
Benzene	3.6	0.50	1		Ethylbenzene	0.92	0.50	1	
Toluene	0.64	0.50	1		Xylenes (total)	1.5	1.0	1	Z
Surrogates:	REC (%)	Control Limits		Qual					
1,4-Bromofluorobenzene	118	70-130							

Client Sample Number	Lab Sample Number	Date/Time Collected	Matrix	Instrument	Date Prepared	Date/Time Analyzed	QC Batch ID
MW2	09-05-2483-3-D	05/27/09 10:45	Aqueous	GC 8	06/01/09	06/01/09 20:52	090601B02

Parameter	Result	RL	DF	Qual	Parameter	Result	RL	DF	Qual
Benzene	5.5	0.50	1		Ethylbenzene	ND	0.50	1	
Toluene	ND	0.50	1		Xylenes (total)	ND	1.0	1	
Surrogates:	REC (%)	Control Limits		Qual					
1,4-Bromofluorobenzene	110	70-130							

Client Sample Number	Lab Sample Number	Date/Time Collected	Matrix	Instrument	Date Prepared	Date/Time Analyzed	QC Batch ID
MW3	09-05-2483-4-D	05/27/09 11:15	Aqueous	GC 8	06/01/09	06/01/09 22:34	090601B02

Parameter	Result	RL	DF	Qual	Parameter	Result	RL	DF	Qual
Benzene	220	0.50	1		Ethylbenzene	79	0.50	1	
Toluene	12	0.50	1		Xylenes (total)	260	1.0	1	
Surrogates:	REC (%)	Control Limits		Qual					
1,4-Bromofluorobenzene	166	70-130		2					


Client Sample Number	Lab Sample Number	Date/Time Collected	Matrix	Instrument	Date Prepared	Date/Time Analyzed	QC Batch ID
MW4	09-05-2483-5-D	05/27/09 10:15	Aqueous	GC 8	06/01/09	06/01/09 23:08	090601B02

Parameter	Result	RL	DF	Qual	Parameter	Result	RL	DF	Qual
Benzene	53	0.50	1		Ethylbenzene	11	0.50	1	
Toluene	2.9	0.50	1		Xylenes (total)	7.6	1.0	1	
Surrogates:	REC (%)	Control Limits		Qual					
1,4-Bromofluorobenzene	130	70-130							

Client Sample Number	Lab Sample Number	Date/Time Collected	Matrix	Instrument	Date Prepared	Date/Time Analyzed	QC Batch ID
MW5	09-05-2483-6-D	05/27/09 11:00	Aqueous	GC 8	06/01/09	06/01/09 23:42	090601B02

Parameter	Result	RL	DF	Qual	Parameter	Result	RL	DF	Qual
Benzene	47	0.50	1		Ethylbenzene	7.7	0.50	1	
Toluene	2.5	0.50	1		Xylenes (total)	8.3	1.0	1	
Surrogates:	REC (%)	Control Limits		Qual					
1,4-Bromofluorobenzene	117	70-130							

RL - Reporting Limit , DF - Dilution Factor , Qual - Qualifiers



Analytical Report



Environmental Resolutions, Inc.
 601 North McDowell Blvd.
 Petaluma, CA 94954-2312

Date Received: 05/29/09
 Work Order No: 09-05-2483
 Preparation: EPA 5030B
 Method: EPA 8021B
 Units: ug/L

Project: ExxonMobil 70104

Page 2 of 3

Client Sample Number	Lab Sample Number	Date/Time Collected	Matrix	Instrument	Date Prepared	Date/Time Analyzed	QC Batch ID
MW6	09-05-2483-7-D	05/27/09 12:37	Aqueous	GC 8	06/01/09	06/02/09 00:16	090601B02

Parameter	Result	RL	DF	Qual	Parameter	Result	RL	DF	Qual
Benzene	4.2	0.50	1		Ethylbenzene	43	0.50	1	
Toluene	1.6	0.50	1		Xylenes (total)	72	1.0	1	
Surrogates:	REC (%)	Control Limits		Qual					
1,4-Bromofluorobenzene	116	70-130							

Client Sample Number	Lab Sample Number	Date/Time Collected	Matrix	Instrument	Date Prepared	Date/Time Analyzed	QC Batch ID
MW7	09-05-2483-8-D	05/27/09 11:09	Aqueous	GC 8	06/01/09	06/02/09 03:38	090601B02

Parameter	Result	RL	DF	Qual	Parameter	Result	RL	DF	Qual
Benzene	ND	0.50	1		Ethylbenzene	ND	0.50	1	
Toluene	ND	0.50	1		Xylenes (total)	ND	1.0	1	
Surrogates:	REC (%)	Control Limits		Qual					
1,4-Bromofluorobenzene	109	70-130							

Client Sample Number	Lab Sample Number	Date/Time Collected	Matrix	Instrument	Date Prepared	Date/Time Analyzed	QC Batch ID
MW8	09-05-2483-9-D	05/27/09 09:05	Aqueous	GC 8	06/01/09	06/02/09 04:12	090601B02

Parameter	Result	RL	DF	Qual	Parameter	Result	RL	DF	Qual
Benzene	ND	0.50	1		Ethylbenzene	ND	0.50	1	
Toluene	ND	0.50	1		Xylenes (total)	ND	1.0	1	
Surrogates:	REC (%)	Control Limits		Qual					
1,4-Bromofluorobenzene	106	70-130							


Client Sample Number	Lab Sample Number	Date/Time Collected	Matrix	Instrument	Date Prepared	Date/Time Analyzed	QC Batch ID
MW9	09-05-2483-10-E	05/27/09 09:42	Aqueous	GC 8	06/01/09	06/02/09 10:39	090601B02

Parameter	Result	RL	DF	Qual	Parameter	Result	RL	DF	Qual
Benzene	ND	0.50	1		Ethylbenzene	ND	0.50	1	
Toluene	ND	0.50	1		Xylenes (total)	ND	1.0	1	
Surrogates:	REC (%)	Control Limits		Qual					
1,4-Bromofluorobenzene	109	70-130							

Client Sample Number	Lab Sample Number	Date/Time Collected	Matrix	Instrument	Date Prepared	Date/Time Analyzed	QC Batch ID
MW11	09-05-2483-11-E	05/27/09 10:18	Aqueous	GC 8	06/01/09	06/02/09 11:13	090601B02

Parameter	Result	RL	DF	Qual	Parameter	Result	RL	DF	Qual
Benzene	710	10	20		Ethylbenzene	1200	10	20	
Toluene	990	10	20		Xylenes (total)	5200	20	20	
Surrogates:	REC (%)	Control Limits		Qual					
1,4-Bromofluorobenzene	120	70-130							

RL - Reporting Limit , DF - Dilution Factor , Qual - Qualifiers



Analytical Report



Environmental Resolutions, Inc.
601 North McDowell Blvd.
Petaluma, CA 94954-2312

Date Received: 05/29/09
Work Order No: 09-05-2483
Preparation: EPA 5030B
Method: EPA 8021B
Units: ug/L

Project: ExxonMobil 70104

Page 3 of 3

Client Sample Number	Lab Sample Number	Date/Time Collected	Matrix	Instrument	Date Prepared	Date/Time Analyzed	QC Batch ID
Method Blank	099-12-667-457	N/A	Aqueous	GC 8	06/01/09	06/01/09 19:45	090601B02

Parameter	Result	RL	DF	Qual	Parameter	Result	RL	DF	Qual
Benzene	ND	0.50	1		Ethylbenzene	ND	0.50	1	
Toluene	ND	0.50	1		Xylenes (total)	ND	1.0	1	
Surrogates:	REC (%)	Control Limits		Qual					
1,4-Bromofluorobenzene	112	70-130							

RL - Reporting Limit , DF - Dilution Factor , Qual - Qualifiers

Analytical Report



Environmental Resolutions, Inc.
 601 North McDowell Blvd.
 Petaluma, CA 94954-2312

Date Received: 05/29/09
 Work Order No: 09-05-2483
 Preparation: EPA 5030B
 Method: EPA 8260B
 Units: ug/L

Project: ExxonMobil 70104

Page 1 of 3

Client Sample Number	Lab Sample Number	Date/Time Collected	Matrix	Instrument	Date Prepared	Date/Time Analyzed	QC Batch ID
MW2	09-05-2483-3-A	05/27/09 10:45	Aqueous	GC/MS Q	06/08/09	06/09/09 07:36	090608L02

Parameter	Result	RL	DF	Qual	Parameter	Result	RL	DF	Qual
Methyl-t-Butyl Ether (MTBE)	1.2	0.50	1		Tert-Amyl-Methyl Ether (TAME)	ND	0.50	1	
Tert-Butyl Alcohol (TBA)	47	5.0	1		Ethanol	ND	50	1	
Diisopropyl Ether (DIPE)	ND	0.50	1		1,2-Dibromoethane	ND	0.50	1	
Ethyl-t-Butyl Ether (ETBE)	ND	0.50	1		1,2-Dichloroethane	ND	0.50	1	
<u>Surrogates:</u>	<u>REC (%)</u>	<u>Control Limits</u>		<u>Qual</u>	<u>Surrogates:</u>	<u>REC (%)</u>	<u>Control Limits</u>		<u>Qual</u>
1,2-Dichloroethane-d4	116	73-145			1,4-Bromofluorobenzene	98	74-110		
Dibromofluoromethane	111	81-135			Toluene-d8	98	83-119		

Client Sample Number	Lab Sample Number	Date/Time Collected	Matrix	Instrument	Date Prepared	Date/Time Analyzed	QC Batch ID
MW3	09-05-2483-4-A	05/27/09 11:15	Aqueous	GC/MS Q	06/08/09	06/09/09 08:07	090608L02


Parameter	Result	RL	DF	Qual	Parameter	Result	RL	DF	Qual
Methyl-t-Butyl Ether (MTBE)	9.1	2.5	5		Tert-Amyl-Methyl Ether (TAME)	ND	2.5	5	
Tert-Butyl Alcohol (TBA)	220	25	5		Ethanol	ND	250	5	
Diisopropyl Ether (DIPE)	ND	2.5	5		1,2-Dibromoethane	ND	2.5	5	
Ethyl-t-Butyl Ether (ETBE)	ND	2.5	5		1,2-Dichloroethane	ND	2.5	5	
<u>Surrogates:</u>	<u>REC (%)</u>	<u>Control Limits</u>		<u>Qual</u>	<u>Surrogates:</u>	<u>REC (%)</u>	<u>Control Limits</u>		<u>Qual</u>
1,2-Dichloroethane-d4	114	73-145			1,4-Bromofluorobenzene	101	74-110		
Dibromofluoromethane	110	81-135			Toluene-d8	97	83-119		

Client Sample Number	Lab Sample Number	Date/Time Collected	Matrix	Instrument	Date Prepared	Date/Time Analyzed	QC Batch ID
MW4	09-05-2483-5-A	05/27/09 10:15	Aqueous	GC/MS Q	06/08/09	06/09/09 08:38	090608L02

Comment(s): -The reporting limits are elevated due to high levels of non-target compounds.

Parameter	Result	RL	DF	Qual	Parameter	Result	RL	DF	Qual
Methyl-t-Butyl Ether (MTBE)	ND	2.5	5		Tert-Amyl-Methyl Ether (TAME)	ND	2.5	5	
Tert-Butyl Alcohol (TBA)	ND	25	5		Ethanol	ND	250	5	
Diisopropyl Ether (DIPE)	ND	2.5	5		1,2-Dibromoethane	ND	2.5	5	
Ethyl-t-Butyl Ether (ETBE)	ND	2.5	5		1,2-Dichloroethane	ND	2.5	5	
<u>Surrogates:</u>	<u>REC (%)</u>	<u>Control Limits</u>		<u>Qual</u>	<u>Surrogates:</u>	<u>REC (%)</u>	<u>Control Limits</u>		<u>Qual</u>
1,2-Dichloroethane-d4	113	73-145			1,4-Bromofluorobenzene	103	74-110		
Dibromofluoromethane	109	81-135			Toluene-d8	99	83-119		

RL - Reporting Limit , DF - Dilution Factor , Qual - Qualifiers



Analytical Report



Environmental Resolutions, Inc.
601 North McDowell Blvd.
Petaluma, CA 94954-2312

Date Received: 05/29/09
Work Order No: 09-05-2483
Preparation: EPA 5030B
Method: EPA 8260B
Units: ug/L

Project: ExxonMobil 70104

Page 2 of 3

Client Sample Number	Lab Sample Number	Date/Time Collected	Matrix	Instrument	Date Prepared	Date/Time Analyzed	QC Batch ID
MW5	09-05-2483-6-A	05/27/09 11:00	Aqueous	GC/MS Q	06/08/09	06/09/09 09:09	090608L02

Comment(s): -The reporting limits are elevated due to high levels of non-target compounds.

Parameter	Result	RL	DF	Qual	Parameter	Result	RL	DF	Qual
Methyl-t-Butyl Ether (MTBE)	ND	5.0	10		Tert-Amyl-Methyl Ether (TAME)	ND	5.0	10	
Tert-Butyl Alcohol (TBA)	ND	50	10		Ethanol	ND	500	10	
Diisopropyl Ether (DIPE)	ND	5.0	10		1,2-Dibromoethane	ND	5.0	10	
Ethyl-t-Butyl Ether (ETBE)	ND	5.0	10		1,2-Dichloroethane	ND	5.0	10	
Surrogates:	REC (%)	Control Limits		Qual	Surrogates:	REC (%)	Control Limits		Qual
1,2-Dichloroethane-d4	116	73-145			1,4-Bromofluorobenzene	101	74-110		
Dibromofluoromethane	107	81-135			Toluene-d8	101	83-119		


Client Sample Number	Lab Sample Number	Date/Time Collected	Matrix	Instrument	Date Prepared	Date/Time Analyzed	QC Batch ID
MW6	09-05-2483-7-B	05/27/09 12:37	Aqueous	GC/MS Q	06/09/09	06/10/09 10:21	090609L02


Parameter	Result	RL	DF	Qual	Parameter	Result	RL	DF	Qual
Methyl-t-Butyl Ether (MTBE)	ND	10	20		Tert-Amyl-Methyl Ether (TAME)	ND	10	20	
Tert-Butyl Alcohol (TBA)	860	100	20		Ethanol	ND	1000	20	
Diisopropyl Ether (DIPE)	ND	10	20		1,2-Dibromoethane	ND	10	20	
Ethyl-t-Butyl Ether (ETBE)	ND	10	20		1,2-Dichloroethane	ND	10	20	
Surrogates:	REC (%)	Control Limits		Qual	Surrogates:	REC (%)	Control Limits		Qual
1,2-Dichloroethane-d4	108	73-145			1,4-Bromofluorobenzene	97	74-110		
Dibromofluoromethane	96	81-135			Toluene-d8	98	83-119		

Client Sample Number	Lab Sample Number	Date/Time Collected	Matrix	Instrument	Date Prepared	Date/Time Analyzed	QC Batch ID
MW7	09-05-2483-8-A	05/27/09 11:09	Aqueous	GC/MS Q	06/08/09	06/09/09 10:22	090608L02

Parameter	Result	RL	DF	Qual	Parameter	Result	RL	DF	Qual
Methyl-t-Butyl Ether (MTBE)	1.8	0.50	1		Tert-Amyl-Methyl Ether (TAME)	ND	0.50	1	
Tert-Butyl Alcohol (TBA)	ND	5.0	1		Ethanol	ND	50	1	
Diisopropyl Ether (DIPE)	ND	0.50	1		1,2-Dibromoethane	ND	0.50	1	
Ethyl-t-Butyl Ether (ETBE)	ND	0.50	1		1,2-Dichloroethane	ND	0.50	1	
Surrogates:	REC (%)	Control Limits		Qual	Surrogates:	REC (%)	Control Limits		Qual
1,2-Dichloroethane-d4	124	73-145			1,4-Bromofluorobenzene	96	74-110		
Dibromofluoromethane	108	81-135			Toluene-d8	97	83-119		

RL - Reporting Limit , DF - Dilution Factor , Qual - Qualifiers





Analytical Report



Environmental Resolutions, Inc.
601 North McDowell Blvd.
Petaluma, CA 94954-2312

Date Received: 05/29/09
Work Order No: 09-05-2483
Preparation: EPA 5030B
Method: EPA 8260B
Units: ug/L

Project: ExxonMobil 70104

Page 3 of 3

Client Sample Number	Lab Sample Number	Date/Time Collected	Matrix	Instrument	Date Prepared	Date/Time Analyzed	QC Batch ID
Method Blank	099-12-880-132	N/A	Aqueous	GC/MS Q	06/08/09	06/09/09 02:32	090608L02

Parameter	Result	RL	DF	Qual	Parameter	Result	RL	DF	Qual
Methyl-t-Butyl Ether (MTBE)	ND	0.50	1		Tert-Amyl-Methyl Ether (TAME)	ND	0.50	1	
Tert-Butyl Alcohol (TBA)	ND	5.0	1		Ethanol	ND	50	1	
Diisopropyl Ether (DIPE)	ND	0.50	1		1,2-Dibromoethane	ND	0.50	1	
Ethyl-t-Butyl Ether (ETBE)	ND	0.50	1		1,2-Dichloroethane	ND	0.50	1	
Surrogates:	REC (%)	Control Limits		Qual	Surrogates:	REC (%)	Control Limits		Qual
1,2-Dichloroethane-d4	117	73-145			1,4-Bromofluorobenzene	99	74-110		
Dibromofluoromethane	101	81-135			Toluene-d8	98	83-119		

Client Sample Number	Lab Sample Number	Date/Time Collected	Matrix	Instrument	Date Prepared	Date/Time Analyzed	QC Batch ID
Method Blank	099-12-880-135	N/A	Aqueous	GC/MS Q	06/09/09	06/10/09 03:13	090609L02

Parameter	Result	RL	DF	Qual	Parameter	Result	RL	DF	Qual
Methyl-t-Butyl Ether (MTBE)	ND	0.50	1		Tert-Amyl-Methyl Ether (TAME)	ND	0.50	1	
Tert-Butyl Alcohol (TBA)	ND	5.0	1		Ethanol	ND	50	1	
Diisopropyl Ether (DIPE)	ND	0.50	1		1,2-Dibromoethane	ND	0.50	1	
Ethyl-t-Butyl Ether (ETBE)	ND	0.50	1		1,2-Dichloroethane	ND	0.50	1	
Surrogates:	REC (%)	Control Limits		Qual	Surrogates:	REC (%)	Control Limits		Qual
1,2-Dichloroethane-d4	99	73-145			1,4-Bromofluorobenzene	93	74-110		
Dibromofluoromethane	91	81-135			Toluene-d8	96	83-119		

RL - Reporting Limit DF - Dilution Factor Qual - Qualifiers

Analytical Report



Environmental Resolutions, Inc.
601 North McDowell Blvd.
Petaluma, CA 94954-2312

Date Received: 05/29/09
Work Order No: 09-05-2483
Preparation: EPA 5030B
Method: EPA 8260B
Units: ug/L

Project: ExxonMobil 70104

Page 1 of 3

Client Sample Number	Lab Sample Number	Date/Time Collected	Matrix	Instrument	Date Prepared	Date/Time Analyzed	QC Batch ID
MW1	09-05-2483-2-A	05/27/09 10:56	Aqueous	GC/MS Q	06/08/09	06/09/09 07:06	090608L02

Parameter	Result	RL	DF	Qual	Parameter	Result	RL	DF	Qual
Methyl-t-Butyl Ether (MTBE)	3600	50	100		Tert-Amyl-Methyl Ether (TAME)	ND	25	50	
Tert-Butyl Alcohol (TBA)	9100	250	50		1,2-Dibromoethane	ND	25	50	
Diisopropyl Ether (DIPE)	ND	25	50		1,2-Dichloroethane	ND	25	50	
Ethyl-t-Butyl Ether (ETBE)	ND	25	50						
Surrogates:	REC (%)	Control Limits		Qual	Surrogates:	REC (%)	Control Limits		Qual
1,2-Dichloroethane-d4	114	73-145			1,4-Bromofluorobenzene	97	74-110		
Dibromofluoromethane	107	81-135			Toluene-d8	100	83-119		

Client Sample Number	Lab Sample Number	Date/Time Collected	Matrix	Instrument	Date Prepared	Date/Time Analyzed	QC Batch ID
MW8	09-05-2483-9-A	05/27/09 09:05	Aqueous	GC/MS Q	06/08/09	06/09/09 10:53	090608L02

Parameter	Result	RL	DF	Qual	Parameter	Result	RL	DF	Qual
Methyl-t-Butyl Ether (MTBE)	ND	0.50	1		Tert-Amyl-Methyl Ether (TAME)	ND	0.50	1	
Tert-Butyl Alcohol (TBA)	ND	5.0	1		1,2-Dibromoethane	ND	0.50	1	
Diisopropyl Ether (DIPE)	ND	0.50	1		1,2-Dichloroethane	ND	0.50	1	
Ethyl-t-Butyl Ether (ETBE)	ND	0.50	1						
Surrogates:	REC (%)	Control Limits		Qual	Surrogates:	REC (%)	Control Limits		Qual
1,2-Dichloroethane-d4	114	73-145			1,4-Bromofluorobenzene	95	74-110		
Dibromofluoromethane	107	81-135			Toluene-d8	100	83-119		

Client Sample Number	Lab Sample Number	Date/Time Collected	Matrix	Instrument	Date Prepared	Date/Time Analyzed	QC Batch ID
MW9	09-05-2483-10-A	05/27/09 09:42	Aqueous	GC/MS Q	06/09/09	06/10/09 10:51	090609L02

Parameter	Result	RL	DF	Qual	Parameter	Result	RL	DF	Qual
Methyl-t-Butyl Ether (MTBE)	0.67	0.50	1		Tert-Amyl-Methyl Ether (TAME)	ND	0.50	1	
Tert-Butyl Alcohol (TBA)	ND	5.0	1		1,2-Dibromoethane	ND	0.50	1	
Diisopropyl Ether (DIPE)	ND	0.50	1		1,2-Dichloroethane	ND	0.50	1	
Ethyl-t-Butyl Ether (ETBE)	ND	0.50	1						
Surrogates:	REC (%)	Control Limits		Qual	Surrogates:	REC (%)	Control Limits		Qual
1,2-Dichloroethane-d4	107	73-145			1,4-Bromofluorobenzene	88	74-110		
Dibromofluoromethane	98	81-135			Toluene-d8	95	83-119		

RL - Reporting Limit , DF - Dilution Factor , Qual - Qualifiers



Analytical Report



Environmental Resolutions, Inc.
 601 North McDowell Blvd.
 Petaluma, CA 94954-2312

Date Received: 05/29/09
 Work Order No: 09-05-2483
 Preparation: EPA 5030B
 Method: EPA 8260B
 Units: ug/L

Project: ExxonMobil 70104

Page 2 of 3

Client Sample Number	Lab Sample Number	Date/Time Collected	Matrix	Instrument	Date Prepared	Date/Time Analyzed	QC Batch ID
MW11	09-05-2483-11-B	05/27/09 10:18	Aqueous	GC/MS Q	06/10/09	06/10/09 17:13	090610L01

Parameter	Result	RL	DF	Qual	Parameter	Result	RL	DF	Qual
Methyl-t-Butyl Ether (MTBE)	ND	10	20		Tert-Amyl-Methyl Ether (TAME)	ND	10	20	
Tert-Butyl Alcohol (TBA)	120	100	20		1,2-Dibromoethane	ND	10	20	
Diisopropyl Ether (DIPE)	ND	10	20		1,2-Dichloroethane	18	10	20	
Ethyl-t-Butyl Ether (ETBE)	ND	10	20						
<u>Surrogates:</u>	<u>REC (%)</u>	<u>Control Limits</u>		<u>Qual</u>	<u>Surrogates:</u>	<u>REC (%)</u>	<u>Control Limits</u>		<u>Qual</u>
1,2-Dichloroethane-d4	95	73-145			1,4-Bromofluorobenzene	98	74-110		
Dibromofluoromethane	96	81-135			Toluene-d8	98	83-119		


Method Blank	099-12-884-149	N/A	Aqueous	GC/MS Q	06/08/09	06/09/09 02:32	090608L02
--------------	----------------	-----	---------	---------	----------	-------------------	-----------

Parameter	Result	RL	DF	Qual	Parameter	Result	RL	DF	Qual
Methyl-t-Butyl Ether (MTBE)	ND	0.50	1		Tert-Amyl-Methyl Ether (TAME)	ND	0.50	1	
Tert-Butyl Alcohol (TBA)	ND	5.0	1		1,2-Dibromoethane	ND	0.50	1	
Diisopropyl Ether (DIPE)	ND	0.50	1		1,2-Dichloroethane	ND	0.50	1	
Ethyl-t-Butyl Ether (ETBE)	ND	0.50	1						
<u>Surrogates:</u>	<u>REC (%)</u>	<u>Control Limits</u>		<u>Qual</u>	<u>Surrogates:</u>	<u>REC (%)</u>	<u>Control Limits</u>		<u>Qual</u>
1,2-Dichloroethane-d4	117	73-145			1,4-Bromofluorobenzene	99	74-110		
Dibromofluoromethane	101	81-135			Toluene-d8	98	83-119		

Method Blank	099-12-884-150	N/A	Aqueous	GC/MS Q	06/09/09	06/10/09 03:13	090609L02
--------------	----------------	-----	---------	---------	----------	-------------------	-----------

Parameter	Result	RL	DF	Qual	Parameter	Result	RL	DF	Qual
Methyl-t-Butyl Ether (MTBE)	ND	0.50	1		Tert-Amyl-Methyl Ether (TAME)	ND	0.50	1	
Tert-Butyl Alcohol (TBA)	ND	5.0	1		1,2-Dibromoethane	ND	0.50	1	
Diisopropyl Ether (DIPE)	ND	0.50	1		1,2-Dichloroethane	ND	0.50	1	
Ethyl-t-Butyl Ether (ETBE)	ND	0.50	1						
<u>Surrogates:</u>	<u>REC (%)</u>	<u>Control Limits</u>		<u>Qual</u>	<u>Surrogates:</u>	<u>REC (%)</u>	<u>Control Limits</u>		<u>Qual</u>
1,2-Dichloroethane-d4	99	73-145			1,4-Bromofluorobenzene	93	74-110		
Dibromofluoromethane	91	81-135			Toluene-d8	96	83-119		

RL - Reporting Limit , DF - Dilution Factor , Qual - Qualifiers



Analytical Report



Environmental Resolutions, Inc.	Date Received:	05/29/09
601 North McDowell Blvd.	Work Order No:	09-05-2483
Petaluma, CA 94954-2312	Preparation:	EPA 5030B
	Method:	EPA 8260B
	Units:	ug/L


Project: ExxonMobil 70104

Page 3 of 3

Client Sample Number	Lab Sample Number	Date/Time Collected	Matrix	Instrument	Date Prepared	Date/Time Analyzed	QC Batch ID
Method Blank	099-12-884-153	N/A	Aqueous	GC/MS Q	06/10/09	06/10/09 14:41	090610L01

Parameter	Result	RL	DF	Qual	Parameter	Result	RL	DF	Qual
Methyl-t-Butyl Ether (MTBE)	ND	0.50	1		Tert-Amyl-Methyl Ether (TAME)	ND	0.50	1	
Tert-Butyl Alcohol (TBA)	ND	5.0	1		1,2-Dibromoethane	ND	0.50	1	
Diisopropyl Ether (DIPE)	ND	0.50	1		1,2-Dichloroethane	ND	0.50	1	
Ethyl-t-Butyl Ether (ETBE)	ND	0.50	1						
<u>Surrogates:</u>	<u>REC (%)</u>	<u>Control Limits</u>		<u>Qual</u>	<u>Surrogates:</u>	<u>REC (%)</u>	<u>Control Limits</u>		<u>Qual</u>
1,2-Dichloroethane-d4	105	73-145			1,4-Bromofluorobenzene	89	74-110		
Dibromofluoromethane	98	81-135			Toluene-d8	96	83-119		

RL - Reporting Limit DF - Dilution Factor Qual - Qualifiers



Quality Control - Spike/Spike Duplicate



Environmental Resolutions, Inc.
601 North McDowell Blvd.
Petaluma, CA 94954-2312


Date Received: 05/29/09
Work Order No: 09-05-2483
Preparation: EPA 5030B
Method: EPA 8015B (M)

Project ExxonMobil 70104

Quality Control Sample ID	Matrix	Instrument	Date Prepared	Date Analyzed	MS/MSD Batch Number
MW1	Aqueous	GC 29	06/05/09	06/06/09	090605S01

Parameter	MS %REC	MSD %REC	%REC CL	RPD	RPD CL	Qualifiers
TPH as Gasoline	179	176	68-122	1	0-18	3

RPD - Relative Percent Difference , CL - Control Limit



Quality Control - Spike/Spike Duplicate



Environmental Resolutions, Inc.
601 North McDowell Blvd.
Petaluma, CA 94954-2312


Date Received: 05/29/09
Work Order No: 09-05-2483
Preparation: EPA 5030B
Method: EPA 8015B (M)

Project ExxonMobil 70104

Quality Control Sample ID	Matrix	Instrument	Date Prepared	Date Analyzed	MS/MSD Batch Number
09-05-2617-3	Aqueous	GC 29	06/08/09	06/08/09	090608S01

<u>Parameter</u>	<u>MS %REC</u>	<u>MSD %REC</u>	<u>%REC CL</u>	<u>RPD</u>	<u>RPD CL</u>	<u>Qualifiers</u>
TPH as Gasoline	92	83	68-122	10	0-18	

RPD - Relative Percent Difference, CL - Control Limit



Quality Control - Spike/Spike Duplicate



Environmental Resolutions, Inc.
601 North McDowell Blvd.
Petaluma, CA 94954-2312


Date Received: 05/29/09
Work Order No: 09-05-2483
Preparation: EPA 5030B
Method: EPA 8021B

Project ExxonMobil 70104

Quality Control Sample ID	Matrix	Instrument	Date Prepared	Date Analyzed	MS/MSD Batch Number
MW1	Aqueous	GC 8	06/01/09	06/01/09	090601S02

<u>Parameter</u>	<u>MS %REC</u>	<u>MSD %REC</u>	<u>%REC CL</u>	<u>RPD</u>	<u>RPD CL</u>	<u>Qualifiers</u>
Benzene	106	103	57-129	3	0-23	
Toluene	94	94	50-134	0	0-26	
Ethylbenzene	95	93	58-130	2	0-26	
p/m-Xylene	98	96	58-130	2	0-28	
o-Xylene	92	90	57-123	3	0-26	
Methyl-t-Butyl Ether (MTBE)	64	56	44-134	0	0-27	

RPD - Relative Percent Difference , CL - Control Limit



Quality Control - Spike/Spike Duplicate



Environmental Resolutions, Inc.
601 North McDowell Blvd.
Petaluma, CA 94954-2312


Date Received: 05/29/09
Work Order No: 09-05-2483
Preparation: EPA 5030B
Method: EPA 8260B


Project ExxonMobil 70104

Quality Control Sample ID	Matrix	Instrument	Date Prepared	Date Analyzed	MS/MSD Batch Number
09-05-2338-2	Aqueous	GC/MS Q	06/08/09	06/09/09	090608S02

Parameter	MS %REC	MSD %REC	%REC CL	RPD	RPD CL	Qualifiers
Benzene	108	108	86-122	1	0-8	
Toluene	107	109	85-127	1	0-12	
Ethylbenzene	107	109	70-130	1	0-30	
Methyl-t-Butyl Ether (MTBE)	302	341	64-136	1	0-28	3
Tert-Butyl Alcohol (TBA)	88	83	27-183	5	0-60	
Diisopropyl Ether (DIPE)	92	94	78-126	3	0-16	
Ethyl-t-Butyl Ether (ETBE)	94	92	67-133	2	0-21	
Tert-Amyl-Methyl Ether (TAME)	96	98	63-141	2	0-21	
Ethanol	113	108	11-167	5	0-64	
1,1-Dichloroethene	107	111	52-142	4	0-23	
1,2-Dibromoethane	99	98	70-130	1	0-30	
1,2-Dichlorobenzene	102	105	89-119	3	0-10	
Carbon Tetrachloride	97	103	78-138	6	0-9	
Chlorobenzene	104	105	90-120	1	0-9	
Trichloroethene	92	94	78-126	2	0-10	
Vinyl Chloride	108	114	56-140	5	0-21	

RPD - Relative Percent Difference , CL - Control Limit





Quality Control - Spike/Spike Duplicate



Environmental Resolutions, Inc.
601 North McDowell Blvd.
Petaluma, CA 94954-2312


Date Received: 05/29/09
Work Order No: 09-05-2483
Preparation: EPA 5030B
Method: EPA 8260B

Project ExxonMobil 70104

Quality Control Sample ID	Matrix	Instrument	Date Prepared	Date Analyzed	MS/MSD Batch Number
09-05-2475-2	Aqueous	GC/MS Q	06/09/09	06/10/09	090609S02

Parameter	MS %REC	MSD %REC	%REC CL	RPD	RPD CL	Qualifiers
Benzene	117	116	86-122	1	0-8	
Toluene	112	110	85-127	2	0-12	
Ethylbenzene	107	105	70-130	2	0-30	
Methyl-t-Butyl Ether (MTBE)	103	100	64-136	3	0-28	
Tert-Butyl Alcohol (TBA)	101	90	27-183	12	0-60	
Diisopropyl Ether (DIPE)	95	95	78-126	0	0-16	
Ethyl-t-Butyl Ether (ETBE)	88	90	67-133	2	0-21	
Tert-Amyl-Methyl Ether (TAME)	89	91	63-141	2	0-21	
Ethanol	91	91	11-167	0	0-64	
1,1-Dichloroethene	110	110	52-142	1	0-23	
1,2-Dibromoethane	105	108	70-130	3	0-30	
1,2-Dichlorobenzene	106	104	89-119	2	0-10	
Carbon Tetrachloride	95	94	78-138	1	0-9	
Chlorobenzene	107	106	90-120	0	0-9	
Trichloroethene	95	93	78-126	2	0-10	
Vinyl Chloride	109	114	56-140	5	0-21	

RPD - Relative Percent Difference , CL - Control Limit



Quality Control - Spike/Spike Duplicate



Environmental Resolutions, Inc.
601 North McDowell Blvd.
Petaluma, CA 94954-2312


Date Received: 05/29/09
Work Order No: 09-05-2483
Preparation: EPA 5030B
Method: EPA 8260B

Project ExxonMobil 70104

Quality Control Sample ID	Matrix	Instrument	Date Prepared	Date Analyzed	MS/MSD Batch Number
09-05-2338-2	Aqueous	GC/MS Q	06/08/09	06/09/09	090608S02

Parameter	MS %REC	MSD %REC	%REC CL	RPD	RPD CL	Qualifiers
Benzene	108	108	86-122	1	0-8	
Toluene	107	109	85-127	1	0-12	
Ethylbenzene	107	109	70-130	1	0-30	
Methyl-t-Butyl Ether (MTBE)	302	341	64-136	1	0-28	3
Tert-Butyl Alcohol (TBA)	88	83	27-183	5	0-60	
Diisopropyl Ether (DIPE)	92	94	78-126	3	0-16	
Ethyl-t-Butyl Ether (ETBE)	94	92	67-133	2	0-21	
Tert-Amyl-Methyl Ether (TAME)	96	98	63-141	2	0-21	
Ethanol	113	108	11-167	5	0-64	
1,1-Dichloroethene	107	111	52-142	4	0-23	
1,2-Dibromoethane	99	98	70-130	1	0-30	
1,2-Dichlorobenzene	102	105	89-119	3	0-10	
Carbon Tetrachloride	97	103	78-138	6	0-9	
Chlorobenzene	104	105	90-120	1	0-9	
Trichloroethene	92	94	78-126	2	0-10	
Vinyl Chloride	108	114	56-140	5	0-21	

RPD - Relative Percent Difference , CL - Control Limit



Quality Control - Spike/Spike Duplicate



Environmental Resolutions, Inc.
601 North McDowell Blvd.
Petaluma, CA 94954-2312


Date Received: 05/29/09
Work Order No: 09-05-2483
Preparation: EPA 5030B
Method: EPA 8260B


Project ExxonMobil 70104

Quality Control Sample ID	Matrix	Instrument	Date Prepared	Date Analyzed	MS/MSD Batch Number
09-06-0669-5	Aqueous	GC/MS Q	06/10/09	06/10/09	090610S01

<u>Parameter</u>	<u>MS %REC</u>	<u>MSD %REC</u>	<u>%REC CL</u>	<u>RPD</u>	<u>RPD CL</u>	<u>Qualifiers</u>
Benzene	118	114	86-122	4	0-8	
Toluene	113	109	85-127	4	0-12	
Ethylbenzene	109	106	70-130	3	0-30	
Methyl-t-Butyl Ether (MTBE)	103	97	64-136	6	0-28	
Tert-Butyl Alcohol (TBA)	93	92	27-183	2	0-60	
Diisopropyl Ether (DIPE)	102	102	78-126	1	0-16	
Ethyl-t-Butyl Ether (ETBE)	94	90	67-133	5	0-21	
Tert-Amyl-Methyl Ether (TAME)	96	90	63-141	7	0-21	
Ethanol	110	103	11-167	7	0-64	
1,1-Dichloroethene	113	110	52-142	3	0-23	
1,2-Dibromoethane	108	104	70-130	4	0-30	
1,2-Dichlorobenzene	107	105	89-119	1	0-10	
Carbon Tetrachloride	101	98	78-138	3	0-9	
Chlorobenzene	111	109	90-120	2	0-9	
Trichloroethene	98	95	78-126	4	0-10	
Vinyl Chloride	114	107	56-140	7	0-21	

RPD - Relative Percent Difference , CL - Control Limit





Quality Control - LCS/LCS Duplicate



Environmental Resolutions, Inc.
601 North McDowell Blvd.
Petaluma, CA 94954-2312


Date Received: N/A
Work Order No: 09-05-2483
Preparation: EPA 3510C
Method: EPA 8015B (M)

Project: ExxonMobil 70104

Quality Control Sample ID	Matrix	Instrument	Date Prepared	Date Analyzed	LCS/LCSD Batch Number
099-12-330-1,113	Aqueous	GC 46	05/29/09	06/02/09	090529B22

<u>Parameter</u>	<u>LCS %REC</u>	<u>LCSD %REC</u>	<u>%REC CL</u>	<u>RPD</u>	<u>RPD CL</u>	<u>Qualifiers</u>
TPH as Diesel	101	102	75-117	0	0-13	

RPD - Relative Percent Difference , CL - Control Limit



Quality Control - LCS/LCS Duplicate



Environmental Resolutions, Inc.
601 North McDowell Blvd.
Petaluma, CA 94954-2312


Date Received: N/A
Work Order No: 09-05-2483
Preparation: EPA 5030B
Method: EPA 8015B (M)

Project: ExxonMobil 70104

Quality Control Sample ID	Matrix	Instrument	Date Prepared	Date Analyzed	LCS/LCSD Batch Number
099-12-436-3,357	Aqueous	GC 29	06/05/09	06/05/09	090605B01

Parameter	LCS %REC	LCSD %REC	%REC CL	RPD	RPD CL	Qualifiers
TPH as Gasoline	82	82	78-120	1	0-10	

RPD - Relative Percent Difference, CL - Control Limit



Quality Control - LCS/LCS Duplicate



Environmental Resolutions, Inc.
601 North McDowell Blvd.
Petaluma, CA 94954-2312

Date Received: N/A
Work Order No: 09-05-2483
Preparation: EPA 5030B
Method: EPA 8015B (M)

Project: ExxonMobil 70104

Quality Control Sample ID	Matrix	Instrument	Date Prepared	Date Analyzed	LCS/LCSD Batch Number
099-12-436-3,363	Aqueous	GC 29	06/08/09	06/08/09	090608B01

Parameter	<u>LCS %REC</u>	<u>LCSD %REC</u>	<u>%REC CL</u>	<u>RPD</u>	<u>RPD CL</u>	<u>Qualifiers</u>
TPH as Gasoline	96	98	78-120	2	0-10	

RPD - Relative Percent Difference , CL - Control Limit



Environmental Resolutions, Inc.
 601 North McDowell Blvd.
 Petaluma, CA 94954-2312


Date Received: N/A
 Work Order No: 09-05-2483
 Preparation: EPA 5030B
 Method: EPA 8021B

Project: ExxonMobil 70104

Quality Control Sample ID	Matrix	Instrument	Date Analyzed	Lab File ID	LCS Batch Number
099-12-667-457	Aqueous	GC 8	06/01/09	016F1601	090601B02

Parameter	Conc Added	Conc Recovered	LCS %Rec	%Rec CL	Qualifiers
Benzene	100	95.7	96	70-118	
Toluene	100	90.7	91	66-114	
Ethylbenzene	100	94.4	94	72-114	
p/m-Xylene	200	195	98	74-116	
o-Xylene	100	94.3	94	72-114	
Methyl-t-Butyl Ether (MTBE)	100	97.5	97	41-137	

RPD - Relative Percent Difference, CL - Control Limit



Quality Control - LCS/LCS Duplicate



Environmental Resolutions, Inc.
601 North McDowell Blvd.
Petaluma, CA 94954-2312


Date Received: N/A
Work Order No: 09-05-2483
Preparation: EPA 5030B
Method: EPA 8260B


Project: ExxonMobil 70104

Quality Control Sample ID	Matrix	Instrument	Date Prepared	Date Analyzed	LCS/LCSD Batch Number		
099-12-880-132	Aqueous	GC/MS Q	06/08/09	06/09/09	090608L02		
Parameter	LCS %REC	LCSD %REC	%REC CL	ME CL	RPD	RPD CL	Qualifiers
Benzene	106	104	87-117	82-122	1	0-7	
Toluene	105	102	85-127	78-134	3	0-7	
Ethylbenzene	103	102	80-120	73-127	1	0-20	
Methyl-t-Butyl Ether (MTBE)	91	88	67-133	56-144	2	0-16	
Tert-Butyl Alcohol (TBA)	84	81	34-154	14-174	3	0-19	
Diisopropyl Ether (DIPE)	105	104	80-122	73-129	0	0-8	
Ethyl-t-Butyl Ether (ETBE)	97	94	73-127	64-136	3	0-11	
Tert-Amyl-Methyl Ether (TAME)	93	91	69-135	58-146	2	0-12	
Ethanol	95	96	34-124	19-139	1	0-44	
1,1-Dichloroethene	108	105	71-131	61-141	2	0-14	
1,2-Dibromoethane	100	98	80-120	73-127	2	0-20	
1,2-Dichlorobenzene	102	102	88-118	83-123	0	0-8	
Carbon Tetrachloride	98	97	78-132	69-141	1	0-8	
Chlorobenzene	102	101	88-118	83-123	1	0-8	
Trichloroethene	99	95	85-121	79-127	5	0-11	
Vinyl Chloride	110	112	64-136	52-148	1	0-10	

Total number of LCS compounds : 16
Total number of ME compounds : 0
Total number of ME compounds allowed : 1
LCS ME CL validation result : Pass

RPD - Relative Percent Difference , CL - Control Limit





Quality Control - LCS/LCS Duplicate



Environmental Resolutions, Inc.
601 North McDowell Blvd.
Petaluma, CA 94954-2312

Date Received: N/A
Work Order No: 09-05-2483
Preparation: EPA 5030B
Method: EPA 8260B

Project: ExxonMobil 70104

Quality Control Sample ID	Matrix	Instrument	Date Prepared	Date Analyzed	LCS/LCSD Batch Number		
099-12-880-135	Aqueous	GC/MS Q	06/09/09	06/10/09	090609L02		
Parameter	LCS %REC	LCSD %REC	%REC CL	ME_CL	RPD	RPD CL	Qualifiers
Benzene	112	112	87-117	82-122	0	0-7	
Toluene	107	108	85-127	78-134	1	0-7	
Ethylbenzene	105	105	80-120	73-127	1	0-20	
Methyl-t-Butyl Ether (MTBE)	94	99	67-133	56-144	5	0-16	
Tert-Butyl Alcohol (TBA)	88	93	34-154	14-174	6	0-19	
Diisopropyl Ether (DIPE)	98	92	80-122	73-129	6	0-8	
Ethyl-t-Butyl Ether (ETBE)	88	86	73-127	64-136	1	0-11	
Tert-Amyl-Methyl Ether (TAME)	91	91	69-135	58-146	0	0-12	
Ethanol	97	104	34-124	19-139	7	0-44	
1,1-Dichloroethene	107	110	71-131	61-141	2	0-14	
1,2-Dibromoethane	104	108	80-120	73-127	4	0-20	
1,2-Dichlorobenzene	104	107	88-118	83-123	3	0-8	
Carbon Tetrachloride	93	93	78-132	69-141	1	0-8	
Chlorobenzene	106	107	88-118	83-123	1	0-8	
Trichloroethene	106	103	85-121	79-127	4	0-11	
Vinyl Chloride	116	114	64-136	52-148	2	0-10	

Total number of LCS compounds : 16


Total number of ME compounds : 0

Total number of ME compounds allowed : 1

LCS ME CL validation result : Pass

RPD - Relative Percent Difference , CL - Control Limit





Quality Control - LCS/LCS Duplicate



Environmental Resolutions, Inc.
601 North McDowell Blvd.
Petaluma, CA 94954-2312

Date Received: N/A
Work Order No: 09-05-2483
Preparation: EPA 5030B
Method: EPA 8260B

Project: ExxonMobil 70104

Quality Control Sample ID	Matrix	Instrument	Date Prepared	Date Analyzed	LCS/LCSD Batch Number		
099-12-884-149	Aqueous	GC/MS Q	06/08/09	06/09/09	090608L02		
Parameter	LCS %REC	LCSD %REC	%REC CL	ME CL	RPD	RPD CL	Qualifiers
Benzene	106	104	87-117	82-122	1	0-7	
Toluene	105	102	85-127	78-134	3	0-7	
Ethylbenzene	103	102	80-120	73-127	1	0-20	
Methyl-t-Butyl Ether (MTBE)	91	88	67-133	56-144	2	0-16	
Tert-Butyl Alcohol (TBA)	84	81	34-154	14-174	3	0-19	
Diisopropyl Ether (DIPE)	105	104	80-122	73-129	0	0-8	
Ethyl-t-Butyl Ether (ETBE)	97	94	73-127	64-136	3	0-11	
Tert-Amyl-Methyl Ether (TAME)	93	91	69-135	58-146	2	0-12	
Ethanol	95	96	34-124	19-139	1	0-44	
1,1-Dichloroethene	108	105	71-131	61-141	2	0-14	
1,2-Dibromoethane	100	98	80-120	73-127	2	0-20	
1,2-Dichlorobenzene	102	102	88-118	83-123	0	0-8	
Carbon Tetrachloride	98	97	78-132	69-141	1	0-8	
Chlorobenzene	102	101	88-118	83-123	1	0-8	
Trichloroethene	99	95	85-121	79-127	5	0-11	
Vinyl Chloride	110	112	64-136	52-148	1	0-10	


Total number of LCS compounds : 16

Total number of ME compounds : 0

Total number of ME compounds allowed : 1

LCS ME CL validation result : Pass

RPD - Relative Percent Difference , CL - Control Limit



Quality Control - LCS/LCS Duplicate



Environmental Resolutions, Inc.
601 North McDowell Blvd.
Petaluma, CA 94954-2312

Date Received: N/A
Work Order No: 09-05-2483
Preparation: EPA 5030B
Method: EPA 8260B

Project: ExxonMobil 70104

Quality Control Sample ID	Matrix	Instrument	Date Prepared	Date Analyzed	LCS/LCSD Batch Number		
099-12-884-153	Aqueous	GC/MS Q	06/10/09	06/10/09	090610L01		
Parameter	LCS %REC	LCSD %REC	%REC CL	ME CL	RPD	RPD CL	Qualifiers
Benzene	112	114	87-117	82-122	1	0-7	
Toluene	108	109	85-127	78-134	2	0-7	
Ethylbenzene	105	106	80-120	73-127	1	0-20	
Methyl-t-Butyl Ether (MTBE)	97	95	67-133	56-144	2	0-16	
Tert-Butyl Alcohol (TBA)	87	91	34-154	14-174	3	0-19	
Diisopropyl Ether (DIPE)	100	93	80-122	73-129	7	0-8	
Ethyl-t-Butyl Ether (ETBE)	90	88	73-127	64-136	2	0-11	
Tert-Amyl-Methyl Ether (TAME)	92	92	69-135	58-146	1	0-12	
Ethanol	103	102	34-124	19-139	1	0-44	
1,1-Dichloroethene	111	108	71-131	61-141	2	0-14	
1,2-Dibromoethane	108	109	80-120	73-127	0	0-20	
1,2-Dichlorobenzene	107	107	88-118	83-123	1	0-8	
Carbon Tetrachloride	97	96	78-132	69-141	0	0-8	
Chlorobenzene	107	109	88-118	83-123	2	0-8	
Trichloroethene	97	99	85-121	79-127	2	0-11	
Vinyl Chloride	115	113	64-136	52-148	1	0-10	

Total number of LCS compounds : 16

Total number of ME compounds : 0


Total number of ME compounds allowed : 1

LCS ME CL validation result : Pass

RPD - Relative Percent Difference , CL - Control Limit


Work Order Number: 09-05-2483

<u>Qualifier</u>	<u>Definition</u>
*	See applicable analysis comment.
1	Surrogate compound recovery was out of control due to a required sample dilution, therefore, the sample data was reported without further clarification.
2	Surrogate compound recovery was out of control due to matrix interference. The associated method blank surrogate spike compound was in control and, therefore, the sample data was reported without further clarification.
3	Recovery of the Matrix Spike (MS) or Matrix Spike Duplicate (MSD) compound was out of control due to matrix interference. The associated LCS and/or LCSD was in control and, therefore, the sample data was reported without further clarification.
4	The MS/MSD RPD was out of control due to matrix interference. The LCS/LCSD RPD was in control and, therefore, the sample data was reported without further clarification.
5	The PDS/PDSD associated with this batch of samples was out of control due to a matrix interference effect. The associated batch LCS/LCSD was in control and, hence, the associated sample data was reported with no further corrective action required.
A	Result is the average of all dilutions, as defined by the method.
B	Analyte was present in the associated method blank.
C	Analyte presence was not confirmed on primary column.
E	Concentration exceeds the calibration range.
I	Compound did not meet method-described identification guidelines. Identification was based on additional GC/MS characteristics.
J	Analyte was detected at a concentration below the reporting limit and above the laboratory method detection limit. Reported value is estimated.
ND	Parameter not detected at the indicated reporting limit.
Q	Spike recovery and RPD control limits do not apply resulting from the parameter concentration in the sample exceeding the spike concentration by a factor of four or greater.
X	% Recovery and/or RPD out-of-range.
Z	Analyte presence was not confirmed by second column or GC/MS analysis. Solid - Unless otherwise indicated, solid sample data is reported on a wet weight basis, not corrected for % moisture.



CHAIN OF CUSTODY RECORD

2483



7440 Lincoln Way
Garden Grove, CA 92841
TEL: (714) 895-5494

FAX: (714) 894-7501



Shipping Method: Lab Courier Hand Deliver Commercial Express Other:

Consultant Name: Environmental Resolutions, Inc.

Address: 601 N McDowell Blvd

City/State/Zip: Petaluma, California 94954

Project Manager Paula Sime

Telephone Number: (707) 766-2000

ERI Job Number: 250613X

Sampler Name: (Print) SAAR/NURAM

Sampler Signature: [Signature]

ExxonMobil Engineer Jennifer Sedlachek

Telephone Number (510) 547-8196

Account #:

PO #: 4510812579

Facility ID # 70104

Global ID# T0600100555

Site Address 1725 Park Street

City, State Zip Alameda, California

TAT
 24 hour 72 hour
 48 hour 96 hour
 8 day

PROVIDE:
EDF Report

Special Instructions:
Use silica gel clean up for all TPHd analysis.
Oxygenates = MTBE, ETBE, TBA, TAME, DIPE, 1,2-DCA, EDB
Set TBA reporting limit at or below 12 ug/L.

Sample ID / Description	DATE	TIME	COMP	GRAB	PRESERV (VOA/LITER)	NUMBER (VOA/LITER)	Matrix			Analyze For:									
							Water	Soil	Vapor	TPHd 8015B	TPHg 8015B	BTEX 8021B	Oxygenates 8260B	Ethanol 8260B					
1 QCBB	5/27/09	940			HCL	2	X			H	O	L	D						
2 MW1		1056			HCL/none	6/2	X			X	X	X	X						
3 MW2		1045			HCL/none	6/2	X			X	X	X	X	X					
4 MW3		1115			HCL/none	6/2	X			X	X	X	X	X					
5 MW4		1015			HCL/none	6/2	X			X	X	X	X	X					
6 MW5		1100			HCL/none	6/2	X			X	X	X	X	X					
7 MW6		1237			HCL/none	6/2	X			X	X	X	X	X					
8 MW7		1109			HCL/none	6/2	X			X	X	X	X	X					
9 MW8		905			HCL/none	6/2	X			X	X	X	X						
10 MW9		942			HCL/none	6/2	X			X	X	X	X						
11 MW11		1018			HCL/none	6/2	X			X	X	X	X						

Relinquished by: SAAR/NURAM Date 5/27/09 Time 1356

Received by: Ta Conalley Date 5/28/09 Time 1600

Laboratory Comments:
Temperature Upon Receipt:
Sample Containers Intact?
VOAs Free of Headspace?

Relinquished by: [Signature] Date 5-28-09 Time 1800

Received by: [Signature] Date 05/29/09 Time 1030

GSO AB# 511952669

SAMPLE RECEIPT FORM

Cooler 1 of 1

CLIENT: ERT

DATE: 05/29/09

TEMPERATURE: (Criteria: 0.0 °C – 6.0 °C, not frozen)

Temperature 2.0 °C - 0.2 °C (CF) = 1.8 °C Blank Sample

Sample(s) outside temperature criteria (PM/APM contacted by: _____).

Sample(s) outside temperature criteria but received on ice/chilled on same day of sampling.

Received at ambient temperature, placed on ice for transport by Courier.

Ambient Temperature: Air Filter Metals Only PCBs Only Initial: NC

CUSTODY SEALS INTACT:

Cooler _____ No (Not Intact) Not Present N/A Initial: NC

Sample _____ No (Not Intact) Not Present Initial: TW

SAMPLE CONDITION:	Yes	No	N/A
Chain-Of-Custody (COC) document(s) received with samples.....	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
COC document(s) received complete.....	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
<input type="checkbox"/> Collection date/time, matrix, and/or # of containers logged in based on sample labels.			
<input type="checkbox"/> COC not relinquished. <input type="checkbox"/> No date relinquished. <input type="checkbox"/> No time relinquished.			
Sampler's name indicated on COC.....	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Sample container label(s) consistent with COC.....	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Sample container(s) intact and good condition.....	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Correct containers and volume for analyses requested.....	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Analyses received within holding time.....	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Proper preservation noted on COC or sample container.....	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
<input type="checkbox"/> Unpreserved vials received for Volatiles analysis			
Volatile analysis container(s) free of headspace.....	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Tedlar bag(s) free of condensation.....	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>

CONTAINER TYPE:

Solid: 4ozCGJ 8ozCGJ 16ozCGJ Sleeve EnCores® TerraCores® _____

Water: VOA VOA^h VOA_{na2} 125AGB 125AGB^h 125AGB^p 1AGB 1AGB_{na2} 1AGB^s

500AGB 500AGJ 500AGJ^s 250AGB 250CGB 250CGB^s 1PB 500PB 500PB^{na}


250PB 250PBⁿ 125PB 125PB^z 100PB 100PB^{na2} _____ _____ _____

Air: Tedlar® Summa® _____ Other: _____

Container: C: Clear A: Amber P: Plastic G: Glass J: Jar (Wide-mouth) B: Bottle (Narrow-mouth) **Checked/Labeled by:** TW

Preservative: h: HCL n: HNO3 na₂: Na₂S₂O₃ Na: NaOH p: H₃PO₄ s: H₂SO₄ z_{na}: ZnAc₂+NaOH f: Field-filtered **Reviewed by:** WWS

Scanned by: WWS



April 13, 2009

Paula Sime
Environmental Resolutions, Inc.
601 North McDowell Blvd.
Petaluma, CA 94954-2312

RECEIVED
APR 17 2009

BY:.....

Subject: **Calscience Work Order No.: 09-04-0757**
Client Reference: ExxonMobil 70104

Dear Client:

Enclosed is an analytical report for the above-referenced project. The samples included in this report were received 4/9/2009 and analyzed in accordance with the attached chain-of-custody.


Unless otherwise noted, all analytical testing was accomplished in accordance with the guidelines established in our Quality Systems Manual, applicable standard operating procedures, and other related documentation. The original report of subcontracted analysis, if any, is provided herein, and follows the standard Calscience data package. The results in this analytical report are limited to the samples tested and any reproduction thereof must be made in its entirety.

Note that the Chain-of-Custody Record and Sample Receipt Form are integral parts of this report.

If you have any questions regarding this report, please do not hesitate to contact the undersigned.

Sincerely,

Calscience Environmental
Laboratories, Inc.
Cecile deGuia
Project Manager



Analytical Report



Environmental Resolutions, Inc.	Date Received:	04/09/09
601 North McDowell Blvd.	Work Order No:	09-04-0757
Petaluma, CA 94954-2312	Preparation:	N/A
	Method:	EPA TO-3M

Project: ExxonMobil 70104

Page 1 of 1

Client Sample Number	Lab Sample Number	Date/Time Collected	Matrix	Instrument	Date Prepared	Date/Time Analyzed	QC Batch ID
A-EFF	09-04-0757-1-A	04/07/09 13:00	Air	GC 13	N/A	04/09/09 11:34	090409L01

Parameter	Result	RL	DF	Qual	Units
TPH as Gasoline	ND	1.5	1		ppm (v/v)

A-INT2	09-04-0757-2-A	04/07/09 13:13	Air	GC 13	N/A	04/09/09 13:49	090409L01
--------	----------------	-------------------	-----	-------	-----	-------------------	-----------

Parameter	Result	RL	DF	Qual	Units
TPH as Gasoline	ND	1.5	1		ppm (v/v)

A-INT1	09-04-0757-3-A	04/07/09 13:30	Air	GC 13	N/A	04/09/09 13:59	090409L01
--------	----------------	-------------------	-----	-------	-----	-------------------	-----------

Parameter	Result	RL	DF	Qual	Units
TPH as Gasoline	ND	1.5	1		ppm (v/v)

A-INF	09-04-0757-4-A	04/07/09 13:45	Air	GC 13	N/A	04/09/09 13:33	090409L01
-------	----------------	-------------------	-----	-------	-----	-------------------	-----------

Parameter	Result	RL	DF	Qual	Units
TPH as Gasoline	ND	1.5	1		ppm (v/v)

Method Blank	098-01-005-1,754	N/A	Air	GC 13	N/A	04/09/09 08:18	090409L01
--------------	------------------	-----	-----	-------	-----	-------------------	-----------

Parameter	Result	RL	DF	Qual	Units
TPH as Gasoline	ND	1.5	1		ppm (v/v)

RL - Reporting Limit , DF - Dilution Factor , Qual - Qualifiers

Analytical Report



Environmental Resolutions, Inc.
 601 North McDowell Blvd.
 Petaluma, CA 94954-2312

Date Received: 04/09/09
 Work Order No: 09-04-0757
 Preparation: N/A
 Method: EPA TO-15M
 Units: ppm (v/v)

Project: ExxonMobil 70104

Page 1 of 2

Client Sample Number	Lab Sample Number	Date/Time Collected	Matrix	Instrument	Date Prepared	Date/Time Analyzed	QC Batch ID
A-EFF	09-04-0757-1-A	04/07/09 13:00	Air	GC/MS YY	N/A	04/10/09 01:05	090409L01

Parameter	Result	RL	DF	Qual	Parameter	Result	RL	DF	Qual
Benzene	ND	0.00050	1		Xylenes (total)	ND	0.0020	1	
Toluene	0.0017	0.00050	1		Methyl-t-Butyl Ether (MTBE)	0.036	0.0020	1	
Ethylbenzene	ND	0.00050	1						
Surrogates:	REC (%)	Control Limits		Qual	Surrogates:	REC (%)	Control Limits		Qual
1,4-Bromofluorobenzene	93	57-129			1,2-Dichloroethane-d4	71	47-137		
Toluene-d8	93	78-156							

Client Sample Number	Lab Sample Number	Date/Time Collected	Matrix	Instrument	Date Prepared	Date/Time Analyzed	QC Batch ID
A-INT2	09-04-0757-2-A	04/07/09 13:13	Air	GC/MS YY	N/A	04/10/09 01:50	090409L01

Parameter	Result	RL	DF	Qual	Parameter	Result	RL	DF	Qual
Benzene	ND	0.00050	1		Xylenes (total)	ND	0.0020	1	
Toluene	0.0016	0.00050	1		Methyl-t-Butyl Ether (MTBE)	0.014	0.0020	1	
Ethylbenzene	ND	0.00050	1						
Surrogates:	REC (%)	Control Limits		Qual	Surrogates:	REC (%)	Control Limits		Qual
1,4-Bromofluorobenzene	92	57-129			1,2-Dichloroethane-d4	75	47-137		
Toluene-d8	98	78-156							


Client Sample Number	Lab Sample Number	Date/Time Collected	Matrix	Instrument	Date Prepared	Date/Time Analyzed	QC Batch ID
A-INT1	09-04-0757-3-A	04/07/09 13:30	Air	GC/MS YY	N/A	04/10/09 02:36	090409L01

Parameter	Result	RL	DF	Qual	Parameter	Result	RL	DF	Qual
Benzene	0.00057	0.00050	1		Xylenes (total)	ND	0.0020	1	
Toluene	0.0016	0.00050	1		Methyl-t-Butyl Ether (MTBE)	0.059	0.0050	2.5	
Ethylbenzene	ND	0.00050	1						
Surrogates:	REC (%)	Control Limits		Qual	Surrogates:	REC (%)	Control Limits		Qual
1,4-Bromofluorobenzene	94	57-129			1,2-Dichloroethane-d4	77	47-137		
Toluene-d8	97	78-156							

Client Sample Number	Lab Sample Number	Date/Time Collected	Matrix	Instrument	Date Prepared	Date/Time Analyzed	QC Batch ID
A-INF	09-04-0757-4-A	04/07/09 13:45	Air	GC/MS YY	N/A	04/10/09 03:21	090409L01

Parameter	Result	RL	DF	Qual	Parameter	Result	RL	DF	Qual
Benzene	ND	0.00050	1		Xylenes (total)	ND	0.0020	1	
Toluene	0.0044	0.00050	1		Methyl-t-Butyl Ether (MTBE)	0.073	0.0080	4	
Ethylbenzene	ND	0.00050	1						
Surrogates:	REC (%)	Control Limits		Qual	Surrogates:	REC (%)	Control Limits		Qual
1,4-Bromofluorobenzene	98	57-129			1,2-Dichloroethane-d4	81	47-137		
Toluene-d8	98	78-156							

RL - Reporting Limit , DF - Dilution Factor , Qual - Qualifiers



Analytical Report



Environmental Resolutions, Inc.
601 North McDowell Blvd.
Petaluma, CA 94954-2312

Date Received: 04/09/09
Work Order No: 09-04-0757
Preparation: N/A
Method: EPA TO-15M
Units: ppm (v/v)

Project: ExxonMobil 70104

Page 2 of 2


Table with 8 columns: Client Sample Number, Lab Sample Number, Date/Time Collected, Matrix, Instrument, Date Prepared, Date/Time Analyzed, QC Batch ID. Row 1: Method Blank, 097-09-002-8,419, N/A, Air, GC/MS YY, N/A, 04/09/09 15:16, 090409L01

Table with 10 columns: Parameter, Result, RL, DF, Qual, Parameter, Result, RL, DF, Qual. Rows include Benzene, Toluene, Ethylbenzene, Surrogates, 1,4-Bromofluorobenzene, Toluene-d8.

Table with 8 columns: Client Sample Number, Lab Sample Number, Date/Time Collected, Matrix, Instrument, Date Prepared, Date/Time Analyzed, QC Batch ID. Row 1: Method Blank, 097-09-002-8,427, N/A, Air, GC/MS YY, N/A, 04/10/09 17:14, 090410L01

Table with 10 columns: Parameter, Result, RL, DF, Qual, Parameter, Result, RL, DF, Qual. Rows include Benzene, Toluene, Ethylbenzene, Surrogates, 1,4-Bromofluorobenzene, Toluene-d8.

RL - Reporting Limit , DF - Dilution Factor , Qual - Qualifiers



Analytical Report



Environmental Resolutions, Inc.
601 North McDowell Blvd.
Petaluma, CA 94954-2312

Date Received: 04/09/09
Work Order No: 09-04-0757
Preparation: N/A
Method: EPA TO-3M

Project: ExxonMobil 70104

Page 1 of 1

Client Sample Number	Lab Sample Number	Date/Time Collected	Matrix	Instrument	Date Prepared	Date/Time Analyzed	QC Batch ID
A-EFF	09-04-0757-1-A	04/07/09 13:00	Air	GC 13	N/A	04/09/09 11:34	090409L01

Parameter	Result	RL	DF	Qual	Units
TPH as Gasoline	ND	5.7	1		mg/m3

Client Sample Number	Lab Sample Number	Date/Time Collected	Matrix	Instrument	Date Prepared	Date/Time Analyzed	QC Batch ID
A-INT2	09-04-0757-2-A	04/07/09 13:13	Air	GC 13	N/A	04/09/09 13:49	090409L01

Parameter	Result	RL	DF	Qual	Units
TPH as Gasoline	ND	5.7	1		mg/m3

Client Sample Number	Lab Sample Number	Date/Time Collected	Matrix	Instrument	Date Prepared	Date/Time Analyzed	QC Batch ID
A-INT1	09-04-0757-3-A	04/07/09 13:30	Air	GC 13	N/A	04/09/09 13:59	090409L01

Parameter	Result	RL	DF	Qual	Units
TPH as Gasoline	ND	5.7	1		mg/m3


Client Sample Number	Lab Sample Number	Date/Time Collected	Matrix	Instrument	Date Prepared	Date/Time Analyzed	QC Batch ID
A-INF	09-04-0757-4-A	04/07/09 13:45	Air	GC 13	N/A	04/09/09 13:33	090409L01

Parameter	Result	RL	DF	Qual	Units
TPH as Gasoline	ND	5.7	1		mg/m3

Client Sample Number	Lab Sample Number	Date/Time Collected	Matrix	Instrument	Date Prepared	Date/Time Analyzed	QC Batch ID
Method Blank	098-01-005-1,754	N/A	Air	GC 13	N/A	04/09/09 08:18	090409L01

Parameter	Result	RL	DF	Qual	Units
TPH as Gasoline	ND	5.7	1		mg/m3

RL - Reporting Limit , DF - Dilution Factor , Qual - Qualifiers



Analytical Report



Environmental Resolutions, Inc.
601 North McDowell Blvd.
Petaluma, CA 94954-2312

Date Received: 04/09/09
Work Order No: 09-04-0757
Preparation: N/A
Method: EPA TO-15M
Units: mg/m3

Project: ExxonMobil 70104

Page 2 of 2


Client Sample Number	Lab Sample Number	Date/Time Collected	Matrix	Instrument	Date Prepared	Date/Time Analyzed	QC Batch ID
Method Blank	097-09-002-8,419	N/A	Air	GC/MS YY	N/A	04/09/09 15:16	090409L01


Parameter	Result	RL	DF	Qual	Parameter	Result	RL	DF	Qual
Benzene	ND	0.0016	1		Xylenes (total)	ND	0.0087	1	
Toluene	ND	0.0019	1		Methyl-t-Butyl Ether (MTBE)	ND	0.0072	1	
Ethylbenzene	ND	0.0022	1						
Surrogates:	REC (%)	Control Limits		Qual	Surrogates:	REC (%)	Control Limits		Qual
1,4-Bromofluorobenzene	87	57-129			1,2-Dichloroethane-d4	96	47-137		
Toluene-d8	99	78-156							

Client Sample Number	Lab Sample Number	Date/Time Collected	Matrix	Instrument	Date Prepared	Date/Time Analyzed	QC Batch ID
Method Blank	097-09-002-8,427	N/A	Air	GC/MS YY	N/A	04/10/09 17:14	090410L01

Parameter	Result	RL	DF	Qual	Parameter	Result	RL	DF	Qual
Benzene	ND	0.0016	1		Xylenes (total)	ND	0.0087	1	
Toluene	ND	0.0019	1		Methyl-t-Butyl Ether (MTBE)	ND	0.0072	1	
Ethylbenzene	ND	0.0022	1						
Surrogates:	REC (%)	Control Limits		Qual	Surrogates:	REC (%)	Control Limits		Qual
1,4-Bromofluorobenzene	90	57-129			1,2-Dichloroethane-d4	95	47-137		
Toluene-d8	96	78-156							

RL - Reporting Limit , DF - Dilution Factor , Qual - Qualifiers





Quality Control - Duplicate



Environmental Resolutions, Inc.
 601 North McDowell Blvd.
 Petaluma, CA 94954-2312


Date Received: 04/09/09
 Work Order No: 09-04-0757
 Preparation: N/A
 Method: EPA TO-3M

Project: ExxonMobil 70104

Quality Control Sample ID	Matrix	Instrument	Date Prepared:	Date Analyzed:	Duplicate Batch Number
09-04-0592-1	Air	GC 13	N/A	04/09/09	090409D01

Parameter	Sample Conc	DUP Conc	RPD	RPD CL	Qualifiers
TPH as Gasoline	670	660	2	0-20	

RPD - Relative Percent Difference , CL - Control Limit



Quality Control - Duplicate



Environmental Resolutions, Inc.
601 North McDowell Blvd.
Petaluma, CA 94954-2312


Date Received: 04/09/09
Work Order No: 09-04-0757
Preparation: N/A
Method: EPA TO-3M


Project: ExxonMobil 70104

Quality Control Sample ID	Matrix	Instrument	Date Prepared:	Date Analyzed:	Duplicate Batch Number
09-04-0592-1	Air	GC 13	N/A	04/09/09	090409D01

Parameter	Sample Conc.	DUP Conc	RPD	RPD CL	Qualifiers
TPH as Gasoline	2600	2500	2	0-20	

RPD - Relative Percent Difference , CL - Control Limit





Quality Control - LCS/LCS Duplicate



Environmental Resolutions, Inc.
601 North McDowell Blvd.
Petaluma, CA 94954-2312


Date Received: N/A
Work Order No: 09-04-0757
Preparation: N/A
Method: EPA TO-15M

Project: ExxonMobil 70104

Quality Control Sample ID	Matrix	Instrument	Date Prepared	Date Analyzed	LCS/LCSD Batch Number
097-09-002-8,419	Air	GC/MS YY	N/A	04/09/09	090409L01

Parameter	LCS %REC	LCSD %REC	%REC CL	RPD	RPD CL	Qualifiers
Benzene	84	98	60-156	16	0-40	
Toluene	82	98	56-146	18	0-43	
Ethylbenzene	92	108	52-154	17	0-38	
p/m-Xylene	91	108	42-156	17	0-41	
o-Xylene	100	111	52-148	11	0-38	

RPD - Relative Percent Difference , CL - Control Limit



Quality Control - LCS/LCS Duplicate



Environmental Resolutions, Inc.
601 North McDowell Blvd.
Petaluma, CA 94954-2312

Date Received: N/A
Work Order No: 09-04-0757
Preparation: N/A
Method: EPA TO-15M

Project: ExxonMobil 70104

Quality Control Sample ID	Matrix	Instrument	Date Prepared	Date Analyzed	LCS/LCSD Batch Number
097-09-002-8,427	Air	GC/MS YY	N/A	04/10/09	090410L01

Parameter	LCS %REC	LCSD %REC	%REC CL	RPD	RPD CL	Qualifiers
Benzene	95	97	60-156	2	0-40	
Toluene	94	98	56-146	4	0-43	
Ethylbenzene	105	107	52-154	2	0-38	
p/m-Xylene	103	105	42-156	2	0-41	
o-Xylene	106	108	52-148	1	0-38	

RPD - Relative Percent Difference, CL - Control Limit


Work Order Number: 09-04-0757

<u>Qualifier</u>	<u>Definition</u>
*	See applicable analysis comment.
1	Surrogate compound recovery was out of control due to a required sample dilution, therefore, the sample data was reported without further clarification.
2	Surrogate compound recovery was out of control due to matrix interference. The associated method blank surrogate spike compound was in control and, therefore, the sample data was reported without further clarification.
3	Recovery of the Matrix Spike (MS) or Matrix Spike Duplicate (MSD) compound was out of control due to matrix interference. The associated LCS and/or LCSD was in control and, therefore, the sample data was reported without further clarification.
4	The MS/MSD RPD was out of control due to matrix interference. The LCS/LCSD RPD was in control and, therefore, the sample data was reported without further clarification.
5	The PDS/PDSD associated with this batch of samples was out of control due to a matrix interference effect. The associated batch LCS/LCSD was in control and, hence, the associated sample data was reported with no further corrective action required.
A	Result is the average of all dilutions, as defined by the method.
B	Analyte was present in the associated method blank.
C	Analyte presence was not confirmed on primary column.
E	Concentration exceeds the calibration range.
I	Compound did not meet method-described identification guidelines. Identification was based on additional GC/MS characteristics.
J	Analyte was detected at a concentration below the reporting limit and above the laboratory method detection limit. Reported value is estimated.
ND	Parameter not detected at the indicated reporting limit.
Q	Spike recovery and RPD control limits do not apply resulting from the parameter concentration in the sample exceeding the spike concentration by a factor of four or greater.
X	% Recovery and/or RPD out-of-range.
Z	Analyte presence was not confirmed by second column or GC/MS analysis.



CHAIN OF CUSTODY RECORD

0757

 7440 LINCOLN WAY GARDEN GROVE, CA 92841 TEL: (714) 895-5494 FAX: (714) 894-7501 ExxonMobil	Consultant Name: <u>Environmental Resolutions, Inc.</u> Address: <u>601 North McDowell</u> City/State/Zip: <u>Petaluma, CA 94954</u> Project Manager: <u>Paula Sime</u> Telephone Number: <u>707-766-2000</u> ERI Job Number: <u>2506-11X (monthly)</u> Sampler Name: (Print) <u>Jon Heumann</u> Sampler Signature: <u>[Signature]</u>	ExxonMobil Engineer: <u>Jennifer Sedlachek</u> Telephone Number: <u>510-547-8196</u> Account #: <u>10228</u> PO #: <u>4508883534</u> Facility ID #: <u>7-0104</u> Global ID#: _____ Site Address: <u>1725 Park Street</u> City, State Zip: <u>Alameda, California</u>
--	---	--

TAT	PROVIDE: EDF Report	Special Instructions: * Include TPHg, BTEX, and MTBE	Matrix			Analyze For:														
			Water	Soil	Vapor	TO-3M+TO-15*														
<input type="checkbox"/> 24 hour <input type="checkbox"/> 72 hour <input type="checkbox"/> 48 hour <input type="checkbox"/> 96 hour <input checked="" type="checkbox"/> 8 day			DATE	TIME	COMP	GRAB	PRESERV	NUMBER												
			4/7/09	13 ⁰⁰		X	NONE	1-1L			X	X								
			↓	13 ⁴⁵		X	NONE	1-1L			X	X								
			↓	13 ³⁰		X	NONE	1-1L			X	X								
			↓	13 ⁴⁵		X	NONE	1-1L			X	X								

Relinquished by: <u>J Heumann</u> Date <u>4/8/09</u> Time <u>9:00</u> Relinquished by: <u>Tomalley GSO</u> Date <u>4/8/09</u> Time <u>1730</u> GSO # <u>51162428/6</u>	Received by: <u>Tomalley CEE</u> Time <u>1435</u> Received by: <u>near R. ca</u> Time <u>10:30</u>	Laboratory Comments: Temperature Upon Receipt: Sample Containers Intact? VOAs Free of Headspace?
--	---	---

SAMPLE RECEIPT FORM

BOX 1 of 1
Cooler

CLIENT: ERI

DATE: 04 / 09 / 09

TEMPERATURE: (Criteria: 0.0°C – 6.0°C, not frozen)

Temperature _____ °C - 0.2°C (CF) = _____ °C Blank Sample

Sample(s) outside temperature criteria (PM/APM contacted by: _____).

Sample(s) outside temperature criteria but received on ice/chilled on same day of sampling.

Received at ambient temperature, placed on ice for transport by Courier.

Ambient Temperature: Air Filter Metals Only PCBs Only Initial: PS

CUSTODY SEALS INTACT:

Cooler BOX No (Not Intact) Not Present N/A Initial: PS

Sample _____ No (Not Intact) Not Present Initial: PS

SAMPLE CONDITION:

	Yes	No	N/A
Chain-Of-Custody (COC) document(s) received with samples.....	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
COC document(s) received complete.....	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
<input type="checkbox"/> Collection date/time, matrix, and/or # of containers logged in based on sample labels.			
<input type="checkbox"/> COC not relinquished. <input type="checkbox"/> No date relinquished. <input type="checkbox"/> No time relinquished.			
Sampler's name indicated on COC.....	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Sample container label(s) consistent with COC.....	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Sample container(s) intact and good condition.....	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Correct containers and volume for analyses requested.....	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Analyses received within holding time.....	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Proper preservation noted on COC or sample container.....	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
<input type="checkbox"/> Unpreserved vials received for Volatiles analysis			
Volatile analysis container(s) free of headspace.....	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Tedlar bag(s) free of condensation.....	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

CONTAINER TYPE:

Solid: 4ozCGJ 8ozCGJ 16ozCGJ Sleeve EnCores® TerraCores® _____

Water: VOA VOAh VOAna₂ 125AGB 125AGBh 125AGBp 1AGB 1AGBna₂ 1AGBs


500AGB 500AGJ 500AGJs 250AGB 250CGB 250CGBs 1PB 500PB 500PBna

250PB 250PBn 125PB 125PBzanna 100PBsterile 100PBna₂ _____ _____ _____

Air: Tedlar® Summa® _____ **Sludge/Other:** _____ **Checked/Labeled by:** PS

Container: C: Clear A: Amber P: Plastic G: Glass J: Jar (Wide-mouth) B: Bottle (Narrow-mouth) **Reviewed by:** [Signature]

Preservative: h: HCL n: HNO₃ na₂: Na₂S₂O₃ Na: NaOH p: H₃PO₄ s: H₂SO₄ zanna: ZnAc₂+NaOH **Scanned by:** PS



May 21, 2009

RECEIVED
MAY 22 2009

Paula Sime
Environmental Resolutions, Inc.
601 North McDowell Blvd.
Petaluma, CA 94954-2312

BY:.....

Subject: **Calscience Work Order No.: 09-05-1505**
Client Reference: **ExxonMobil 70104**

Dear Client:

Enclosed is an analytical report for the above-referenced project. The samples included in this report were received 5/16/2009 and analyzed in accordance with the attached chain-of-custody.

Unless otherwise noted, all analytical testing was accomplished in accordance with the guidelines established in our Quality Systems Manual, applicable standard operating procedures, and other related documentation. The original report of subcontracted analysis, if any, is provided herein, and follows the standard Calscience data package. The results in this analytical report are limited to the samples tested and any reproduction thereof must be made in its entirety.


Note that the Chain-of-Custody Record and Sample Receipt Form are integral parts of this report.

If you have any questions regarding this report, please do not hesitate to contact the undersigned.

Sincerely,

Calscience Environmental
Laboratories, Inc.
Cecile deGuia
Project Manager





Analytical Report



Environmental Resolutions, Inc.
601 North McDowell Blvd.
Petaluma, CA 94954-2312

Date Received: 05/16/09
Work Order No: 09-05-1505
Preparation: N/A
Method: EPA TO-3M

Project: ExxonMobil 70104

Page 1 of 1

Client Sample Number	Lab Sample Number	Date/Time Collected	Matrix	Instrument	Date Prepared	Date/Time Analyzed	QC Batch ID
A-EFF	09-05-1505-1-A	05/15/09 13:00	Air	GC 13	N/A	05/16/09 12:19	090516L01

Parameter	Result	RL	DF	Qual	Units
TPH as Gasoline	ND	1.5	1		ppm (v/v)

A-INT2	09-05-1505-2-A	05/15/09 13:15	Air	GC 13	N/A	05/16/09 13:13	090516L01
--------	----------------	-------------------	-----	-------	-----	-------------------	-----------

Parameter	Result	RL	DF	Qual	Units
TPH as Gasoline	ND	1.5	1		ppm (v/v)

A-INT1	09-05-1505-3-A	05/15/09 13:30	Air	GC 13	N/A	05/16/09 13:24	090516L01
--------	----------------	-------------------	-----	-------	-----	-------------------	-----------

Parameter	Result	RL	DF	Qual	Units
TPH as Gasoline	ND	1.5	1		ppm (v/v)


A-INF	09-05-1505-4-A	05/15/09 13:45	Air	GC 13	N/A	05/16/09 13:35	090516L01
-------	----------------	-------------------	-----	-------	-----	-------------------	-----------

Parameter	Result	RL	DF	Qual	Units
TPH as Gasoline	ND	1.5	1		ppm (v/v)

Method Blank	098-01-005-1,802	N/A	Air	GC 13	N/A	05/16/09 09:39	090516L01
--------------	------------------	-----	-----	-------	-----	-------------------	-----------

Parameter	Result	RL	DF	Qual	Units
TPH as Gasoline	ND	1.5	1		ppm (v/v)

RL - Reporting Limit , DF - Dilution Factor , Qual - Qualifiers



Analytical Report



Environmental Resolutions, Inc.
601 North McDowell Blvd.
Petaluma, CA 94954-2312

Date Received: 05/16/09
Work Order No: 09-05-1505
Preparation: N/A
Method: EPA TO-15M
Units: ppm (v/v)

Project: ExxonMobil 70104

Page 1 of 2

Client Sample Number	Lab Sample Number	Date/Time Collected	Matrix	Instrument	Date Prepared	Date/Time Analyzed	QC Batch ID
A-EFF	09-05-1505-1-A	05/15/09 13:00	Air	GC/MS DD	N/A	05/17/09 01:31	090516L01

Comment(s): -The method has been modified to use Tedlar bags instead of Summa Canisters.

Parameter	Result	RL	DF	Qual	Parameter	Result	RL	DF	Qual
Benzene	ND	0.00050	1		Xylenes (total)	0.0027	0.0020	1	
Toluene	0.0025	0.00050	1		Methyl-t-Butyl Ether (MTBE)	0.11	0.0080	4	
Ethylbenzene	0.00090	0.00050	1						
Surrogates:	REC (%)	Control Limits		Qual	Surrogates:	REC (%)	Control Limits		Qual
1,4-Bromofluorobenzene	94	57-129			1,2-Dichloroethane-d4	98	47-137		
Toluene-d8	99	78-156							

Client Sample Number	Lab Sample Number	Date/Time Collected	Matrix	Instrument	Date Prepared	Date/Time Analyzed	QC Batch ID
A-INT2	09-05-1505-2-A	05/15/09 13:15	Air	GC/MS DD	N/A	05/17/09 02:20	090516L01

Comment(s): -The method has been modified to use Tedlar bags instead of Summa Canisters.


Parameter	Result	RL	DF	Qual	Parameter	Result	RL	DF	Qual
Benzene	ND	0.00050	1		Xylenes (total)	ND	0.0020	1	
Toluene	0.0030	0.00050	1		Methyl-t-Butyl Ether (MTBE)	0.032	0.0020	1	
Ethylbenzene	ND	0.00050	1						
Surrogates:	REC (%)	Control Limits		Qual	Surrogates:	REC (%)	Control Limits		Qual
1,4-Bromofluorobenzene	90	57-129			1,2-Dichloroethane-d4	98	47-137		
Toluene-d8	99	78-156							

Client Sample Number	Lab Sample Number	Date/Time Collected	Matrix	Instrument	Date Prepared	Date/Time Analyzed	QC Batch ID
A-INT1	09-05-1505-3-A	05/15/09 13:30	Air	GC/MS DD	N/A	05/17/09 03:08	090516L01

Comment(s): -The method has been modified to use Tedlar bags instead of Summa Canisters.

Parameter	Result	RL	DF	Qual	Parameter	Result	RL	DF	Qual
Benzene	0.0013	0.00050	1		Xylenes (total)	ND	0.0020	1	
Toluene	0.0030	0.00050	1		Methyl-t-Butyl Ether (MTBE)	0.12	0.010	5	
Ethylbenzene	ND	0.00050	1						
Surrogates:	REC (%)	Control Limits		Qual	Surrogates:	REC (%)	Control Limits		Qual
1,4-Bromofluorobenzene	84	57-129			1,2-Dichloroethane-d4	98	47-137		
Toluene-d8	98	78-156							

RL - Reporting Limit DF - Dilution Factor Qual - Qualifiers



Analytical Report



Environmental Resolutions, Inc.
601 North McDowell Blvd.
Petaluma, CA 94954-2312

Date Received: 05/16/09
Work Order No: 09-05-1505
Preparation: N/A
Method: EPA TO-15M
Units: ppm (v/v)

Project: ExxonMobil 70104

Page 2 of 2

Client Sample Number	Lab Sample Number	Date/Time Collected	Matrix	Instrument	Date Prepared	Date/Time Analyzed	QC Batch ID
A-INF	09-05-1505-4-A	05/15/09 13:45	Air	GC/MS DD	N/A	05/17/09 03:58	090516L01

Comment(s): -The method has been modified to use Tedlar bags instead of Summa Canisters.

Parameter	Result	RL	DF	Qual	Parameter	Result	RL	DF	Qual
Benzene	ND	0.00050	1		Xylenes (total)	ND	0.0020	1	
Toluene	0.0038	0.00050	1		Methyl-t-Butyl Ether (MTBE)	0.094	0.0080	4	
Ethylbenzene	ND	0.00050	1						
<u>Surrogates:</u>	<u>REC (%)</u>	<u>Control Limits</u>		<u>Qual</u>	<u>Surrogates:</u>	<u>REC (%)</u>	<u>Control Limits</u>		<u>Qual</u>
1,4-Bromofluorobenzene	89	57-129			1,2-Dichloroethane-d4	99	47-137		
Toluene-d8	100	78-156							


Method Blank	097-09-002-8,559	N/A	Air	GC/MS DD	N/A	05/17/09 11:05	090517L01
--------------	------------------	-----	-----	----------	-----	-------------------	-----------

Parameter	Result	RL	DF	Qual	Parameter	Result	RL	DF	Qual
Benzene	ND	0.00050	1		Xylenes (total)	ND	0.0020	1	
Toluene	ND	0.00050	1		Methyl-t-Butyl Ether (MTBE)	ND	0.0020	1	
Ethylbenzene	ND	0.00050	1						
<u>Surrogates:</u>	<u>REC (%)</u>	<u>Control Limits</u>		<u>Qual</u>	<u>Surrogates:</u>	<u>REC (%)</u>	<u>Control Limits</u>		<u>Qual</u>
1,4-Bromofluorobenzene	80	57-129			1,2-Dichloroethane-d4	100	47-137		
Toluene-d8	95	78-156							

Method Blank	097-09-002-8,563	N/A	Air	GC/MS DD	N/A	05/16/09 11:38	090516L01
--------------	------------------	-----	-----	----------	-----	-------------------	-----------

Parameter	Result	RL	DF	Qual	Parameter	Result	RL	DF	Qual
Benzene	ND	0.00050	1		Xylenes (total)	ND	0.0020	1	
Toluene	ND	0.00050	1		Methyl-t-Butyl Ether (MTBE)	ND	0.0020	1	
Ethylbenzene	ND	0.00050	1						
<u>Surrogates:</u>	<u>REC (%)</u>	<u>Control Limits</u>		<u>Qual</u>	<u>Surrogates:</u>	<u>REC (%)</u>	<u>Control Limits</u>		<u>Qual</u>
1,4-Bromofluorobenzene	89	57-129			1,2-Dichloroethane-d4	100	47-137		
Toluene-d8	93	78-156							

RL - Reporting Limit , DF - Dilution Factor , Qual - Qualifiers



Analytical Report



Environmental Resolutions, Inc.
601 North McDowell Blvd.
Petaluma, CA 94954-2312

Date Received: 05/16/09
Work Order No: 09-05-1505
Preparation: N/A
Method: EPA TO-3M

Project: ExxonMobil 70104

Page 1 of 1

Client Sample Number	Lab Sample Number	Date/Time Collected	Matrix	Instrument	Date Prepared	Date/Time Analyzed	QC Batch ID
A-EFF	09-05-1505-1-A	05/15/09 13:00	Air	GC 13	N/A	05/16/09 12:19	090516L01

Parameter	Result	RL	DF	Qual	Units
TPH as Gasoline	ND	5.7	1		mg/m3

A-INT2	09-05-1505-2-A	05/15/09 13:15	Air	GC 13	N/A	05/16/09 13:13	090516L01
--------	----------------	-------------------	-----	-------	-----	-------------------	-----------

Parameter	Result	RL	DF	Qual	Units
TPH as Gasoline	ND	5.7	1		mg/m3

A-INT1	09-05-1505-3-A	05/15/09 13:30	Air	GC 13	N/A	05/16/09 13:24	090516L01
--------	----------------	-------------------	-----	-------	-----	-------------------	-----------

Parameter	Result	RL	DF	Qual	Units
TPH as Gasoline	ND	5.7	1		mg/m3


A-JNF	09-05-1505-4-A	05/15/09 13:45	Air	GC 13	N/A	05/16/09 13:35	090516L01
-------	----------------	-------------------	-----	-------	-----	-------------------	-----------

Parameter	Result	RL	DF	Qual	Units
TPH as Gasoline	ND	5.7	1		mg/m3

Method Blank	098-01-005-1,802	N/A	Air	GC 13	N/A	05/16/09 09:39	090516L01
--------------	------------------	-----	-----	-------	-----	-------------------	-----------

Parameter	Result	RL	DF	Qual	Units
TPH as Gasoline	ND	5.7	1		mg/m3

RL - Reporting Limit , DF - Dilution Factor , Qual - Qualifiers



Analytical Report



Environmental Resolutions, Inc.
601 North McDowell Blvd.
Petaluma, CA 94954-2312

Date Received: 05/16/09
Work Order No: 09-05-1505
Preparation: N/A
Method: EPA TO-15M
Units: mg/m3

Project: ExxonMobil 70104

Page 1 of 2

Client Sample Number	Lab Sample Number	Date/Time Collected	Matrix	Instrument	Date Prepared	Date/Time Analyzed	QC Batch ID
A-EFF	09-05-1505-1-A	05/15/09 13:00	Air	GC/MS DD	N/A	05/17/09 01:31	090516L01

Comment(s): -The method has been modified to use Tedlar bags instead of Summa Canisters.

Parameter	Result	RL	DF	Qual	Parameter	Result	RL	DF	Qual
Benzene	ND	0.0016	1		Xylenes (total)	0.012	0.0087	1	
Toluene	0.0096	0.0019	1		Methyl-t-Butyl Ether (MTBE)	0.40	0.029	4	
Ethylbenzene	0.0039	0.0022	1						
Surrogates:	REC (%)	Control Limits		Qual	Surrogates:	REC (%)	Control Limits		Qual
1,4-Bromofluorobenzene	94	57-129			1,2-Dichloroethane-d4	98	47-137		
Toluene-d8	99	78-156							

Client Sample Number	Lab Sample Number	Date/Time Collected	Matrix	Instrument	Date Prepared	Date/Time Analyzed	QC Batch ID
A-INT2	09-05-1505-2-A	05/15/09 13:15	Air	GC/MS DD	N/A	05/17/09 02:20	090516L01

Comment(s): -The method has been modified to use Tedlar bags instead of Summa Canisters.

Parameter	Result	RL	DF	Qual	Parameter	Result	RL	DF	Qual
Benzene	ND	0.0016	1		Xylenes (total)	ND	0.0087	1	
Toluene	0.011	0.0019	1		Methyl-t-Butyl Ether (MTBE)	0.12	0.0072	1	
Ethylbenzene	ND	0.0022	1						
Surrogates:	REC (%)	Control Limits		Qual	Surrogates:	REC (%)	Control Limits		Qual
1,4-Bromofluorobenzene	90	57-129			1,2-Dichloroethane-d4	98	47-137		
Toluene-d8	99	78-156							

Client Sample Number	Lab Sample Number	Date/Time Collected	Matrix	Instrument	Date Prepared	Date/Time Analyzed	QC Batch ID
A-INT1	09-05-1505-3-A	05/15/09 13:30	Air	GC/MS DD	N/A	05/17/09 03:08	090516L01

Comment(s): -The method has been modified to use Tedlar bags instead of Summa Canisters.

Parameter	Result	RL	DF	Qual	Parameter	Result	RL	DF	Qual
Benzene	0.0042	0.0016	1		Xylenes (total)	ND	0.0087	1	
Toluene	0.011	0.0019	1		Methyl-t-Butyl Ether (MTBE)	0.44	0.036	5	
Ethylbenzene	ND	0.0022	1						
Surrogates:	REC (%)	Control Limits		Qual	Surrogates:	REC (%)	Control Limits		Qual
1,4-Bromofluorobenzene	84	57-129			1,2-Dichloroethane-d4	98	47-137		
Toluene-d8	98	78-156							

RL - Reporting Limit , DF - Dilution Factor , Qual - Qualifiers

Analytical Report



Environmental Resolutions, Inc.
 601 North McDowell Blvd.
 Petaluma, CA 94954-2312

Date Received: 05/16/09
 Work Order No: 09-05-1505
 Preparation: N/A
 Method: EPA TO-15M
 Units: mg/m3

Project: ExxonMobil 70104

Page 2 of 2

Client Sample Number	Lab Sample Number	Date/Time Collected	Matrix	Instrument	Date Prepared	Date/Time Analyzed	QC Batch ID
A-INF	09-05-1505-4-A	05/15/09 13:45	Air	GC/MS DD	N/A	05/17/09 03:58	090516L01

Comment(s): -The method has been modified to use Tedlar bags instead of Summa Canisters.

Parameter	Result	RL	DF	Qual	Parameter	Result	RL	DF	Qual
Benzene	ND	0.0016	1		Xylenes (total)	ND	0.0087	1	
Toluene	0.014	0.0019	1		Methyl-t-Butyl Ether (MTBE)	0.34	0.029	4	
Ethylbenzene	ND	0.0022	1						
Surrogates:	REC (%)	Control Limits		Qual	Surrogates:	REC (%)	Control Limits		Qual
1,4-Bromofluorobenzene	89	57-129			1,2-Dichloroethane-d4	99	47-137		
Toluene-d8	100	78-156							


Method Blank	Lab Sample Number	Date/Time Collected	Matrix	Instrument	Date Prepared	Date/Time Analyzed	QC Batch ID
Method Blank	097-09-002-8,559	N/A	Air	GC/MS DD	N/A	05/17/09 11:05	090517L01

Parameter	Result	RL	DF	Qual	Parameter	Result	RL	DF	Qual
Benzene	ND	0.0016	1		Xylenes (total)	ND	0.0087	1	
Toluene	ND	0.0019	1		Methyl-t-Butyl Ether (MTBE)	ND	0.0072	1	
Ethylbenzene	ND	0.0022	1						
Surrogates:	REC (%)	Control Limits		Qual	Surrogates:	REC (%)	Control Limits		Qual
1,4-Bromofluorobenzene	80	57-129			1,2-Dichloroethane-d4	100	47-137		
Toluene-d8	95	78-156							

Method Blank	Lab Sample Number	Date/Time Collected	Matrix	Instrument	Date Prepared	Date/Time Analyzed	QC Batch ID
Method Blank	097-09-002-8,563	N/A	Air	GC/MS DD	N/A	05/16/09 11:38	090516L01

Parameter	Result	RL	DF	Qual	Parameter	Result	RL	DF	Qual
Benzene	ND	0.0016	1		Xylenes (total)	ND	0.0087	1	
Toluene	ND	0.0019	1		Methyl-t-Butyl Ether (MTBE)	ND	0.0072	1	
Ethylbenzene	ND	0.0022	1						
Surrogates:	REC (%)	Control Limits		Qual	Surrogates:	REC (%)	Control Limits		Qual
1,4-Bromofluorobenzene	89	57-129			1,2-Dichloroethane-d4	100	47-137		
Toluene-d8	93	78-156							

RL - Reporting Limit , DF - Dilution Factor , Qual - Qualifiers



Quality Control - Duplicate



Environmental Resolutions, Inc.
 601 North McDowell Blvd.
 Petaluma, CA 94954-2312


Date Received: 05/16/09
 Work Order No: 09-05-1505
 Preparation: N/A
 Method: EPA TO-3M

Project: ExxonMobil 70104

Quality Control Sample ID	Matrix	Instrument	Date Prepared:	Date Analyzed:	Duplicate Batch Number
09-05-1470-1	Air	GC 13	N/A	05/16/09	090516D01

<u>Parameter</u>	<u>Sample Conc.</u>	<u>DUP Conc</u>	<u>RPD</u>	<u>RPD CL</u>	<u>Qualifiers</u>
TPH as Gasoline	360	380	3	0-20	

RPD - Relative Percent Difference , CL - Control Limit



Quality Control - Duplicate



Environmental Resolutions, Inc.
 601 North McDowell Blvd.
 Petaluma, CA 94954-2312


Date Received: 05/16/09
 Work Order No: 09-05-1505
 Preparation: N/A
 Method: EPA TO-3M

Project: ExxonMobil 70104

Quality Control Sample ID	Matrix	Instrument	Date Prepared:	Date Analyzed:	Duplicate Batch Number
09-05-1470-1	Air	GC 13	N/A	05/16/09	090516D01

Parameter	Sample Conc	DUP Conc	RPD	RPD CL	Qualifiers
TPH as Gasoline	1400	1400	3	0-20	

RPD - Relative Percent Difference , CL - Control Limit



Quality Control - LCS/LCS Duplicate



Environmental Resolutions, Inc.
601 North McDowell Blvd.
Petaluma, CA 94954-2312


Date Received: N/A
Work Order No: 09-05-1505
Preparation: N/A
Method: EPA TO-15M

Project: ExxonMobil 70104

Quality Control Sample ID	Matrix	Instrument	Date Prepared	Date Analyzed	LCS/LCSD Batch Number
097-09-002-8,563	Air	GC/MS DD	N/A	05/16/09	090516L01

Parameter	LCS %REC	LCSD %REC	%REC CL	RPD	RPD CL	Qualifiers
Benzene	109	111	60-156	3	0-40	
Toluene	107	111	56-146	3	0-43	
Ethylbenzene	110	113	52-154	3	0-38	
p/m-Xylene	107	110	42-156	3	0-41	
o-Xylene	110	114	52-148	4	0-38	

RPD - Relative Percent Difference, CL - Control Limit



Quality Control - LCS/LCS Duplicate



Environmental Resolutions, Inc.
601 North McDowell Blvd.
Petaluma, CA 94954-2312

Date Received: N/A
Work Order No: 09-05-1505
Preparation: N/A
Method: EPA TO-15M

Project: ExxonMobil 70104

Quality Control Sample ID	Matrix	Instrument	Date Prepared	Date Analyzed	LCS/LCSD Batch Number
097-09-002-8,559	Air	GC/MS DD	N/A	05/17/09	090517L01

Parameter	LCS %REC	LCSD %REC	%REC CL	RPD	RPD CL	Qualifiers
Benzene	106	108	60-156	3	0-40	
Toluene	105	108	56-146	3	0-43	
Ethylbenzene	106	109	52-154	3	0-38	
p/m-Xylene	104	107	42-156	3	0-41	
o-Xylene	106	110	52-148	3	0-38	

RPD - Relative Percent Difference , CL - Control Limit

Work Order Number: 09-05-1505

<u>Qualifier</u>	<u>Definition</u>
*	See applicable analysis comment.
1	Surrogate compound recovery was out of control due to a required sample dilution, therefore, the sample data was reported without further clarification.
2	Surrogate compound recovery was out of control due to matrix interference. The associated method blank surrogate spike compound was in control and, therefore, the sample data was reported without further clarification.
3	Recovery of the Matrix Spike (MS) or Matrix Spike Duplicate (MSD) compound was out of control due to matrix interference. The associated LCS and/or LCSD was in control and, therefore, the sample data was reported without further clarification.
4	The MS/MSD RPD was out of control due to matrix interference. The LCS/LCSD RPD was in control and, therefore, the sample data was reported without further clarification.
5	The PDS/PDSD associated with this batch of samples was out of control due to a matrix interference effect. The associated batch LCS/LCSD was in control and, hence, the associated sample data was reported with no further corrective action required.
A	Result is the average of all dilutions, as defined by the method.
B	Analyte was present in the associated method blank.
C	Analyte presence was not confirmed on primary column.
E	Concentration exceeds the calibration range.
I	Compound did not meet method-described identification guidelines. Identification was based on additional GC/MS characteristics.
J	Analyte was detected at a concentration below the reporting limit and above the laboratory method detection limit. Reported value is estimated.
ND	Parameter not detected at the indicated reporting limit.
Q	Spike recovery and RPD control limits do not apply resulting from the parameter concentration in the sample exceeding the spike concentration by a factor of four or greater.
X	% Recovery and/or RPD out-of-range.
Z	Analyte presence was not confirmed by second column or GC/MS analysis. Solid - Unless otherwise indicated, solid sample data is reported on a wet weight basis, not corrected for % moisture.



SAMPLE RECEIPT FORM

Box 1 of 1
Cooler

CLIENT: ERI

DATE: 5/16/09

TEMPERATURE: (Criteria: 0.0°C – 6.0°C, not frozen)

Temperature °C - 0.2°C (CF) = °C Blank Sample

Sample(s) outside temperature criteria (PM/APM contacted by:).

Sample(s) outside temperature criteria but received on ice/chilled on same day of sampling.

Received at ambient temperature, placed on ice for transport by Courier.

Ambient Temperature: Air Filter Metals Only PCBs Only Initial: JD

CUSTODY SEALS INTACT:

Cooler No (Not Intact) Not Present N/A Initial: JD

Sample No (Not Intact) Not Present Initial: MH

SAMPLE CONDITION:

	Yes	No	N/A
Chain-Of-Custody (COC) document(s) received with samples.....	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
COC document(s) received complete.....	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
<input type="checkbox"/> Collection date/time, matrix, and/or # of containers logged in based on sample labels.			
<input type="checkbox"/> COC not relinquished. <input type="checkbox"/> No date relinquished. <input type="checkbox"/> No time relinquished.			
Sampler's name indicated on COC.....	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Sample container label(s) consistent with COC.....	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Sample container(s) intact and good condition.....	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Correct containers and volume for analyses requested.....	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Analyses received within holding time.....	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Proper preservation noted on COC or sample container.....	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
<input type="checkbox"/> Unpreserved vials received for Volatiles analysis			
Volatile analysis container(s) free of headspace.....	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Tedlar bag(s) free of condensation.....	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

CONTAINER TYPE:

Solid: 4ozCGJ 8ozCGJ 16ozCGJ Sleeve EnCores® TerraCores®

Water: VOA VOA_h VOA_{na2} 125AGB 125AGB_h 125AGB_p 1AGB 1AGB_{na2} 1AGB_s


500AGB 500AGJ 500AGJ_s 250AGB 250CGB 250CGB_s 1PB 500PB 500PB_{na}

250PB 250PB_n 125PB 125PB_{z_{na}} 100PB 100PB_{na2}

Air: Tedlar® Summa® **Other:** **Checked/Labeled by:** MH

Container: C: Clear A: Amber P: Plastic G: Glass J: Jar (Wide-mouth) B: Bottle (Narrow-mouth) **Reviewed by:** YL

Preservative: h: HCL n: HNO3 na₂: Na₂S₂O₃ Na: NaOH p: H₃PO₄ s: H₂SO₄ z_{na}: ZnAc₂+NaOH f: Field-filtered **Scanned by:** MH



June 22, 2009

RECEIVED
JUN 25 2009

Paula Sime
Environmental Resolutions, Inc.
601 North McDowell Blvd.
Petaluma, CA 94954-2312

BY:.....

Subject: **Calscience Work Order No.: 09-06-1301**
Client Reference: **ExxonMobil 70104**

Dear Client:

Enclosed is an analytical report for the above-referenced project. The samples included in this report were received 6/13/2009 and analyzed in accordance with the attached chain-of-custody.


Unless otherwise noted, all analytical testing was accomplished in accordance with the guidelines established in our Quality Systems Manual, applicable standard operating procedures, and other related documentation. The original report of subcontracted analysis, if any, is provided herein, and follows the standard Calscience data package. The results in this analytical report are limited to the samples tested and any reproduction thereof must be made in its entirety.


Note that the Chain-of-Custody Record and Sample Receipt Form are integral parts of this report.

If you have any questions regarding this report, please do not hesitate to contact the undersigned.

Sincerely,

Calscience Environmental
Laboratories, Inc.
Cecile deGuia
Project Manager





Analytical Report



Environmental Resolutions, Inc.
601 North McDowell Blvd.
Petaluma, CA 94954-2312

Date Received: 06/13/09
Work Order No: 09-06-1301
Preparation: N/A
Method: EPA TO-3M

Project: ExxonMobil 70104

Page 1 of 1

Client Sample Number	Lab Sample Number	Date/Time Collected	Matrix	Instrument	Date Prepared	Date/Time Analyzed	QC Batch ID
A-EFF	09-06-1301-1-A	06/11/09 11:00	Air	GC 13	N/A	06/13/09 10:16	090613L01

Parameter	Result	RL	DF	Qual	Units
TPH as Gasoline	ND	1.5	1		ppm (v/v)

A-INT2	09-06-1301-2-A	06/11/09 11:05	Air	GC 13	N/A	06/13/09 10:55	090613L01
--------	----------------	-------------------	-----	-------	-----	-------------------	-----------

Parameter	Result	RL	DF	Qual	Units
TPH as Gasoline	ND	1.5	1		ppm (v/v)

A-INT1	09-06-1301-3-A	06/11/09 11:10	Air	GC 13	N/A	06/13/09 11:17	090613L01
--------	----------------	-------------------	-----	-------	-----	-------------------	-----------

Parameter	Result	RL	DF	Qual	Units
TPH as Gasoline	ND	1.5	1		ppm (v/v)


A-INF	09-06-1301-4-A	06/11/09 11:15	Air	GC 13	N/A	06/13/09 11:26	090613L01
-------	----------------	-------------------	-----	-------	-----	-------------------	-----------

Parameter	Result	RL	DF	Qual	Units
TPH as Gasoline	ND	1.5	1		ppm (v/v)

Method Blank	098-01-005-1,836	N/A	Air	GC 13	N/A	06/13/09 09:02	090613L01
--------------	------------------	-----	-----	-------	-----	-------------------	-----------

Parameter	Result	RL	DF	Qual	Units
TPH as Gasoline	ND	1.5	1		ppm (v/v)

RL - Reporting Limit , DF - Dilution Factor , Qual - Qualifiers



Analytical Report



Environmental Resolutions, Inc.
601 North McDowell Blvd.
Petaluma, CA 94954-2312

Date Received: 06/13/09
Work Order No: 09-06-1301
Preparation: N/A
Method: EPA TO-15M
Units: ppm (v/v)

Project: ExxonMobil 70104

Page 1 of 2

Client Sample Number	Lab Sample Number	Date/Time Collected	Matrix	Instrument	Date Prepared	Date/Time Analyzed	QC Batch ID
A-EFF	09-06-1301-1-A	06/11/09 11:00	Air	GC/MS AA	N/A	06/13/09 17:24	090613L01

Comment(s): -The method has been modified to use Tedlar bags instead of Summa Canisters.

Parameter	Result	RL	DF	Qual	Parameter	Result	RL	DF	Qual
Benzene	ND	0.00050	1		Xylenes (total)	ND	0.0020	1	
Toluene	0.00059	0.00050	1		Methyl-t-Butyl Ether (MTBE)	0.20	0.010	5	
Ethylbenzene	ND	0.00050	1						
<u>Surrogates:</u>	<u>REC (%)</u>	<u>Control Limits</u>		<u>Qual</u>	<u>Surrogates:</u>	<u>REC (%)</u>	<u>Control Limits</u>		<u>Qual</u>
1,4-Bromofluorobenzene	101	57-129			1,2-Dichloroethane-d4	101	47-137		
Toluene-d8	100	78-156							

Client Sample Number	Lab Sample Number	Date/Time Collected	Matrix	Instrument	Date Prepared	Date/Time Analyzed	QC Batch ID
A-INT2	09-06-1301-2-A	06/11/09 11:05	Air	GC/MS AA	N/A	06/13/09 18:11	090613L01

Comment(s): -The method has been modified to use Tedlar bags instead of Summa Canisters.


Parameter	Result	RL	DF	Qual	Parameter	Result	RL	DF	Qual
Benzene	ND	0.00050	1		Xylenes (total)	ND	0.0020	1	
Toluene	0.00062	0.00050	1		Methyl-t-Butyl Ether (MTBE)	0.043	0.0020	1	
Ethylbenzene	ND	0.00050	1						
<u>Surrogates:</u>	<u>REC (%)</u>	<u>Control Limits</u>		<u>Qual</u>	<u>Surrogates:</u>	<u>REC (%)</u>	<u>Control Limits</u>		<u>Qual</u>
1,4-Bromofluorobenzene	101	57-129			1,2-Dichloroethane-d4	103	47-137		
Toluene-d8	100	78-156							

Client Sample Number	Lab Sample Number	Date/Time Collected	Matrix	Instrument	Date Prepared	Date/Time Analyzed	QC Batch ID
A-INT1	09-06-1301-3-A	06/11/09 11:10	Air	GC/MS AA	N/A	06/13/09 18:58	090613L01

Comment(s): -The method has been modified to use Tedlar bags instead of Summa Canisters.

Parameter	Result	RL	DF	Qual	Parameter	Result	RL	DF	Qual
Benzene	0.00077	0.00050	1		Xylenes (total)	ND	0.0020	1	
Toluene	0.00059	0.00050	1		Methyl-t-Butyl Ether (MTBE)	0.11	0.0080	4	
Ethylbenzene	ND	0.00050	1						
<u>Surrogates:</u>	<u>REC (%)</u>	<u>Control Limits</u>		<u>Qual</u>	<u>Surrogates:</u>	<u>REC (%)</u>	<u>Control Limits</u>		<u>Qual</u>
1,4-Bromofluorobenzene	102	57-129			1,2-Dichloroethane-d4	103	47-137		
Toluene-d8	100	78-156							

RL - Reporting Limit , DF - Dilution Factor , Qual - Qualifiers



Analytical Report



Environmental Resolutions, Inc.
601 North McDowell Blvd.
Petaluma, CA 94954-2312

Date Received: 06/13/09
Work Order No: 09-06-1301
Preparation: N/A
Method: EPA TO-15M
Units: ppm (v/v)

Project: ExxonMobil 70104

Page 2 of 2

Client Sample Number	Lab Sample Number	Date/Time Collected	Matrix	Instrument	Date Prepared	Date/Time Analyzed	QC Batch ID
A-INF	09-06-1301-4-A	06/11/09 11:15	Air	GC/MS AA	N/A	06/13/09 19:47	090613L01

Comment(s): -The method has been modified to use Tedlar bags instead of Summa Canisters.

Parameter	Result	RL	DF	Qual	Parameter	Result	RL	DF	Qual
Benzene	0.00070	0.00050	1		Xylenes (total)	ND	0.0020	1	
Toluene	0.00087	0.00050	1		Methyl-t-Butyl Ether (MTBE)	0.24	0.010	5	
Ethylbenzene	ND	0.00050	1						
Surrogates:	REC (%)	Control Limits		Qual	Surrogates:	REC (%)	Control Limits		Qual
1,4-Bromofluorobenzene	101	57-129			1,2-Dichloroethane-d4	103	47-137		
Toluene-d8	99	78-156							


Method Blank	097-09-002-8,658	N/A	Air	GC/MS AA	N/A	06/14/09 10:44	090614L01
--------------	------------------	-----	-----	----------	-----	----------------	-----------

Parameter	Result	RL	DF	Qual	Parameter	Result	RL	DF	Qual
Benzene	ND	0.00050	1		Xylenes (total)	ND	0.0020	1	
Toluene	ND	0.00050	1		Methyl-t-Butyl Ether (MTBE)	ND	0.0020	1	
Ethylbenzene	ND	0.00050	1						
Surrogates:	REC (%)	Control Limits		Qual	Surrogates:	REC (%)	Control Limits		Qual
1,4-Bromofluorobenzene	101	57-129			1,2-Dichloroethane-d4	108	47-137		
Toluene-d8	99	78-156							

Method Blank	097-09-002-8,659	N/A	Air	GC/MS AA	N/A	06/13/09 12:41	090613L01
--------------	------------------	-----	-----	----------	-----	----------------	-----------

Parameter	Result	RL	DF	Qual	Parameter	Result	RL	DF	Qual
Benzene	ND	0.00050	1		Xylenes (total)	ND	0.0020	1	
Toluene	ND	0.00050	1		Methyl-t-Butyl Ether (MTBE)	ND	0.0020	1	
Ethylbenzene	ND	0.00050	1						
Surrogates:	REC (%)	Control Limits		Qual	Surrogates:	REC (%)	Control Limits		Qual
1,4-Bromofluorobenzene	102	57-129			1,2-Dichloroethane-d4	116	47-137		
Toluene-d8	99	78-156							

RL - Reporting Limit , DF - Dilution Factor , Qual - Qualifiers



Analytical Report



Environmental Resolutions, Inc.
601 North McDowell Blvd.
Petaluma, CA 94954-2312

Date Received: 06/13/09
Work Order No: 09-06-1301
Preparation: N/A
Method: EPA TO-3M

Project: ExxonMobil 70104

Page 1 of 1

Client Sample Number	Lab Sample Number	Date/Time Collected	Matrix	Instrument	Date Prepared	Date/Time Analyzed	QC Batch ID
A-EFF	09-06-1301-1-A	06/11/09 11:00	Air	GC 13	N/A	06/13/09 10:16	090613L01

Parameter	Result	RL	DF	Qual	Units
TPH as Gasoline	ND	5.7	1		mg/m3

A-INT2	09-06-1301-2-A	06/11/09 11:05	Air	GC 13	N/A	06/13/09 10:55	090613L01
--------	----------------	----------------	-----	-------	-----	----------------	-----------

Parameter	Result	RL	DF	Qual	Units
TPH as Gasoline	ND	5.7	1		mg/m3

A-INT1	09-06-1301-3-A	06/11/09 11:10	Air	GC 13	N/A	06/13/09 11:17	090613L01
--------	----------------	----------------	-----	-------	-----	----------------	-----------

Parameter	Result	RL	DF	Qual	Units
TPH as Gasoline	ND	5.7	1		mg/m3


A-INF	09-06-1301-4-A	06/11/09 11:15	Air	GC 13	N/A	06/13/09 11:26	090613L01
-------	----------------	----------------	-----	-------	-----	----------------	-----------

Parameter	Result	RL	DF	Qual	Units
TPH as Gasoline	ND	5.7	1		mg/m3

Method Blank	098-01-005-1,836	N/A	Air	GC 13	N/A	06/13/09 09:02	090613L01
--------------	------------------	-----	-----	-------	-----	----------------	-----------

Parameter	Result	RL	DF	Qual	Units
TPH as Gasoline	ND	5.7	1		mg/m3

RL - Reporting Limit , DF - Dilution Factor , Qual - Qualifiers



Analytical Report



Environmental Resolutions, Inc.
601 North McDowell Blvd.
Petaluma, CA 94954-2312

Date Received: 06/13/09
Work Order No: 09-06-1301
Preparation: N/A
Method: EPA TO-15M
Units: mg/m3

Project: ExxonMobil 70104

Page 1 of 2

Client Sample Number	Lab Sample Number	Date/Time Collected	Matrix	Instrument	Date Prepared	Date/Time Analyzed	QC Batch ID
A-EFF	09-06-1301-1-A	06/11/09 11:00	Air	GC/MS AA	N/A	06/13/09 17:24	090613L01

Comment(s): -The method has been modified to use Tedlar bags instead of Summa Canisters.

Parameter	Result	RL	DF	Qual	Parameter	Result	RL	DF	Qual
Benzene	ND	0.0016	1		Xylenes (total)	ND	0.0087	1	
Toluene	0.0022	0.0019	1		Methyl-t-Butyl Ether (MTBE)	0.72	0.036	5	
Ethylbenzene	ND	0.0022	1						
<u>Surrogates:</u>	<u>REC (%)</u>	<u>Control Limits</u>		<u>Qual</u>	<u>Surrogates:</u>	<u>REC (%)</u>	<u>Control Limits</u>		<u>Qual</u>
1,4-Bromofluorobenzene	101	57-129			1,2-Dichloroethane-d4	101	47-137		
Toluene-d8	100	78-156							

Client Sample Number	Lab Sample Number	Date/Time Collected	Matrix	Instrument	Date Prepared	Date/Time Analyzed	QC Batch ID
A-INT2	09-06-1301-2-A	06/11/09 11:05	Air	GC/MS AA	N/A	06/13/09 18:11	090613L01

Comment(s): -The method has been modified to use Tedlar bags instead of Summa Canisters.


Parameter	Result	RL	DF	Qual	Parameter	Result	RL	DF	Qual
Benzene	ND	0.0016	1		Xylenes (total)	ND	0.0087	1	
Toluene	0.0023	0.0019	1		Methyl-t-Butyl Ether (MTBE)	0.15	0.0072	1	
Ethylbenzene	ND	0.0022	1						
<u>Surrogates:</u>	<u>REC (%)</u>	<u>Control Limits</u>		<u>Qual</u>	<u>Surrogates:</u>	<u>REC (%)</u>	<u>Control Limits</u>		<u>Qual</u>
1,4-Bromofluorobenzene	101	57-129			1,2-Dichloroethane-d4	103	47-137		
Toluene-d8	100	78-156							

Client Sample Number	Lab Sample Number	Date/Time Collected	Matrix	Instrument	Date Prepared	Date/Time Analyzed	QC Batch ID
A-INT1	09-06-1301-3-A	06/11/09 11:10	Air	GC/MS AA	N/A	06/13/09 18:58	090613L01

Comment(s): -The method has been modified to use Tedlar bags instead of Summa Canisters.

Parameter	Result	RL	DF	Qual	Parameter	Result	RL	DF	Qual
Benzene	0.0025	0.0016	1		Xylenes (total)	ND	0.0087	1	
Toluene	0.0022	0.0019	1		Methyl-t-Butyl Ether (MTBE)	0.38	0.029	4	
Ethylbenzene	ND	0.0022	1						
<u>Surrogates:</u>	<u>REC (%)</u>	<u>Control Limits</u>		<u>Qual</u>	<u>Surrogates:</u>	<u>REC (%)</u>	<u>Control Limits</u>		<u>Qual</u>
1,4-Bromofluorobenzene	102	57-129			1,2-Dichloroethane-d4	103	47-137		
Toluene-d8	100	78-156							

RL - Reporting Limit , DF - Dilution Factor , Qual - Qualifiers



Analytical Report



Environmental Resolutions, Inc.
601 North McDowell Blvd.
Petaluma, CA 94954-2312

Date Received: 06/13/09
Work Order No: 09-06-1301
Preparation: N/A
Method: EPA TO-15M
Units: mg/m3

Project: ExxonMobil 70104

Page 2 of 2

Client Sample Number	Lab Sample Number	Date/Time Collected	Matrix	Instrument	Date Prepared	Date/Time Analyzed	QC Batch ID
A-INF	09-06-1301-4-A	06/11/09 11:15	Air	GC/MS AA	N/A	06/13/09 19:47	090613L01

Comment(s): -The method has been modified to use Tedlar bags instead of Summa Canisters.

Parameter	Result	RL	DF	Qual	Parameter	Result	RL	DF	Qual
Benzene	0.0022	0.0016	1		Xylenes (total)	ND	0.0087	1	
Toluene	0.0033	0.0019	1		Methyl-t-Butyl Ether (MTBE)	0.87	0.036	5	
Ethylbenzene	ND	0.0022	1						
Surrogates:	REC (%)	Control Limits		Qual	Surrogates:	REC (%)	Control Limits		Qual
1,4-Bromofluorobenzene	101	57-129			1,2-Dichloroethane-d4	103	47-137		
Toluene-d8	99	78-156							


Method Blank	097-09-002-8,658	N/A	Air	GC/MS AA	N/A	06/14/09 10:44	090614L01
--------------	------------------	-----	-----	----------	-----	-------------------	-----------

Parameter	Result	RL	DF	Qual	Parameter	Result	RL	DF	Qual
Benzene	ND	0.0016	1		Xylenes (total)	ND	0.0087	1	
Toluene	ND	0.0019	1		Methyl-t-Butyl Ether (MTBE)	ND	0.0072	1	
Ethylbenzene	ND	0.0022	1						
Surrogates:	REC (%)	Control Limits		Qual	Surrogates:	REC (%)	Control Limits		Qual
1,4-Bromofluorobenzene	101	57-129			1,2-Dichloroethane-d4	108	47-137		
Toluene-d8	99	78-156							

Method Blank	097-09-002-8,659	N/A	Air	GC/MS AA	N/A	06/13/09 12:41	090613L01
--------------	------------------	-----	-----	----------	-----	-------------------	-----------

Parameter	Result	RL	DF	Qual	Parameter	Result	RL	DF	Qual
Benzene	ND	0.0016	1		Xylenes (total)	ND	0.0087	1	
Toluene	ND	0.0019	1		Methyl-t-Butyl Ether (MTBE)	ND	0.0072	1	
Ethylbenzene	ND	0.0022	1						
Surrogates:	REC (%)	Control Limits		Qual	Surrogates:	REC (%)	Control Limits		Qual
1,4-Bromofluorobenzene	102	57-129			1,2-Dichloroethane-d4	116	47-137		
Toluene-d8	99	78-156							

RL - Reporting Limit , DF - Dilution Factor , Qual - Qualifiers



Quality Control - Duplicate



Environmental Resolutions, Inc.
601 North McDowell Blvd.
Petaluma, CA 94954-2312


Date Received: 06/13/09
Work Order No: 09-06-1301
Preparation: N/A
Method: EPA TO-3M

Project: ExxonMobil 70104

Quality Control Sample ID	Matrix	Instrument	Date Prepared:	Date Analyzed:	Duplicate Batch Number
09-06-1297-10	Air	GC 13	N/A	06/13/09	090613D01

Parameter	Sample Conc	DUP Conc	RPD	RPD CL	Qualifiers
TPH as Gasoline	17	16	4	0-20	

RPD - Relative Percent Difference , CL - Control Limit



Quality Control - Duplicate



Environmental Resolutions, Inc.
 601 North McDowell Blvd.
 Petaluma, CA 94954-2312


Date Received: 06/13/09
 Work Order No: 09-06-1301
 Preparation: N/A
 Method: EPA TO-3M

Project: ExxonMobil 70104

Quality Control Sample ID	Matrix	Instrument	Date Prepared:	Date Analyzed:	Duplicate Batch Number
09-06-1297-10	Air	GC 13	N/A	06/13/09	090613D01

<u>Parameter</u>	<u>Sample Conc</u>	<u>DUP Conc</u>	<u>RPD</u>	<u>RPD CL</u>	<u>Qualifiers</u>
TPH as Gasoline	64	61	4	0-20	

RPD - Relative Percent Difference , CL - Control Limit



Quality Control - LCS/LCS Duplicate



Environmental Resolutions, Inc.
601 North McDowell Blvd.
Petaluma, CA 94954-2312


Date Received: N/A
Work Order No: 09-06-1301
Preparation: N/A
Method: EPA TO-15M

Project: ExxonMobil 70104

Quality Control Sample ID	Matrix	Instrument	Date Prepared	Date Analyzed	LCS/LCSD Batch Number
097-09-002-8,659	Air	GC/MS AA	N/A	06/13/09	090613L01

Parameter	LCS %REC	LCSD %REC	%REC CL	RPD	RPD CL	Qualifiers
Benzene	98	102	60-156	4	0-40	
Toluene	100	104	56-146	4	0-43	
Ethylbenzene	106	112	52-154	5	0-38	
p/m-Xylene	102	106	42-156	4	0-41	
o-Xylene	107	112	52-148	4	0-38	

RPD - Relative Percent Difference, CL - Control Limit



Quality Control - LCS/LCS Duplicate



Environmental Resolutions, Inc.
601 North McDowell Blvd.
Petaluma, CA 94954-2312

Date Received: N/A
Work Order No: 09-06-1301
Preparation: N/A
Method: EPA TO-15M

Project: ExxonMobil 70104

Quality Control Sample ID	Matrix	Instrument	Date Prepared	Date Analyzed	LCS/LCSD Batch Number
097-09-002-8,658	Air	GC/MS AA	N/A	06/14/09	090614L01


Parameter	LCS %REC	LCSD %REC	%REC CL	RPD	RPD CL	Qualifiers
Benzene	105	103	60-156	2	0-40	
Toluene	108	105	56-146	3	0-43	
Ethylbenzene	116	111	52-154	4	0-38	
p/m-Xylene	110	105	42-156	4	0-41	
o-Xylene	116	112	52-148	4	0-38	

RPD - Relative Percent Difference , CL - Control Limit



Work Order Number: 09-06-1301

<u>Qualifier</u>	<u>Definition</u>
*	See applicable analysis comment.
1	Surrogate compound recovery was out of control due to a required sample dilution, therefore, the sample data was reported without further clarification.
2	Surrogate compound recovery was out of control due to matrix interference. The associated method blank surrogate spike compound was in control and, therefore, the sample data was reported without further clarification.
3	Recovery of the Matrix Spike (MS) or Matrix Spike Duplicate (MSD) compound was out of control due to matrix interference. The associated LCS and/or LCSD was in control and, therefore, the sample data was reported without further clarification.
4	The MS/MSD RPD was out of control due to matrix interference. The LCS/LCSD RPD was in control and, therefore, the sample data was reported without further clarification.
5	The PDS/PDSD associated with this batch of samples was out of control due to a matrix interference effect. The associated batch LCS/LCSD was in control and, hence, the associated sample data was reported with no further corrective action required.
A	Result is the average of all dilutions, as defined by the method.
B	Analyte was present in the associated method blank.
C	Analyte presence was not confirmed on primary column.
E	Concentration exceeds the calibration range.
I	Compound did not meet method-described identification guidelines. Identification was based on additional GC/MS characteristics.
J	Analyte was detected at a concentration below the reporting limit and above the laboratory method detection limit. Reported value is estimated.
ND	Parameter not detected at the indicated reporting limit.
Q	Spike recovery and RPD control limits do not apply resulting from the parameter concentration in the sample exceeding the spike concentration by a factor of four or greater.
X	% Recovery and/or RPD out-of-range.
Z	Analyte presence was not confirmed by second column or GC/MS analysis. Solid - Unless otherwise indicated, solid sample data is reported on a wet weight basis, not corrected for % moisture.



WORK ORDER #: 09-06-1301

SAMPLE RECEIPT FORM

Box 1 of 1
Cooler

CLIENT: ERI

DATE: 06/13/09

TEMPERATURE: (Criteria: 0.0°C – 6.0°C, not frozen)

Temperature _____ °C - 0.2°C (CF) = _____ °C Blank Sample

Sample(s) outside temperature criteria (PM/APM contacted by: _____).

Sample(s) outside temperature criteria but received on ice/chilled on same day of sampling.

Received at ambient temperature, placed on ice for transport by Courier.

Ambient Temperature: Air Filter Metals Only PCBs Only Initial: YL

CUSTODY SEALS INTACT:

Cooler _____ No (Not Intact) Not Present N/A Initial: YL

Sample _____ No (Not Intact) Not Present Initial: YL

SAMPLE CONDITION:	Yes	No	N/A
Chain-Of-Custody (COC) document(s) received with samples.....	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
COC document(s) received complete.....	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
<input type="checkbox"/> Collection date/time, matrix, and/or # of containers logged in based on sample labels.			
<input type="checkbox"/> COC not relinquished. <input type="checkbox"/> No date relinquished. <input type="checkbox"/> No time relinquished.			
Sampler's name indicated on COC.....	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Sample container label(s) consistent with COC.....	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Sample container(s) intact and good condition.....	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Correct containers and volume for analyses requested.....	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Analyses received within holding time.....	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Proper preservation noted on COC or sample container.....	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
<input type="checkbox"/> Unpreserved vials received for Volatiles analysis			
Volatile analysis container(s) free of headspace.....	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Tedlar bag(s) free of condensation.....	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

CONTAINER TYPE:

Solid: 4ozCGJ 8ozCGJ 16ozCGJ Sleeve EnCores® TerraCores® _____

Water: VOA VOA_h VOA_{na2} 125AGB 125AGB_h 125AGB_p 1AGB 1AGB_{na2} 1AGB_s


500AGB 500AGJ 500AGJ_s 250AGB 250CGB 250CGB_s 1PB 500PB 500PB_{na}

250PB 250PB_n 125PB 125PB_{z_{na}} 100PB 100PB_{na2} _____ _____ _____

Air: Tedlar® Summa® _____ **Other:** _____ **Checked/Labeled by:** YL

Container: C: Clear A: Amber P: Plastic G: Glass J: Jar (Wide-mouth) B: Bottle (Narrow-mouth) **Reviewed by:** W-SC

Preservative: h: HCL n: HNO3 na₂:Na₂S₂O₃ Na: NaOH p: H₃PO₄ s: H₂SO₄ z_{na}: ZnAc₂+NaOH f: Field-filtered **Scanned by:** YL



April 17, 2009

Paula Sime
Environmental Resolutions, Inc.
601 North McDowell Blvd.
Petaluma, CA 94954-2312

RECEIVED
APR 20 2009

BY:.....

Subject: **Calscience Work Order No.: 09-04-0753**
Client Reference: ExxonMobil 70104

Dear Client:

Enclosed is an analytical report for the above-referenced project. The samples included in this report were received 4/9/2009 and analyzed in accordance with the attached chain-of-custody.


Unless otherwise noted, all analytical testing was accomplished in accordance with the guidelines established in our Quality Systems Manual, applicable standard operating procedures, and other related documentation. The original report of subcontracted analysis, if any, is provided herein, and follows the standard Calscience data package. The results in this analytical report are limited to the samples tested and any reproduction thereof must be made in its entirety.

Note that the Chain-of-Custody Record and Sample Receipt Form are integral parts of this report.

If you have any questions regarding this report, please do not hesitate to contact the undersigned.

Sincerely,

Calscience Environmental
Laboratories, Inc.
Cecile deGuia
Project Manager





Analytical Report



Environmental Resolutions, Inc.
601 North McDowell Blvd.
Petaluma, CA 94954-2312

Date Received: 04/09/09
Work Order No: 09-04-0753
Preparation: EPA 5030B
Method: EPA 8015B (M)

Project: ExxonMobil 70104

Page 1 of 2

Client Sample Number	Lab Sample Number	Date/Time Collected	Matrix	Instrument	Date Prepared	Date/Time Analyzed	QC Batch ID
W-PSP-1	09-04-0753-1-C	04/07/09 14:00	Aqueous	GC 1	04/10/09	04/10/09 19:49	090410B03

Parameter	Result	RL	DF	Qual	Units
TPH as Gasoline	ND	50	1		ug/L

Surrogates: REC (%) Control Limits Qual

1,4-Bromofluorobenzene 90 38-134

W-INT2	09-04-0753-2-C	04/07/09 14:15	Aqueous	GC 1	04/10/09	04/10/09 20:21	090410B03
--------	----------------	-------------------	---------	------	----------	-------------------	-----------

Parameter	Result	RL	DF	Qual	Units
TPH as Gasoline	ND	50	1		ug/L

Surrogates: REC (%) Control Limits Qual

1,4-Bromofluorobenzene 90 38-134

W-INT1	09-04-0753-3-C	04/07/09 14:36	Aqueous	GC 1	04/10/09	04/10/09 20:53	090410B03
--------	----------------	-------------------	---------	------	----------	-------------------	-----------

Parameter	Result	RL	DF	Qual	Units
TPH as Gasoline	ND	50	1		ug/L

Surrogates: REC (%) Control Limits Qual

1,4-Bromofluorobenzene 89 38-134


W-INF	09-04-0753-4-C	04/07/09 14:45	Aqueous	GC 1	04/10/09	04/10/09 21:25	090410B03
-------	----------------	-------------------	---------	------	----------	-------------------	-----------

Parameter	Result	RL	DF	Qual	Units
TPH as Gasoline	360	50	1		ug/L

Surrogates: REC (%) Control Limits Qual

1,4-Bromofluorobenzene 91 38-134

RL - Reporting Limit , DF - Dilution Factor , Qual - Qualifiers



Analytical Report



Environmental Resolutions, Inc.
601 North McDowell Blvd.
Petaluma, CA 94954-2312

Date Received: 04/09/09
Work Order No: 09-04-0753
Preparation: EPA 5030B
Method: EPA 8015B (M)


Project: ExxonMobil 70104

Page 2 of 2

Client Sample Number	Lab Sample Number	Date/Time Collected	Matrix	Instrument	Date Prepared	Date/Time Analyzed	QC Batch ID
Method Blank	099-12-436-3,108	N/A	Aqueous	GC 1	04/10/09	04/10/09 19:18	090410B03

Parameter	Result	RL	DF	Qual	Units
TPH as Gasoline	ND	50	1		ug/L
<u>Surrogates:</u>	<u>REC (%)</u>	<u>Control Limits</u>		<u>Qual</u>	
1,4-Bromofluorobenzene	90	38-134			

RL - Reporting Limit , DF - Dilution Factor , Qual - Qualifiers



Analytical Report



Environmental Resolutions, Inc.
601 North McDowell Blvd.
Petaluma, CA 94954-2312

Date Received: 04/09/09
Work Order No: 09-04-0753
Preparation: EPA 5030B
Method: EPA 8021B
Units: ug/L

Project: ExxonMobil 70104

Page 1 of 2

Client Sample Number	Lab Sample Number	Date/Time Collected	Matrix	Instrument	Date Prepared	Date/Time Analyzed	QC Batch ID
W-PSP-1	09-04-0753-1-C	04/07/09 14:00	Aqueous	GC 8	04/10/09	04/10/09 12:35	090410B01

Parameter	Result	RL	DF	Qual	Parameter	Result	RL	DF	Qual
Benzene	ND	0.50	1		Xylenes (total)	ND	1.0	1	
Toluene	ND	0.50	1		Methyl-t-Butyl Ether (MTBE)	ND	5.0	1	
Ethylbenzene	ND	0.50	1						
Surrogates:	REC (%)	Control Limits		Qual					
1,4-Bromofluorobenzene	108	70-130							

Client Sample Number	Lab Sample Number	Date/Time Collected	Matrix	Instrument	Date Prepared	Date/Time Analyzed	QC Batch ID
W-INT2	09-04-0753-2-C	04/07/09 14:15	Aqueous	GC 8	04/10/09	04/10/09 14:16	090410B01

Parameter	Result	RL	DF	Qual	Parameter	Result	RL	DF	Qual
Benzene	ND	0.50	1		Xylenes (total)	ND	1.0	1	
Toluene	ND	0.50	1		Methyl-t-Butyl Ether (MTBE)	ND	5.0	1	
Ethylbenzene	ND	0.50	1						
Surrogates:	REC (%)	Control Limits		Qual					
1,4-Bromofluorobenzene	104	70-130							


Client Sample Number	Lab Sample Number	Date/Time Collected	Matrix	Instrument	Date Prepared	Date/Time Analyzed	QC Batch ID
W-INT1	09-04-0753-3-C	04/07/09 14:36	Aqueous	GC 8	04/10/09	04/10/09 14:50	090410B01

Parameter	Result	RL	DF	Qual	Parameter	Result	RL	DF	Qual
Benzene	ND	0.50	1		Xylenes (total)	ND	1.0	1	
Toluene	ND	0.50	1		Methyl-t-Butyl Ether (MTBE)	ND	5.0	1	
Ethylbenzene	ND	0.50	1						
Surrogates:	REC (%)	Control Limits		Qual					
1,4-Bromofluorobenzene	105	70-130							

Client Sample Number	Lab Sample Number	Date/Time Collected	Matrix	Instrument	Date Prepared	Date/Time Analyzed	QC Batch ID
W-INF	09-04-0753-4-C	04/07/09 14:45	Aqueous	GC 8	04/10/09	04/10/09 15:24	090410B01

Parameter	Result	RL	DF	Qual	Parameter	Result	RL	DF	Qual
Benzene	ND	0.50	1		Xylenes (total)	ND	1.0	1	
Toluene	ND	0.50	1		Methyl-t-Butyl Ether (MTBE)	490	5.0	1	
Ethylbenzene	ND	0.50	1						
Surrogates:	REC (%)	Control Limits		Qual					
1,4-Bromofluorobenzene	112	70-130							

RL - Reporting Limit , DF - Dilution Factor , Qual - Qualifiers



Analytical Report



Environmental Resolutions, Inc.
601 North McDowell Blvd.
Petaluma, CA 94954-2312

Date Received: 04/09/09
Work Order No: 09-04-0753
Preparation: EPA 5030B
Method: EPA 8021B
Units: ug/L


Project: ExxonMobil 70104

Page 2 of 2

Client Sample Number	Lab Sample Number	Date/Time Collected	Matrix	Instrument	Date Prepared	Date/Time Analyzed	QC Batch ID
Method Blank	099-12-667-409	N/A	Aqueous	GC 8	04/10/09	04/10/09 12:01	090410B01

Parameter	Result	RL	DF	Qual	Parameter	Result	RL	DF	Qual
Benzene	ND	0.50	1		Xylenes (total)	ND	1.0	1	
Toluene	ND	0.50	1		Methyl-t-Butyl Ether (MTBE)	ND	5.0	1	
Ethylbenzene	ND	0.50	1						
Surrogates:	REC (%)	Control Limits		Qual					
1,4-Bromofluorobenzene	117	70-130							

RL - Reporting Limit , DF - Dilution Factor , Qual - Qualifiers



Quality Control - Spike/Spike Duplicate



Environmental Resolutions, Inc.
601 North McDowell Blvd.
Petaluma, CA 94954-2312


Date Received: 04/09/09
Work Order No: 09-04-0753
Preparation: EPA 5030B
Method: EPA 8015B (M)

Project ExxonMobil 70104

Quality Control Sample ID	Matrix	Instrument	Date Prepared	Date Analyzed	MS/MSD Batch Number
W-INF	Aqueous	GC 1	04/10/09	04/10/09	090410S02

<u>Parameter</u>	<u>MS %REC</u>	<u>MSD %REC</u>	<u>%REC CL</u>	<u>RPD</u>	<u>RPD CL</u>	<u>Qualifiers</u>
TPH as Gasoline	89	87	68-122	3	0-18	

RPD - Relative Percent Difference , CL - Control Limit



Quality Control - Spike/Spike Duplicate



Environmental Resolutions, Inc.
601 North McDowell Blvd.
Petaluma, CA 94954-2312


Date Received: 04/09/09
Work Order No: 09-04-0753
Preparation: EPA 5030B
Method: EPA 8021B

Project ExxonMobil 70104

Quality Control Sample ID	Matrix	Instrument	Date Prepared	Date Analyzed	MS/MSD Batch Number
W-PSP-1	Aqueous	GC 8	04/10/09	04/10/09	090410S01

<u>Parameter</u>	<u>MS %REC</u>	<u>MSD %REC</u>	<u>%REC CL</u>	<u>RPD</u>	<u>RPD CL</u>	<u>Qualifiers</u>
Benzene	114	110	57-129	3	0-23	
Toluene	108	104	50-134	4	0-26	
Ethylbenzene	114	112	58-130	1	0-26	
p/m-Xylene	118	116	58-130	1	0-28	
o-Xylene	110	109	57-123	1	0-26	
Methyl-t-Butyl Ether (MTBE)	116	113	44-134	3	0-27	

RPD - Relative Percent Difference , CL - Control Limit



Quality Control - LCS/LCS Duplicate




Environmental Resolutions, Inc. 601 North McDowell Blvd. Petaluma, CA 94954-2312	Date Received: N/A Work Order No: 09-04-0753 Preparation: EPA 5030B Method: EPA 8015B (M)
--	--

Project: ExxonMobil 70104

Quality Control Sample ID	Matrix	Instrument	Date Prepared	Date Analyzed	LCS/LCSD Batch Number
099-12-436-3,108	Aqueous	GC 1	04/10/09	04/10/09	090410B03

<u>Parameter</u>	<u>LCS %REC</u>	<u>LCSD %REC</u>	<u>%REC CL</u>	<u>RPD</u>	<u>RPD CL</u>	<u>Qualifiers</u>
TPH as Gasoline	101	103	78-120	2	0-10	

RPD - Relative Percent Difference , CL - Control Limit



Quality Control - LCS/LCS Duplicate



Environmental Resolutions, Inc.
601 North McDowell Blvd.
Petaluma, CA 94954-2312

Date Received: N/A
Work Order No: 09-04-0753
Preparation: EPA 5030B
Method: EPA 8021B

Project: ExxonMobil 70104

Quality Control Sample ID	Matrix	Instrument	Date Prepared	Date Analyzed	LCS/LCSD Batch Number
099-12-667-409	Aqueous	GC 8	04/10/09	04/10/09	090410B01

Parameter	LCS %REC	LCSD %REC	%REC CL	RPD	RPD CL	Qualifiers
Benzene	111	110	70-118	1	0-9	
Toluene	102	102	66-114	0	0-9	
Ethylbenzene	112	113	72-114	1	0-9	
p/m-Xylene	117	118	74-116	1	0-9	X
o-Xylene	109	110	72-114	1	0-9	
Methyl-t-Butyl Ether (MTBE)	115	114	41-137	1	0-13	

Note "X" : The percent recovery is above acceptable control limits. The samples and method blank associated with this batch are non-detect, and therefore, the results have been reported without further clarification.


RPD - Relative Percent Difference , CL - Control Limit

Work Order Number: 09-04-0753

<u>Qualifier</u>	<u>Definition</u>
*	See applicable analysis comment.
1	Surrogate compound recovery was out of control due to a required sample dilution, therefore, the sample data was reported without further clarification.
2	Surrogate compound recovery was out of control due to matrix interference. The associated method blank surrogate spike compound was in control and, therefore, the sample data was reported without further clarification.
3	Recovery of the Matrix Spike (MS) or Matrix Spike Duplicate (MSD) compound was out of control due to matrix interference. The associated LCS and/or LCSD was in control and, therefore, the sample data was reported without further clarification.
4	The MS/MSD RPD was out of control due to matrix interference. The LCS/LCSD RPD was in control and, therefore, the sample data was reported without further clarification.
5	The PDS/PDSD associated with this batch of samples was out of control due to a matrix interference effect. The associated batch LCS/LCSD was in control and, hence, the associated sample data was reported with no further corrective action required.
A	Result is the average of all dilutions, as defined by the method.
B	Analyte was present in the associated method blank.
C	Analyte presence was not confirmed on primary column.
E	Concentration exceeds the calibration range.
I	Compound did not meet method-described identification guidelines. Identification was based on additional GC/MS characteristics.
J	Analyte was detected at a concentration below the reporting limit and above the laboratory method detection limit. Reported value is estimated.
ND	Parameter not detected at the indicated reporting limit.
Q	Spike recovery and RPD control limits do not apply resulting from the parameter concentration in the sample exceeding the spike concentration by a factor of four or greater.
X	% Recovery and/or RPD out-of-range.
Z	Analyte presence was not confirmed by second column or GC/MS analysis.

CHAIN OF CUSTODY RECORD


0753

 <p>7440 LINCOLN WAY GARDEN GROVE, CA 92841 TEL: (714) 895-5494 FAX: (714) 894-7501 ExxonMobil</p>	<p>Consultant Name: <u>Environmental Resolutions, Inc.</u> Address: <u>610 North McDowell</u> City/State/Zip: <u>Petaluma, CA 94954</u> Project Manager: <u>Paula Sime</u> Telephone Number: <u>707-766-2000</u> ERI Job Number: <u>2506 11X (April)</u> Sampler Name: (Print) <u>J. Herman</u> Sampler Signature: <u>J. Herman</u></p>	<p>ExxonMobil Engineer: <u>Jennifer Sedlachek</u> Telephone Number: <u>510-547-8196</u> Account #: <u>10228</u> PO #: <u>4508883534</u> Facility ID #: <u>7-0104</u> Global ID#: _____ Site Address: <u>1725 Park Street</u> City, State Zip: <u>Alameda, California</u></p>
--	---	--

TAT	PROVIDE:	Special Instructions:	Matrix			Analyze For:												
			Water	Soil	Vapor	TPHg 8015B	BTEX 8021B	MTBE 8020										
<input type="checkbox"/> 24 hour <input type="checkbox"/> 72 hour <input type="checkbox"/> 48 hour <input type="checkbox"/> 96 hour <input checked="" type="checkbox"/> 8 day	EDF Report																	
Sample ID / Description	DATE	TIME	COMP	GRAB	PRESERV	NUMBER	Water	Soil	Vapor	TPHg 8015B	BTEX 8021B	MTBE 8020						
1 W-PSP-1	4/7/09	1400		X	HCl	4 voa	X			X	X	X						
2 W-INT 2	↓	1445		X	HCl	4 voa	X			X	X	X						
3 W-INT 1	↓	1436		X	HCl	4 voa	X			X	X	X						
4 W-INF	↓	1445		X	HCl	4 voa	X			X	X	X						

Relinquished by: <u>J. Herman</u> Date: <u>4/8/09</u> Time: <u>900</u>	Received by: <u>T. O'Malley CEC</u> Date: <u>4/8/09</u> Time: <u>1435</u>	Laboratory Comments: Temperature Upon Receipt: Sample Containers Intact? VOAs Free of Headspace?
Relinquished by: <u>T. O'Malley TO</u> Date: <u>4/8/09</u> Time: <u>1730</u>	Received by: <u>CalciScience</u> Date: <u>040909</u> Time: <u>1030</u>	

5116 24940



WORK ORDER #: 09-04-0753

SAMPLE RECEIPT FORM

Cooler 1 of 1

CLIENT: ERI

DATE: 04/09/09

TEMPERATURE: (Criteria: 0.0°C - 6.0°C, not frozen)

Temperature 2.6°C - 0.2°C (CF) = 2.4°C [X] Blank [] Sample

- [] Sample(s) outside temperature criteria (PM/APM contacted by: _____).
[] Sample(s) outside temperature criteria but received on ice/chilled on same day of sampling.

[] Received at ambient temperature, placed on ice for transport by Courier.

Ambient Temperature: [] Air [] Filter [] Metals Only [] PCBs Only

Initial: NC

CUSTODY SEALS INTACT:

- [] Cooler [] _____ [] No (Not Intact) [X] Not Present [] N/A
[] Sample [] _____ [] No (Not Intact) [X] Not Present

Initial: NC

Initial: BF

SAMPLE CONDITION:

Table with 4 columns: Item, Yes, No, N/A. Rows include Chain-Of-Custody (COC) document(s) received with samples, COC document(s) received complete, Collection date/time, matrix, and/or # of containers logged in based on sample labels, COC not relinquished, No date relinquished, No time relinquished, Sampler's name indicated on COC, Sample container label(s) consistent with COC, Sample container(s) intact and good condition, Correct containers and volume for analyses requested, Analyses received within holding time, Proper preservation noted on COC or sample container, Unpreserved vials received for Volatiles analysis, Volatile analysis container(s) free of headspace, Tedlar bag(s) free of condensation.


CONTAINER TYPE:

- Solid: [] 4ozCGJ [] 8ozCGJ [] 16ozCGJ [] Sleeve [] EnCores® [] TerraCores® [] _____
Water: [] VOA [X] VOAh [] VOAna2 [] 125AGB [] 125AGBh [] 125AGBp [] 1AGB [] 1AGBna2 [] 1AGBs
[] 500AGB [] 500AGJ [] 500AGJs [] 250AGB [] 250CGB [] 250CGBs [] 1PB [] 500PB [] 500PBna
[] 250PB [] 250PBn [] 125PB [] 125PBzanna [] 100PBsterile [] 100PBna2 [] _____ [] _____ [] _____

Air: [] Tedlar® [] Summa® [] _____ Sludge/Other: [] _____ Checked/Labeled by: BF

Container: C: Clear A: Amber P: Plastic G: Glass J: Jar (Wide-mouth) B: Bottle (Narrow-mouth) Reviewed by: D.L

Preservative: h: HCL n: HNO3 na2:Na2S2O3 Na: NaOH p: H3PO4 s: H2SO4 znna: ZnAc2+NaOH Scanned by: BF



May 29, 2009

Paula Sime
Environmental Resolutions, Inc.
601 North McDowell Blvd.
Petaluma, CA 94954-2312

RECEIVED
JUN 01 2009

BY:.....

Subject: **Calscience Work Order No.: 09-05-1546**
Client Reference: **ExxonMobil 70104**

Dear Client:

Enclosed is an analytical report for the above-referenced project. The samples included in this report were received 5/16/2009 and analyzed in accordance with the attached chain-of-custody.


Unless otherwise noted, all analytical testing was accomplished in accordance with the guidelines established in our Quality Systems Manual, applicable standard operating procedures, and other related documentation. The original report of subcontracted analysis, if any, is provided herein, and follows the standard Calscience data package. The results in this analytical report are limited to the samples tested and any reproduction thereof must be made in its entirety.


Note that the Chain-of-Custody Record and Sample Receipt Form are integral parts of this report.

If you have any questions regarding this report, please do not hesitate to contact the undersigned.

Sincerely,

Calscience Environmental
Laboratories, Inc.
Cecile deGuia
Project Manager





Analytical Report



Environmental Resolutions, Inc.
601 North McDowell Blvd.
Petaluma, CA 94954-2312

Date Received: 05/16/09
Work Order No: 09-05-1546
Preparation: EPA 5030B
Method: EPA 8015B (M)

Project: ExxonMobil 70104

Page 1 of 2

Client Sample Number	Lab Sample Number	Date/Time Collected	Matrix	Instrument	Date Prepared	Date/Time Analyzed	QC Batch ID
W-PSP-1	09-05-1546-1-D	05/15/09 14:00	Aqueous	GC 29	05/26/09	05/27/09 19:16	090526B02

Parameter	Result	RL	DF	Qual	Units
TPH as Gasoline	ND	50	1		ug/L
<u>Surrogates:</u>	<u>REC (%)</u>	<u>Control Limits</u>		<u>Qual</u>	
1,4-Bromofluorobenzene	81	38-134			

Client Sample Number	Lab Sample Number	Date/Time Collected	Matrix	Instrument	Date Prepared	Date/Time Analyzed	QC Batch ID
W-INT2	09-05-1546-2-D	05/15/09 14:15	Aqueous	GC 29	05/26/09	05/27/09 19:49	090526B02

Parameter	Result	RL	DF	Qual	Units
TPH as Gasoline	ND	50	1		ug/L
<u>Surrogates:</u>	<u>REC (%)</u>	<u>Control Limits</u>		<u>Qual</u>	
1,4-Bromofluorobenzene	81	38-134			

Client Sample Number	Lab Sample Number	Date/Time Collected	Matrix	Instrument	Date Prepared	Date/Time Analyzed	QC Batch ID
W-INT1	09-05-1546-3-D	05/15/09 14:30	Aqueous	GC 29	05/26/09	05/27/09 20:22	090526B02

Parameter	Result	RL	DF	Qual	Units
TPH as Gasoline	ND	50	1		ug/L
<u>Surrogates:</u>	<u>REC (%)</u>	<u>Control Limits</u>		<u>Qual</u>	
1,4-Bromofluorobenzene	83	38-134			

Client Sample Number	Lab Sample Number	Date/Time Collected	Matrix	Instrument	Date Prepared	Date/Time Analyzed	QC Batch ID
W-INF	09-05-1546-4-D	05/15/09 14:45	Aqueous	GC 29	05/26/09	05/27/09 20:56	090526B02

Parameter	Result	RL	DF	Qual	Units
TPH as Gasoline	360	50	1		ug/L
<u>Surrogates:</u>	<u>REC (%)</u>	<u>Control Limits</u>		<u>Qual</u>	
1,4-Bromofluorobenzene	82	38-134			

RL - Reporting Limit DF - Dilution Factor Qual - Qualifiers



Analytical Report



Environmental Resolutions, Inc.
601 North McDowell Blvd.
Petaluma, CA 94954-2312

Date Received: 05/16/09
Work Order No: 09-05-1546
Preparation: EPA 5030B
Method: EPA 8015B (M)

Project: ExxonMobil 70104

Page 2 of 2

Client Sample Number	Lab Sample Number	Date/Time Collected	Matrix	Instrument	Date Prepared	Date/Time Analyzed	QC Batch ID
Method Blank	098-12-436-3,303	N/A	Aqueous	GC 29	05/26/09	05/27/09 12:10	090526B02

<u>Parameter</u>	<u>Result</u>	<u>RL</u>	<u>DF</u>	<u>Qual</u>	<u>Units</u>
TPH as Gasoline	ND	50	1		ug/L
<u>Surrogates:</u>	<u>REC (%)</u>	<u>Control Limits</u>		<u>Qual</u>	
1,4-Bromofluorobenzene	77	38-134			

RL - Reporting Limit , DF - Dilution Factor , Qual - Qualifiers

Analytical Report



Environmental Resolutions, Inc.
 601 North McDowell Blvd.
 Petaluma, CA 94954-2312


Date Received: 05/16/09
 Work Order No: 09-05-1546
 Preparation: EPA 5030B
 Method: EPA 8021B
 Units: ug/L

Project: ExxonMobil 70104

Page 1 of 2

Client Sample Number	Lab Sample Number	Date/Time Collected	Matrix	Instrument	Date Prepared	Date/Time Analyzed	QC Batch ID		
W-PSP-1	09-05-1546-1-C	05/15/09 14:00	Aqueous	GC 8	05/19/09	05/19/09 18:29	090519B01		
<u>Parameter</u>	<u>Result</u>	<u>RL</u>	<u>DF</u>	<u>Qual</u>	<u>Parameter</u>	<u>Result</u>	<u>RL</u>	<u>DF</u>	<u>Qual</u>
Benzene	ND	0.50	1		Xylenes (total)	ND	1.0	1	
Toluene	ND	0.50	1		Methyl-t-Butyl Ether (MTBE)	ND	5.0	1	
Ethylbenzene	ND	0.50	1						
<u>Surrogates:</u>	<u>REC (%)</u>	<u>Control Limits</u>		<u>Qual</u>					
1,4-Bromofluorobenzene	107	70-130							
W-INT2	09-05-1546-2-C	05/15/09 14:15	Aqueous	GC 8	05/19/09	05/19/09 19:03	090519B01		
<u>Parameter</u>	<u>Result</u>	<u>RL</u>	<u>DF</u>	<u>Qual</u>	<u>Parameter</u>	<u>Result</u>	<u>RL</u>	<u>DF</u>	<u>Qual</u>
Benzene	ND	0.50	1		Xylenes (total)	ND	1.0	1	
Toluene	ND	0.50	1		Methyl-t-Butyl Ether (MTBE)	ND	5.0	1	
Ethylbenzene	ND	0.50	1						
<u>Surrogates:</u>	<u>REC (%)</u>	<u>Control Limits</u>		<u>Qual</u>					
1,4-Bromofluorobenzene	101	70-130							
W-INT1	09-05-1546-3-C	05/15/09 14:30	Aqueous	GC 8	05/19/09	05/19/09 20:45	090519B01		
<u>Parameter</u>	<u>Result</u>	<u>RL</u>	<u>DF</u>	<u>Qual</u>	<u>Parameter</u>	<u>Result</u>	<u>RL</u>	<u>DF</u>	<u>Qual</u>
Benzene	ND	0.50	1		Xylenes (total)	ND	1.0	1	
Toluene	ND	0.50	1		Methyl-t-Butyl Ether (MTBE)	ND	5.0	1	
Ethylbenzene	ND	0.50	1						
<u>Surrogates:</u>	<u>REC (%)</u>	<u>Control Limits</u>		<u>Qual</u>					
1,4-Bromofluorobenzene	96	70-130							
W-INF	09-05-1546-4-C	05/15/09 14:45	Aqueous	GC 8	05/19/09	05/19/09 21:19	090519B01		
<u>Parameter</u>	<u>Result</u>	<u>RL</u>	<u>DF</u>	<u>Qual</u>	<u>Parameter</u>	<u>Result</u>	<u>RL</u>	<u>DF</u>	<u>Qual</u>
Benzene	ND	0.50	1		Xylenes (total)	ND	1.0	1	
Toluene	ND	0.50	1		Methyl-t-Butyl Ether (MTBE)	470	5.0	1	
Ethylbenzene	ND	0.50	1						
<u>Surrogates:</u>	<u>REC (%)</u>	<u>Control Limits</u>		<u>Qual</u>					
1,4-Bromofluorobenzene	103	70-130							

RL - Reporting Limit , DF - Dilution Factor , Qual - Qualifiers



Analytical Report



Environmental Resolutions, Inc.
 601 North McDowell Blvd.
 Petaluma, CA 94954-2312

Date Received: 05/16/09
 Work Order No: 09-05-1546
 Preparation: EPA 5030B
 Method: EPA 8021B
 Units: ug/L


Project: ExxonMobil 70104

Page 2 of 2

Client Sample Number	Lab Sample Number	Date/Time Collected	Matrix	Instrument	Date Prepared	Date/Time Analyzed	QC Batch ID
Method Blank	099-12-667-446	N/A	Aqueous	GC 8	05/19/09	05/19/09 15:38	090519B01

Parameter	Result	RL	DF	Qual	Parameter	Result	RL	DF	Qual
Benzene	ND	0.50	1		Xylenes (total)	ND	1.0	1	
Toluene	ND	0.50	1		Methyl-t-Butyl Ether (MTBE)	ND	5.0	1	
Ethylbenzene	ND	0.50	1						
Surrogates:	REC (%)	Control Limits		Qual					
1,4-Bromofluorobenzene	119	70-130							

RL - Reporting Limit DF - Dilution Factor Qual - Qualifiers



Quality Control - Spike/Spike Duplicate




Environmental Resolutions, Inc. 601 North McDowell Blvd. Petaluma, CA 94954-2312	Date Received: 05/16/09 Work Order No: 09-05-1546 Preparation: EPA 5030B Method: EPA 8015B (M)
--	---

Project ExxonMobil 70104

Quality Control Sample ID	Matrix	Instrument	Date Prepared	Date Analyzed	MS/MSD Batch Number
09-05-2009-1	Aqueous	GC 29	05/26/09	05/26/09	090526S01

Parameter	MS %REC	MSD %REC	%REC CL	RPD	RPD CL	Qualifiers
TPH as Gasoline	86	86	68-122	0	0-18	

RPD - Relative Percent Difference, CL - Control Limit



Quality Control - Spike/Spike Duplicate



Environmental Resolutions, Inc.
601 North McDowell Blvd.
Petaluma, CA 94954-2312


Date Received: 05/16/09
Work Order No: 09-05-1546
Preparation: EPA 5030B
Method: EPA 8021B

Project ExxonMobil 70104

Quality Control Sample ID	Matrix	Instrument	Date Prepared	Date Analyzed	MS/MSD Batch Number
W-INT2	Aqueous	GC 8	05/19/09	05/19/09	090519S01

Parameter	MS %REC	MSD %REC	%REC CL	RPD	RPD CL	Qualifiers
Benzene	118	104	57-129	12	0-23	
Toluene	104	91	50-134	13	0-26	
Ethylbenzene	95	91	58-130	5	0-26	
p/m-Xylene	101	94	58-130	8	0-28	
o-Xylene	93	86	57-123	8	0-26	
Methyl-t-Butyl Ether (MTBE)	120	93	44-134	25	0-27	

RPD - Relative Percent Difference , CL - Control Limit



Quality Control - LCS/LCS Duplicate



Environmental Resolutions, Inc.
601 North McDowell Blvd.
Petaluma, CA 94954-2312


Date Received: N/A
Work Order No: 09-05-1546
Preparation: EPA 5030B
Method: EPA 8015B (M)

Project: ExxonMobil 70104

Quality Control Sample ID	Matrix	Instrument	Date Prepared	Date Analyzed	LCS/LCSD Batch Number
099-12-436-3,303	Aqueous	GC 29	05/26/09	05/27/09	090526B02

<u>Parameter</u>	<u>LCS %REC</u>	<u>LCSD %REC</u>	<u>%REC CL</u>	<u>RPD</u>	<u>RPD CL</u>	<u>Qualifiers</u>
TPH as Gasoline	88	89	78-120	1	0-10	

RPD - Relative Percent Difference , CL - Control Limit



Quality Control - LCS/LCS Duplicate



Environmental Resolutions, Inc.
601 North McDowell Blvd.
Petaluma, CA 94954-2312

Date Received: N/A
Work Order No: 09-05-1546
Preparation: EPA 5030B
Method: EPA 8021B

Project: ExxonMobil 70104

Quality Control Sample ID	Matrix	Instrument	Date Prepared	Date Analyzed	LCS/LCSD Batch Number
099-12-667-446	Aqueous	GC 8	05/19/09	05/19/09	090519B01

Parameter	LCS %REC	LCSD %REC	%REC CL	RPD	RPD CL	Qualifiers
Benzene	115	115	70-118	0	0-9	
Toluene	104	103	66-114	1	0-9	
Ethylbenzene	96	95	72-114	0	0-9	
p/m-Xylene	100	100	74-116	0	0-9	
o-Xylene	93	92	72-114	1	0-9	
Methyl-t-Butyl Ether (MTBE)	125	122	41-137	3	0-13	

RPD - Relative Percent Difference , CL - Control Limit




Work Order Number: 09-05-1546

<u>Qualifier</u>	<u>Definition</u>
*	See applicable analysis comment.
1	Surrogate compound recovery was out of control due to a required sample dilution, therefore, the sample data was reported without further clarification.
2	Surrogate compound recovery was out of control due to matrix interference. The associated method blank surrogate spike compound was in control and, therefore, the sample data was reported without further clarification.
3	Recovery of the Matrix Spike (MS) or Matrix Spike Duplicate (MSD) compound was out of control due to matrix interference. The associated LCS and/or LCSD was in control and, therefore, the sample data was reported without further clarification.
4	The MS/MSD RPD was out of control due to matrix interference. The LCS/LCSD RPD was in control and, therefore, the sample data was reported without further clarification.
5	The PDS/PDSD associated with this batch of samples was out of control due to a matrix interference effect. The associated batch LCS/LCSD was in control and, hence, the associated sample data was reported with no further corrective action required.
A	Result is the average of all dilutions, as defined by the method.
B	Analyte was present in the associated method blank.
C	Analyte presence was not confirmed on primary column.
E	Concentration exceeds the calibration range.
I	Compound did not meet method-described identification guidelines. Identification was based on additional GC/MS characteristics.
J	Analyte was detected at a concentration below the reporting limit and above the laboratory method detection limit. Reported value is estimated.
ND	Parameter not detected at the indicated reporting limit.
Q	Spike recovery and RPD control limits do not apply resulting from the parameter concentration in the sample exceeding the spike concentration by a factor of four or greater.
X	% Recovery and/or RPD out-of-range.
Z	Analyte presence was not confirmed by second column or GC/MS analysis. Solid - Unless otherwise indicated, solid sample data is reported on a wet weight basis, not corrected for % moisture.




CHAIN OF CUSTODY RECORD

1546'

 7440 LINCOLN WAY GARDEN GROVE, CA 92841 TEL: (714) 895-5494 FAX: (714) 894-7501 ExxonMobil	Consultant Name: <u>Environmental Resolutions, Inc.</u> Address: <u>610 North McDowell</u> City/State/Zip: <u>Petaluma, CA 94954</u> Project Manager: <u>Paula Sime</u> Telephone Number: <u>707-766-2000</u> ERI Job Number: <u>2506 11X (May)</u> Sampler Name: (Print) <u>Jon Herman</u> Sampler Signature: <u>[Signature]</u>	ExxonMobil Engineer <u>Jennifer Sedlachek</u> Telephone Number <u>510-547-8196</u> Account #: <u>10228</u> PO #: <u>4508883534</u> Facility ID # <u>7-0104</u> Global ID# _____ Site Address <u>1725 Park Street</u> City, State Zip <u>Alameda, California</u>
--	--	--

TAT <input type="checkbox"/> 24 hour <input type="checkbox"/> 48 hour <input checked="" type="checkbox"/> 8 day	PROVIDE: EDF Report	Special Instructions:	Matrix			Analyze For:								
			Water	Soil	Vapor	TPHg 8015B	BTEX 8021B	MTBE 8020						
Sample ID / Description	DATE	TIME	COMP	GRAB	PRESERV	NUMBER								
1 W-PSP-1	5/15	1400		X	HCl	4 voa	X			X	X	X		
2 W-INT 2		1445		X	HCl	4 voa	X			X	X	X		
3 W-INT 1		1430		X	HCl	4 voa	X			X	X	X		
4 W-INF		1445		X	HCl	4 voa	X			X	X	X		

Relinquished by: <u>[Signature]</u> Date: <u>5/15/09</u> Time: <u>1500</u>	Received by: <u>T. O'Malley CEZ</u> Date: <u>5/15/09</u> Time: <u>1510</u>	Laboratory Comments: Temperature Upon Receipt: Sample Containers Intact? VOAs Free of Headspace?
Relinquished by: <u>[Signature]</u> Date: <u>5/15/09</u> Time: <u>1730</u>	Received by CalScience: <u>[Signature]</u> Date: <u>5/16/09</u> Time: <u>0940</u>	



WORK ORDER #: 09-05-1546

SAMPLE RECEIPT FORM

Cooler 1 of 1

CLIENT: GRA ER

DATE: 03/16/09

TEMPERATURE: (Criteria: 0.0°C – 6.0°C, not frozen)

Temperature 3.3 °C - 0.2°C (CF) = 3.1 °C Blank Sample

Sample(s) outside temperature criteria (PM/APM contacted by: _____).

Sample(s) outside temperature criteria but received on ice/chilled on same day of sampling.

Received at ambient temperature, placed on ice for transport by Courier.

Ambient Temperature: Air Filter Metals Only PCBs Only Initial: MA

CUSTODY SEALS INTACT:

Cooler _____ No (Not Intact) Not Present N/A Initial: MA

Sample _____ No (Not Intact) Not Present Initial: MH

SAMPLE CONDITION:

	Yes	No	N/A
Chain-Of-Custody (COC) document(s) received with samples.....	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
COC document(s) received complete.....	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
<input type="checkbox"/> Collection date/time, matrix, and/or # of containers logged in based on sample labels.			
<input type="checkbox"/> COC not relinquished. <input type="checkbox"/> No date relinquished. <input type="checkbox"/> No time relinquished.			
Sampler's name indicated on COC.....	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Sample container label(s) consistent with COC.....	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Sample container(s) intact and good condition.....	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Correct containers and volume for analyses requested.....	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Analyses received within holding time.....	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Proper preservation noted on COC or sample container.....	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
<input type="checkbox"/> Unpreserved vials received for Volatiles analysis			
Volatile analysis container(s) free of headspace.....	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Tedlar bag(s) free of condensation.....	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>

CONTAINER TYPE:

Solid: 4ozCGJ 8ozCGJ 16ozCGJ Sleeve EnCores® TerraCores® _____

Water: VOA VOAh VOAna₂ 125AGB 125AGBh 125AGBp 1AGB 1AGBna₂ 1AGBs


500AGB 500AGJ 500AGJs 250AGB 250CGB 250CGBs 1PB 500PB 500PBna

250PB 250PBn 125PB 125PBzanna 100PB 100PBna₂ _____ _____ _____

Air: Tedlar® Summa® _____ Other: _____ Checked/Labeled by: MH

Container: C: Clear A: Amber P: Plastic G: Glass J: Jar (Wide-mouth) B: Bottle (Narrow-mouth) Reviewed by: MA

Preservative: h: HCL n: HNO3 na₂:Na₂S₂O₃ Na: NaOH p: H₃PO₄ s: H₂SO₄ zanna: ZnAc₂+NaOH f: Field-filtered Scanned by: MH



June 24, 2009

RECEIVED
JUN 25 2009

Paula Sime
Environmental Resolutions, Inc.
601 North McDowell Blvd.
Petaluma, CA 94954-2312

BY:.....

Subject: **Calscience Work Order No.: 09-06-1314**
Client Reference: ExxonMobil 70104

Dear Client:

Enclosed is an analytical report for the above-referenced project. The samples included in this report were received 6/13/2009 and analyzed in accordance with the attached chain-of-custody.

Unless otherwise noted, all analytical testing was accomplished in accordance with the guidelines established in our Quality Systems Manual, applicable standard operating procedures, and other related documentation. The original report of subcontracted analysis, if any, is provided herein, and follows the standard Calscience data package. The results in this analytical report are limited to the samples tested and any reproduction thereof must be made in its entirety.


Note that the Chain-of-Custody Record and Sample Receipt Form are integral parts of this report.

If you have any questions regarding this report, please do not hesitate to contact the undersigned.

Sincerely,

Cecile deGuia

Calscience Environmental
Laboratories, Inc.
Cecile deGuia
Project Manager



Analytical Report



Environmental Resolutions, Inc.
 601 North McDowell Blvd.
 Petaluma, CA 94954-2312

Date Received: 06/13/09
 Work Order No: 09-06-1314
 Preparation: EPA 5030B
 Method: EPA 8015B (M)

Project: ExxonMobil 70104

Page 1 of 2

Client Sample Number	Lab Sample Number	Date/Time Collected	Matrix	Instrument	Date Prepared	Date/Time Analyzed	QC Batch ID
W-PSP-1	09-06-1314-1-C	06/11/09 10:20	Aqueous	GC 30	06/19/09	06/19/09 09:49	090618B01

Parameter	Result	RL	DF	Qual	Units
TPH as Gasoline	ND	50	1		ug/L
<u>Surrogates:</u>	<u>REC (%)</u>	<u>Control Limits</u>		<u>Qual</u>	
1,4-Bromofluorobenzene	74	38-134			

W-INT2	09-06-1314-2-C	06/11/09 10:25	Aqueous	GC 30	06/19/09	06/19/09 10:23	090618B01
--------	----------------	-------------------	---------	-------	----------	-------------------	-----------

Parameter	Result	RL	DF	Qual	Units
TPH as Gasoline	ND	50	1		ug/L
<u>Surrogates:</u>	<u>REC (%)</u>	<u>Control Limits</u>		<u>Qual</u>	
1,4-Bromofluorobenzene	74	38-134			


W-INT1	09-06-1314-3-C	06/11/09 10:30	Aqueous	GC 30	06/19/09	06/19/09 10:56	090618B01
--------	----------------	-------------------	---------	-------	----------	-------------------	-----------

Parameter	Result	RL	DF	Qual	Units
TPH as Gasoline	ND	50	1		ug/L
<u>Surrogates:</u>	<u>REC (%)</u>	<u>Control Limits</u>		<u>Qual</u>	
1,4-Bromofluorobenzene	75	38-134			

W-INF	09-06-1314-4-C	06/11/09 10:35	Aqueous	GC 30	06/19/09	06/19/09 11:30	090618B01
-------	----------------	-------------------	---------	-------	----------	-------------------	-----------

Parameter	Result	RL	DF	Qual	Units
TPH as Gasoline	ND	50	1		ug/L
<u>Surrogates:</u>	<u>REC (%)</u>	<u>Control Limits</u>		<u>Qual</u>	
1,4-Bromofluorobenzene	73	38-134			

RL - Reporting Limit , DF - Dilution Factor , Qual - Qualifiers



Analytical Report



Environmental Resolutions, Inc.
 601 North McDowell Blvd.
 Petaluma, CA 94954-2312

Date Received: 06/13/09
 Work Order No: 09-06-1314
 Preparation: EPA 5030B
 Method: EPA 8015B (M)

Project: ExxonMobil 70104

Page 2 of 2

Client Sample Number	Lab Sample Number	Date/Time Collected	Matrix	Instrument	Date Prepared	Date/Time Analyzed	QC Batch ID
Method Blank	099-12-436-3,425	N/A	Aqueous	GC 30	06/18/09	06/18/09 23:13	090618B01

Parameter	Result	RL	DF	Qual	Units
TPH as Gasoline	ND	50	1		ug/L
<u>Surrogates:</u>	<u>REC (%)</u>	<u>Control Limits</u>		<u>Qual</u>	
1,4-Bromofluorobenzene	66	38-134			

RL - Reporting Limit , DF - Dilution Factor , Qual - Qualifiers



Analytical Report



Environmental Resolutions, Inc.
601 North McDowell Blvd.
Petaluma, CA 94954-2312

Date Received: 06/13/09
Work Order No: 09-06-1314
Preparation: EPA 5030B
Method: EPA 8021B
Units: ug/L

Project: ExxonMobil 70104

Page 1 of 2

Client Sample Number	Lab Sample Number	Date/Time Collected	Matrix	Instrument	Date Prepared	Date/Time Analyzed	QC Batch ID
W-PSP-1	09-06-1314-1-D	06/11/09 10:20	Aqueous	GC 8	06/15/09	06/15/09 15:54	090615B01

Parameter	Result	RL	DF	Qual	Parameter	Result	RL	DF	Qual
Benzene	ND	0.50	1		Xylenes (total)	3.4	1.0	1	
Toluene	0.69	0.50	1	Z	Methyl-t-Butyl Ether (MTBE)	ND	5.0	1	
Ethylbenzene	ND	0.50	1						
Surrogates:	REC (%)	Control Limits		Qual					
1,4-Bromofluorobenzene	111	70-130							

Client Sample Number	Lab Sample Number	Date/Time Collected	Matrix	Instrument	Date Prepared	Date/Time Analyzed	QC Batch ID
W-INT2	09-06-1314-2-D	06/11/09 10:25	Aqueous	GC 8	06/15/09	06/15/09 16:28	090615B01

Parameter	Result	RL	DF	Qual	Parameter	Result	RL	DF	Qual
Benzene	ND	0.50	1		Xylenes (total)	ND	1.0	1	
Toluene	ND	0.50	1		Methyl-t-Butyl Ether (MTBE)	ND	5.0	1	
Ethylbenzene	ND	0.50	1						
Surrogates:	REC (%)	Control Limits		Qual					
1,4-Bromofluorobenzene	110	70-130							


Client Sample Number	Lab Sample Number	Date/Time Collected	Matrix	Instrument	Date Prepared	Date/Time Analyzed	QC Batch ID
W-INT1	09-06-1314-3-D	06/11/09 10:30	Aqueous	GC 8	06/15/09	06/15/09 17:03	090615B01

Parameter	Result	RL	DF	Qual	Parameter	Result	RL	DF	Qual
Benzene	ND	0.50	1		Xylenes (total)	ND	1.0	1	
Toluene	ND	0.50	1		Methyl-t-Butyl Ether (MTBE)	ND	5.0	1	
Ethylbenzene	ND	0.50	1						
Surrogates:	REC (%)	Control Limits		Qual					
1,4-Bromofluorobenzene	116	70-130							

Client Sample Number	Lab Sample Number	Date/Time Collected	Matrix	Instrument	Date Prepared	Date/Time Analyzed	QC Batch ID
W-INF	09-06-1314-4-C	06/11/09 10:35	Aqueous	GC 8	06/16/09	06/16/09 14:13	090616B01

Parameter	Result	RL	DF	Qual	Parameter	Result	RL	DF	Qual
Benzene	ND	2.5	5		Xylenes (total)	ND	5.0	5	
Toluene	ND	2.5	5		Methyl-t-Butyl Ether (MTBE)	700	25	5	
Ethylbenzene	ND	2.5	5						
Surrogates:	REC (%)	Control Limits		Qual					
1,4-Bromofluorobenzene	108	70-130							

RL - Reporting Limit , DF - Dilution Factor , Qual - Qualifiers



Analytical Report



Environmental Resolutions, Inc.
601 North McDowell Blvd.
Petaluma, CA 94954-2312

Date Received: 06/13/09
Work Order No: 09-06-1314
Preparation: EPA 5030B
Method: EPA 8021B
Units: ug/L

Page 2 of 2

Project: ExxonMobil 70104


Client Sample Number	Lab Sample Number	Date/Time Collected	Matrix	Instrument	Date Prepared	Date/Time Analyzed	QC Batch ID
Method Blank	099-12-667-475	N/A	Aqueous	GC 8	06/15/09	06/15/09 11:56	090615B01

Parameter	Result	RL	DF	Qual	Parameter	Result	RL	DF	Qual
Benzene	ND	0.50	1		Xylenes (total)	ND	1.0	1	
Toluene	ND	0.50	1		Methyl-t-Butyl Ether (MTBE)	ND	5.0	1	
Ethylbenzene	ND	0.50	1						
Surrogates:	REC (%)	Control Limits		Qual					
1,4-Bromofluorobenzene	109	70-130							

Client Sample Number	Lab Sample Number	Date/Time Collected	Matrix	Instrument	Date Prepared	Date/Time Analyzed	QC Batch ID
Method Blank	099-12-667-477	N/A	Aqueous	GC 8	06/16/09	06/16/09 11:56	090616B01

Parameter	Result	RL	DF	Qual	Parameter	Result	RL	DF	Qual
Benzene	ND	0.50	1		Xylenes (total)	ND	1.0	1	
Toluene	ND	0.50	1		Methyl-t-Butyl Ether (MTBE)	ND	5.0	1	
Ethylbenzene	ND	0.50	1						
Surrogates:	REC (%)	Control Limits		Qual					
1,4-Bromofluorobenzene	108	70-130							

RL - Reporting Limit , DF - Dilution Factor , Qual - Qualifiers



Quality Control - Spike/Spike Duplicate




Environmental Resolutions, Inc. 601 North McDowell Blvd. Petaluma, CA 94954-2312	Date Received: 06/13/09 Work Order No: 09-06-1314 Preparation: EPA 5030B Method: EPA 8015B (M)
--	---

Project ExxonMobil 70104

Quality Control Sample ID	Matrix	Instrument	Date Prepared	Date Analyzed	MS/MSD Batch Number
09-06-1352-1	Aqueous	GC 30	06/18/09	06/19/09	090618S01

Parameter	MS %REC	MSD %REC	%REC CL	RPD	RPD CL	Qualifiers
TPH as Gasoline	74	88	68-122	11	0-18	

RPD - Relative Percent Difference , CL - Control Limit



Quality Control - Spike/Spike Duplicate



Environmental Resolutions, Inc.
601 North McDowell Blvd.
Petaluma, CA 94954-2312


Date Received: 06/13/09
Work Order No: 09-06-1314
Preparation: EPA 5030B
Method: EPA 8021B

Project ExxonMobil 70104

Quality Control Sample ID	Matrix	Instrument	Date Prepared	Date Analyzed	MS/MSD Batch Number
09-06-1317-1	Aqueous	GC 8	06/15/09	06/15/09	090615S01

<u>Parameter</u>	<u>MS %REC</u>	<u>MSD %REC</u>	<u>%REC CL</u>	<u>RPD</u>	<u>RPD CL</u>	<u>Qualifiers</u>
Benzene	112	108	57-129	4	0-23	
Toluene	102	96	50-134	6	0-26	
Ethylbenzene	95	98	58-130	3	0-26	
p/m-Xylene	99	100	58-130	2	0-28	
o-Xylene	91	94	57-123	3	0-26	
Methyl-t-Butyl Ether (MTBE)	116	114	44-134	1	0-27	

RPD - Relative Percent Difference, CL - Control Limit



Quality Control - Spike/Spike Duplicate



Environmental Resolutions, Inc.
601 North McDowell Blvd.
Petaluma, CA 94954-2312


Date Received: 06/13/09
Work Order No: 09-06-1314
Preparation: EPA 5030B
Method: EPA 8021B

Project ExxonMobil 70104

Quality Control Sample ID	Matrix	Instrument	Date Prepared	Date Analyzed	MS/MSD Batch Number
09-06-1305-11	Aqueous	GC 8	06/16/09	06/16/09	090616S01

<u>Parameter</u>	<u>MS %REC</u>	<u>MSD %REC</u>	<u>%REC CL</u>	<u>RPD</u>	<u>RPD CL</u>	<u>Qualifiers</u>
Benzene	106	104	57-129	1	0-23	
Toluene	93	92	50-134	1	0-26	
Ethylbenzene	95	94	58-130	0	0-26	
p/m-Xylene	99	97	58-130	2	0-28	
o-Xylene	92	90	57-123	1	0-26	
Methyl-t-Butyl Ether (MTBE)	110	97	44-134	12	0-27	

RPD - Relative Percent Difference, CL - Control Limit



Quality Control - LCS/LCS Duplicate



Environmental Resolutions, Inc.
601 North McDowell Blvd.
Petaluma, CA 94954-2312


Date Received: N/A
Work Order No: 09-06-1314
Preparation: EPA 5030B
Method: EPA 8015B (M)

Project: ExxonMobil 70104

Quality Control Sample ID	Matrix	Instrument	Date Prepared	Date Analyzed	LCS/LCSD Batch Number
099-12-436-3,425	Aqueous	GC 30	06/18/09	06/18/09	090618B01

Parameter	LCS %REC	LCSD %REC	%REC CL	RPD	RPD CL	Qualifiers
TPH as Gasoline	89	92	78-120	3	0-10	

RPD - Relative Percent Difference , CL - Control Limit



Quality Control - LCS/LCS Duplicate



Environmental Resolutions, Inc.
601 North McDowell Blvd.
Petaluma, CA 94954-2312


Date Received: N/A
Work Order No: 09-06-1314
Preparation: EPA 5030B
Method: EPA 8021B

Project: ExxonMobil 70104

Quality Control Sample ID	Matrix	Instrument	Date Prepared	Date Analyzed	LCS/LCSD Batch Number
099-12-667-475	Aqueous	GC 8	06/15/09	06/15/09	090615B01

Parameter	LCS %REC	LCSD %REC	%REC CL	RPD	RPD CL	Qualifiers
Benzene	108	108	70-118	0	0-9	
Toluene	103	100	66-114	3	0-9	
Ethylbenzene	108	105	72-114	3	0-9	
p/m-Xylene	112	109	74-116	3	0-9	
o-Xylene	108	105	72-114	3	0-9	
Methyl-t-Butyl Ether (MTBE)	112	110	41-137	1	0-13	

RPD - Relative Percent Difference, CL - Control Limit



Quality Control - LCS/LCS Duplicate



Environmental Resolutions, Inc.
601 North McDowell Blvd.
Petaluma, CA 94954-2312

Date Received: N/A
Work Order No: 09-06-1314
Preparation: EPA 5030B
Method: EPA 8021B

Project: ExxonMobil 70104

Quality Control Sample ID	Matrix	Instrument	Date Prepared	Date Analyzed	LCS/LCSD Batch Number
099-12-667-477	Aqueous	GC 8	06/16/09	06/16/09	090616B01

Parameter	LCS %REC	LCSD %REC	%REC CL	RPD	RPD CL	Qualifiers
Benzene	102	105	70-118	3	0-9	
Toluene	99	101	66-114	2	0-9	
Ethylbenzene	108	108	72-114	1	0-9	
p/m-Xylene	112	113	74-116	1	0-9	
o-Xylene	108	108	72-114	0	0-9	
Methyl-t-Butyl Ether (MTBE)	108	111	41-137	3	0-13	



RPD - Relative Percent Difference, CL - Control Limit

Work Order Number: 09-06-1314




<u>Qualifier</u>	<u>Definition</u>
*	See applicable analysis comment.
1	Surrogate compound recovery was out of control due to a required sample dilution, therefore, the sample data was reported without further clarification.
2	Surrogate compound recovery was out of control due to matrix interference. The associated method blank surrogate spike compound was in control and, therefore, the sample data was reported without further clarification.
3	Recovery of the Matrix Spike (MS) or Matrix Spike Duplicate (MSD) compound was out of control due to matrix interference. The associated LCS and/or LCSD was in control and, therefore, the sample data was reported without further clarification.
4	The MS/MSD RPD was out of control due to matrix interference. The LCS/LCSD RPD was in control and, therefore, the sample data was reported without further clarification.
5	The PDS/PDSD associated with this batch of samples was out of control due to a matrix interference effect. The associated batch LCS/LCSD was in control and, hence, the associated sample data was reported with no further corrective action required.
A	Result is the average of all dilutions, as defined by the method.
B	Analyte was present in the associated method blank.
C	Analyte presence was not confirmed on primary column.
E	Concentration exceeds the calibration range.
I	Compound did not meet method-described identification guidelines. Identification was based on additional GC/MS characteristics.
J	Analyte was detected at a concentration below the reporting limit and above the laboratory method detection limit. Reported value is estimated.
ND	Parameter not detected at the indicated reporting limit.
Q	Spike recovery and RPD control limits do not apply resulting from the parameter concentration in the sample exceeding the spike concentration by a factor of four or greater.
X	% Recovery and/or RPD out-of-range.
Z	Analyte presence was not confirmed by second column or GC/MS analysis. Solid - Unless otherwise indicated, solid sample data is reported on a wet weight basis, not corrected for % moisture.

CHAIN OF CUSTODY RECORD


1314

 <p>7440 LINCOLN WAY GARDEN GROVE, CA 92841 TEL: (714) 895-5494 FAX: (714) 894-7501</p> <p>ExxonMobil</p>	<p>Consultant Name: <u>Environmental Resolutions, Inc.</u></p> <p>Address: <u>610 North McDowell</u></p> <p>City/State/Zip: <u>Petaluma, CA 94954</u></p> <p>Project Manager: <u>Paula Sime</u></p> <p>Telephone Number: <u>707-766-2000</u></p> <p>ERI Job Number: <u>2506 11X (June)</u></p> <p>Sampler Name: (Print) <u>Josh Barrerus</u></p> <p>Sampler Signature: </p>	<p>ExxonMobil Engineer <u>Jennifer Sedlachek</u></p> <p>Telephone Number <u>510-547-8196</u></p> <p>Account #: <u>10228</u></p> <p>PO #: <u>4508883534</u></p> <p>Facility ID # <u>7-0104</u></p> <p>Global ID# _____</p> <p>Site Address <u>1725 Park Street</u></p> <p>City, State Zip <u>Alameda, California</u></p>
---	---	---

TAT	PROVIDE:	Special Instructions:	Matrix			Analyze For:													
			Water	Soil	Vapor	TPHg 8015B	BTEX 8021B	MTBE 8020											
<input type="checkbox"/> 24 hour <input type="checkbox"/> 72 hour <input type="checkbox"/> 48 hour <input type="checkbox"/> 96 hour <input checked="" type="checkbox"/> 8 day	EDF Report																		
Sample ID / Description	DATE	TIME	COMP	GRAB	PRESERV	NUMBER	Water	Soil	Vapor	TPHg 8015B	BTEX 8021B	MTBE 8020							
1 W-PSP-1	6/11/09	1020		X	HCl	4 voa	X			X	X	X							
2 W-INT 2	6/11/09	1025		X	HCl	4 voa	X			X	X	X							
3 W-INT 1	6/11/09	1030		X	HCl	4 voa	X			X	X	X							
4 W-INF	6/11/09	1035		X	HCl	4 voa	X			X	X	X							

Relinquished by: 	Date: <u>6/12/09</u>	Time: <u>07:00</u>	Received by: <u>ra smalley</u>	Time: <u>1335</u>	Laboratory Comments: Temperature Upon Receipt: Sample Containers Intact? VOAs Free of Headspace?
Relinquished by: 	Date: <u>6-12-09</u>	Time: <u>1730</u>	Received by Calscience: 	Time: <u>6:45-8:45</u>	

652 512 056603



WORK ORDER #: 09-06-1314

SAMPLE RECEIPT FORM

Cooler 1 of 1

CLIENT: ER1

DATE: 6/13/09

TEMPERATURE: (Criteria: 0.0°C - 6.0°C, not frozen)

Temperature 2.6°C - 0.2°C (CF) = 2.4°C [X] Blank [] Sample

- [] Sample(s) outside temperature criteria (PM/APM contacted by: _____).
[] Sample(s) outside temperature criteria but received on ice/chilled on same day of sampling.

[X] Received at ambient temperature, placed on ice for transport by Courier.

Ambient Temperature: [] Air [] Filter [] Metals Only [] PCBs Only

Initial: JD

CUSTODY SEALS INTACT:

- [] Cooler [] _____ [] No (Not Intact) [X] Not Present [] N/A
[] Sample [] _____ [] No (Not Intact) [X] Not Present

Initial: OD

Initial: R

SAMPLE CONDITION:

Table with 4 columns: Item, Yes, No, N/A. Rows include Chain-Of-Custody (COC) document(s) received with samples, COC document(s) received complete, Sampler's name indicated on COC, Sample container label(s) consistent with COC, etc.

CONTAINER TYPE:

- Solid: [] 4ozCGJ [] 8ozCGJ [] 16ozCGJ [] Sleeve [] EnCores [] TerraCores
Water: [] VOA [X] VOAh [] VOAna2 [] 125AGB [] 125AGBh [] 125AGBp [] 1AGB [] 1AGBna2 [] 1AGBs
[] 500AGB [] 500AGJ [] 500AGJs [] 250AGB [] 250CGB [] 250CGBs [] 1PB [] 500PB [] 500PBna
[] 250PB [] 250PBn [] 125PB [] 125PBzanna [] 100PB [] 100PBna2

Air: [] Tedlar [] Summa [] _____ Other: [] _____ Checked/Labeled by: [Signature]

Container: C: Clear A: Amber P: Plastic G: Glass J: Jar (Wide-mouth) B: Bottle (Narrow-mouth) Reviewed by: [Signature]

Preservative: h: HCL n: HNO3 na2:Na2S2O3 Na: NaOH p: H3PO4 s: H2SO4 znna: ZnAc2+NaOH f: Field-filtered Scanned by: [Signature]

APPENDIX C
FIELD DATA SHEETS



DAILY FIELD REPORT

Environmental Resolutions, Inc.

PROJECT: 50104 JOB # + ACTIVITY: 250613X
 SUBJECT: QM DATE: 5/27/09
 EQUIPMENT USED: - SHEET: 1 OF 1
 NAME: I. INGRAM PROJECT MNGR: Paula

ON SITE 745

Sunny, Warm

SAFETY

OPEN WELLS MW3, MW2, MW4, MW5, MW7

DTW WELLS MW3, MW2, MW4, MW5, MW7

Purge + Sample wells

MW3, MW2, MW4, MW5, MW7

Purge + Sample MW6

TOTAL Purge H₂O : 119

TOTAL DECON H₂O : 20

TOTAL H₂O TO HRS : 139

ON SITE 745

Daily Field Report

Environmental Resolutions, Inc.



VALUE, QUALITY, RESPONSE

Project ID #: 70104

ERI Job # 0225062009

Subject: 1/4 LY GW SAMPLING

Date: 5/27/2009

Equipment Used: SOLINST/HYDAC/PUMPS/BATTS'S/SAMPLING EQUIPMENT/ETC.

Sheet: 1

Name(s): INGRAM, ISAAC

Time Arrived On Site: 7:30 AM

Time Departed Site: 12:45 PM

Total Travel 2.25

- 7:30 AM -ARRIVED ON SITE
- INFORMED STATION OF WORK TO BE DONE
- SET UP EXCLUSION ZONE AND CHOCKED THE WHEELS ON VEHICLE
- 7:45 AM -HELD H&S MEETING/REVIEWED HOSPITAL ROUTE
- REVIEWED APPLICABLE JSA'S
- PERFORMED SPSA FOR: BUSY STATION; TOOK TIME TO BE SAFE
- SET UP EXCLUSION ZONE AROUND WELLS TO BE OPENED
- STARTED PAPERWORK FOR SITE AND LABELS
- SET UP DECON/WORK AREA AND DECON'D EQUIPMENT
- 8:00 AM -OPENED WELLS AND ALLOWED WELLS TO CHARGE
- 8:15 AM -STARTED MEASURING/FINISHED AT 8:45 AM
- 8:45 AM -STARTED PURGING/FINISHED AT 12:15 PM
- 10:00 AM -STARTED SAMPLING/FINISHED AT 12:30 PM
- DECON'D EQUIPMENT/CLEANED UP DECON STATION/LOADED TRUCK
- BROKE DOWN EXCLUSION ZONE/LOADED TRUCK
- Total Purge 119
- Total Decon 20
- Total Water To Onsite System 139
- 12:45 PM -ERI OFF SITE

*M/P/S 5 WELLS

*M/S 0 WELLS

*M/S LOW FLOW 0 WELLS

*MO 0 WELLS

*O/P 0 WELLS

*POTABLE 0 WELLS

TOTAL PURGED GALLONS: 119

*0 T/C SET UPS

*PURGED WATER TO ONSITE SYSTEM

Depth to Water Data		QRT	2nd	YEAR	2009.00	Calc Case Volume for purge			
ERI #	2506 13x					2" WELL x 0.163			
Site #	7-0104	Address:	1725 Park St., Alameda, CA			4" WELL x 0.652			
PM:	Paula Sime					6" WELL x 1.467			
Date:	5/27/2009					r (squared) x 0.163			
Tech:		II		Recharge formula:					
DTW Time				Step 1 ▶	Calc 80% in feet▶	TD - PreDTW x .80 (ft) =			
Start:				Step 2 ▶	Calc PostDTW (ft)▶	TD - PostDTW (ft) =			
Finish:				Take ratio of result from Step 2 and Step 1 to find % recharge					
WELL ID	TD	PreDTW	CASE D	CASE V	PostDTW	Rechrg 80%	Sample Time	DTP	Prd Thick
MW 1	20.42		4	13.31					
MW 2	15.14	5.10	4	6.55	12.28	N			
MW 3	14.05	5.14	4	5.81	5.44	Y			
MW 4	17.96	5.40	4	8.19	6.10	Y			
MW 5	18.81	5.26	4	8.83	6.42	Y			
MW 6	18.3		4	11.93					
MW 7	18.36	5.01	4	8.70		Y			
MW 8	18.73		2	3.05					
MW 9	18.68		2	3.04					
MW 11	14.74		2	2.40					
EW 1	X		4						
EW 3	X		4						
EW 5	X		4						

MONITORING - FIELD LOG					
ERI #	2506 13x		QRT	2nd	2009
Client:	ExxonMobil		DATE:	5/27/09	
Site ID:	7-0104		TECH	II	
ADDRESS:			PM:	Paula Sime	
1725 Park St., Alameda, CA			Total Purge Volume		
		PRG			
WELL #	TIME	VOL	TEMP	COND	pH
BB					
COMMENTS:					
		PRG			
MW4	TIME	VOL	TEMP	COND	pH
	8:45	9	F	MS	
	8:50	9	69.80	0.37	8.97
	8:55	18	69.00	0.37	8.96
	9:00	27	68.70	0.30	8.94
TOTAL PURGE	27				
COMMENTS:					
		PRG			
MW2	TIME	VOL	TEMP	COND	pH
	9:08	7	F	MS	
	9:12	7	71.70	0.29	8.65
	9:15	14	71.80	0.30	8.60
	9:18	21			
TOTAL PURGE	20				
COMMENTS:	DRY@20				
		PRG			
MW7	TIME	VOL	TEMP	COND	pH
	9:28	9	F	MS	
	9:33	9	69.00	0.19	8.76
	9:38	18	68.30	0.19	8.41
	9:42	27	68.10	0.18	8.15
TOTAL PURGE	27				
COMMENTS:					

MONITORING - FIELD LOG					
ERI #	2506 13x		QRT	2nd	2009
Client:	ExxonMobil		DATE:	5/27/09	
Site ID:	7-0104		TECH	II	
ADDRESS:			PM:	Paula Sime	
1725 Park St., Alameda, CA			Total Purge Volume		
		PRG			
MW5	TIME	VOL	TEMP	COND	pH
	9:50	9	F	MS	
	9:55	9	68.80	0.35	7.84
	10:00	18	68.70	0.37	7.59
	10:05	27	68.20	0.39	7.57
TOTAL PURGE	27				
COMMENTS:					
		PRG			
MW3	TIME	VOL	TEMP	COND	pH
	10:22	6	F	MS	
	10:25	6	69.90	0.59	7.26
	10:28	12	70.10	0.60	7.63
	10:31	18	69.30	0.60	7.60
TOTAL PURGE	18				
COMMENTS:					
Total Purge		119.00			
Total Decon		20			
Total Water To GRS		139			



DAILY FIELD REPORT

Environmental Resolutions, Inc.

PROJECT: 7-0104 JOB # + ACTIVITY: 2506 13X

SUBJECT: Im. DATE: 5-27-09

EQUIPMENT USED: _____ SHEET: 1 OF 1

NAME: JOE S. PROJECT MNGR: PAULA

Onsite + 700 Safed checked 1/2
w/ ISAACS

Open Wells.

DTW wells could NOT DTW well EWI
DOTO TRUCK parked in top.

Set up T.C. For MW8, MW9.

Truck moved From EWI To DTW.

~~Purged~~ Purged & Sampled MW11 & MW1.
Also Sampled MW7.

purged .65

Decon. 15

TOTAL. 80 TO SYSTEM

+ ISAACS

OFFSITE + 1265

Daily Field Report

Environmental Resolutions, Inc.



VALUE, QUALITY, RESPONSE

Project ID #: 70104

ERI Job # 0225062009

Subject: 1/4 LY GW SAMPLING

Date: 5/27/2009

Equipment Used: SOLINST/HYDAC/PUMPS/BATTS'S/SAMPLING EQUIPMENT/ETC.

Sheet: 1

Name(s): SALGADO, JOSE A

Time Arrived On Site: 7:30 AM

Time Departed Site: 12:45 PM

Total Travel 2.25

7:30 AM -ARRIVED ON SITE

-INFORMED STATION OF WORK TO BE DONE

-SET UP EXCLUSION ZONE AND CHOCKED THE WHEELS ON VEHICLE

7:45 AM -HELD H&S MEETING/REVIEWED HOSPITAL ROUTE

-REVIEWED APPLICABLE JSA'S

-PERFORMED SPSA FOR: TRAFFIC

-SET UP EXCLUSION ZONE AROUND WELLS TO BE OPENED

-STARTED PAPERWORK FOR SITE AND LABELS

-SET UP DECON/WORK AREA AND DECON'D EQUIPMENT

7:45 AM -OPENED WELLS AND ALLOWED WELLS TO CHARGE

8:00 AM -STARTED MEASURING/FINISHED AT 8:15 AM

8:30 AM -STARTED PURGING/FINISHED AT 12:15 PM

8:45 AM -STARTED SAMPLING/FINISHED AT 12:30 PM

12:30 PM -STARTED PURGE WATER TREATMENT/FINISHED AT 12:45 PM

-DECON'D EQUIPMENT/CLEANED UP DECON STATION/LOADED TRUCK

-BROKE DOWN EXCLUSION ZONE/LOADED TRUCK

-purge 65/decon 15/total 80

12:45 PM -ERI OFF SITE

*M/P/S 5 WELLS

*M/S 0 WELLS

*M/S LOW FLOW 0 WELLS

*MO 3 WELLS

*O/P 0 WELLS

*POTABLE 0 WELLS

TOTAL PURGED GALLONS: 0

*1 T/C SET UPS

*PURGED WATER TO ONSITE SYSTEM

20372 North Sea Circle, Lake Forest, CA 92630

Office: 949-340-1020

Fax: 949-470-1838

WATER SAMPLING SITE STATUS

Date: 5-27-09

Inspected by: Jesse S.

ERI Job Number: 2506 Station No.: 70104

Site Address: 1725 Park St. Alameda.

Well ID	Well Head Screws	Rubber Gasket	Well Cap Locking	Lock on Well Cap	Concrete Well Seal	Well Head PVC	Water in Well Vault	Well Cover	Fence/Gate Condition	# Drums	Drum Contents	Building Condition	Site Appearance	Comments / Well Covers
	N/R/ok	N/R/ok	N/R/ok	N/R/ok	N/R/ok	N/R/ok	Y/N	N/R/ok	N/R/ok	N/R/ok	s/w/e	g/v/o	N/R/ok	
MWB	ok	N	ok	ok	ok	ok	N	N	ok					
MW9	ok	ok	ok	ok	ok	ok	Y	N	ok					
MW11	ok	ok	ok	ok	ok	ok	N	N	ok					
MW1	N	N	ok	ok	ok	ok	N	N	ok					
EWS	N	N	ok	N	ok	ok	N	N	ok					
EWS	N	N	ok	N	ok	ok	N	N	ok					
EWS	N	N	ok	N	ok	ok	N	N	ok					
MWB	3/4	N	ok	ok	ok	ok	N	3/4	ok					

N = Not repairable in time available-see comments.
 R = Repaired-see comments
 ok = No action needed.

Y = Yes.
 N = No.

s = Soil.
 w = Water.
 e = Empty.

g = Graffiti on walls.
 v = Vagrants (or evidence of).
 o = Open (not secured).

Depth to Water Data		QRT	2nd	YEAR	2009.00	Calc Case Volume for purge			
ERI #	2506 13x							2" WELL x 0.163	
Site #	7-0104	Address:	1725 Park St., Alameda, CA					4" WELL x 0.652	
PM:	Paula Sime							6" WELL x 1.467	
Date:	5/27/2009							r (squared) x 0.163	
Tech:	JS								
DTW Time						Recharge formula:			
Start:						Step 1▶	Calc 80% in feet▶	TD - PreDTW x .80 (ft) =	
Finish:						Step 2▶	Calc PostDTW (ft)▶	TD - PostDTW (ft) =	
						Take ratio of result from Step 2 and Step 1 to find % recharge			
WELL ID	TD	PreDTW	CASE D	CASE V	PostDTW	Rechrg 80%	Sample Time	DTP	Prd Thick
MW 1	20.42	5.85	4	9.50	12.51	N	10:56		
MW 2	15.14		4	9.87					
MW 3	14.05		4	9.16					
MW 4	17.96		4	11.71					
MW 5	18.81		4	12.26					
MW 6	18.3	5.26	4	8.50	13.10	N	12:37		
MW 7	18.36		4	11.97	5.03	Y	11:09		
MW 8	18.73	5.12	2	2.22	7.00	Y	9:05		
MW 9	18.68	6.21	2	2.03	9.51	N	9:42		
MW 11	14.74	5.88	2	1.44	7.61	Y	10:18		
EW 1	X	4.14	4						
EW 3	X	4.88	4						
EW 5	X	4.75	4						

MONITORING - FIELD LOG					
ERI #	2506 13x		QRT	2nd	2009
Client:	ExxonMobil		DATE:	5/27/09	
Site ID:	7-0104		TECH	JS	
ADDRESS:			PM:	Paula Sime	
1725 Park St., Alameda, CA			Total Purge Volume		
		PRG			
WELL #	TIME	VOL	TEMP	COND	pH
BB					
COMMENTS:					
		PRG			
MW8	TIME	VOL	TEMP	COND	pH
	8:45	3		US	
	8:47	3	21.20	334.00	7.03
	8:50	6	20.90	364.00	6.87
	8:51	9	20.80	383.00	6.80
	8:54	12	20.70	396.00	6.84
TOTAL PURGE	12				
COMMENTS:					
		PRG			
MW9	TIME	VOL	TEMP	COND	pH
	9:18	3		US	
	9:21	3	21.20	486.00	6.87
	9:24	6	21.30	521.00	7.28
	9:27	9	20.40	552.00	7.11
	9:30	12	20.70	556.00	7.11
	9:33	15			
TOTAL PURGE	13				
COMMENTS:	DRY@13				
		PRG			
MW11	TIME	VOL	TEMP	COND	pH
	9:57	2		US	
	9:59	2	20.40	345.00	6.79
	10:00	4	20.00	432.00	6.79
	10:01	6	19.90	424.00	6.83
	10:03	8	19.80	425.00	6.96
	10:06	10	20.00	430.00	6.90
TOTAL PURGE	10				
COMMENTS:	DRY@10				
		PRG			
MW1	TIME	VOL	TEMP	COND	pH
	10:31	10		US	
	10:36	10	19.40	714.00	6.78
	10:41	20	20.20	700.00	6.81
	10:46	30	20.00	710.00	6.81
TOTAL PURGE	30				
COMMENTS:					

MONITORING - FIELD LOG					
ERI #	2506 13x		QRT	2nd	2009
Client:	ExxonMobil		DATE:	5/27/09	
Site ID:	7-0104		TECH	JS	
ADDRESS:			PM:	Paula Sime	
1725 Park St., Alameda, CA			Total Purge Volume		
		PRG			
MW6	TIME	VOL	TEMP	COND	pH
	12:12	9	F	MS	
	12:18	9	66.20	0.45	7.51
	12:24	18	64.70	0.47	7.38
	12:30	27	64.30	0.51	7.40
TOTAL PURGE	27				
COMMENTS:					