



**RECEIVED**  
 12:53 pm, Apr 13, 2009  
 Alameda County  
 Environmental Health

25-1871 03 ✓ 02  
 2 3 ✓ 5 6

Quality Assurance Services  
 Materials Consulting  
 Since 1954


Testing Engineers, Inc.

LABORATORY NO. DL369      REPORT OF SOIL TESTS      DATE: 5/18/98  
 JOB DATA: 38319      SAMPLE DATA: sampled 5/15/98  
 John's Excavating, Misc      Source: Dumbarton La Vista  
 95 MacArthur, Oakland      tank excavation backfill

Field Inspector: C Cotton

**VISUAL CLASSIFICATION:**  
 Brown silty clayey gravel

**MAXIMUM DENSITY DETERMINATION:**  
 Method ASTM D1557  
 Optimum Moisture, % 8.9  
 Maximum Dry Density 2.18 g/cc  
 (lbs. cu. ft.) 136.4



Reviewed by Terry Chiccano  
 Terry Chiccano, Soils/Asphalt  
 Field Operations Manager

lcc: John's Excavating



# TESTING ENGINEERS, INC.

## INSPECTION REPORT

WR#DV545

PROJECT # 38319

TYPE OF INSPECTION:  
Nuclear Density

PROJECT: Johns Excavating  
96 McArthur Blvd., Oakland

PLACE OF INSPECTION:  
Jobsite

DATE 5-15-98

HOURS 8

INSPECTOR Cottom

Reported to: Mike Meyers  
Feature: Tank excavation backfill

Company: Johns Excavating

Field Test Procedure: ASTM D2922 & D3017

Laboratory Test Procedure: ASTM D1557

Material Description	Moisture Percentage	Max. density g/cc	Laboratory Ref. No.
1. Brown clayey silty gravel DQ LaVista	8.9%	2.18 g/cc	DL369

### FIELD TEST RESULTS

Location	Elevation	Curve No.	Field Density g/cc	Field Moisture %	Relative Comp. %	Project Specified %
1. 35' from Harrison & 17' from MacArthur sidewalk	-7'FG	1	2.00	9.5	92	90
2. 25' from Harrison & 20' from MacArthur sidewalk	-7'FG	1	2.05	7.8	94	90
3. 25' from Harrison & 30' from MacArthur sidewalk	-7'FG	1	2.10	7.1	96	90
4. 40' from Harrison & 48' from MacArthur sidewalk	-5'FG	1	2.08	8.7	95	90
5. 35' from Harrison & 40' from MacArthur sidewalk	-5'FG	1	2.05	8.9	94	90
6. 32' from Harrison & 28' from MacArthur sidewalk	-5'FG	1	2.15	8.4	99	90
7. 33' from Harrison & 45' from MacArthur sidewalk	-3'FG	1	2.03	7.9	93	90
8. 28' from Harrison & 27' from MacArthur sidewalk	-3'FG	1	2.01	9.0	92	90
9. 31' from Harrison & 22' from MacArthur sidewalk	-3'FG	1	2.10	7.6	96	90
10. 45' from Harrison & 45' from MacArthur sidewalk	-1'FG	1	2.12	6.6	97	95
11. 20' from Harrison & 40' from MacArthur sidewalk	-1'FG	1	2.14	7.5	98	95
12. 30' from Harrison & 25' from MacArthur sidewalk	-1'FG	1	2.06	8.3	94*	95
13. 45' from Harrison & 45' from MacArthur sidewalk	FG	1	2.09	7.2	96	95
14. 35' from Harrison & 50' from MacArthur sidewalk	FG	1	2.09	8.6	96	95

Project #: 38319  
Project Name: Johns Excavating  
Work Request #: DV545

---


**FIELD TEST RESULTS**

Location	Elevation	Curve No.	Field Density g/cc	Field Moisture %	Relative Comp. %	Project Specified %
15, 25' from Harrison & 25' from MacArthur sidewalk	FG	1	2.09	6.7	96	95

Note: FG = Finish Grade

**\*BELOW PROJECT SPECIFICATIONS**

NOTE: Test results constitute the reporting of factual information derived from test(s) made by our laboratory following prescribed procedures. These test results should not be considered as an engineering opinion with respect thereto.

Reviewed by:   
Terry R. Chiccino  
Soils & Asphalt Field Manager

cc:



# EXCAVATION PERMIT

## TO EXCAVATE IN STREETS OR OTHER SPECIFIED WORK

CIVIL  
ENGINEERING

PAGE 2 of 2

PERMIT NUMBER <b>X9800352</b>		SITE ADDRESS/LOCATION <b>96 MacArthur BL (off FRANKLIN)</b>
APPROX. START DATE	APPROX. END DATE	24-HOUR EMERGENCY PHONE NUMBER (Permit not valid without 24-Hour number)
CONTRACTOR'S LICENSE # AND CLASS		CITY BUSINESS TAX #

**ATTENTION:**

- State law requires that the contractor/owner call *Underground Service Alert (USA)* two working days before excavating. This permit is not valid unless applicant has secured an inquiry identification number issued by USA. The USA telephone number is 1 (800) 642-2444. UNDERGROUND SERVICE ALERT (USA) # \_\_\_\_\_
- 48 hours prior to starting work, YOU MUST CALL (510) 238-3651 TO SCHEDULE AN INSPECTION.**

**OWNER/BUILDER**

I hereby affirm that I am exempt from the Contractor's License Law for the following reason (Sec. 7031.5 Business and Professions Code: Any city or county which requires a permit to construct, alter, improve, demolish, or repair any structure, prior to its issuance; also requires the applicant for such permit to file a signed statement that he is licensed pursuant to the provisions of the Contractor's License law Chapter 9 (commencing with Sec. 7000) of Division 3 of the Business and Professions Code, or that he is exempt therefrom and the basis for the alleged exemption. Any violation of Section 7031.5 by any applicant for a permit subjects the applicant to a civil penalty of not more than \$500):

I, as an owner of the property, or my employees with wages as their sole compensation, will do the work, and the structure is not intended or offered for sale (Sec. 7044, Business Professions Code). The Contractor's License Law does not apply to an owner of property who builds or improves thereon, and who does such work himself or through his own employees, provided that such improvements are not intended or offered for sale. If however, the building or improvement is sold within one year of completion, the owner-builder will have the burden of proving that he did not build or improve for the purpose of sale)

I, as owner of the property, am exempt from the sale requirements of the above due to: (1) I am improving my principal place of residence or appurtenances thereto, (2) the work will be performed prior to sale, (3) I have resided in the residence for the 12 months prior to completion of the work, and (4) I have not claimed exemption on this subdivision on more than two structures more than once during any three-year period. (Sec. 7044 Business and Professions Code).

I, as owner of the property, am exclusively contracting with licensed contractors to construct the project. (Sec. 7044, Business and Professions Code: The Contractor's License Law does not apply to an owner of property who builds or improves thereon, and who contracts for such projects with a contractor(s) licensed pursuant to the Contractor's License Law).

I am exempt under Sec. \_\_\_\_\_ B&PC for this reason: \_\_\_\_\_

**WORKER'S COMPENSATION**

I hereby affirm that I have a certificate of consent to self-insure, or a certificate of Worker's Compensation Insurance, or a certified copy thereof (Sec. 3700, Labor Code).

Policy # \_\_\_\_\_ Company Name \_\_\_\_\_

I certify that in the performance of the work for which this permit is issued, I shall not employ any person in any manner so as to become subject to the Worker's Compensation Laws of California (not required for work valued at one hundred dollars (\$100) or less).

**NOTICE TO APPLICANT:** If, after making this Certificate of Exemption, you should become subject to the Worker's Compensation provisions of the Labor Code, you must forthwith comply with such provisions or this permit shall be deemed revoked. This permit is issued pursuant to all provisions of Title 12 Chapter 12.12 of the Oakland Municipal Code. It is granted upon the express condition that the permittee shall be responsible for all claims and liabilities arising out of work performed under the permit or arising out of permittee's failure to perform the obligations with respect to street maintenance. The permittee shall, and by acceptance of the permit agrees to defend, indemnify, save and hold harmless the City, its officers and employees, from and against any and all suits, claims, or actions brought by any person for or on account of any bodily injuries, disease or illness or damage to persons and/or property sustained or arising in the construction of the work performed under the permit or in consequence of permittee's failure to perform the obligations with respect to street maintenance. This permit is void 90 days from the date of issuance unless an extension is granted by the Director of the Office of Planning and Building.

I hereby affirm that I am licensed under provisions of Chapter 9 of Division 3 of the Business and Professions Code and my license is in full force and effect (if contractor), that I have read this permit and agree to its requirements, and that the above information is true and correct under penalty of law.

Signature of Permittee: *Ronald J. [Signature]* Date: **5-4-98**

Agent for  Contractor  Owner

DATE STREET LAST RESURFACED	SPECIAL PAVING DETAIL REQUIRED? <input type="checkbox"/> YES <input type="checkbox"/> NO	HOLIDAY RESTRICTION? (NOV 1 - JAN 1) <input type="checkbox"/> YES <input type="checkbox"/> NO	LIMITED OPERATION AREA? (7AM-9AM & 4PM-6PM) <input type="checkbox"/> YES <input type="checkbox"/> NO
ISSUED BY: <i>[Signature]</i>		DATE ISSUED: <b>5/4/98</b>	



# BUILDING SEWER INSPECTION PERMIT

206  
206

CIVIL ENGINEERING

PAGE 2 of 2

PERMIT NUMBER	3L980289
---------------	----------

SITE ADDRESS/LOCATION	96 MacArthur BL. (ON FRANKLIN ST)
-----------------------	-----------------------------------

ATTENTION:	<p>1) State law requires that the contractor/owner call <i>Underground Service Alert (USA)</i> two working days before excavating. This permit is not valid unless applicant has secured an inquiry identification number issued by USA. The USA telephone number is 1 (800) 642-2444. UNDERGROUND SERVICE ALERT (USA) # _____</p> <p>2) <b>48 hours prior to starting work, you must call to schedule an inspection. For the inspection of a sewer main connection, call (510) 615-5566. For any other type of sewer connection, call (510) 238-3651.</b></p> <p>3) All new sewers or sewer replacements will be air tested or water tested in accordance with Chapter 13.08.500 of the Oakland Municipal Code.</p>
------------	--

OWNER/BUILDER	<p>I hereby affirm that I am exempt from the Contractor's License Law for the following reason (Sec. 7031.5 Business and Professions Code: Any city or county which requires a permit to construct, alter, improve, demolish, or repair any structure, prior to its issuance, also requires the applicant for such permit to file a signed statement that he is licensed pursuant to the provisions of the Contractor's License Law Chapter 9 (commencing with Sec. 7000) of Division 3 of the Business and Professions Code, or that he is exempt therefrom and the basis for the alleged exemption. Any violation of Section 7031.5 by any applicant for a permit subjects the applicant to a civil penalty of not more than \$500):</p> <p><input type="checkbox"/> I, as an owner of the property, or any employees with wages as their sole compensation, will do the work, and the structure is not intended or offered for sale (Sec. 7044, Business Professions Code: The Contractor's License Law does not apply to an owner of property who builds or improves thereon, and who does such work himself or through his own employees, provided that such improvements are not intended or offered for sale. If however, the building or improvement is sold within one year of completion, the owner-builder will have the burden of proving that he did not build or improve for the purpose of sale).</p> <p><input type="checkbox"/> I, as owner of the property, am exempt from the sale requirements of the above due to: (1) I am improving my principal place of residence or appurtenances thereto, (2) the work will be performed prior to sale, (3) I have resided in the residence for the 12 months prior to completion of the work, and (4) I have not claimed exemption on this subdivision on more than two structures more than once during any three-year period. (Sec. 7044 Business and Professions Code).</p> <p><input type="checkbox"/> I, as owner of the property, am exclusively contracting with licensed contractors to construct the project. (Sec. 7044, Business and Professions Code: The Contractor's License Law does not apply to an owner of property who builds or improves thereon, and who contracts for such projects with a contractor(s) licensed pursuant to the Contractor's License Law).</p> <p><input type="checkbox"/> I am exempt under Sec. _____, B&amp;PC for this reason _____</p>
---------------	---

WORKER'S COMPENSATION	<p><input type="checkbox"/> I hereby affirm that I have a certificate of consent to self-insure, or a certificate of Worker's Compensation Insurance, or a certified copy thereof (Sec. 3700, Labor Code).</p> <p>Policy # _____ Company Name _____</p> <p><input type="checkbox"/> I certify that in the performance of the work for which this permit is issued, I shall not employ any person in any manner so as to become subject to the Worker's Compensation Laws of California (not required for work valued at one hundred dollars (\$100) or less).</p>
-----------------------	---

**NOTICE TO APPLICANT:** If, after making this Certificate of Exemption, you should become subject to the Worker's Compensation provisions of the Labor Code, you must forthwith comply with such provisions or this permit shall be deemed revoked. This permit is issued pursuant to all provisions of Title 13 Chapter 13.08 of the Oakland Municipal Code. It is granted upon the express condition that the permittee shall be responsible for all claims and liabilities arising out of work performed under the permit or arising out of permittee's failure to perform the obligations with respect to street maintenance. The permittee shall, and by acceptance of the permit agrees to defend, indemnify, save and hold harmless the City, its officers and employees, from and against any and all suits, claims, or actions brought by any person for or on account of any bodily injuries, disease or illness or damage to persons and/or property sustained or arising in the construction of the work performed under the permit or in consequence of permittee's failure to perform the obligations with respect to street maintenance.

I hereby affirm that I am licensed under provisions of Chapter 9 of Division 3 of the Business and Professions Code and my license is in full force and effect (if contractor), that I have read this permit and agree to its requirements, and that the above information is true and correct under penalty of law.	
Signature of Permittee <i>Ronald K. [Signature]</i>	Date 5-4-98
<input checked="" type="checkbox"/> Agent for <input type="checkbox"/> Contractor <input type="checkbox"/> Owner	

STREET EXCAVATION PERMIT REQUIRED? <input type="checkbox"/> YES <input type="checkbox"/> NO	SPECIAL PROVISIONS
ISSUED BY <i>[Signature]</i>	DATE ISSUED 5/4/98

LATERAL CAPPED ON PROPERTY  
STEVE FOSTER 5/18/98



Descr demolition of gas station w/ancillary structure (canopy)

Scope Incl Building: YES Electrical: NO Mechanical: NO Plumbing: NO  
 Work Type DEMOLITION #Units Plans Energy Calcs  
 Bldg Sq Ft 1,584 #Stories Survey Struct Calcs  
 Est Value Const Type Soil Report Occup Codes  
 Bldg Use FUEL DISPENSING STATION Zoning

Applicant Phone# Lic# License Classes  
 Owner TOSCO MARKETING CO (714)428-6425 361828 A  
 Contractor JOHN'S EXCAVATION X  
 Arch/Engr  
 Agent DON BARNETT (916)635-2444  
 Public Addr 1128 HALYARD DR, SANTA ROSA CA, 95401

\$628.16 TOTAL FEES PAID AT FILING

\$41.00	App'l	\$1.00	State Regs
\$232.00	Process	\$1.00	School
\$1.00	Bedroom	\$1.00	Plot Plan
\$1.00	Address	\$1.00	Electric
\$1.00	SMIP	\$1.00	Mechanical
\$51.66	Fire	\$1.00	Plumbing
\$258.50	Permit	\$19.37	Recd Mgmt
\$1.00	Invetg	\$25.83	Gen Plan
\$1.00	Other	\$1.00	Fld Chk
\$1.00	Zone Insp	\$1.00	Proc Coord

\$1.00 TOTAL FEES PAID AT ISSUANCE

Plans Processed By \_\_\_\_\_ Date \_\_\_\_\_ Permit Issued By \_\_\_\_\_ Date 5/4/98  
 Special Inspections \_\_\_\_\_  
 Finald By \_\_\_\_\_ Date \_\_\_\_\_

OWNER/BUILDER APPLICANT

I hereby affirm that I am exempt from the Contractors License Law for the following reason (Sec. 7031.5, Business and Professions Code: Any city or country which requires a permit to construct, alter, improve, renewish, or repair any structure, prior to its issuance, also requires the applicant for such permit to file a signed statement that he is licensed pursuant to the provisions of the Contractor's License Law Chapter 9 (commencing with Sec. 7000) of Division 3 of the Business and Professions Code, or that he is exempt therefrom and the basis for the alleged exemption. Any violation of Section 7031.6 by any applicant for a permit subjects the applicant to a civil penalty of not more than \$500).

I, as owner of the property, or my employees with wages as their sole compensation, will do the work, and the structure is not intended or offered for sale (Sec. 7044, Business and Professions Code: The Contractor's License Law does not apply to an Owner of property who builds or improves (thorough, and who does such work himself or through his own employees, provided that such improvements are not intended or offered for sale. If, however, the building or improvement is sold within one year of the completion, the owner-builder will have the burden of proving that he did not build or improve for the purpose of sale).

I, as owner of the property, am exempt from the said requirements of the above due to: (1) I am improving my principal place of residence or appurtenances thereto, (2) the work will be performed prior to each (3) I have resided in the residence for the 12 months prior to the completion of the work, and (4) I have not claimed exemption in this subdivision on more than two structures more than once during any three-year period. (Section 7044, Business and Professions Code)

I, as owner of the property, am exclusively contracting with licensed contractors to construct the project (Sec. 7044, Business and Professions Code. The Contractor's License Law does not apply to an owner of property who builds or improves thereon, and who contracts for such projects with a contractor's licensed pursuant to the Contractor's License Law).

I am exempt under Sec. \_\_\_\_\_ B&P.C. for this reason: \_\_\_\_\_

Signature of Owner or Authorized Agent \_\_\_\_\_ Date \_\_\_\_\_

I CERTIFY THAT I HAVE READ THIS APPLICATION AND STATE THAT THE INFORMATION GIVEN IS TRUE AND CORRECT. I AGREE TO COMPLY WITH ALL LOCAL ORDINANCES AND STATE LAWS RELATING TO BUILDING CONSTRUCTION AND I MAKE THIS STATEMENT UNDER PENALTY OF LAW. I HEREBY AUTHORIZE REPRESENTATIVES OF THE CITY TO ENTER UPON THE ABOVE MENTIONED PROPERTY FOR INSPECTION PURPOSES, EXCEPT IN THOSE CONSTRUCTION PROJECTS WHERE THE BUILDING OFFICIAL ISUE TO THE NATURE OF THE PROJECT, DEMS THESE LIMITATIONS TO BE UNREASONABLE. EVERY PERMIT ISSUED BY THE BUILDING OFFICIAL, UNDER THE PROVISIONS OF THIS CODE, SHALL EXPIRE BY LIMITATION AND BECOME NULL AND VOID IF THE BUILDING OR WORK AUTHORIZED BY SUCH PERMIT DOES NOT RECEIVE AN APPROVAL OF A MAJOR INSPECTION, AS FURTHER IDENTIFIED IN SECTION 9-14 OF THIS CHAPTER, WITHIN 180 DAYS FOLLOWING THE ISSUANCE DATE OF SUCH PERMIT OR PEN I OWING THE APPROVAL DATE OF A PREVIOUS MAJOR INSPECTION, DO NOT CONCEAL OR COVER ANY CONSTRUCTION UNITS UNTIL THE WORK IS INSPECTED AND THE INSPECTION RESCHEDULED BY THE BACK OF THE JOB COPY OF THIS PERMIT. ALL INSPECTION REQUESTS ARE REQUIRED AT LEAST 24 HOURS IN ADVANCE OF THE INSPECTION.

I hereby agree to save defend, indemnify and keep harmless the City of Oakland and its officers, employees, agents and volunteers from all actions, claims, demands, litigation, or proceedings, including those for Attorney's fees, arising the City in consequence of the granting of this permit or from the use or occupancy of any sidewalk, street or sub-sidewalk or otherwise by virtue thereof, and will in all things strictly comply with the conditions under which this permit is granted.

Contractor  
 Owner  
 Authorized Agent for:  Contractor  Owner  
 Address of Agent: \_\_\_\_\_ CITY \_\_\_\_\_ STATE \_\_\_\_\_ ZIP \_\_\_\_\_ TELEPHONE \_\_\_\_\_

I hereby affirm under penalty of perjury one of the following declarations:

I have and will maintain a certificate of consent to self-insure for worker's compensation, as provided for by Section 3700 of the Labor Code, for the performance of the work for which this permit is issued.

I have and will maintain worker's compensation insurance, as required by Section 3700 of the Labor Code, for the performance of the work for which this permit is issued. My worker's compensation insurance carrier and policy number are: \_\_\_\_\_

Carrier \_\_\_\_\_ Policy Number \_\_\_\_\_

(This section need not be completed if the permit is for one hundred dollars (\$100) or less)

I certify that in the performance of the work for which this permit is issued, I shall not employ any person in any manner so as to become subject to the workers compensation laws of California, and agree that (i) should become subject to the worker's compensation provisions of Section 3700 of the Labor Code, I shall forthwith comply with those provisions.

WARNING: Failure to secure worker's compensation is unlawful, and shall subject any employer to criminal penalties and civil fines up to one hundred thousand dollars (\$100,000), in addition to the cost of compensation, damages as provided for in Section 3706 of the Labor Code, interest, and attorney's fees.

Signature of Owner or Authorized Agent \_\_\_\_\_ Date \_\_\_\_\_

I hereby affirm, under penalty of perjury, that there is a construction lending agency for the performance of the work for which this permit is issued (Sec. 3087, Civ. C):

Lender's Name \_\_\_\_\_  
 Address \_\_\_\_\_  
 City \_\_\_\_\_ State \_\_\_\_\_ Zip \_\_\_\_\_ Phone \_\_\_\_\_

I hereby affirm that I am licensed under provisions of Chapter 9 (commencing with Section 7000) of Division 3 of the Business and Professions Code, and my license is in full force and effect.

License # and Class: 361828 A City Business TAX # \_\_\_\_\_  
 Contractor's Name: John's Excavation Phone: 707-578-\_\_\_\_\_  
 Signature: Ronald K. Brown Date: 5-4-98

DISTRICT ADDRESS: WORKER'S COMPENSATION LENDER CONTRACTOR

96 MacArthur Blvd

**INTEGRATED WASTESTREAM MANAGEMENT, INC.**

950 Ames Avenue, Milpitas, CA 95035  
 Phone: (408) 942-8955 Fax: (408) 942-1499

**BILL OF LADING TICKET**

Ticket No. 50183-ER

DATE: 5/6/98 TIME: 9:30 AM PM TRUCK/TRAILER NO. 102

COSIGNOR: SEAPORT PETROLEUM CORPORATION

COSIGNEE: TOSCO NORTHWEST / 96 MacArthur Blvd. Oakland, CA

PRODUCT	API/TEMP	GROSS GALLONS	NET GALLONS
GASOLINE 3, UN 1203 P.G. II		247	247
DIESEL FUEL 3, NA 1993 P.G. III LOW SULFUR 0.05% MAX			
DIESEL FUEL 3, NA 1993 P.G. III HIGH SULFUR			
METHYL TERTIARY BUTYL ETHER 3, P.G. III UN 2398			
ETHANOL 3, UN 1170 P.G. II			
METER READING — GROSS GALLONS:			
CARRIER: <u>INTEGRATED WASTESTREAM MANAGEMENT, INC.</u>			

CARRIER CERTIFIES THAT THE CONTAINER SUPPLIED FOR THIS SHIPMENT IS IN A PROPER CONTAINER FOR THE TRANSPORTATION OF THIS COMMODITY AS DESCRIBED ABOVE.

DESTINATION: SEAPORT PETROLEUM/ 675 Seaport Blvd., Port of Redwood City, CA 94063

PRODUCT REC'D IN GOOD ORDER: Javier R. Valdes 5-11-98

IN EVENT OF HAZARDOUS MATERIAL INCIDENT CALL: CHEMTREC 1/800-424-9307

ALAMEDA COUNTY HEALTH CARE SERVICE AGENCY  
 DEPARTMENT OF ENVIRONMENTAL HEALTH  
 ENVIRONMENTAL PROTECTION DIVISION  
 1131 HARBOR BAY PARKWAY, RM 250  
 ALAMEDA, CA 94502-6577  
 PHONE # 510/567-6700  
 FAX # 510/337-9335

ROBERT WESTON

Project Specialist

ACCEPTED

Underground Storage Tank Closure Permit Application  
 Alameda County Division of Hazardous Materials  
 1131 Harbor Bay Parkway, Suite 250  
 Alameda, CA 94502-6577

These closure/removal plans have been received and found to be acceptable and essentially meet the requirements of State and Local Health Laws. Changes to your closure plans indicated by this Department are to assure compliance with State and local laws. The project proposed herein is not released for issuance of any required building permits for construction/destruction.

One copy of the accepted plans must be on the job and available to all contractors and craftsmen involved with the removal.

Any changes or alterations of these plans and specifications must be submitted to this Department and to the Fire and Building Inspection Department to determine if such changes meet the requirements of State and local laws. Notify this Department at least 72 hours prior to the following required inspections:

- Removal of Tank(s) and Piping
- Sampling
- Final Inspection

Issuance of a) permit to operate, b) permanent site closure, is dependent on compliance with accepted plans and all applicable laws and regulations.

THERE IS A FINANCIAL PENALTY FOR NOT OBTAINING THESE INSPECTIONS.

Contact Specialist

APRIL 15, 1998

CONTRACTOR REQUIRED TO SIGN PLAN. SAFETY PLAN TO BE ON-SITE. SEE DETAILS FOR SAMPLING IN TABLE 2.

PW

UNDERGROUND TANK CLOSURE PLAN

\*\*\* Complete according to attached instructions \*\*\*

1. Name of Business TOSCO SERVICE STATION #1871  
 Business Owner or Contact Person (PRINT) MR. STEVE GUIN
  2. Site Address M<sup>A</sup>ARTHUR BL. & HARRISON ST  
 city OAKLAND, CA zip 94610 Phone 510-6553670
  3. Mailing Address \_\_\_\_\_  
 City \_\_\_\_\_ Zip \_\_\_\_\_ Phone \_\_\_\_\_
  4. Property owner TOSCO MARKETING COMPANY  
 Business Name (if applicable) \_\_\_\_\_  
 Address P.O. BOX 1948, 76 BROADWAY  
 city, state SACRAMENTO, CA zip 95812-1948
  5. Generator name under which tank will be manifested  
CALIFORNIA HAZARDOUS MATERIALS TOSCO
- EPA ID# under which tank will be manifested CA R 0 0 0 0 3 1 2 1 1



6. Contractor TBA JOHN'S EXCAVATING  
Address 1128 HALYARD DRIVE  
City SANTA ROSA Phone 707-578-1184  
License Type A HAZ ID# 361828

\*Effective January 1, 1992, Business and Professional Code, Section 7058.7 requires prime contractors to also hold Hazardous Waste Certification issued by the State Contractors License Board.

7. Consultant (if applicable) TAIT AND ASSOCIATES  
Address 2880 SUNRISE BLVD STE 206  
City, state RANCHO CORDOVA, CA Phone (916) 635-2444

8. Main Contact Person for Investigation (if applicable)  
Name STEVE GUIN Title CONTRACT ENGINEER  
Company TOSCO MARKETING COMPANY  
Phone (916)-558-7607

9. Number of underground tanks being closed with this plan 3  
Length of piping being removed under this plan \_\_\_\_\_  
Total number of underground tanks at this facility (\*\*confirmed with owner or operator) 3

10. State Registered Hazardous Waste Transporters/Facilities (see instructions).

\*\* Underground storage tanks must be handled as hazardous waste \*\*

a) Product/Residual Sludge/Rinsate Transporter  
Name ERICKSON, INC. EPA I.D. No. CAD009466392  
Hauler License No. \_\_\_\_\_ License Exp. Date \_\_\_\_\_  
Address 255 PARR BLVD.  
City RICHMOND State CA zip 94801

b) Product/Residual Sludge/Rinsate Disposal Site  
Name ERICKSON, INC. EPA ID# CAD009466392  
Address 255 PARR BLVD  
City RICHMOND State CA zip 94801

c) Tank and Piping Transporter

Name ERICKSON INC. EPA I.D. No. CAD 009466392  
Hauler License No. \_\_\_\_\_ License Exp. Date \_\_\_\_\_  
Address 255 PARR BLVD  
City Richmond State CA Zip 94801

d) Tank and Piping Disposal Site

Name ERICKSON INC EPA I.D. No. CAD 009466392  
Address 255 PARR BLVD.  
City Richmond State CA Zip 94801

11. Sample Collector

Name \_\_\_\_\_  
Company TEAM ENGINEERING  
Address P.O. Box 1265  
City BISHOP State CA Zip 93515 Phone 760-872-1033

12. Laboratory

Name BC LABORATORIES Ph. no. (805) 327-4911  
Address 4100 Atlas Ct.  
City BAKERSFIELD State CA Zip 93308  
State Certification No. \_\_\_\_\_

13. Have tanks or pipes leaked in the past? Yes[ ] No[ ] Unknown[]

If yes, describe. \_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

14. Describe methods to be used for rendering tanks inert:

SEE J-0 SPECIFICATIONS.

Before tanks are pumped out and inerted, all associated piping must be flushed out into the tanks. All accessible associated piping must then be removed. Inaccessible piping must be permanently plugged.

The Bay Area Air Quality Management District, 415/771-6000, along with local Fire and Building Departments, must also be contacted for tank removal permits. Fire departments typically require the use of a combustible gas indicator to verify tank inertness. It is the contractor's responsibility to bring a working combustible gas indicator on-site to verify that the tank is inert.

15. Tank History and Sampling Information \*\*\* (see instructions) \*\*\*

Tank		Material to be sampled (tank contents, soil, groundwater)	Location and Depth of Samples
Capacity	Use History include date last used (estimated)		
1) 12,000-gal.	12-12-84 TO 12-15-97	SOIL, H <sub>2</sub> O	TWO FEET INTO NATIVE SOIL -
2) 12,000 gal.	12-12-84 TO 12-15-97		
3) 280 gal WASTE OIL	12-12-84 TO 12-15-97		

One soil sample must be collected for every 20 linear feet of piping that is removed. A ground water sample must be collected if any ground water is present in the excavation.

**Excavated/Stockpiled Soil**

Stockpiled Soil Volume (estimated)	Sampling Plan
------------------------------------	---------------

Stockpiled soil must be placed on bermed plastic and must be completely covered by plastic sheeting.

Will the excavated soil be returned to the excavation immediately after tank removal? [ ] yes [ ] no [ ] unknown

If yes, explain reasoning \_\_\_\_\_

If unknown at this point in time, please be aware that excavated soil may not be returned to the excavation without prior approval from Alameda County. This means that the contractor, consultant, or responsible party must communicate with the Specialist IN ADVANCE of backfilling operations.

16. Chemical methods and associated detection limits to be used for analyzing samples:

The Tri-Regional Board recommended minimum verification analyses and practical quantitation reporting limits should be followed. See attached Table 2.

17. Submit Site Health and Safety Plan (See Instructions)

Contaminant Sought	EPA or Other Sample Preparation Method Number	EPA or Other Analysis Method Number	Method Detection Limit
	SEE ATTACHED TABLE # 2 SAMPLING PROTOCOL		
	* INCLUDE ANALYSIS FOR MTBE IN GASOLINE SAMPLES.		

**TABLE #2**  
RECOMMENDED MINIMUM VERIFICATION ANALYSES FOR  
UNDERGROUND TANK LEAKS

<u>HYDROCARBON LEAK</u>	<u>SOIL ANALYSIS</u>		<u>WATER ANALYSIS</u>	
Unknown Fuel	TPH G	GCFID(5030)	TPH G	GCFID(5030)
	TPH D	GCFID(3550)	TPH D	GCFID(3510)
	BTX&E	8020 or 8240	BTX&E	602, 624 or 8260
	TPH AND BTX&E	8260		
Leaded Gas	TPH G	GCFID(5030)	TPH G	GCFID(5030)
	BTX&E	8020 OR 8240	BTX&E	602 or 624
	TPH AND BTX&E	8260	TOTAL LEAD AA	
	TOTAL LEAD AA			
	-----Optional-----			
	TEL	DHS-LUFT	TEL	DHS-LUFT
	EDB	DHS-AB1803	EDB	DHS-AB1803
* Unleaded Gas	TPH G	GCFID(5030)	TPH G	GCFID(5030)
	BTX&E	8020 or 8240	BTX&E	602, 624 or 8260
	TPH AND BTX&E	8260		
Diesel, Jet Fuel and Kerosene	TPH D	GCFID(3550)	TPH D	GCFID(3510)
	BTX&E	8020 or 8240	BTX&E	602, 624 or 8260
	TPH AND BTX&E	8260		
Fuel/Heating Oil	TPH D	GCFID(3550)	TPH D	GCFID(3510)
	BTX&E	8020 or 8240	BTX&E	602, 624 or 8260
	TPH AND BTX&E	8260		
Chlorinated Solvents	CL HC	8010 or 8240	CL HC	601 or 624
	BTX&E	8020 or 8240	BTX&E	602 or 624
	CL HC AND BTX&E	8260	CL HC AND BTX&E	8260
Non-chlorinated Solvents	TPH D	GCFID(3550)	TPH D	GCFID(3510)
	BTX&E	8020 or 8240	BTX&E	602 or 624
	TPH AND BTX&E	8260	TPH and BTX&E	8260
Waste and Used Oil or Unknown (All analyses must be completed and submitted)	TPH G	GCFID(5030)	TPH G	GCFID(5030)
	TPH D	GCFID(3550)	TPH D	GCFID(3510)
	TPH AND BTX&E	8260		
	O & G	5520 D & F	O & G	5520 B & F
	BTX&E	8020 or 8240	BTX&E	602, 624 or 8260
	CL HC	8010 or 8240	CL HC	601 or 624
	ICAP or AA TO DETECT METALS: Cd, Cr, Pb, Zn, Ni			
	METHOD 8270 FOR SOIL OR WATER TO DETECT:			
	PCB*		PCB	
	PCP*		PCP	
	PNA		PNA	
	CREOSOTE		CREOSOTE	

\* If found, analyze for dibenzofurans (PCBs) or dioxins (PCP)

Reference: Tri-Regional Board Staff Recommendations for Preliminary Evaluation and Investigation of Underground Tank Sites, 10 August 1990

18. Submit Worker's Compensation Certificate copy  
 Name of Insurer STATE FUND
19. Submit Plot Plan **\*\*\* (See Instructions) \*\*\***
20. Enclose Deposit (See Instructions)
21. Report any leaks or contamination to this office within 5 days of discovery.  
 The written report shall be made on an Underground Storage Tank Unauthorized Leak/Contamination Site Report (ULR) form.
22. Submit a closure report to this office within 60 days of the tank removal. The report must contain all information listed in item 22 of the instructions.
23. Submit State (Underground Storage Tank Permit Application) Forms A and B (one B form for each UST to be removed) (mark box 8 for "tank removed" in the upper right hand corner)

I declare that to the best of my knowledge and belief that the statements and information provided above are correct and true.

I understand that information, in addition to that provided above, may be needed in order to obtain approval from the Environmental Protection Division and that no work is to begin on this project until this plan is approved.

I understand that any changes in design, materials or equipment will void this plan if prior approval is not obtained.

I understand that all work performed during this project will be done in compliance with all applicable OSHA (Occupational Safety and Health Administration) requirements concerning personnel health and safety. I understand that site and worker safety are solely the responsibility of the property owner or his agent and that this responsibility is not shared nor assumed by the County of Alameda.

Once I have received my stamped, accepted closure plan, I will contact the project Hazardous Materials Specialist at least three working days in advance of site work to schedule the required inspections.

CONTRACTOR INFORMATION

Name of Business JOHN'S EXCAVATING  
 Name of Individual JOHN PULLSON  
 Signature Carolyn Pullson (Office Manager) Date 4-28-97

PROPERTY OWNER OR MOST RECENT TANK OPERATOR (Circle one)

Name of Business TOSCO MARKETING CO.  
 Name of Individual STEVE GUIN  
 Signature Stephan Morales (agent for owner) Date 11/26/97

**ALAMEDA COUNTY ENVIRONMENTAL PROTECTION DIVISION**

**DECLARATION OF SITE ACCOUNT REFUND RECIPIENT**

There may be excess funds remaining in the Site Account at the completion of this project. The PAYOR (person or company that issues the check) will use this form to predesignate another party to receive any funds refunded at the completion of this project. In the absence of this form, the PAYOR will receive the refund.

**SITE INFORMATION:**

1120  
Site ID Number  
(if known)

Tosco Service Station # 1871  
Name of Site

MACARTHUR BLVD + HARRISON ST.  
Street Address

OAKLAND, CA  
City, State & Zip Code

I designate the following person or business to receive any refund due at the completion of all deposit/refund projects:

TOSCO MARKETING Co.  
Name

P.O. BOX 1948 (76 BROADWAY AVE)  
Street Address

SACRAMENTO, CA 95812-1948  
City, State & Zip Code

Stephanie Morales (agent for owner) 11/26/97  
Signature of Payor TAIT + ASSOCIATES Date

Stephanie Morales (agent for owner) TAIT + ASSOCIATES  
Name of Payor Company Name of Payor  
(PLEASE PRINT CLEARLY)

**RETURN FORM TO:**  
County of Alameda, Environmental Protection  
1131 Harbor Bay Parkway, Rm 250  
Alameda CA 94502-6577  
Phone#(510) 567-6700



95788282  
 IN CASE OF EMERGENCY OR SPILL, CALL THE NATIONAL RESPONSE CENTER 1-800-424-8802; WITHIN CALIFORNIA, CALL 1-800-852-7550  
 GENERATOR  
 FACILITY

<b>UNIFORM HAZARDOUS WASTE MANIFEST</b>		1. Generator's US EPA ID No. <b>CAL000175940</b>	Manifest Document No. <b>8282</b>		2. Page 1 of 1	Information in the shaded areas is not required by Federal law.	
3. Generator's Name and Mailing Address <b>SITE ADDRESS: 46 MACARTHUR #1871 OAKLAND, CA (CAL000175940)</b>		4. Generator's Phone		5. Transporter 1 Company Name		6. US EPA ID Number	
7. Transporter 2 Company Name		8. US EPA ID Number		9. Designated Facility Name and Site Address <b>CAD 009186039D</b>		10. US EPA ID Number	
11. US DOT Description (including Proper Shipping Name, Hazard Class, and ID Number)		12. Containers No. Type		13. Total Quantity		14. Unit Wt/Vol	
a. <b>NON-PCRA HAZARDOUS WASTE SOLID (Waste Oil Tank) WASTE EMPTY STORAGE TANK</b>		10 010K		12 0000		P 30 3 9	
b. <b>NON-PCRA HAZARDOUS WASTE SOLID (Waste Oil Tank) WASTE EMPTY STORAGE TANK</b>		001T		00550		P 1	
c.							
d.							
15. Special Handling Instructions and Additional Information		2		01		01	
16. GENERATOR'S CERTIFICATION: I hereby declare that the contents of this consignment are fully and accurately described above by proper shipping name and are classified, packed, marked, and labeled, and are in all respects in proper condition for transport by highway according to applicable international and national government regulations.  If I am a large quantity generator, I certify that I have a program in place to reduce the volume and toxicity of waste generated to the degree I have determined to be economically practicable and that I have selected the practicable method of treatment, storage, or disposal currently available to me which minimizes the present and future threat to human health and the environment; OR, if I am a small quantity generator, I have made a good faith effort to minimize my waste generation and select the best waste management method that is available to me and that I can afford.							
Printed/Typed Name <b>T. Berry</b>		Signature <i>J. Berry</i>		Month Day Year <b>05 11 1998</b>			
17. Transporter 1 Acknowledgement of Receipt of Materials		Printed/Typed Name <b>IVAN L. BRETHERMAN</b>		Signature <i>Ivan L. Brettherman</i>		Month Day Year <b>05 11 1998</b>	
18. Transporter 2 Acknowledgement of Receipt of Materials		Printed/Typed Name		Signature		Month Day Year	
19. Discrepancy Indication Space <b>Corrections to 11 a+b above to correct tank capacities.</b>							
20. Facility Owner or Operator Certification of receipt of hazardous materials covered by this manifest except as noted in Item 19.		Printed/Typed Name <b>DAVID SATO</b>		Signature <i>DAVE SATO</i>		Month Day Year <b>05 11 1998</b>	

DO NOT WRITE BELOW THIS LINE.

IN CASE OF EMERGENCY OR SPILL, CALL THE NATIONAL RESPONSE CENTER 1-800-424-8802; WITHIN CALIFORNIA, CALL 1-800-872-7550

<b>UNIFORM HAZARDOUS WASTE MANIFEST</b>		1. Generator's EPA ID No.	Manifest Document No.		2. Page 1 of 1	Information in the shaded areas is not required by Federal law.	
3. Generator's Name and Mailing Address		CA, L 000775940 3 8 2 8 3		Site Address: 96 MACARTHUR #1871 OAKLAND, CA		Manifest ID Number: 95780283	
4. Generator's Phone		6. US EPA ID Number		C. State Transporter ID		D. Transporter's Phone	
5. Transporter 1 Company Name		7. Transporter 2 Company Name		E. State Transporter ID		F. Transporter's Phone	
9. Designated Facility Name and Site Address		10. US EPA ID Number		G. State Facility ID		H. Facility's Phone	
AD100914063A2							
11. US DOT Description (including Proper Shipping Name, Hazard Class, and ID Number)		12. Containers		13. Total	14. Unit	Waste Number	
		No.	Type	Quantity	Wt/Vol	State	
a.		001		12000		EPA/Other	
b.						State	
c.						EPA/Other	
d.						State	
						EPA/Other	
15. Special Handling Instructions and Additional Information		22614		Handling Code for Waste List 1-14		01	
16. GENERATOR'S CERTIFICATION: I hereby declare that the contents of this consignment are fully and accurately described above by proper shipping name and are classified, packed, marked, and labeled, and are in all respects in proper condition for transport by highway according to applicable international and national government regulations.							
If I am a large quantity generator, I certify that I have a program in place to reduce the volume and toxicity of waste generated to the degree I have determined to be economically practicable and that I have selected the practicable method of treatment, storage, or disposal currently available to me which minimizes the present and future threat to human health and the environment; OR, if I am a small quantity generator, I have made a good faith effort to minimize my waste generation and select the best waste management method that is available to me and that I can afford.							
Printed/Typed Name		Signature		Month	Day	Year	
TICA BERRY		T. Berry		05	11	1998	
17. Transporter 1 Acknowledgement of Receipt of Materials		Signature		Month	Day	Year	
Printed/Typed Name		Signature		Month	Day	Year	
DAVE FLURY		Dave Flury		05	11	1998	
18. Transporter 2 Acknowledgement of Receipt of Materials		Signature		Month	Day	Year	
Printed/Typed Name		Signature		Month	Day	Year	
19. Discrepancy Indication Space		Signature		Month	Day	Year	
Printed/Typed Name		Signature		Month	Day	Year	
DAVID SATO		DAVE SATO		05	11	1998	

DO NOT WRITE BELOW THIS LINE.

DAY OR NIGHT  
TELEPHONE  
(510) 235-1393

# CERTIFICATE CERTIFIED SERVICES COMPANY

255 Parr Boulevard • Richmond, California 94801

NO. 26006

CUSTOMER
JOB NO. 972154
JOHN'S EXC

FOR: ERICKSON, INC. TANK NO. 22614

LOCATION: RICHMOND, CA DATE: 5/19/88 TIME: 9:22:49 AM

TEST METHOD VISUAL GASTECH/1314 SMPN LAST PRODUCT UG

This is to certify that I have personally determined that this tank is in accordance with the American Petroleum Institute and have found the condition to be in accordance with its assigned designation. This certificate is based on conditions existing at the time the inspection herein set forth was completed and is issued subject to compliance with all qualifications and instructions.

TANK SIZE 12,000 GALLON TANK CONDITION SAFE FOR FIRE

REMARKS: OXYGEN 20.9% LOWER EXPLOSIVE LIMIT LESS THAN 0.1% ERICKSON, INC. HERBY CERTIFIES THAT THE ABOVE NUMBERED TANK HAS BEEN CUT OPEN, PROCESSED, AND THEREFORE DESTROYED AT OUR PERMITTED HAZARDOUS WASTE FACILITY.  
ERICKSON, INC. HAS THE APROPRIATE PERMITS FOR, AND HAS ACCEPTED THE TANK SHIPPED TO US FOR PROCESSING.

In the event of any physical or atmospheric changes affecting the gas-free conditions of the above tanks, or if in any doubt, immediately stop all hot work and contact the undersigned. This permit is valid for 24 hours if no physical or atmospheric changes occur.

## STANDARD SAFETY DESIGNATION

**SAFE FOR MEN:** Means that in the compartment or space so designated (a) The oxygen content of the atmosphere is at least 19.5 percent by volume; and that (b) Toxic materials in the atmosphere are within permissible concentrations; and (c) In the judgment of the Inspector, the residues are not capable of producing toxic materials under existing atmospheric conditions while maintained as directed on the Inspector's certificate.

**SAFE FOR FIRE:** Means that in the compartment so designated (a) The concentration of flammable materials in the atmosphere is below 10 percent of the lower explosive limit; and that (b) In the judgment of the Inspector, the residues are not capable of producing a higher concentration that permitted under existing atmospheric conditions in the presence of fire and while maintained as directed on the Inspector's certificate, and further, (c) All adjacent spaces have either been cleaned sufficiently to prevent the spread of fire, are satisfactorily inerted, or in the case of fuel tanks, have been treated as deemed necessary by the Inspector.

The undersigned representative acknowledges receipt of this certificate and understands the conditions and limitations under which it was issued.

Lancea Collier  
REPRESENTATIVE

TITLE

Dave Jato  
INSPECTOR

DAY OR NIGHT  
TELEPHONE  
(510) 235-1393

# CERTIFICATE CERTIFIED SERVICES COMPANY

255 Parr Boulevard • Richmond, California 94801

NO. 26007

CUSTOMER
JOB NO. 972154
JOHN'S EXC

FOR: ERICKSON, INC. TANK NO. 22815

LOCATION: RICHMOND, CA DATE: 5/20/98 TIME: 9:24:31 AM

TEST METHOD VISUAL GASTECH/1314 SMPN LAST PRODUCT UO

This is to certify that I have personally determined that this tank is in accordance with the American Petroleum Institute and have found the condition to be in accordance with its assigned designation. This certificate is based on conditions existing at the time the inspection herein set forth was completed and is issued subject to compliance with all qualifications and instructions.

TANK SIZE 550 GALLON TANK CONDITION SAFE FOR FIRE

REMARKS: OXYGEN 20.9% LOWER EXPLOSIVE LIMIT LESS THAN 0.1% ERICKSON, INC. HERBY CERTIFIES THAT THE ABOVE NUMBERED TANK HAS BEEN CUT OPEN, PROCESSED, AND THEREFORE DESTROYED AT OUR PERMITTED HAZARDOUS WASTE FACILITY.  
ERICKSON, INC. HAS THE APROPRIATE PERMITS FOR, AND HAS ACCEPTED THE TANK SHIPPED TO US FOR PROCESSING.

In the event of any physical or atmospheric changes affecting the gas-free conditions of the above tanks, or if in any doubt, immediately stop all hot work and contact the undersigned. This permit is valid for 24 hours if no physical or atmospheric changes occur.

## STANDARD SAFETY DESIGNATION

**SAFE FOR MEN:** Means that in the compartment or space so designated (a) The oxygen content of the atmosphere is at least 19.5 percent by volume; and that (b) Toxic materials in the atmosphere are within permissible concentrations; and (c) In the judgment of the Inspector, the residues are not capable of producing toxic materials under existing atmospheric conditions while maintained as directed on the Inspector's certificate.

**SAFE FOR FIRE:** Means that in the compartment so designated (a) The concentration of flammable materials in the atmosphere is below 10 percent of the lower explosive limit; and that (b) In the judgment of the Inspector, the residues are not capable of producing a higher concentration than permitted under existing atmospheric conditions in the presence of fire and while maintained as directed on the Inspector's certificate, and further, (c) All adjacent spaces have either been cleaned sufficiently to prevent the spread of fire, are satisfactorily inerted, or in the case of fuel tanks, have been treated as deemed necessary by the Inspector.

The undersigned representative acknowledges receipt of this certificate and understands the conditions and limitations under which it was issued.

Ratree Collier  
REPRESENTATIVE

TITLE

Dave Jato  
INSPECTOR

DAY OR NIGHT  
TELEPHONE  
(510) 235-1393

# CERTIFICATE CERTIFIED SERVICES COMPANY

255 Parr Boulevard • Richmond, California 94801

NO. 26008

CUSTOMER

JOB NO. 972154

JOHN'S EXC

FOR: ERICKSON, INC. TANK NO. 22616

LOCATION: RICHMOND, CA DATE: 5/19/98 TIME: 9:25:16 AM

TEST METHOD VISUAL GASTECH/1314 SMPN LAST PRODUCT UG

This is to certify that I have personally determined that this tank is in accordance with the American Petroleum Institute and have found the condition to be in accordance with its assigned designation. This certificate is based on conditions existing at the time the inspection herein set forth was completed and is issued subject to compliance with all qualifications and instructions.

TANK SIZE 12,000 GALLON TANK CONDITION SAFE FOR FIRE

REMARKS: OXYGEN 20.9% LOWER EXPLOSIVE LIMIT LESS THAN 0.1% ERICKSON, INC. HERBY CERTIFIES THAT THE  
ABOVE NUMBERED TANK HAS BEEN CUT OPEN, PROCESSED, AND THEREFORE DESTROYED AT OUR  
PERMITTED HAZARDOUS WASTE FACILITY.  
ERICKSON, INC. HAS THE APROPRIATE PERMITS FOR, AND HAS ACCEPTED THE TANK SHIPPED TO US  
FOR PROCESSING.

In the event of any physical or atmospheric changes affecting the gas-free conditions of the above tanks, or if in any doubt, immediately stop all hot work and contact the undersigned. This permit is valid for 24 hours if no physical or atmospheric changes occur.

## STANDARD SAFETY DESIGNATION

**SAFE FOR MEN:** Means that in the compartment or space so designated (a) The oxygen content of the atmosphere is at least 19.5 percent by volume; and that (b) Toxic materials in the atmosphere are within permissible concentrations; and (c) In the judgment of the Inspector, the residues are not capable of producing toxic materials under existing atmospheric conditions while maintained as directed on the Inspector's certificate.

**SAFE FOR FIRE:** Means that in the compartment so designated (a) The concentration of flammable materials in the atmosphere is below 10 percent of the lower explosive limit; and that (b) In the judgment of the Inspector, the residues are not capable of producing a higher concentration that permitted under existing atmospheric conditions in the presence of fire and while maintained as directed on the Inspector's certificate, and further, (c) All adjacent spaces have either been cleaned sufficiently to prevent the spread of fire, are satisfactorily inerted, or in the case of fuel tanks, have been treated as deemed necessary by the Inspector.

The undersigned representative acknowledges receipt of this certificate and understands the conditions and limitations under which it was issued.

REPRESENTATIVE

TITLE

INSPECTOR