

RECEIVED

1:13 pm, Apr 13, 2009

00  
21

Alameda County  
Environmental Health

FILE # 1871 SS  
white -env.health  
RPT yellow -capillary TRANS  
pink -files  
2 3 ✓ 4

ALAMEDA COUNTY, DEPARTMENT  
ENVIRONMENTAL HEALTH  
Hazardous Materials Inspection Form

II, III

Site ID # \_\_\_\_\_ Site Name Unocal Today's Date 4/13/09

Site Address 96 MacArthur Blvd

City Oakland Zip 94610 Phone \_\_\_\_\_

MAX AMT stored > 500 lbs, 55 gal., 200 cft.?

Inspection Categories:

- I. Haz. Mat/Waste GENERATOR/TRANSPORTER
- II. Business Plans, Acute Hazardous Materials
- III. Underground Tanks 280-gal removal of waste oil UST

Calif. Administration Code (CAC) or the Health & Safety Code (HS&C)

11:10 arrived onsite  
Comments: Larry James of OFD onsite.

11:25 Removal of UST: tar wrapped, no obvious holes. Soil in pit is stained. ~80 gal waste oil was removed recently for UST. UST hauled by Erickson under manifest # 93238754. Tank invert at 7' bgs. Excavated the area, there is soil to 9' bgs. 12:25 Tank bottom sample at ~9' bgs. Sample is clayey silt, green w/ slight HC odor.

12:30 Continued excavating bottom sides; they plan to install a new UST in same pit. The soil's odor is like gasoline; that appear to be waste oil. 1:00 Took bottom sample at 14' bgs. This is the capillary fringe. Sample is moist, sandy silt w/ gravel. 1:05 Began sampling the 4 walls at 9' bgs, which are also stained near + have gasoline odor. We don't want to disrupt their business any more by chasing the plume laterally; another well may be necessary. Stockpile is ~50 yd<sup>3</sup> + will be properly sampled + disposed.

12:5 left site

Contact: ROBERT BOUST  
Title: Site Env. Eng.  
Signature: Robert Boust

Inspector: Jennifer Eberle  
Signature: J Eberle

II, III

II.A BUSINESS PLANS (Title 19)

- 1. Immediate Reporting 2703
- 2. Bus. Plan Stds. 25503(b)
- 3. RR Cars > 30 days 25503.7
- 4. Inventory Information 25504(a)
- 5. Inventory Complete 2730
- 6. Emergency Response 25504(b)
- 7. Training 25504(c)
- 8. Deficiency 25505(a)
- 9. Modification 25505(c)

II.B ACUTELY HAZ. MATLS

- 10. Registration Form Filed 25533(a)
- 11. Form Complete 25533(b)
- 12. RMPP Contents 25534(c)
- 13. Implement Sch. Req'd? (Y/N)
- 14. OHSite Conseq. Assess. 25524(c)
- 15. Probable Risk Assessment 25534(d)
- 16. Persons Responsible 25534(g)
- 17. Certification 25534(i)
- 18. Exemption Request? (Y/N) 25536(b)
- 19. Trade Secret Requested? 25538

III. UNDERGROUND TANKS (Title 23)

- 1. Permit Application 25284 (H&S)
- 2. Pipeline Leak Detection 25292 (H&S)
- 3. Records Maintenance 2712
- 4. Release Report 2651
- 5. Closure Plans 2670

- 6. Method
  - 1) Monthly Test
  - 2) Daily Vadose Semi-annual groundwater One time test
  - 3) Daily Vadose One time test Annual tank test
  - 4) Monthly Groundwater One time test
  - 5) Daily Inventory Annual tank testing Cont pipe leak det Vadose/gndwater mon.
  - 6) Daily Inventory Annual tank testing Cont pipe leak det
  - 7) Weekly Tank Gauge Annual tank test
  - 8) Annual Tank Testing Daily Inventory
  - 9) Other

- 7. Precls Tank Test Date: 2643
- 8. Inventory Rec. 2644
- 9. Soil Testing 2646
- 10. Ground Water 2647

- 11. Monitor Plan 2632
- 12. Access, Secure 2634
- 13. Plans Submit Date: 2711
- 14. As Built Date: 2638

Monitoring for Existing Tanks

New Tanks

Rev 6/88