

RECEIVED

9:59 am, Jan 18, 2011

Alameda County
Environmental Health



ENVIRONMENTAL ENGINEERING, INC.
6620 Owens Drive, Suite A • Pleasanton, CA 94588
TEL (925)734-6400 • FAX (925)734-6401
www.somaenv.com

January 17, 2011

Ms. Audrey Comeaux
East Bay Municipal Utility District
P. O. Box 24055
Oakland, CA 94623-1055

Re: 3820 Manila Avenue, Oakland, CA
Wastewater Discharge Permit No. 50638151


Dear Ms. Comeaux:

As you requested, enclosed is SOMA's "Second Semi-Annual 2010 Self-Monitoring Report" for the subject permit. This report has been uploaded to the State's GeoTracker database.

Thank you for your time in reviewing our report. If you have any questions or comments, please call me at (925) 734-6400.

Sincerely,

Mansour Sepehr, Ph.D., PE
Principal Hydrogeologist



Enclosure

cc: Mr. Jerry Wickham, Alameda County Dept. of Env. Health w/o enclosure
Mr. Albert M. Cohen, LOEB&LOEB LLP w/enclosure

**Second Semi-Annual 2010 Self-Monitoring Report
Treatment System Discharge to EBMUD Sewer
For Permit No. 50638151**

**The Former Glovatorium Facility
3820 Manila Avenue
Oakland, California**

January 17, 2011

Project 2515

Prepared for:

**Loeb & Loeb LLP
10100 Santa Monica Boulevard, Suite 2200
Los Angeles, California 90067-4164**



ENVIRONMENTAL ENGINEERING, INC.

6620 Owens Drive Suite A Pleasanton CA 94588 Ph: 925.734.6400 F: 925.734-6401 www.somaenv.com

Perjury Statement

Stuart Depper
Name

Responsible Party
Title

3820 Manila Avenue Oakland 94609
Street Address City Zip

I declare under penalty of perjury that the information and/or recommendations contained in the attached document or report were prepared under my direction and to the best of my knowledge true and correct.



Signature

1-17-11
Date

CERTIFICATION

SOMA Environmental Engineering, Inc. has prepared this report for the Law Offices of Loeb & Loeb LLP, to comply with East Bay Municipal Utility District requirements for discharge of extracted and treated groundwater resulting from cleanup of groundwater using Multi-Phase Extraction technology.



Mansour Sepehr, PhD, PE
Principal Hydrogeologist



TABLE OF CONTENTS

CERTIFICATION	i
LIST OF TABLES.....	ii
1. INTRODUCTION	1
2. MULTI-PHASE EXTRACTION PILOT TESTING AND TREATMENT SYSTEM OPERATION	1
3. CONCLUSIONS	2

LIST OF TABLES

Table 1: Total Volume of Water Treated, Operational Data, and Laboratory Analytical Results for Effluent Samples

LIST OF APPENDICES

Appendix A: Laboratory Results and Chain of Custody Forms for the Treatment System

1. INTRODUCTION

SOMA Environmental Engineering, Inc. (SOMA) has prepared this report for the Law Offices of Loeb & Loeb LLP on behalf of their client, the owners of the subject property. The property, the former Glovatorium, is located at 3820 Manila Avenue (formerly known as 3815 Broadway), Oakland, California.

This report presents a record of wastewater discharged from the remediation system located at 3820 Manila Avenue, Oakland, California into the East Bay Municipal Utility District (EBMUD) sewer system for the period of July to December 2010 as per requirements of the wastewater discharge permit. The remediation system is operated by SOMA Environmental Engineering, Inc. (SOMA).

2. MULTI-PHASE EXTRACTION PILOT TESTING AND TREATMENT SYSTEM OPERATION

SOMA began discharging treated groundwater from operation of Multi-Phase Extraction (MPE) pilot testing into the EBMUD sewer system on September 15, 2008 after receipt of the Special Discharge Permit issued by EBMUD. The extraction was discontinued in October 2008 and resumed on December 17, 2008. After expiration of the Special Discharge Permit EBMUD issued a Wastewater Discharge permit on September 17, 2009 for discharge from MPE operation on the site

Approximately 127,201 gallons of groundwater have been treated and discharged into the EBMUD sewer system during the MPE event (as of December 22, 2010). The treatment system was offline from December 14, 2009 until August 13, 2010. Active discharge to the sewer system began on August 16, 2010. The treatment system was offline again from December 8 to December 13, 2010 due to wet weather. The treatment system was also offline from December 14 to 21, 2010 for MPE equipment upgrade and from December 23, 2010 to January 3, 2011 due to Christmas and New Year holiday.

The groundwater extracted during the MPE is treated by the treatment system consisting of one 1,000-lb granular activated carbon (GAC-1) unit followed by one 55 gallon carbon polishing vessel. SOMA conducts regular system maintenance to ensure compliance with the EBMUD wastewater discharge permit. Most recent carbon change-out was conducted on both carbon units on August 13, 2010.

During this reporting period treatment system effluent samples (PSP-1) were collected on September 8, 2010 and December 8, 2010. Appendix A includes laboratory reports for treatment system samples collected during the quarterly sampling event (September and December 2010)

Table 1 shows the total volume of effluent discharged into the EBMUD sewer system, historical laboratory analysis results of samples collected from effluent of the treatment system, and pertinent maintenance history.

3. CONCLUSIONS

1. Approximately 127,201 gallons of groundwater have been treated and discharged into the EBMUD sewer system during the MPE event (as of December 22, 2010). Since the system resumed operation on August 16, 2010, approximately 10,612 gallons of groundwater has been treated and discharged into the on-site sewer main.
2. During the current reporting period effluent samples were in compliance with the discharge permit requirements. Therefore, the remedial system has remained in compliance with the EBMUD permit conditions

TABLE 1

Total Volume of Water Treated, Operational Data, and Effluent Analytical Results

Second Semi-Annual 2010 Self-Monitoring Report: Treatment System Discharge to EBMUD Sewer

Table 1
Total Volume of Water Treated, Operational Data,
and Laboratory Analytical Results for Effluent Samples
3820 Manila Ave, Oakland, California

Effluent		Lab Results for PSP-1 and Operation of Treatment System									
	Totalizer Reading	Benzene	Toluene	Ethylbenzene	Xylenes	PCE	TCE	cis-1,2-DCE	1,3,5-Trimethylbenzene	1,2,4-Trimethylbenzene	Acetone
Date	(gallons)	(µg/L)	(µg/L)	(µg/L)	(µg/L)	(µg/L)	(µg/L)	(µg/L)	(µg/L)	(µg/L)	(µg/L)
9/15/2008	1,010	Special Discharge permit issued, started discharging to EBMUD Sewer									
9/16/2008	1,312	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
9/17/2008	1,417	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
9/18/2008	1,582	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
9/19/2008	2,071	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
9/22/2008	2,327	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
9/23/2008	2,440	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
10/9/2008	2,490	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
10/13/2008	2,490	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
10/14/2008	3,178	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
10/15/2008	3,378	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
10/16/2008	3,568	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
10/17/2008	3,842	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
10/20/2008	3,894	<0.5	1.4	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	17
10/22/2008	3,904	Discharge to EBMUD sewer system discontinued									

Table 1
Total Volume of Water Treated, Operational Data,
and Laboratory Analytical Results for Effluent Samples
3820 Manila Ave, Oakland, California

Date	Effluent Totalizer Reading (gallons)	Lab Results for PSP-1 and Operation of Treatment System									
		Benzene (µg/L)	Toluene (µg/L)	Ethylbenzene (µg/L)	Xylenes (µg/L)	PCE (µg/L)	TCE (µg/L)	cis-1,2-DCE (µg/L)	1,3,5- Trimethylb enzene (µg/L)	1,2,4- Trimethylb enzene (µg/L)	Acetone (µg/L)
12/17/2008	3,904	Discharge to EBMUD sewer system resumed									
12/18/2008	4,461	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
12/19/2008	4,620	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
		No discharge on Dec 20 and 21, 2008									
12/22/2008	4,620	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
		No discharge from Dec 23 to Dec 28, 2008									
12/29/2008	4,640	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
12/30/2008	5,414	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
12/31/2008	5,632	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
		No discharge from Jan 1 to Jan 4 , 2009									
1/5/2009	5,632	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
1/6/2009	6,374	<2.5	<2.5	<2.5	<2.5	<2.5	<2.5	<2.5	<2.5	<2.5	<50
1/7/2009	6,988	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
1/8/2009	7,988	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
1/9/2009	8,299	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
1/12/2009	9,025	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
1/13/2009	9,029	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
1/14/2009	9,029	System shut down and remained off overnight									
1/16/2009	9,195	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
1/19/2009	9,242	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
1/20/2009	9,570	System down upon arrival and restarted shortly after inspection									

Table 1
Total Volume of Water Treated, Operational Data,
and Laboratory Analytical Results for Effluent Samples
3820 Manila Ave, Oakland, California

	Effluent	Lab Results for PSP-1 and Operation of Treatment System									
	Totalizer Reading	Benzene	Toluene	Ethylbenzene	Xylenes	PCE	TCE	cis-1,2-DCE	1,3,5-Trimethylbenzene	1,2,4-Trimethylbenzene	Acetone
Date	(gallons)	(µg/L)	(µg/L)	(µg/L)	(µg/L)	(µg/L)	(µg/L)	(µg/L)	(µg/L)	(µg/L)	(µg/L)
1/21/2009	10,075	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
1/26/2009	10,299	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
1/27/2009	10,805	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
1/28/2009	12,517	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
1/29/2009	13,373	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
1/30/2009	14,313	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
2/2/2009	14,992	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
2/3/2009	15,962	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
2/4/2009	15,989	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
2/5/2009	15,989	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
2/13/2009	16,213	Installed new transfer pump motor on 2/16/09									
2/19/2009	18,332	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
2/20/2009	19,272	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
2/24/2009	21,299	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
2/27/2009	21,387	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
2/28/2009	21,595	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA

Table 1
Total Volume of Water Treated, Operational Data,
and Laboratory Analytical Results for Effluent Samples
3820 Manila Ave, Oakland, California

	Effluent	Lab Results for PSP-1 and Operation of Treatment System									
	Totalizer Reading	Benzene	Toluene	Ethylbenzene	Xylenes	PCE	TCE	cis-1,2-DCE	1,3,5-Trimethylbenzene	1,2,4-Trimethylbenzene	Acetone
Date	(gallons)	(µg/L)	(µg/L)	(µg/L)	(µg/L)	(µg/L)	(µg/L)	(µg/L)	(µg/L)	(µg/L)	(µg/L)
3/9/2009	27,066	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
3/10/2009	27,863	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
3/11/2009	29,562	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
3/12/2009	31,885	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
3/13/2009	31,944	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
3/16/2009	33,184	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
3/17/2009	33,298	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
3/18/2009	33,471	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
3/19/2009	35,947	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
3/20/2009	36,472	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
3/23/2009	38,962	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
3/24/2009	40,307	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
3/25/2009	40,396	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
3/26/2009	42,445	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
3/27/2009	43,427	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
3/30/2009	43,457	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
3/31/2009	45,845	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA

Table 1
Total Volume of Water Treated, Operational Data,
and Laboratory Analytical Results for Effluent Samples
3820 Manila Ave, Oakland, California

	Effluent	Lab Results for PSP-1 and Operation of Treatment System									
	Totalizer Reading	Benzene	Toluene	Ethylbenzene	Xylenes	PCE	TCE	cis-1,2-DCE	1,3,5-Trimethylbenzene	1,2,4-Trimethylbenzene	Acetone
Date	(gallons)	(µg/L)	(µg/L)	(µg/L)	(µg/L)	(µg/L)	(µg/L)	(µg/L)	(µg/L)	(µg/L)	(µg/L)
4/1/2009	46,532	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
4/2/2009	46,589	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
4/3/2009	47,758	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
4/6/2009	50,877	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
4/7/2009	52,058	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
4/8/2009	52,507	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
4/13/2009	53,805	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
4/14/2009	54,061	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
4/15/2009	54,271	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
4/16/2009	54,457	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
4/17/2009	54,665	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
4/20/2009	55,381	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
4/21/2009	55,603	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
4/22/2009	55,803	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
4/23/2009	55,997	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	1.1	0.5	0.6	<10
4/24/2009	56,224	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
4/27/2009	56,839	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
4/28/2009	57,046	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
4/29/2009	57,258	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
4/30/2009	57,454	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA

Table 1
Total Volume of Water Treated, Operational Data,
and Laboratory Analytical Results for Effluent Samples
3820 Manila Ave, Oakland, California

Date	Effluent	Lab Results for PSP-1 and Operation of Treatment System									
	Totalizer Reading (gallons)	Benzene (µg/L)	Toluene (µg/L)	Ethylbenzene (µg/L)	Xylenes (µg/L)	PCE (µg/L)	TCE (µg/L)	cis-1,2-DCE (µg/L)	1,3,5-Trimethylbenzene (µg/L)	1,2,4-Trimethylbenzene (µg/L)	Acetone (µg/L)
5/1/2009	57,623	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
5/7/2009	59,779	5/4-5/6 System shut down for on-site soil investigation									
5/8/2009	59,779	Carbon change-out of 1000 lb liquid phase vessel and 55 gal. polishing vessel									
5/11/2009	63,401	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
5/12/2009	64,127	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
5/13/2009	64,858	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
5/14/2009	65,801	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
5/15/2009	66,591	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
5/18/2009	68,048	System shut down from 5/18/09 to 5/21/09 for installation of new extraction wells									
5/21/2009	68,084	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
5/22/2009	69,117	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
5/26/2009	70,161	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
5/27/2009	71,792	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
5/28/2009	73,061	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
5/29/2009	74,601	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA

Table 1
Total Volume of Water Treated, Operational Data,
and Laboratory Analytical Results for Effluent Samples
3820 Manila Ave, Oakland, California

Date	Effluent	Lab Results for PSP-1 and Operation of Treatment System									
	Totalizer Reading (gallons)	Benzene (µg/L)	Toluene (µg/L)	Ethylbenzene (µg/L)	Xylenes (µg/L)	PCE (µg/L)	TCE (µg/L)	cis-1,2-DCE (µg/L)	1,3,5-Trimethylbenzene (µg/L)	1,2,4-Trimethylbenzene (µg/L)	Acetone (µg/L)
6/1/2009	76,684	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
6/2/2009	77,310	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
6/3/2009	77,793	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
6/4/2009	78,087	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
6/5/2009	78,477	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
6/8/2009	79,507	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
6/9/2009	79,652	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
6/10/2009	79,822	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
6/12/2009	80,166	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
6/15/2009	80,298	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
6/16/2009	80,431	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
6/17/2009	80,526	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
6/18/2009	80,622	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
6/19/2009	80,642	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
6/22/2009	80,869	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
6/23/2009	81,095	Totalizer site glass broke/ Replaced totalizer on 6/24									
6/25/2009	82,095	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
6/26/2009	82,845	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
6/29/2009	84,495	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
6/30/2009	84,995	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA

Table 1
Total Volume of Water Treated, Operational Data,
and Laboratory Analytical Results for Effluent Samples
3820 Manila Ave, Oakland, California

	Effluent	Lab Results for PSP-1 and Operation of Treatment System									
	Totalizer Reading (gallons)	Benzene (µg/L)	Toluene (µg/L)	Ethylbenzene (µg/L)	Xylenes (µg/L)	PCE (µg/L)	TCE (µg/L)	cis-1,2-DCE (µg/L)	1,3,5-Trimethylbenzene (µg/L)	1,2,4-Trimethylbenzene (µg/L)	Acetone (µg/L)
Date											
7/1/2009	85,475	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
7/2/2009	85,808	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
7/3/2009	85,968	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
7/6/2009	86,225	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
7/7/2009	86,365	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
7/8/2009	86,425	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
7/9/2009	86,525	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
7/10/2009	86,615	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
7/13/2009	86,853	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
7/14/2009	87,485	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
7/15/2009	88,161	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
7/16/2009	88,624	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
7/17/2009	89,040	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
7/20/2009	89,295	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
7/21/2009	89,741	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
7/22/2009	90,452	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
7/23/2009	91,032	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
7/24/2009	91,565	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
7/27/2009	92,965	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
7/28/2009	93,441	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA

Table 1
Total Volume of Water Treated, Operational Data,
and Laboratory Analytical Results for Effluent Samples
3820 Manila Ave, Oakland, California

	Effluent	Lab Results for PSP-1 and Operation of Treatment System									
	Totalizer Reading (gallons)	Benzene (µg/L)	Toluene (µg/L)	Ethylbenzene (µg/L)	Xylenes (µg/L)	PCE (µg/L)	TCE (µg/L)	cis-1,2-DCE (µg/L)	1,3,5-Trimethylbenzene (µg/L)	1,2,4-Trimethylbenzene (µg/L)	Acetone (µg/L)
Date											
7/29/2009	93,523	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
7/30/2009	93,571	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
7/31/2009	94,397	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
8/3/2009	95,522	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
8/4/2009	96,027	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
8/5/2009	96,587	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
8/6/2009	97,203	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
8/7/2009	97,639	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
8/10/2009	98,549	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
8/14/2009	98,620	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
8/17/2009	99,026	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
8/18/2009	99,149	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
8/19/2009	99,380	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
8/20/2009	99,433	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
8/21/2009	99,478	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
8/24/2009	99,607	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
8/25/2009	99,677	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
8/26/2009	99,726	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
8/27/2009	99,854	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
8/28/2009	100,067	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
8/31/2009	100,465	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA

Table 1
Total Volume of Water Treated, Operational Data,
and Laboratory Analytical Results for Effluent Samples
3820 Manila Ave, Oakland, California

Date	Effluent	Lab Results for PSP-1 and Operation of Treatment System									
	Totalizer Reading (gallons)	Benzene (µg/L)	Toluene (µg/L)	Ethylbenzene (µg/L)	Xylenes (µg/L)	PCE (µg/L)	TCE (µg/L)	cis-1,2-DCE (µg/L)	1,3,5-Trimethylbenzene (µg/L)	1,2,4-Trimethylbenzene (µg/L)	Acetone (µg/L)
9/1/2009	100,600	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
9/2/2009	100,737	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
9/3/2009	100,778	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
9/4/2009	100,943	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
9/8/2009	101,425	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
9/10/2009	101,629	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
9/17/2009	Wastewater Discharge Permit issued by EBMUD, resumed discharge on Sep 21, 2009										
9/23/2009	102,465	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	31
10/8/2009	103,982	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
11/8/2009	112,361	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
12/11/2009	116,339	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<10
12/14/2009	116,589	Treatment system shut down									
8/13/2010	116,589	Carbon change-out of 1000 lb liquid phase vessel and 55 gal. polishing vessel and restart on 8/16 System down from 8/20 to 8/26 and 8/27 to 9/2 for equipment repair									
9/8/2010	118,009	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<10
10/8/2010	120,995	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
11/8/2010	122,980	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
12/8/2010	126,785	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<10
12/14/2010	126,840	Treatment system shut down from 12/8/10 to 12/13/10 due to wet weather									
12/22/2010	127,201	Treatment system shut down from 12/14/10 to 12/21/10 for equipment upgrade and 12/23/10 to 1/3/11 for holiday									

Table 1
Total Volume of Water Treated, Operational Data,
and Laboratory Analytical Results for Effluent Samples
3820 Manila Ave, Oakland, California

	Effluent	Lab Results for PSP-1 and Operation of Treatment System									
	Totalizer Reading	Benzene	Toluene	Ethylbenzene	Xylenes	PCE	TCE	cis-1,2-DCE	1,3,5-Trimethylbenzene	1,2,4-Trimethylbenzene	Acetone
Date	(gallons)	(µg/L)	(µg/L)	(µg/L)	(µg/L)	(µg/L)	(µg/L)	(µg/L)	(µg/L)	(µg/L)	(µg/L)

Notes:

ND, < : Not Detected above laboratory reporting limits

NA: Not Analyzed

PCE: Tetrachloroethene

TCE: Trichloroethene

cis-1,2-DCE: cis-1,2-Dichloroethene

APPENDIX A

Laboratory Results and Chain of Custody Forms for the Treatment System

Second Semi-Annual 2010 Self-Monitoring Report: Treatment System Discharge to EBMUD Sewer



Curtis & Tompkins, Ltd., Analytical Laboratories, Since 1878

2323 Fifth Street, Berkeley, CA 94710, Phone (510) 486-0900

**Laboratory Job Number 222351
ANALYTICAL REPORT**

SOMA Environmental Engineering Inc. 6620 Owens Dr. Pleasanton, CA 94588	Project : 2515 Location : 3820 Manila Ave Oakland, Ca Level : II
---	--

<u>Sample ID</u>	<u>Lab ID</u>
PSP-1	222351-001
GAC-1	222351-002
INFLUENT	222351-003

This data package has been reviewed for technical correctness and completeness. Release of this data has been authorized by the Laboratory Manager or the Manager's designee, as verified by the following signature. The results contained in this report meet all requirements of NELAC and pertain only to those samples which were submitted for analysis. This report may be reproduced only in its entirety.

Signature: *Deviné N. Tetrault*
Project Manager

Date: 09/17/2010

NELAP # 01107CA

CASE NARRATIVE

Laboratory number: 222351
Client: SOMA Environmental Engineering Inc.
Project: 2515
Location: 3820 Manila Ave Oakland, Ca
Request Date: 09/09/10
Samples Received: 09/09/10

This data package contains sample and QC results for three water samples, requested for the above referenced project on 09/09/10. The samples were received cold and intact.

Volatile Organics by GC/MS (EPA 8260B):

No analytical problems were encountered.

COOLER RECEIPT CHECKLIST



Curtis & Tompkins, Ltd.

Login # 222351 Date Received 9/9/10 Number of coolers 1
Client SONY ENVU Project 3820 MANILA AVE., OAKLAND, CA

Date Opened 9/9/10 By (print) M. Villanueva (sign) [Signature]
Date Logged in 9/10/10 By (print) [Signature] (sign) [Signature]

1. Did cooler come with a shipping slip (airbill, etc) YES NO
Shipping info

2A. Were custody seals present? ... YES (circle) on cooler on samples NO
How many Name Date

2B. Were custody seals intact upon arrival? YES NO N/A

3. Were custody papers dry and intact when received? YES NO

4. Were custody papers filled out properly (ink, signed, etc)? YES NO

5. Is the project identifiable from custody papers? (If so fill out top of form) YES NO

6. Indicate the packing in cooler: (if other, describe)
Bubble Wrap Foam blocks Bags None
Cloth material Cardboard Styrofoam Paper towels

7. Temperature documentation:
Type of ice used: Wet Blue/Gel None Temp(C)
Samples Received on ice & cold without a temperature blank

Samples received on ice directly from the field. Cooling process had begun

8. Were Method 5035 sampling containers present? YES NO
If YES, what time were they transferred to freezer?

9. Did all bottles arrive unbroken/unopened? YES NO

10. Are samples in the appropriate containers for indicated tests? YES NO

11. Are sample labels present, in good condition and complete? YES NO

12. Do the sample labels agree with custody papers? YES NO

13. Was sufficient amount of sample sent for tests requested? YES NO

14. Are the samples appropriately preserved? YES NO N/A

15. Are bubbles > 6mm absent in VOA samples? YES NO N/A

16. Was the client contacted concerning this sample delivery? YES NO
If YES, Who was called? By Date:

COMMENTS
[Blank lines for handwritten notes]

Purgeable Organics by GC/MS

Lab #: 222351	Location: 3820 Manila Ave Oakland, Ca
Client: SOMA Environmental Engineering Inc.	Prep: EPA 5030B
Project#: 2515	Analysis: EPA 8260B
Field ID: PSP-1	Batch#: 166852
Lab ID: 222351-001	Sampled: 09/08/10
Matrix: Water	Received: 09/09/10
Units: ug/L	Analyzed: 09/15/10
Diln Fac: 1.000	

Analyte	Result	RL
Freon 12	ND	1.0
Chloromethane	ND	1.0
Vinyl Chloride	ND	0.5
Bromomethane	ND	1.0
Chloroethane	ND	1.0
Trichlorofluoromethane	ND	1.0
Acetone	ND	10
Freon 113	ND	2.0
1,1-Dichloroethene	ND	0.5
Methylene Chloride	ND	10
Carbon Disulfide	ND	0.5
MTBE	ND	0.5
trans-1,2-Dichloroethene	ND	0.5
Vinyl Acetate	ND	10
1,1-Dichloroethane	ND	0.5
2-Butanone	ND	10
cis-1,2-Dichloroethene	ND	0.5
2,2-Dichloropropane	ND	0.5
Chloroform	ND	0.5
Bromochloromethane	ND	0.5
1,1,1-Trichloroethane	ND	0.5
1,1-Dichloropropene	ND	0.5
Carbon Tetrachloride	ND	0.5
1,2-Dichloroethane	ND	0.5
Benzene	ND	0.5
Trichloroethene	ND	0.5
1,2-Dichloropropane	ND	0.5
Bromodichloromethane	ND	0.5
Dibromomethane	ND	0.5
4-Methyl-2-Pentanone	ND	10
cis-1,3-Dichloropropene	ND	0.5
Toluene	ND	0.5
trans-1,3-Dichloropropene	ND	0.5
1,1,2-Trichloroethane	ND	0.5
2-Hexanone	ND	10
1,3-Dichloropropane	ND	0.5
Tetrachloroethene	ND	0.5

ND= Not Detected

RL= Reporting Limit

Purgeable Organics by GC/MS

Lab #: 222351	Location: 3820 Manila Ave Oakland, Ca
Client: SOMA Environmental Engineering Inc.	Prep: EPA 5030B
Project#: 2515	Analysis: EPA 8260B
Field ID: PSP-1	Batch#: 166852
Lab ID: 222351-001	Sampled: 09/08/10
Matrix: Water	Received: 09/09/10
Units: ug/L	Analyzed: 09/15/10
Diln Fac: 1.000	

Analyte	Result	RL
Dibromochloromethane	ND	0.5
1,2-Dibromoethane	ND	0.5
Chlorobenzene	ND	0.5
1,1,1,2-Tetrachloroethane	ND	0.5
Ethylbenzene	ND	0.5
m,p-Xylenes	ND	0.5
o-Xylene	ND	0.5
Styrene	ND	0.5
Bromoform	ND	1.0
Isopropylbenzene	ND	0.5
1,1,2,2-Tetrachloroethane	ND	0.5
1,2,3-Trichloropropane	ND	0.5
Propylbenzene	ND	0.5
Bromobenzene	ND	0.5
1,3,5-Trimethylbenzene	ND	0.5
2-Chlorotoluene	ND	0.5
4-Chlorotoluene	ND	0.5
tert-Butylbenzene	ND	0.5
1,2,4-Trimethylbenzene	ND	0.5
sec-Butylbenzene	ND	0.5
para-Isopropyl Toluene	ND	0.5
1,3-Dichlorobenzene	ND	0.5
1,4-Dichlorobenzene	ND	0.5
n-Butylbenzene	ND	0.5
1,2-Dichlorobenzene	ND	0.5
1,2-Dibromo-3-Chloropropane	ND	2.0
1,2,4-Trichlorobenzene	ND	0.5
Hexachlorobutadiene	ND	2.0
Naphthalene	ND	2.0
1,2,3-Trichlorobenzene	ND	0.5

Surrogate	%REC	Limits
Dibromofluoromethane	119	80-122
1,2-Dichloroethane-d4	136	71-140
Toluene-d8	104	80-120
Bromofluorobenzene	97	80-121

ND= Not Detected
 RL= Reporting Limit

Purgeable Organics by GC/MS

Lab #: 222351	Location: 3820 Manila Ave Oakland, Ca
Client: SOMA Environmental Engineering Inc.	Prep: EPA 5030B
Project#: 2515	Analysis: EPA 8260B
Field ID: GAC-1	Batch#: 166852
Lab ID: 222351-002	Sampled: 09/08/10
Matrix: Water	Received: 09/09/10
Units: ug/L	Analyzed: 09/15/10
Diln Fac: 1.000	

Analyte	Result	RL
Freon 12	ND	1.0
Chloromethane	ND	1.0
Vinyl Chloride	ND	0.5
Bromomethane	ND	1.0
Chloroethane	ND	1.0
Trichlorofluoromethane	ND	1.0
Acetone	ND	10
Freon 113	ND	2.0
1,1-Dichloroethene	ND	0.5
Methylene Chloride	ND	10
Carbon Disulfide	ND	0.5
MTBE	ND	0.5
trans-1,2-Dichloroethene	ND	0.5
Vinyl Acetate	ND	10
1,1-Dichloroethane	ND	0.5
2-Butanone	ND	10
cis-1,2-Dichloroethene	ND	0.5
2,2-Dichloropropane	ND	0.5
Chloroform	ND	0.5
Bromochloromethane	ND	0.5
1,1,1-Trichloroethane	ND	0.5
1,1-Dichloropropene	ND	0.5
Carbon Tetrachloride	ND	0.5
1,2-Dichloroethane	ND	0.5
Benzene	ND	0.5
Trichloroethene	ND	0.5
1,2-Dichloropropane	ND	0.5
Bromodichloromethane	ND	0.5
Dibromomethane	ND	0.5
4-Methyl-2-Pentanone	ND	10
cis-1,3-Dichloropropene	ND	0.5
Toluene	ND	0.5
trans-1,3-Dichloropropene	ND	0.5
1,1,2-Trichloroethane	ND	0.5
2-Hexanone	ND	10
1,3-Dichloropropane	ND	0.5
Tetrachloroethene	ND	0.5

ND= Not Detected

RL= Reporting Limit

Purgeable Organics by GC/MS

Lab #: 222351	Location: 3820 Manila Ave Oakland, Ca
Client: SOMA Environmental Engineering Inc.	Prep: EPA 5030B
Project#: 2515	Analysis: EPA 8260B
Field ID: GAC-1	Batch#: 166852
Lab ID: 222351-002	Sampled: 09/08/10
Matrix: Water	Received: 09/09/10
Units: ug/L	Analyzed: 09/15/10
Diln Fac: 1.000	

Analyte	Result	RL
Dibromochloromethane	ND	0.5
1,2-Dibromoethane	ND	0.5
Chlorobenzene	ND	0.5
1,1,1,2-Tetrachloroethane	ND	0.5
Ethylbenzene	ND	0.5
m,p-Xylenes	ND	0.5
o-Xylene	ND	0.5
Styrene	ND	0.5
Bromoform	ND	1.0
Isopropylbenzene	ND	0.5
1,1,2,2-Tetrachloroethane	ND	0.5
1,2,3-Trichloropropane	ND	0.5
Propylbenzene	ND	0.5
Bromobenzene	ND	0.5
1,3,5-Trimethylbenzene	ND	0.5
2-Chlorotoluene	ND	0.5
4-Chlorotoluene	ND	0.5
tert-Butylbenzene	ND	0.5
1,2,4-Trimethylbenzene	ND	0.5
sec-Butylbenzene	ND	0.5
para-Isopropyl Toluene	ND	0.5
1,3-Dichlorobenzene	ND	0.5
1,4-Dichlorobenzene	ND	0.5
n-Butylbenzene	ND	0.5
1,2-Dichlorobenzene	ND	0.5
1,2-Dibromo-3-Chloropropane	ND	2.0
1,2,4-Trichlorobenzene	ND	0.5
Hexachlorobutadiene	ND	2.0
Naphthalene	ND	2.0
1,2,3-Trichlorobenzene	ND	0.5

Surrogate	%REC	Limits
Dibromofluoromethane	114	80-122
1,2-Dichloroethane-d4	136	71-140
Toluene-d8	103	80-120
Bromofluorobenzene	96	80-121

ND= Not Detected

RL= Reporting Limit

Purgeable Organics by GC/MS

Lab #: 222351	Location: 3820 Manila Ave Oakland, Ca
Client: SOMA Environmental Engineering Inc.	Prep: EPA 5030B
Project#: 2515	Analysis: EPA 8260B
Field ID: INFLUENT	Batch#: 166907
Lab ID: 222351-003	Sampled: 09/08/10
Matrix: Water	Received: 09/09/10
Units: ug/L	Analyzed: 09/16/10
Diln Fac: 1.000	

Analyte	Result	RL
Freon 12	ND	1.0
Chloromethane	ND	1.0
Vinyl Chloride	ND	0.5
Bromomethane	ND	1.0
Chloroethane	ND	1.0
Trichlorofluoromethane	ND	1.0
Acetone	ND	10
Freon 113	ND	2.0
1,1-Dichloroethene	ND	0.5
Methylene Chloride	ND	10
Carbon Disulfide	ND	0.5
MTBE	1.6	0.5
trans-1,2-Dichloroethene	0.5	0.5
Vinyl Acetate	ND	10
1,1-Dichloroethane	ND	0.5
2-Butanone	ND	10
cis-1,2-Dichloroethene	82	0.5
2,2-Dichloropropane	ND	0.5
Chloroform	ND	0.5
Bromochloromethane	ND	0.5
1,1,1-Trichloroethane	ND	0.5
1,1-Dichloropropene	ND	0.5
Carbon Tetrachloride	ND	0.5
1,2-Dichloroethane	ND	0.5
Benzene	ND	0.5
Trichloroethene	16	0.5
1,2-Dichloropropane	ND	0.5
Bromodichloromethane	ND	0.5
Dibromomethane	ND	0.5
4-Methyl-2-Pentanone	ND	10
cis-1,3-Dichloropropene	ND	0.5
Toluene	ND	0.5
trans-1,3-Dichloropropene	ND	0.5
1,1,2-Trichloroethane	ND	0.5
2-Hexanone	ND	10
1,3-Dichloropropane	ND	0.5
Tetrachloroethene	18	0.5

ND= Not Detected

RL= Reporting Limit

Purgeable Organics by GC/MS

Lab #: 222351	Location: 3820 Manila Ave Oakland, Ca
Client: SOMA Environmental Engineering Inc.	Prep: EPA 5030B
Project#: 2515	Analysis: EPA 8260B
Field ID: INFLUENT	Batch#: 166907
Lab ID: 222351-003	Sampled: 09/08/10
Matrix: Water	Received: 09/09/10
Units: ug/L	Analyzed: 09/16/10
Diln Fac: 1.000	

Analyte	Result	RL
Dibromochloromethane	ND	0.5
1,2-Dibromoethane	ND	0.5
Chlorobenzene	ND	0.5
1,1,1,2-Tetrachloroethane	ND	0.5
Ethylbenzene	ND	0.5
m,p-Xylenes	ND	0.5
o-Xylene	ND	0.5
Styrene	ND	0.5
Bromoform	ND	1.0
Isopropylbenzene	ND	0.5
1,1,2,2-Tetrachloroethane	ND	0.5
1,2,3-Trichloropropane	ND	0.5
Propylbenzene	ND	0.5
Bromobenzene	ND	0.5
1,3,5-Trimethylbenzene	ND	0.5
2-Chlorotoluene	ND	0.5
4-Chlorotoluene	ND	0.5
tert-Butylbenzene	ND	0.5
1,2,4-Trimethylbenzene	0.6	0.5
sec-Butylbenzene	ND	0.5
para-Isopropyl Toluene	ND	0.5
1,3-Dichlorobenzene	ND	0.5
1,4-Dichlorobenzene	ND	0.5
n-Butylbenzene	ND	0.5
1,2-Dichlorobenzene	ND	0.5
1,2-Dibromo-3-Chloropropane	ND	2.0
1,2,4-Trichlorobenzene	ND	0.5
Hexachlorobutadiene	ND	2.0
Naphthalene	ND	2.0
1,2,3-Trichlorobenzene	ND	0.5

Surrogate	%REC	Limits
Dibromofluoromethane	108	80-122
1,2-Dichloroethane-d4	106	71-140
Toluene-d8	99	80-120
Bromofluorobenzene	108	80-121

ND= Not Detected
 RL= Reporting Limit

Batch QC Report

Purgeable Organics by GC/MS			
Lab #:	222351	Location:	3820 Manila Ave Oakland, Ca
Client:	SOMA Environmental Engineering Inc.	Prep:	EPA 5030B
Project#:	2515	Analysis:	EPA 8260B
Matrix:	Water	Batch#:	166852
Units:	ug/L	Analyzed:	09/15/10
Diln Fac:	1.000		

Type: BS Lab ID: QC559913

Analyte	Spiked	Result	%REC	Limits
1,1-Dichloroethene	25.00	21.35	85	72-138
Benzene	25.00	23.26	93	80-122
Trichloroethene	25.00	22.45	90	80-122
Toluene	25.00	23.03	92	80-120
Chlorobenzene	25.00	24.15	97	80-120

Surrogate	%REC	Limits
Dibromofluoromethane	109	80-122
1,2-Dichloroethane-d4	135	71-140
Toluene-d8	101	80-120
Bromofluorobenzene	95	80-121

Type: BSD Lab ID: QC559914

Analyte	Spiked	Result	%REC	Limits	RPD	Lim
1,1-Dichloroethene	25.00	22.33	89	72-138	4	20
Benzene	25.00	24.15	97	80-122	4	20
Trichloroethene	25.00	23.80	95	80-122	6	20
Toluene	25.00	23.82	95	80-120	3	20
Chlorobenzene	25.00	24.92	100	80-120	3	20

Surrogate	%REC	Limits
Dibromofluoromethane	108	80-122
1,2-Dichloroethane-d4	134	71-140
Toluene-d8	101	80-120
Bromofluorobenzene	95	80-121

RPD= Relative Percent Difference

Batch QC Report

Purgeable Organics by GC/MS			
Lab #:	222351	Location:	3820 Manila Ave Oakland, Ca
Client:	SOMA Environmental Engineering Inc.	Prep:	EPA 5030B
Project#:	2515	Analysis:	EPA 8260B
Type:	BLANK	Diln Fac:	1.000
Lab ID:	QC559915	Batch#:	166852
Matrix:	Water	Analyzed:	09/15/10
Units:	ug/L		

Analyte	Result	RL
Freon 12	ND	1.0
Chloromethane	ND	1.0
Vinyl Chloride	ND	0.5
Bromomethane	ND	1.0
Chloroethane	ND	1.0
Trichlorofluoromethane	ND	1.0
Acetone	ND	10
Freon 113	ND	2.0
1,1-Dichloroethene	ND	0.5
Methylene Chloride	ND	10
Carbon Disulfide	ND	0.5
MTBE	ND	0.5
trans-1,2-Dichloroethene	ND	0.5
Vinyl Acetate	ND	10
1,1-Dichloroethane	ND	0.5
2-Butanone	ND	10
cis-1,2-Dichloroethene	ND	0.5
2,2-Dichloropropane	ND	0.5
Chloroform	ND	0.5
Bromochloromethane	ND	0.5
1,1,1-Trichloroethane	ND	0.5
1,1-Dichloropropene	ND	0.5
Carbon Tetrachloride	ND	0.5
1,2-Dichloroethane	ND	0.5
Benzene	ND	0.5
Trichloroethene	ND	0.5
1,2-Dichloropropane	ND	0.5
Bromodichloromethane	ND	0.5
Dibromomethane	ND	0.5
4-Methyl-2-Pentanone	ND	10
cis-1,3-Dichloropropene	ND	0.5
Toluene	ND	0.5
trans-1,3-Dichloropropene	ND	0.5
1,1,2-Trichloroethane	ND	0.5
2-Hexanone	ND	10
1,3-Dichloropropane	ND	0.5
Tetrachloroethene	ND	0.5

ND= Not Detected

RL= Reporting Limit

Batch QC Report

Purgeable Organics by GC/MS			
Lab #:	222351	Location:	3820 Manila Ave Oakland, Ca
Client:	SOMA Environmental Engineering Inc.	Prep:	EPA 5030B
Project#:	2515	Analysis:	EPA 8260B
Type:	BLANK	Diln Fac:	1.000
Lab ID:	QC559915	Batch#:	166852
Matrix:	Water	Analyzed:	09/15/10
Units:	ug/L		

Analyte	Result	RL
Dibromochloromethane	ND	0.5
1,2-Dibromoethane	ND	0.5
Chlorobenzene	ND	0.5
1,1,1,2-Tetrachloroethane	ND	0.5
Ethylbenzene	ND	0.5
m,p-Xylenes	ND	0.5
o-Xylene	ND	0.5
Styrene	ND	0.5
Bromoform	ND	1.0
Isopropylbenzene	ND	0.5
1,1,2,2-Tetrachloroethane	ND	0.5
1,2,3-Trichloropropane	ND	0.5
Propylbenzene	ND	0.5
Bromobenzene	ND	0.5
1,3,5-Trimethylbenzene	ND	0.5
2-Chlorotoluene	ND	0.5
4-Chlorotoluene	ND	0.5
tert-Butylbenzene	ND	0.5
1,2,4-Trimethylbenzene	ND	0.5
sec-Butylbenzene	ND	0.5
para-Isopropyl Toluene	ND	0.5
1,3-Dichlorobenzene	ND	0.5
1,4-Dichlorobenzene	ND	0.5
n-Butylbenzene	ND	0.5
1,2-Dichlorobenzene	ND	0.5
1,2-Dibromo-3-Chloropropane	ND	2.0
1,2,4-Trichlorobenzene	ND	0.5
Hexachlorobutadiene	ND	2.0
Naphthalene	ND	2.0
1,2,3-Trichlorobenzene	ND	0.5

Surrogate	%REC	Limits
Dibromofluoromethane	116	80-122
1,2-Dichloroethane-d4	135	71-140
Toluene-d8	104	80-120
Bromofluorobenzene	97	80-121

ND= Not Detected

RL= Reporting Limit

Batch QC Report

Purgeable Organics by GC/MS			
Lab #:	222351	Location:	3820 Manila Ave Oakland, Ca
Client:	SOMA Environmental Engineering Inc.	Prep:	EPA 5030B
Project#:	2515	Analysis:	EPA 8260B
Field ID:	ZZZZZZZZZZ	Diln Fac:	1.000
MSS Lab ID:	222346-001	Batch#:	166852
Matrix:	Water	Sampled:	09/09/10
Units:	ug/L	Received:	09/09/10

Type: MS Analyzed: 09/15/10
 Lab ID: QC560007

Analyte	MSS Result	Spiked	Result	%REC	Limits
1,1-Dichloroethene	0.4156	25.00	24.41	96	80-134
Benzene	<0.1000	25.00	24.97	100	80-121
Trichloroethene	52.23	25.00	74.16	88	77-126
Toluene	<0.1000	25.00	23.98	96	80-120
Chlorobenzene	<0.1000	25.00	25.39	102	80-120

Surrogate	%REC	Limits
Dibromofluoromethane	111	80-122
1,2-Dichloroethane-d4	136	71-140
Toluene-d8	101	80-120
Bromofluorobenzene	94	80-121

Type: MSD Analyzed: 09/16/10
 Lab ID: QC560008

Analyte	Spiked	Result	%REC	Limits	RPD	Lim
1,1-Dichloroethene	25.00	24.46	96	80-134	0	20
Benzene	25.00	24.35	97	80-121	3	20
Trichloroethene	25.00	72.07	79	77-126	3	20
Toluene	25.00	23.60	94	80-120	2	20
Chlorobenzene	25.00	24.82	99	80-120	2	20

Surrogate	%REC	Limits
Dibromofluoromethane	110	80-122
1,2-Dichloroethane-d4	135	71-140
Toluene-d8	101	80-120
Bromofluorobenzene	95	80-121

RPD= Relative Percent Difference

Batch QC Report

Purgeable Organics by GC/MS			
Lab #:	222351	Location:	3820 Manila Ave Oakland, Ca
Client:	SOMA Environmental Engineering Inc.	Prep:	EPA 5030B
Project#:	2515	Analysis:	EPA 8260B
Type:	BLANK	Diln Fac:	1.000
Lab ID:	QC560162	Batch#:	166907
Matrix:	Water	Analyzed:	09/16/10
Units:	ug/L		

Analyte	Result	RL
Freon 12	ND	1.0
Chloromethane	ND	1.0
Vinyl Chloride	ND	0.5
Bromomethane	ND	1.0
Chloroethane	ND	1.0
Trichlorofluoromethane	ND	1.0
Acetone	ND	10
Freon 113	ND	2.0
1,1-Dichloroethene	ND	0.5
Methylene Chloride	ND	10
Carbon Disulfide	ND	0.5
MTBE	ND	0.5
trans-1,2-Dichloroethene	ND	0.5
Vinyl Acetate	ND	10
1,1-Dichloroethane	ND	0.5
2-Butanone	ND	10
cis-1,2-Dichloroethene	ND	0.5
2,2-Dichloropropane	ND	0.5
Chloroform	ND	0.5
Bromochloromethane	ND	0.5
1,1,1-Trichloroethane	ND	0.5
1,1-Dichloropropene	ND	0.5
Carbon Tetrachloride	ND	0.5
1,2-Dichloroethane	ND	0.5
Benzene	ND	0.5
Trichloroethene	ND	0.5
1,2-Dichloropropane	ND	0.5
Bromodichloromethane	ND	0.5
Dibromomethane	ND	0.5
4-Methyl-2-Pentanone	ND	10
cis-1,3-Dichloropropene	ND	0.5
Toluene	ND	0.5
trans-1,3-Dichloropropene	ND	0.5
1,1,2-Trichloroethane	ND	0.5
2-Hexanone	ND	10
1,3-Dichloropropane	ND	0.5
Tetrachloroethene	ND	0.5

ND= Not Detected

RL= Reporting Limit

Batch QC Report

Purgeable Organics by GC/MS			
Lab #:	222351	Location:	3820 Manila Ave Oakland, Ca
Client:	SOMA Environmental Engineering Inc.	Prep:	EPA 5030B
Project#:	2515	Analysis:	EPA 8260B
Type:	BLANK	Diln Fac:	1.000
Lab ID:	QC560162	Batch#:	166907
Matrix:	Water	Analyzed:	09/16/10
Units:	ug/L		

Analyte	Result	RL
Dibromochloromethane	ND	0.5
1,2-Dibromoethane	ND	0.5
Chlorobenzene	ND	0.5
1,1,1,2-Tetrachloroethane	ND	0.5
Ethylbenzene	ND	0.5
m,p-Xylenes	ND	0.5
o-Xylene	ND	0.5
Styrene	ND	0.5
Bromoform	ND	1.0
Isopropylbenzene	ND	0.5
1,1,2,2-Tetrachloroethane	ND	0.5
1,2,3-Trichloropropane	ND	0.5
Propylbenzene	ND	0.5
Bromobenzene	ND	0.5
1,3,5-Trimethylbenzene	ND	0.5
2-Chlorotoluene	ND	0.5
4-Chlorotoluene	ND	0.5
tert-Butylbenzene	ND	0.5
1,2,4-Trimethylbenzene	ND	0.5
sec-Butylbenzene	ND	0.5
para-Isopropyl Toluene	ND	0.5
1,3-Dichlorobenzene	ND	0.5
1,4-Dichlorobenzene	ND	0.5
n-Butylbenzene	ND	0.5
1,2-Dichlorobenzene	ND	0.5
1,2-Dibromo-3-Chloropropane	ND	2.0
1,2,4-Trichlorobenzene	ND	0.5
Hexachlorobutadiene	ND	2.0
Naphthalene	ND	2.0
1,2,3-Trichlorobenzene	ND	0.5

Surrogate	%REC	Limits
Dibromofluoromethane	105	80-122
1,2-Dichloroethane-d4	110	71-140
Toluene-d8	96	80-120
Bromofluorobenzene	105	80-121

ND= Not Detected

RL= Reporting Limit

Batch QC Report

Purgeable Organics by GC/MS			
Lab #:	222351	Location:	3820 Manila Ave Oakland, Ca
Client:	SOMA Environmental Engineering Inc.	Prep:	EPA 5030B
Project#:	2515	Analysis:	EPA 8260B
Matrix:	Water	Batch#:	166907
Units:	ug/L	Analyzed:	09/16/10
Diln Fac:	1.000		

Type: BS Lab ID: QC560163

Analyte	Spiked	Result	%REC	Limits
1,1-Dichloroethene	25.00	28.24	113	72-138
Benzene	25.00	25.70	103	80-122
Trichloroethene	25.00	23.48	94	80-122
Toluene	25.00	25.06	100	80-120
Chlorobenzene	25.00	24.90	100	80-120

Surrogate	%REC	Limits
Dibromofluoromethane	106	80-122
1,2-Dichloroethane-d4	104	71-140
Toluene-d8	98	80-120
Bromofluorobenzene	106	80-121

Type: BSD Lab ID: QC560164

Analyte	Spiked	Result	%REC	Limits	RPD	Lim
1,1-Dichloroethene	25.00	28.11	112	72-138	0	20
Benzene	25.00	26.35	105	80-122	3	20
Trichloroethene	25.00	24.35	97	80-122	4	20
Toluene	25.00	25.79	103	80-120	3	20
Chlorobenzene	25.00	25.55	102	80-120	3	20

Surrogate	%REC	Limits
Dibromofluoromethane	105	80-122
1,2-Dichloroethane-d4	107	71-140
Toluene-d8	101	80-120
Bromofluorobenzene	103	80-121

RPD= Relative Percent Difference



Curtis & Tompkins, Ltd., Analytical Laboratories, Since 1878

2323 Fifth Street, Berkeley, CA 94710, Phone (510) 486-0900

**Laboratory Job Number 224529
ANALYTICAL REPORT**

SOMA Environmental Engineering Inc. 6620 Owens Dr. Pleasanton, CA 94588	Project : 2515 Location : 3820 Manila Ave Oakland, Ca Level : II
---	--

<u>Sample ID</u>	<u>Lab ID</u>
PSP-1	224529-001
GAC-1	224529-002
INFLUENT	224529-003

This data package has been reviewed for technical correctness and completeness. Release of this data has been authorized by the Laboratory Manager or the Manager's designee, as verified by the following signature. The results contained in this report meet all requirements of NELAC and pertain only to those samples which were submitted for analysis. This report may be reproduced only in its entirety.

Signature: 
Project Manager

Date: 12/15/2010

NELAP # 01107CA

CASE NARRATIVE

Laboratory number: 224529
Client: SOMA Environmental Engineering Inc.
Project: 2515
Location: 3820 Manila Ave Oakland, Ca
Request Date: 12/08/10
Samples Received: 12/08/10

This data package contains sample and QC results for three water samples, requested for the above referenced project on 12/08/10. The samples were received cold and intact.

Volatile Organics by GC/MS (EPA 8260B):

No analytical problems were encountered.

CHAIN OF CUSTODY

Curtis & Tompkins, Ltd.

Analytical Laboratory Since 1878
2323 Fifth Street
Berkeley, CA 94710
(510)486-0900 Phone
(510)486-0532 Fax

AnalysesC&T LOGIN # 224529Sampler: Jesse AcedilloProject No: 2515Report To: Joyce BobekProject Name: 3820 Manila Ave., Oakland, CA Company: SOMA EnvironmentalTurnaround Time: StandardTelephone: 925-734-6400Fax: 925-734-6401

Lab No.	Sample ID.	Sampling Date Time	Matrix			# of Containers	Preservative			
			Soil	Water	Waste		HCL	H ₂ SO ₄	HNO ₃	ICE
	PSP-1	12/8/10 @ 1300	*			4-40ml VOAs	*			*
2	GAC-1	1315	*			4-40ml VOAs	*			*
3	INFLUENT	1330	*			4-40ml VOAs	*			*

8260B (Full List)

Notes:
EDF Output required

RELINQUISHED BY: <u>Jesse Acedillo</u> 12/8/10 @ 3:15 DATE/TIME		RECEIVED BY: <u>Pat Murphy</u> 12/9/10 @ 3:15 pm DATE/TIME	
	DATE/TIME		DATE/TIME
	DATE/TIME		DATE/TIME

COOLER RECEIPT CHECKLIST



Curtis & Tompkins, Ltd.

Login # 224529 Date Received 12/8/10 Number of coolers 1
 Client SOMA Project 3820 MADIL & V12

Date Opened 12/8/10 By (print) M. VILLANUEVA (sign) [Signature]
 Date Logged in ↓ By (print) ↓ (sign) [Signature]

1. Did cooler come with a shipping slip (airbill, etc) _____ YES NO
 Shipping info _____

2A. Were custody seals present? ... YES (circle) on cooler on samples NO
 How many _____ Name _____ Date _____

2B. Were custody seals intact upon arrival? _____ YES NO N/A

3. Were custody papers dry and intact when received? _____ YES NO

4. Were custody papers filled out properly (ink, signed, etc)? _____ YES NO

5. Is the project identifiable from custody papers? (If so fill out top of form) _____ YES NO

6. Indicate the packing in cooler: (if other, describe) _____

- Bubble Wrap Foam blocks Bags None
- Cloth material Cardboard Styrofoam Paper towels

7. Temperature documentation:
 Type of ice used: Wet Blue/Gel None Temp(°C) _____

Samples Received on ice & cold without a temperature blank

Samples received on ice directly from the field. Cooling process had begun

8. Were Method 5035 sampling containers present? _____ YES NO
 If YES, what time were they transferred to freezer? _____

9. Did all bottles arrive unbroken/unopened? _____ YES NO

10. Are samples in the appropriate containers for indicated tests? _____ YES NO

11. Are sample labels present, in good condition and complete? _____ YES NO

12. Do the sample labels agree with custody papers? _____ YES NO

13. Was sufficient amount of sample sent for tests requested? _____ YES NO

14. Are the samples appropriately preserved? _____ YES NO N/A

15. Are bubbles > 6mm absent in VOA samples? _____ YES NO N/A

16. Was the client contacted concerning this sample delivery? _____ YES NO
 If YES, Who was called? _____ By _____ Date: _____

COMMENTS

Purgeable Organics by GC/MS

Lab #: 224529	Location: 3820 Manila Ave Oakland, Ca
Client: SOMA Environmental Engineering Inc.	Prep: EPA 5030B
Project#: 2515	Analysis: EPA 8260B
Field ID: PSP-1	Batch#: 169804
Lab ID: 224529-001	Sampled: 12/08/10
Matrix: Water	Received: 12/08/10
Units: ug/L	Analyzed: 12/09/10
Diln Fac: 1.000	

Analyte	Result	RL
Freon 12	ND	1.0
Chloromethane	ND	1.0
Vinyl Chloride	ND	0.5
Bromomethane	ND	1.0
Chloroethane	ND	1.0
Trichlorofluoromethane	ND	1.0
Acetone	ND	10
Freon 113	ND	2.0
1,1-Dichloroethene	ND	0.5
Methylene Chloride	ND	10
Carbon Disulfide	ND	0.5
MTBE	ND	0.5
trans-1,2-Dichloroethene	ND	0.5
Vinyl Acetate	ND	10
1,1-Dichloroethane	ND	0.5
2-Butanone	ND	10
cis-1,2-Dichloroethene	ND	0.5
2,2-Dichloropropane	ND	0.5
Chloroform	ND	0.5
Bromochloromethane	ND	0.5
1,1,1-Trichloroethane	ND	0.5
1,1-Dichloropropene	ND	0.5
Carbon Tetrachloride	ND	0.5
1,2-Dichloroethane	ND	0.5
Benzene	ND	0.5
Trichloroethene	ND	0.5
1,2-Dichloropropane	ND	0.5
Bromodichloromethane	ND	0.5
Dibromomethane	ND	0.5
4-Methyl-2-Pentanone	ND	10
cis-1,3-Dichloropropene	ND	0.5
Toluene	ND	0.5
trans-1,3-Dichloropropene	ND	0.5
1,1,2-Trichloroethane	ND	0.5
2-Hexanone	ND	10
1,3-Dichloropropane	ND	0.5
Tetrachloroethene	ND	0.5

ND= Not Detected

RL= Reporting Limit

Purgeable Organics by GC/MS

Lab #: 224529	Location: 3820 Manila Ave Oakland, Ca
Client: SOMA Environmental Engineering Inc.	Prep: EPA 5030B
Project#: 2515	Analysis: EPA 8260B
Field ID: PSP-1	Batch#: 169804
Lab ID: 224529-001	Sampled: 12/08/10
Matrix: Water	Received: 12/08/10
Units: ug/L	Analyzed: 12/09/10
Diln Fac: 1.000	

Analyte	Result	RL
Dibromochloromethane	ND	0.5
1,2-Dibromoethane	ND	0.5
Chlorobenzene	ND	0.5
1,1,1,2-Tetrachloroethane	ND	0.5
Ethylbenzene	ND	0.5
m,p-Xylenes	ND	0.5
o-Xylene	ND	0.5
Styrene	ND	0.5
Bromoform	ND	1.0
Isopropylbenzene	ND	0.5
1,1,2,2-Tetrachloroethane	ND	0.5
1,2,3-Trichloropropane	ND	0.5
Propylbenzene	ND	0.5
Bromobenzene	ND	0.5
1,3,5-Trimethylbenzene	ND	0.5
2-Chlorotoluene	ND	0.5
4-Chlorotoluene	ND	0.5
tert-Butylbenzene	ND	0.5
1,2,4-Trimethylbenzene	ND	0.5
sec-Butylbenzene	ND	0.5
para-Isopropyl Toluene	ND	0.5
1,3-Dichlorobenzene	ND	0.5
1,4-Dichlorobenzene	ND	0.5
n-Butylbenzene	ND	0.5
1,2-Dichlorobenzene	ND	0.5
1,2-Dibromo-3-Chloropropane	ND	2.0
1,2,4-Trichlorobenzene	ND	0.5
Hexachlorobutadiene	ND	2.0
Naphthalene	ND	2.0
1,2,3-Trichlorobenzene	ND	0.5

Surrogate	%REC	Limits
Dibromofluoromethane	98	80-125
1,2-Dichloroethane-d4	87	71-146
Toluene-d8	92	80-120
Bromofluorobenzene	96	80-120

ND= Not Detected
 RL= Reporting Limit

Purgeable Organics by GC/MS

Lab #: 224529	Location: 3820 Manila Ave Oakland, Ca
Client: SOMA Environmental Engineering Inc.	Prep: EPA 5030B
Project#: 2515	Analysis: EPA 8260B
Field ID: GAC-1	Batch#: 169804
Lab ID: 224529-002	Sampled: 12/08/10
Matrix: Water	Received: 12/08/10
Units: ug/L	Analyzed: 12/09/10
Diln Fac: 1.000	

Analyte	Result	RL
Freon 12	ND	1.0
Chloromethane	ND	1.0
Vinyl Chloride	ND	0.5
Bromomethane	ND	1.0
Chloroethane	ND	1.0
Trichlorofluoromethane	ND	1.0
Acetone	ND	10
Freon 113	ND	2.0
1,1-Dichloroethene	ND	0.5
Methylene Chloride	ND	10
Carbon Disulfide	ND	0.5
MTBE	ND	0.5
trans-1,2-Dichloroethene	ND	0.5
Vinyl Acetate	ND	10
1,1-Dichloroethane	ND	0.5
2-Butanone	ND	10
cis-1,2-Dichloroethene	ND	0.5
2,2-Dichloropropane	ND	0.5
Chloroform	ND	0.5
Bromochloromethane	ND	0.5
1,1,1-Trichloroethane	ND	0.5
1,1-Dichloropropene	ND	0.5
Carbon Tetrachloride	ND	0.5
1,2-Dichloroethane	ND	0.5
Benzene	ND	0.5
Trichloroethene	ND	0.5
1,2-Dichloropropane	ND	0.5
Bromodichloromethane	ND	0.5
Dibromomethane	ND	0.5
4-Methyl-2-Pentanone	ND	10
cis-1,3-Dichloropropene	ND	0.5
Toluene	ND	0.5
trans-1,3-Dichloropropene	ND	0.5
1,1,2-Trichloroethane	ND	0.5
2-Hexanone	ND	10
1,3-Dichloropropane	ND	0.5
Tetrachloroethene	ND	0.5

ND= Not Detected

RL= Reporting Limit

Purgeable Organics by GC/MS

Lab #: 224529	Location: 3820 Manila Ave Oakland, Ca
Client: SOMA Environmental Engineering Inc.	Prep: EPA 5030B
Project#: 2515	Analysis: EPA 8260B
Field ID: GAC-1	Batch#: 169804
Lab ID: 224529-002	Sampled: 12/08/10
Matrix: Water	Received: 12/08/10
Units: ug/L	Analyzed: 12/09/10
Diln Fac: 1.000	

Analyte	Result	RL
Dibromochloromethane	ND	0.5
1,2-Dibromoethane	ND	0.5
Chlorobenzene	ND	0.5
1,1,1,2-Tetrachloroethane	ND	0.5
Ethylbenzene	ND	0.5
m,p-Xylenes	ND	0.5
o-Xylene	ND	0.5
Styrene	ND	0.5
Bromoform	ND	1.0
Isopropylbenzene	ND	0.5
1,1,2,2-Tetrachloroethane	ND	0.5
1,2,3-Trichloropropane	ND	0.5
Propylbenzene	ND	0.5
Bromobenzene	ND	0.5
1,3,5-Trimethylbenzene	ND	0.5
2-Chlorotoluene	ND	0.5
4-Chlorotoluene	ND	0.5
tert-Butylbenzene	ND	0.5
1,2,4-Trimethylbenzene	ND	0.5
sec-Butylbenzene	ND	0.5
para-Isopropyl Toluene	ND	0.5
1,3-Dichlorobenzene	ND	0.5
1,4-Dichlorobenzene	ND	0.5
n-Butylbenzene	ND	0.5
1,2-Dichlorobenzene	ND	0.5
1,2-Dibromo-3-Chloropropane	ND	2.0
1,2,4-Trichlorobenzene	ND	0.5
Hexachlorobutadiene	ND	2.0
Naphthalene	ND	2.0
1,2,3-Trichlorobenzene	ND	0.5

Surrogate	%REC	Limits
Dibromofluoromethane	101	80-125
1,2-Dichloroethane-d4	88	71-146
Toluene-d8	91	80-120
Bromofluorobenzene	95	80-120

ND= Not Detected
 RL= Reporting Limit

Purgeable Organics by GC/MS

Lab #: 224529	Location: 3820 Manila Ave Oakland, Ca
Client: SOMA Environmental Engineering Inc.	Prep: EPA 5030B
Project#: 2515	Analysis: EPA 8260B
Field ID: INFLUENT	Batch#: 169856
Lab ID: 224529-003	Sampled: 12/08/10
Matrix: Water	Received: 12/08/10
Units: ug/L	Analyzed: 12/10/10
Diln Fac: 2.500	

Analyte	Result	RL
Freon 12	ND	2.5
Chloromethane	ND	2.5
Vinyl Chloride	ND	1.3
Bromomethane	ND	2.5
Chloroethane	ND	2.5
Trichlorofluoromethane	ND	2.5
Acetone	130	25
Freon 113	ND	5.0
1,1-Dichloroethene	ND	1.3
Methylene Chloride	ND	25
Carbon Disulfide	ND	1.3
MTBE	ND	1.3
trans-1,2-Dichloroethene	ND	1.3
Vinyl Acetate	ND	25
1,1-Dichloroethane	ND	1.3
2-Butanone	ND	25
cis-1,2-Dichloroethene	4.2	1.3
2,2-Dichloropropane	ND	1.3
Chloroform	ND	1.3
Bromochloromethane	ND	1.3
1,1,1-Trichloroethane	ND	1.3
1,1-Dichloropropene	ND	1.3
Carbon Tetrachloride	ND	1.3
1,2-Dichloroethane	ND	1.3
Benzene	ND	1.3
Trichloroethene	ND	1.3
1,2-Dichloropropane	ND	1.3
Bromodichloromethane	ND	1.3
Dibromomethane	ND	1.3
4-Methyl-2-Pentanone	ND	25
cis-1,3-Dichloropropene	ND	1.3
Toluene	1.9	1.3
trans-1,3-Dichloropropene	ND	1.3
1,1,2-Trichloroethane	ND	1.3
2-Hexanone	ND	25
1,3-Dichloropropane	ND	1.3
Tetrachloroethene	ND	1.3

ND= Not Detected

RL= Reporting Limit

Purgeable Organics by GC/MS

Lab #: 224529	Location: 3820 Manila Ave Oakland, Ca
Client: SOMA Environmental Engineering Inc.	Prep: EPA 5030B
Project#: 2515	Analysis: EPA 8260B
Field ID: INFLUENT	Batch#: 169856
Lab ID: 224529-003	Sampled: 12/08/10
Matrix: Water	Received: 12/08/10
Units: ug/L	Analyzed: 12/10/10
Diln Fac: 2.500	

Analyte	Result	RL
Dibromochloromethane	ND	1.3
1,2-Dibromoethane	ND	1.3
Chlorobenzene	ND	1.3
1,1,1,2-Tetrachloroethane	ND	1.3
Ethylbenzene	ND	1.3
m,p-Xylenes	ND	1.3
o-Xylene	1.9	1.3
Styrene	ND	1.3
Bromoform	ND	2.5
Isopropylbenzene	ND	1.3
1,1,2,2-Tetrachloroethane	ND	1.3
1,2,3-Trichloropropane	ND	1.3
Propylbenzene	ND	1.3
Bromobenzene	ND	1.3
1,3,5-Trimethylbenzene	5.8	1.3
2-Chlorotoluene	ND	1.3
4-Chlorotoluene	ND	1.3
tert-Butylbenzene	ND	1.3
1,2,4-Trimethylbenzene	5.0	1.3
sec-Butylbenzene	ND	1.3
para-Isopropyl Toluene	ND	1.3
1,3-Dichlorobenzene	ND	1.3
1,4-Dichlorobenzene	ND	1.3
n-Butylbenzene	ND	1.3
1,2-Dichlorobenzene	ND	1.3
1,2-Dibromo-3-Chloropropane	ND	5.0
1,2,4-Trichlorobenzene	ND	1.3
Hexachlorobutadiene	ND	5.0
Naphthalene	ND	5.0
1,2,3-Trichlorobenzene	ND	1.3

Surrogate	%REC	Limits
Dibromofluoromethane	99	80-125
1,2-Dichloroethane-d4	105	71-146
Toluene-d8	101	80-120
Bromofluorobenzene	110	80-120

ND= Not Detected
 RL= Reporting Limit

Batch QC Report

Purgeable Organics by GC/MS			
Lab #:	224529	Location:	3820 Manila Ave Oakland, Ca
Client:	SOMA Environmental Engineering Inc.	Prep:	EPA 5030B
Project#:	2515	Analysis:	EPA 8260B
Matrix:	Water	Batch#:	169804
Units:	ug/L	Analyzed:	12/09/10
Diln Fac:	1.000		

Type: BS Lab ID: QC571720

Analyte	Spiked	Result	%REC	Limits
1,1-Dichloroethene	25.00	26.65	107	65-138
Benzene	25.00	28.10	112	80-124
Trichloroethene	25.00	27.83	111	78-122
Toluene	25.00	24.97	100	80-120
Chlorobenzene	25.00	25.33	101	80-120

Surrogate	%REC	Limits
Dibromofluoromethane	96	80-125
1,2-Dichloroethane-d4	85	71-146
Toluene-d8	90	80-120
Bromofluorobenzene	92	80-120

Type: BSD Lab ID: QC571721

Analyte	Spiked	Result	%REC	Limits	RPD	Lim
1,1-Dichloroethene	25.00	28.09	112	65-138	5	20
Benzene	25.00	27.18	109	80-124	3	20
Trichloroethene	25.00	26.90	108	78-122	3	20
Toluene	25.00	24.13	97	80-120	3	20
Chlorobenzene	25.00	25.86	103	80-120	2	20

Surrogate	%REC	Limits
Dibromofluoromethane	95	80-125
1,2-Dichloroethane-d4	82	71-146
Toluene-d8	91	80-120
Bromofluorobenzene	91	80-120

RPD= Relative Percent Difference

Batch QC Report

Purgeable Organics by GC/MS			
Lab #:	224529	Location:	3820 Manila Ave Oakland, Ca
Client:	SOMA Environmental Engineering Inc.	Prep:	EPA 5030B
Project#:	2515	Analysis:	EPA 8260B
Type:	BLANK	Diln Fac:	1.000
Lab ID:	QC571722	Batch#:	169804
Matrix:	Water	Analyzed:	12/09/10
Units:	ug/L		

Analyte	Result	RL
Freon 12	ND	1.0
Chloromethane	ND	1.0
Vinyl Chloride	ND	0.5
Bromomethane	ND	1.0
Chloroethane	ND	1.0
Trichlorofluoromethane	ND	1.0
Acetone	ND	10
Freon 113	ND	2.0
1,1-Dichloroethene	ND	0.5
Methylene Chloride	ND	10
Carbon Disulfide	ND	0.5
MTBE	ND	0.5
trans-1,2-Dichloroethene	ND	0.5
Vinyl Acetate	ND	10
1,1-Dichloroethane	ND	0.5
2-Butanone	ND	10
cis-1,2-Dichloroethene	ND	0.5
2,2-Dichloropropane	ND	0.5
Chloroform	ND	0.5
Bromochloromethane	ND	0.5
1,1,1-Trichloroethane	ND	0.5
1,1-Dichloropropene	ND	0.5
Carbon Tetrachloride	ND	0.5
1,2-Dichloroethane	ND	0.5
Benzene	ND	0.5
Trichloroethene	ND	0.5
1,2-Dichloropropane	ND	0.5
Bromodichloromethane	ND	0.5
Dibromomethane	ND	0.5
4-Methyl-2-Pentanone	ND	10
cis-1,3-Dichloropropene	ND	0.5
Toluene	ND	0.5
trans-1,3-Dichloropropene	ND	0.5
1,1,2-Trichloroethane	ND	0.5
2-Hexanone	ND	10
1,3-Dichloropropane	ND	0.5
Tetrachloroethene	ND	0.5

ND= Not Detected

RL= Reporting Limit

Batch QC Report

Purgeable Organics by GC/MS			
Lab #:	224529	Location:	3820 Manila Ave Oakland, Ca
Client:	SOMA Environmental Engineering Inc.	Prep:	EPA 5030B
Project#:	2515	Analysis:	EPA 8260B
Type:	BLANK	Diln Fac:	1.000
Lab ID:	QC571722	Batch#:	169804
Matrix:	Water	Analyzed:	12/09/10
Units:	ug/L		

Analyte	Result	RL
Dibromochloromethane	ND	0.5
1,2-Dibromoethane	ND	0.5
Chlorobenzene	ND	0.5
1,1,1,2-Tetrachloroethane	ND	0.5
Ethylbenzene	ND	0.5
m,p-Xylenes	ND	0.5
o-Xylene	ND	0.5
Styrene	ND	0.5
Bromoform	ND	1.0
Isopropylbenzene	ND	0.5
1,1,2,2-Tetrachloroethane	ND	0.5
1,2,3-Trichloropropane	ND	0.5
Propylbenzene	ND	0.5
Bromobenzene	ND	0.5
1,3,5-Trimethylbenzene	ND	0.5
2-Chlorotoluene	ND	0.5
4-Chlorotoluene	ND	0.5
tert-Butylbenzene	ND	0.5
1,2,4-Trimethylbenzene	ND	0.5
sec-Butylbenzene	ND	0.5
para-Isopropyl Toluene	ND	0.5
1,3-Dichlorobenzene	ND	0.5
1,4-Dichlorobenzene	ND	0.5
n-Butylbenzene	ND	0.5
1,2-Dichlorobenzene	ND	0.5
1,2-Dibromo-3-Chloropropane	ND	2.0
1,2,4-Trichlorobenzene	ND	0.5
Hexachlorobutadiene	ND	2.0
Naphthalene	ND	2.0
1,2,3-Trichlorobenzene	ND	0.5

Surrogate	%REC	Limits
Dibromofluoromethane	98	80-125
1,2-Dichloroethane-d4	87	71-146
Toluene-d8	92	80-120
Bromofluorobenzene	89	80-120

ND= Not Detected

RL= Reporting Limit

Batch QC Report

Purgeable Organics by GC/MS			
Lab #:	224529	Location:	3820 Manila Ave Oakland, Ca
Client:	SOMA Environmental Engineering Inc.	Prep:	EPA 5030B
Project#:	2515	Analysis:	EPA 8260B
Matrix:	Water	Batch#:	169856
Units:	ug/L	Analyzed:	12/10/10
Diln Fac:	1.000		

Type: BS Lab ID: QC571925

Analyte	Spiked	Result	%REC	Limits
1,1-Dichloroethene	25.00	23.82	95	65-138
Benzene	25.00	23.35	93	80-124
Trichloroethene	25.00	23.20	93	78-122
Toluene	25.00	23.37	93	80-120
Chlorobenzene	25.00	22.78	91	80-120

Surrogate	%REC	Limits
Dibromofluoromethane	98	80-125
1,2-Dichloroethane-d4	108	71-146
Toluene-d8	104	80-120
Bromofluorobenzene	102	80-120

Type: BSD Lab ID: QC571926

Analyte	Spiked	Result	%REC	Limits	RPD	Lim
1,1-Dichloroethene	25.00	23.21	93	65-138	3	20
Benzene	25.00	22.66	91	80-124	3	20
Trichloroethene	25.00	23.36	93	78-122	1	20
Toluene	25.00	22.77	91	80-120	3	20
Chlorobenzene	25.00	22.53	90	80-120	1	20

Surrogate	%REC	Limits
Dibromofluoromethane	99	80-125
1,2-Dichloroethane-d4	108	71-146
Toluene-d8	103	80-120
Bromofluorobenzene	100	80-120

RPD= Relative Percent Difference

Batch QC Report

Purgeable Organics by GC/MS			
Lab #:	224529	Location:	3820 Manila Ave Oakland, Ca
Client:	SOMA Environmental Engineering Inc.	Prep:	EPA 5030B
Project#:	2515	Analysis:	EPA 8260B
Type:	BLANK	Diln Fac:	1.000
Lab ID:	QC571927	Batch#:	169856
Matrix:	Water	Analyzed:	12/10/10
Units:	ug/L		

Analyte	Result	RL
Freon 12	ND	1.0
Chloromethane	ND	1.0
Vinyl Chloride	ND	0.5
Bromomethane	ND	1.0
Chloroethane	ND	1.0
Trichlorofluoromethane	ND	1.0
Acetone	ND	10
Freon 113	ND	2.0
1,1-Dichloroethene	ND	0.5
Methylene Chloride	ND	10
Carbon Disulfide	ND	0.5
MTBE	ND	0.5
trans-1,2-Dichloroethene	ND	0.5
Vinyl Acetate	ND	10
1,1-Dichloroethane	ND	0.5
2-Butanone	ND	10
cis-1,2-Dichloroethene	ND	0.5
2,2-Dichloropropane	ND	0.5
Chloroform	ND	0.5
Bromochloromethane	ND	0.5
1,1,1-Trichloroethane	ND	0.5
1,1-Dichloropropene	ND	0.5
Carbon Tetrachloride	ND	0.5
1,2-Dichloroethane	ND	0.5
Benzene	ND	0.5
Trichloroethene	ND	0.5
1,2-Dichloropropane	ND	0.5
Bromodichloromethane	ND	0.5
Dibromomethane	ND	0.5
4-Methyl-2-Pentanone	ND	10
cis-1,3-Dichloropropene	ND	0.5
Toluene	ND	0.5
trans-1,3-Dichloropropene	ND	0.5
1,1,2-Trichloroethane	ND	0.5
2-Hexanone	ND	10
1,3-Dichloropropane	ND	0.5
Tetrachloroethene	ND	0.5

ND= Not Detected

RL= Reporting Limit

Batch QC Report

Purgeable Organics by GC/MS			
Lab #:	224529	Location:	3820 Manila Ave Oakland, Ca
Client:	SOMA Environmental Engineering Inc.	Prep:	EPA 5030B
Project#:	2515	Analysis:	EPA 8260B
Type:	BLANK	Diln Fac:	1.000
Lab ID:	QC571927	Batch#:	169856
Matrix:	Water	Analyzed:	12/10/10
Units:	ug/L		

Analyte	Result	RL
Dibromochloromethane	ND	0.5
1,2-Dibromoethane	ND	0.5
Chlorobenzene	ND	0.5
1,1,1,2-Tetrachloroethane	ND	0.5
Ethylbenzene	ND	0.5
m,p-Xylenes	ND	0.5
o-Xylene	ND	0.5
Styrene	ND	0.5
Bromoform	ND	1.0
Isopropylbenzene	ND	0.5
1,1,2,2-Tetrachloroethane	ND	0.5
1,2,3-Trichloropropane	ND	0.5
Propylbenzene	ND	0.5
Bromobenzene	ND	0.5
1,3,5-Trimethylbenzene	ND	0.5
2-Chlorotoluene	ND	0.5
4-Chlorotoluene	ND	0.5
tert-Butylbenzene	ND	0.5
1,2,4-Trimethylbenzene	ND	0.5
sec-Butylbenzene	ND	0.5
para-Isopropyl Toluene	ND	0.5
1,3-Dichlorobenzene	ND	0.5
1,4-Dichlorobenzene	ND	0.5
n-Butylbenzene	ND	0.5
1,2-Dichlorobenzene	ND	0.5
1,2-Dibromo-3-Chloropropane	ND	2.0
1,2,4-Trichlorobenzene	ND	0.5
Hexachlorobutadiene	ND	2.0
Naphthalene	ND	2.0
1,2,3-Trichlorobenzene	ND	0.5

Surrogate	%REC	Limits
Dibromofluoromethane	101	80-125
1,2-Dichloroethane-d4	107	71-146
Toluene-d8	103	80-120
Bromofluorobenzene	104	80-120

ND= Not Detected

RL= Reporting Limit

Batch QC Report

Purgeable Organics by GC/MS			
Lab #:	224529	Location:	3820 Manila Ave Oakland, Ca
Client:	SOMA Environmental Engineering Inc.	Prep:	EPA 5030B
Project#:	2515	Analysis:	EPA 8260B
Field ID:	ZZZZZZZZZZ	Batch#:	169856
MSS Lab ID:	224574-008	Sampled:	12/09/10
Matrix:	Water	Received:	12/09/10
Units:	ug/L	Analyzed:	12/10/10
Diln Fac:	1.000		

Type: MS Lab ID: QC571981

Analyte	MSS Result	Spiked	Result	%REC	Limits
1,1-Dichloroethene	<0.1591	25.00	24.34	97	75-133
Benzene	<0.1000	25.00	23.32	93	80-121
Trichloroethene	<0.1000	25.00	23.98	96	75-124
Toluene	<0.1000	25.00	23.54	94	80-120
Chlorobenzene	<0.1000	25.00	23.05	92	80-120

Surrogate	%REC	Limits
Dibromofluoromethane	99	80-125
1,2-Dichloroethane-d4	107	71-146
Toluene-d8	101	80-120
Bromofluorobenzene	100	80-120

Type: MSD Lab ID: QC571982

Analyte	Spiked	Result	%REC	Limits	RPD	Lim
1,1-Dichloroethene	25.00	23.34	93	75-133	4	20
Benzene	25.00	22.64	91	80-121	3	20
Trichloroethene	25.00	23.09	92	75-124	4	20
Toluene	25.00	23.03	92	80-120	2	20
Chlorobenzene	25.00	22.61	90	80-120	2	20

Surrogate	%REC	Limits
Dibromofluoromethane	98	80-125
1,2-Dichloroethane-d4	106	71-146
Toluene-d8	101	80-120
Bromofluorobenzene	102	80-120

RPD= Relative Percent Difference