



ENVIRONMENTAL  
PROTECTION

98 JUN 24 PM 4:03

June 19, 1998

Alameda County Health Agency  
1131 Harbor Bay Pkwy., 2nd floor  
Alameda, CA 94502

RE: STATISTICAL INVENTORY RECONCILIATION (SIR)  
60-DAY FAILURE CONFIRMATION TEST RESULTS

Dear County:

Pursuant to CCR, Title 23, Section 2646.1(d), you were notified that the gasoline UST system(s) referenced on the attached, failed 60-day SIR analysis for the months of March and April 1998.

Attached please find a copy of the original notification. Also attached, is a copy of the follow-up UST precision test. This test does not confirm the SIR failure results.

If you have any questions, please contact me at (602) 200-4530.

Respectfully,

Carmen Tucker, Testing Analyst  
Environmental Compliance

Attachments

cc: Site Manager  
Compliance Specialist  
BOM

3550 N. Central Ave.  
Phoenix, AZ 85012  
602.200.4700  
fax: 602.530.5088





**TOSCO**  
Marketing  
Company

May 22, 1998

Alameda County Health Agency  
1131 Harbor Bay  
Alameda, CA 94502

RE: STATISTICAL INVENTORY RECONCILIATION (SIR)  
TWO MONTHS ANALYSIS FAILURE OR INCONCLUSIVE NOTIFICATION

Dear County:

Pursuant to CCR, Title 23, Section 2646.1(d), Reporting of suspected releases, you are being notified that the following gasoline UST system(s) located within your jurisdiction failed SIR analysis for two months (March/ April 1998).

Attached please find a copy of the SIR Summary for each site. A tank integrity test will be conducted on the above mentioned tanks within 10 days of this notice. If the tank integrity test confirms the SIR findings, the tank will be put out of operation until further investigation and repairs can be done. All test results will be forwarded to the County.

Respectfully,

Carmen Tucker, Testing Analyst  
Tosco Marketing Company

Attachments

CC: Operations Manager  
Steve Boyd, Compliance Specialist, South Coast  
Tom DuMont, Compliance Specialist, North Coast

3550 N. Central Avenue  
Suite 400, DC-40  
Phoenix, AZ 85012



## STATISTICAL INVENTORY RECONCILIATION (SIR) MONTHLY REPORT

<b>SIR Provider</b>	USTMAN Industries, Inc.	<b>Phone:</b> (800) 253-8054
<b>SIR Version</b>	USTMAN Ver. 95.2A	<b>Date of SIR report:</b> 5/20/98
<b>Period Covered</b>	4/98	What is the required number of usable inventory days per tank? 30

<b>Facility Name</b>	Circle K No. 30189		
<b>Tank Location</b>	<b>Address</b> 3255 MCCARTNEY RD	<b>City</b> ALAMEDA	
	<b>Phone</b> (510) 523-7408	<b>State</b> CA	<b>Zip</b> 94501
<b>Tank Owner</b>	<b>Name</b> Tosco Marketing Co.		
	<b>Address</b> P.O. Box 52084		
<b>Tank Operator</b>	<b>City</b> Phoenix	<b>Phone</b> (602) 200-4530	
	<b>Name</b> Tosco Marketing Co.	<b>Phone</b> (602) 200-4530	

Tank Number	Tank Contents	Tank Capacity (gallons)	April 98			3/98	2/98	
			Leak Threshold	Minimum Detectable Leak Rate	Calculated Leak Rate	Pass, Fail, Inconclusive	Pass, Fail, Inconclusive	
			gph	gph	gph			
1	UnLeaded Plus	5929	0.10	0.11	-0.03	Pass	Inc.	Inc.
2	Unleaded Premium	9728	0.10	0.36	-1.6	Fail	Fail	Fail
3	UnLeaded Regular	11627	0.10	0.37	1.91	Inc.	Inc.	Inc.

<b>Person conducting evaluation</b>	Administrator : Michael Lessley	
<b>Signature (optional)</b>	<i>Michael Lessley</i>	