

R. S. EAGAN & CO.
 150-K Mason Circle
 CONCORD, CALIFORNIA 94520
 (415) 682-3636
 FAX (415) 682-0518

LETTER OF TRANSMITTAL

DATE	12-29-89-	JOB NO	89/190
ATTENTION	Katherine Chesick		
RE:	O.M.S. San Lorenzo		

89 DEC 30 AM 11:31

TO Alameda County Health Care Services
Dept of Environmental Health
Hazardous Materials Division
80 Swan Way, Room 200
Oakland, CA 94621

WE ARE SENDING YOU Attached Under separate cover via _____ the following items:

- Shop drawings Prints Plans Samples Specifications
 Copy of letter Change order _____

COPIES	DATE	NO.	DESCRIPTION
1	12-21-89		Letter to Dick Smith Of March Construction
1			Lab Reports
1			Chain of Custody Record
1			Map

THESE ARE TRANSMITTED as checked below:

- For approval Approved as submitted Resubmit _____ copies for approval
 For your use Approved as noted Submit _____ copies for distribution
 As requested Returned for corrections Return _____ corrected prints
 For review and comment _____
 FOR BIDS DUE _____ 19 _____ PRINTS RETURNED AFTER LOAN TO US

REMARKS _____

COPY TO _____

SIGNED: _____

R.S. EAGAN & CO.

General Contractors
General Engineering, Process Piping & Electrical

LIC. #476428

150-K MASON CIRCLE
CONCORD, CA 94520
(415) 682-3636

December 21, 1989

March Construction Company
P.O. Box 223
San Lorenzo, CA 94580

Attention: Mr. Dick Smith

RE: O.M.S. San Lorenzo

Dear Dick:

Following are the soil sample results for two sample locations:

Sample #1 was taken from a soil stockpile area.

Sample #2 was taken from a depth of 18" at the former location of the product piping which showed corrosion.

Based on this information we will await the states direction on proceeding with any removal work, however, we will proceed with the tank installation work.


Sincerely,

R.S. EAGAN & CO.

Robert S. Corsun

Robert S. Corsun
Project Manager

RSC:jj



DATE: 12/12/89

LOG NO.: 8125

DATE SAMPLED: 12/4/89

DATE RECEIVED: 12/4/89

CUSTOMER: R.S. Eagan and Company

REQUESTER: Bob Eagan

PROJECT: Cal. National Guard, 16501 Ashland Avenue, San Lorenzo, CA

 Sample Type: Soil

<u>Constituent</u>	<u>Units</u>	<u>Stockpile</u>		<u>Beneath piping</u>	
		<u>Concen- tration</u>	<u>Detection Limit</u>	<u>Concen- tration</u>	<u>Detection Limit</u>
DHS Method:					
Total Petroleum Hydrocarbons as Gasoline	mg/kg	250	30	0.9	0.6
Modified EPA Method 8020:					
Benzene	mg/kg	1.6	0.8	< 0.05	0.05
Toluene	mg/kg	12	0.6	< 0.05	0.05
Xylenes	mg/kg	42	2	< 0.2	0.2
Ethylbenzene	mg/kg	8.9	0.8	0.058	0.05

A handwritten signature in cursive script, reading 'Louis W. DuPuis', written over a horizontal line.

 Louis W. DuPuis
 Quality Assurance/Quality Control Manager

LWD: jon


8125

CHAIN OF CUSTODY RECORD

PROJ. NO.		PROJECT NAME				NO. OF CON- TAINERS	REMARKS				
		Cal National Guard 16501 Ashland Ave San Lorenzo CA									
SAMPLERS: (Signatures) <i>[Signature]</i> <i>[Signature]</i>											
STA. NO.	DATE	TIME	COMP.	GRAB	STATION LOCATION						
#1	12/4	2:00		X	Soil (2 BT)	2	X				
#2	89	2:25		X	Soil (2 BT)	2	X				
Relinquished by: (Signature)			Date / Time		Received by: (Signature)			Date / Time		Received by: (Signature)	
Relinquished by: (Signature)			Date / Time		Received by: (Signature)			Date / Time		Received by: (Signature)	
Relinquished by: (Signature)			Date / Time		Received for Laboratory by: (Signature)			Date / Time		Remarks	


TPH-G/BTXE
7 day FAT

Andy Pesse *Eagan Eto*




Cal. National Guard
16501 Ashland Ave.
San Lorenzo, California


N



Pile #1



vehicle ramp



#2
(18")



Gasoline
pump



Gasoline
pump



Pipe trench