

Data Chart for Tank System Tightness Test

PLEASE PRINT

1. OWNER Property <input checked="" type="checkbox"/> Tank(s) <input checked="" type="checkbox"/>	ALAMEDA 901 LINCOLN AVE ALAMEDA RICK ZURAS (415) 865-32 Name Address Representative Telephone SAME AS ABOVE Name Address Representative Telephone					
2. OPERATOR	SAME AS ABOVE Name Address Telephone					
3. REASON FOR TEST (Explain Fully)	OWNER SATISFACTION					
4. WHO REQUESTED TEST AND WHEN	RICK ZURAS Name Title Company or Affiliation Date Address Telephone					
5. TANK INVOLVED Use additional lines for manifolded tanks	Identify by Direction	Capacity	Brand/Supplier	Grade	Approx Age	Steel/Fiberglass
	SOUTH EAST	10126	ACE	REGULAR	10 YRS	STEEL
6. INSTALLATION DATA	Location	Cover	Fills	Vents	Siphones	Pumps
	SOUTH SIDE FRONT OF BUILDING	CONCRETE	4" W/ROPTUBES	2"	NONE	OLD TOILET SUB PUMP
	North inside driveway, Rear of station, etc.	Concrete, Black Top, Earth, etc	Size, Titefill make, Drop tubes, Remote Fills	Size, Manifolded	Which tanks?	Suction, Remote, Make if known
7. UNDERGROUND WATER	Depth to the Water table _____ <input checked="" type="checkbox"/> is the water over the tank? <input type="checkbox"/> Yes <input type="checkbox"/> No					
8. FILL-UP ARRANGEMENTS	Tanks to be filled _____ hr. _____ Date Arranged by _____ Name Telephone Extra product to "top off" and run tank tester How and who to provide? Consider NO Lead. Terminal or other contact for notice or inquiry _____ Company Name Telephone					
9. CONTRACTOR, MECHANICS, any other contractor involved	BAY COUNTIES SERVICE STATION MAINTENANCE					
10. OTHER INFORMATION OR REMARKS	Additional information on any items above Officials or others to be advised when testing is in progress or completed Visitors or observers present during test, etc					
11. TEST RESULTS	Tests were made on the above tank systems in accordance with test procedures prescribed for as detailed on attached test charts with results as follows:					
	Tank Identification	Tight	Leakage Indicated	Date Tested		
	REGULAR					
12. SENSOR CERTIFICATION	13. This is to certify that these tank systems were tested on the date(s) shown. Those indicated as "Tight" meet the criteria established by National Fire Protection Association Pamphlet 329. Technicians 1. ROBERT RIVERA Certification # 414813131 2. _____ Certification # _____					
Date 5-22-88 1679 Serial No. of Thermal Sensor	Robert Zuras BAY COUNTIES SERV. STA MAINT. Testing Contractor or Company. By: Signature 1096 VERBA BUENA AVE EMERYVILLE CA. 94608 Address					

15. TANK TO TEST
SOUTH EAST
Identify by position
REGULAR
Brand and Grade

15a. BRIEF DIAGRAM OF TANK FIELD
REGULAR SURGHE
REGULAR
STOR-G

16. CAPACITY
 Nominal Capacity 10000 Gallons
 By most accurate capacity chart available 10126 Gallons

From
 Station Chart
 Tank Manufacturer's Chart
 Company Engineering Data
 Charts supplied with
 Other _____

17. FILL-UP FOR TEST
 Stick Water Bottom before Fill-up _____ to 1/4" in _____ Gallons
 Tank Diameter 95 in _____ Inventory _____ Gallons
 Total Gallons ea Reading
10126 10126
TDP DEF 20
H2O 0
10146
 Transfer total to line 25a

18. SPECIAL CONDITIONS AND PROCEDURES TO TEST THIS TANK
 Water in tank Line(s) being tested with LVLLT
 High water table in tank excavation

See manual sections applicable Check below and record procedure in log (27)
 Use maximum allowable test pressure for all tests
 Four pound rule does not apply to doublewalled tanks
 Complete section below.

1. Is four pound rule required? Yes No
2. Height to 12" mark from bottom of tank _____ in.
3. Pressure at bottom of tank _____ P.S.I.
4. Pressure at top of tank _____ P.S.I.

19. TANK MEASUREMENTS FOR TSTT ASSEMBLY
 Bottom of tank to grade* _____ 133 in.
 Add 30" for "T" probe assy _____ 30 in.
 Total tubing to assemble — approximate _____ 163 in.

20. EXTENSION HOSE SETTING
 Tank top to grade* _____ 38 in.
 Extend hose on suction tube 6" or more below tank top _____ 44 in.
 *If Fill pipe extends above grade, use top of fill.


22. Thermal-Sensor reading after circulation 15324 digits
68/69 °F
 Between
 23. Digits per °F in range or expected change 326 digits

COEFFICIENT OF EXPANSION (Complete after circulation)
 24a. Corrected A.P.I. Gravity 59.5
 Observed A.P.I. Gravity _____
 Hydrometer employed _____ 7 H
 Observed Sample Temperature _____ 70 °F
 Corrected A.P.I. Gravity @ 60°F, From Table A _____ 58.2
 Coefficient of Expansion for Involved Product From Table B _____ .00060082
 Transfer COE to Line 25b

21. VAPOR RECOVERY SYSTEM Stage I Stage II

24b. COEFFICIENT OF EXPANSION RECIPROCAL METHOD
 Type of Product _____
 Hydrometer Employed _____ H
 Temperature in Tank After Circulation _____ °F
 Temperature of Sample _____ °F
 Difference (+/-) _____ °F
 Observed A.P.I. Gravity _____
 Reciprocal _____ Page # _____
 Total quantity in full tank (16 or 17) _____ Reciprocal _____ Volume change in this tank per °F _____
 Transfer to Line 26a

24c. FOR TESTING WITH WATER see Table C & D
 Water Temperature after Circulation Table C _____ °F
 Coefficient of Water Table D _____
 Added Surfactant? Yes No Transfer COE to Line 25b.



NOTES.

The above calculations are to be used for dry soil conditions to establish a positive pressure advantage, or when using the four pound rule to compensate for the presence of subsurface water in the tank area.

Refer to N.F.P.A. 30, Sections 2-32.4 and 2-7.2 and the tank manufacturer regarding allowable system test pressures.

25. $(a) 10146 \times (b) .00060082 = (c) 6.0959197$ gallons
Total quantity in full tank (16 or 17) Coefficient of expansion for involved product Volume change in this tank per °F

26. $(a) 6.0959197 \times (b) 326 = (c) .0186991$
Volume change per °F (25 or 24b) Digits per °F in test Range (23) Volume change per digit Compute to 4 decimal places This is test factor (e) .0187

Data Chart for Tank System Tightness Test

521-3100

PLEASE PRINT

1. OWNER Property Tank(s)

ALAMEDA COLLARS 901 LINCOLN AVE ALAMEDA 945901 RICK ZURAS (415) 865-3200

NAME: SAME AS ABOVE ADDRESS: Address REPRESENTATIVE: Telephone: Telephone: Telephone:

2. OPERATOR: SAME AS ABOVE

3. REASON FOR TEST (Explain Fully): OWNER SATISFACTION

RECEIVED
AUG 26 1988

HAZARDOUS MATERIALS

4. WHO REQUESTED TEST AND WHEN

RICK ZURAS 8-16-88

Name Title Company or Affiliation Date

Address Telephone

5. TANK INVOLVED

Identify by Direction	Capacity	Brand/Supplier	Grade	Approx Age	Steel/Fiberglass
SOUTHWEST	1012G	ACE	REGULAR	10 YRS	STEEL TANK
SOUTH WEST	1012G	ACE	SUBSTANTIAL U.L.	10 YRS	STEEL TANK

Use additional lines for manifolded tanks

6. INSTALLATION DATA

Location	Cover	Fills	Vents	Siphones	Pumps
SOUTH SIDE FRONT OF BUILDING BOTH TANKS North inside driveway, Rear of station, etc	CONCRETE BOTH TANKS Concrete, Black Top, Earth, etc.	4" W/PROP TUBES BOTH TANKS Size, Titefill make, Drop tubes, Remote Fills	2" BOTH TANKS Size, Manifolded	NONE which tanks?	OLD TORNE SUB PUMP BOTH TANKS Suction, Remote, Make if known

7. UNDERGROUND WATER

Depth to the Water table _____

Is the water over the tank? Yes No

8. FILL-UP ARRANGEMENTS

Tanks to be filled _____ hr. _____ Date Arranged by _____ Name Telephone

Extra product to 'top off' and run tank tester How and who to provide? Consider NO Lead.

Terminal or other contact for notices or inquiry _____ Company Name Telephone

9. CONTRACTOR, MECHANICS, any other contractor involved

BAY COUNTIES SERVICE STATION MAINTENANCE

10. OTHER INFORMATION OR REMARKS

Additional information on any items above Officials or others to be advised when testing is in progress or completed Visitors or observers present during test, etc.

11. TEST RESULTS

Tests were made on the above tank systems in accordance with test procedures prescribed for as detailed on attached test charts with results as follows:

Tank Identification	Tight	Leakage Indicated	Date Tested
REGULAR	- .004		
SUPER	- .007	- .127	
DIESEL			DID NOT TEST

12. SENSOR CERTIFICATION

8-22-88 Date

1679 Serial No. of Thermal Sensor

13. This is to certify that these tank systems were tested on the date(s) shown. Those indicated as "Tight" meet the criteria established by National Fire Protection Association Pamphlet 323.

Technicians

1. ROBERT RIVERA

Certification # 41481313

2. _____

Certification # _____


Robert Rivera BAY COUNTIES SERVICE STATION MAINT
Testing Contractor or Company. By Signature

1096 YERBA BUENA AVE. EMERYVILLE CA.
Address

15. TANK TO TEST

SOUTH EAST / SOUTH WEST
 Identity by position
REGULAR / SUPREME C.I.L
 Brand and Grade

15a. BRIEF DIAGRAM OF TANK FIELD



16. CAPACITY

Nominal Capacity 10,000 Gallons
 By most accurate capacity chart available 10126 Gallons

- From
 Station Chart
 Tank Manufacturer's Chart
 Company Engineering Data
 Charts supplied with
 Other

17. FILL-UP FOR TEST

Stick Water Bottom before Fill-up _____ in _____ Gallons Tank Diameter 95 in Inventory 10126 Total Gallons ea Reading 10126
TOP OFF 20
H2O 0
10146

18. SPECIAL CONDITIONS AND PROCEDURES TO TEST THIS TANK


- Water in tank Line(s) being tested with LVLLT
 High water table in tank excavation

See manual sections applicable Check below and record procedure in log (27).

Use maximum allowable test pressure for all tests Four pound rule does not apply to doublewalled tanks.

Complete section below:

1. Is four pound rule required? Yes No
 2. Height to 12" mark from bottom of tank _____ in
 3. Pressure at bottom of tank _____ P S I
 4. Pressure at top of tank _____ P S I



Depth of burial 38 in.
 Tank dia 95 in.
 Water table 0 in.

NOTES:

The above calculations are to be used for dry soil conditions to establish a positive pressure advantage, or when using the four pound rule to compensate for the presence of subsurface water in the tank area.

Refer to N.F.P.A. 30, Sections 2-3.2.4 and 2-7.2 and the tank manufacturer regarding allowable system test pressures

19. TANK MEASUREMENTS FOR TSTT ASSEMBLY

Bottom of tank to grade* 133 in.
 Add 30" for "T" probe assy 30 in.
 Total tubing to assemble -- approximate 163 in.

20. EXTENSION HOSE SETTING

Tank top to grade* 38 in.
 Extend hose on suction tube 6" or more below tank top 44 in.

*If fill pipe extends above grade, use top of fill.

22. Thermal-Sensor reading after circulation 15231 digits
68/69 °F Between
 23. Digits per °F in range of expected change 326 digits

COEFFICIENT OF EXPANSION (Complete after circulation)

24a. Corrected A.P.I. Gravity 59.8
 Observed A.P.I. Gravity _____
 Hydrometer employed 7 H
 Observed Sample Temperature 71 °F
 Corrected A.P.I. Gravity @ 60°F, From Table A, 58.4
 Coefficient of Expansion for Involved Product From Table B, .00060224
 Transfer COE to Line 25b

21. VAPOR RECOVERY SYSTEM Stage I Stage II

24b. COEFFICIENT OF EXPANSION RECIPROCAL METHOD

Type of Product _____
 Hydrometer Employed _____ H
 Temperature in Tank After Circulation _____ °F
 Temperature of Sample _____ °F
 Difference (+/-) _____ °F
 Observed A.P.I. Gravity _____
 Reciprocal _____ Page # _____
 Total quantity in full tank (16 or 17) _____ Reciprocal _____ Volume change in this tank per °F _____
 Transfer to Line 26a.

24c. FOR TESTING WITH WATER see Table C & D

Water Temperature after Circulation Table C _____ °F
 Coefficient of Water Table D, _____
 Added Surfactant? Yes No Transfer COE to Line 25b.

25. (a) 10146 × (b) .00060224 = (c) 6.110327 gallons
 Total quantity in full tank (16 or 17) Coefficient of expansion for involved product Volume change in this tank per °F
 26. (a) 6.110327 ÷ 326 = 0.0187433 This is
 Volume change per °F (25 or 24b) Digits per °F in test Range (23) Volume change per digit Compute to 4 decimal places test factor (a) 0.0188

27. Sensor Calibration 1679 / 16604		30. HYDROSTATIC PRESSURE CONTROL		31. VOLUME MEASUREMENTS (V) RECORD TO .001 GAL.			34. TEMPERATURE COMPENSATION USE FACTOR (a)			38. NET VOLUME CHANGING EACH READING	39. ACCUMULATED CHANGE	
LOG OF TEST PROCEDURES												
28. DATE	Record details of setting up and running test (Use full length of line if needed)	29. Reading No	30. Standpipe Level in Inches		32. Product in Graduate		33. Product Replaced (-)	35. Thermal Sensor Reading	36. Change Higher + Lower - (c)	37. Computation (c) * (a) = Expansion + Contraction -	38. Temperature Adjustment Volume Minus Expansion (+) or Contraction (-) #33(V) - #37(T)	39. At Low Level compute Change per Hour (NFPA criteria)
			Beginning of Reading	Level to which Restored	Before Reading	After Reading	Product Recovered (+)					
0800	ARRIVED AT TEST LOCATION; SET UP EQUIPMENT; PURGED AIR OUT OF LINES											
1015	PUMP PRIMED AND RUNNING											
1145	API SAMPLE REMOVED											
1200	FIRST SENSOR READING	1		42				15				
1215	START HIGH LEVEL TEST	2	43.5	42	.305	.415	+ .110	237	+6	+ .113	- .003	
1230	HIGH LEVEL TEST CONTINUE	3	43.6	42	.415	.535	+ .120	245	+8	+ .150	- .030	- .033
1245	" " " "	4	43.5	42	.535	.640	+ .105	249	+6	+ .113	- .008	- .091
1300	" " " "	5	43.5	42	.640	.740	+ .100	258	+9	+ .169	- .069	- .110
1315	" " " "	6	43.5	42	.740	.845	+ .105	263	+5	+ .094	+ .011	- .099
1320	DROPPED TO LOW LEVEL TEST							15				
1325	FIRST SENSOR READING	1		12				267				
1340	START LOW LEVEL TEST	2	14.7	12	.320	.515	+ .175	273	+6	+ .113	+ .062	
1355	LOW LEVEL TEST CONTINUE	3	14.0	12	.515	.655	+ .140	280	+7	+ .132	+ .008	+ .070
1410	" " " "	4	13.6	12	.650	.760	+ .110	285	+5	+ .094	+ .016	+ .086
1425	" " " "	5	13.6	12	.760	.870	+ .110	289	+4	+ .075 + .094	+ .035 + .016	+ .121 + .102
1440	" " " "	6	13.5	12	.870	.970	+ .100	294	+5	+ .094	+ .006	+ .113 + .102
1455	" " " "	7	13.5	12	.970	.330	+ .105	300	+6	+ .113	- .008	+ .100
1510	" " " "	8	13.4	12	.330	.930	+ .100	303	+3	+ .057	+ .043	+ .143
	TEST INCONCLUSIVE; RETESTED TANK; SEE ATTACHED READINGS											

REGULAR FACTOR A = 0.0188