

ARCO Products Company
2000 Alameda de las Pulgas
Mailing Address: Box 5811
San Mateo, California 94402
Telephone 415 571 2400



January 4, 1989 ⁹⁰

Hazardous Material Division
80 Swan Way Room 200
Oakland, Ca. 94621

12,000 gal

Attn: Ed Howell

Re: Tank Test Results
ARCO # 2152 _____
22141 Center St. _____
Castro Valley, Ca. _____

Dear Sirs:

This letter is to notify you that the tanks and piping at the above facility passed the latest tank test, as noted in the attached test results.

ARCO is committed to the compliance of all environmental laws that govern the safe operation of underground storage tanks. Feel free to call me at 415-571-2424.

Sincerely,

ARCO Products Company
a division of Atlantic Richfield Company

C. A. Holman
Env. Compl. Engineer

REM:cc
Enclosure
Form #1

Data Chart for Tank System Tightness Test

10.3
15.4

PLEASE PRINT

1. OWNER Property Tank(s)

Name: Area SS #2152 Address: 22141 CENTER ST / RIVERVIEW Representative: _____ Telephone: 581-1208

Name: _____ Address: _____ Representative: _____ Telephone: _____

Name: _____ Address: _____ Telephone: _____

3. REASON FOR TEST
(Explain Fully)
NEW TANKS

4. WHO REQUESTED TEST AND WHEN

Name: COURTLAND HOLMAN Title: Area Company or Affiliation: _____ Date: 10/17/84

Address: _____ Telephone: _____

5. TANK INVOLVED
Use additional lines for manifolded tanks

Identify by Direction	Capacity	Brand/Supplier	Grade	Approx Age	Steel/Fiberglass
<u>CENTER TANK</u>	<u>12,000</u>	<u>Area</u>	<u>REVIEW</u>	<u>-</u>	<u>DOUBLE WALL</u> <u>1130765203</u>

6. INSTALLATION DATA

Location	Cover	Fills	Vents	Siphones	Pumps
<u>NORTHEAST OF BUILDING</u> North inside driveway. Rear of station, etc	<u>Full</u> <u>54x3</u> Concrete, Black Top. Earth, etc.	<u>4"</u> Size, Titellil make, Drop tubes, Remote Fills	<u>2"</u> Size, Manifolded	<u> </u> Which tanks?	<u> </u> Suction, Remote. Make if known

7. UNDERGROUND WATER

Depth to the Water table _____

Is the water over the tank? Yes No

8. FILL-UP ARRANGEMENTS

Tanks to be filled 630 hr. 10/17/84 Date Arranged by COURTLAND HOLMAN Name: _____ Telephone: _____

Extra product to "top off" and run tank tester. How and who to provide? Consider NO Lead.

Terminal or other contact for notice or inquiry _____ Company: _____ Name: _____ Telephone: _____

9. CONTRACTOR, MECHANICS, any other contractor involved

GETLER - FURN INC
JIM REED
SCOTT MOWLE

10. OTHER INFORMATION OR REMARKS

1. TESTED WITH CENTER VENT & VENT COVER

Additional information on any items above. Officials or others to be advised when testing is in progress or completed. Visitors or observers present during test, etc

11. TEST RESULTS

Tests were made on the above tank systems in accordance with test procedures prescribed for as detailed on attached test charts with results as follows:

Tank Identification	Tight	Leakage Indicated	Date Tested
<u>12000 GALLON</u> <u>REVIEW</u>	<u>YES</u>		<u>10/17/84</u>

12. SENSOR CERTIFICATION
10/17/84 Date

Serial No of Thermal Sensor _____


13. This is to certify that these tank systems were tested on the date(s) shown. Those indicated as "Tight" meet the criteria established by the National Fire Protection Association Pamphlet 329.

Technicians
1. Jim Reed
2. Scott Mowle

Certification # 414313017
1984

Testing Contractor or Company By Signature _____
Address _____

15. TANK TO TEST
Middle Tank
 Identity by position
ARCO - Regular
 Brand and Grade



16. CAPACITY
 Nominal Capacity 12,000 Gallons
 By most accurate capacity chart available 11630 Gallons
 From
 Station Chart
 Tank Manufacturer's Chart
 Company Engineering Data
 Charts supplied with
 Other

17. FILL-UP FOR TEST
 Suck Water Bottom before Fill-up 2 in. to 1/4" in. Gallons Tank Diameter 92" in. Inventory Gallons Total Gallons ex. Reading
11630
TOP OFF 25
11655
 Transfer total to line 25a

18. SPECIAL CONDITIONS AND PROCEDURES TO TEST THIS TANK
 Water in tank Line(s) being tested with LVLLT
 High water table in tank excavation
 See manual sections applicable Check below and record procedure in log (27)
 Use maximum allowable test pressure for all tests Four pound rule does not apply to doublewalled tanks.
 Complete section below

- 1 Is four pound rule required? Yes No
- 2 Height to 12" mark from bottom of tank _____ in.
- 3 Pressure at bottom of tank _____ P.S.I.
- 4 Pressure at top of tank _____ P.S.I.

19. TANK MEASUREMENTS FOR TSTT ASSEMBLY
 Bottom of tank to grade* _____ 173" in.
 Add 30" for "T" probe assy _____ 30" in.
 Total tubing to assemble - approximate _____ 203" in.

20. EXTENSION HOSE SETTING
 Tank top to grade* _____ 81" in.
 Extend hose on suction tube 6" or more below tank top _____ 91' in.
 *If fill pipe extends above grade use top of fill


22. Thermal-Sensor reading after circulation _____ 3220 digits
 _____ 67.13 °F
 Between _____ 21.1 digits
 23. Digits per °F in range of expected change

COEFFICIENT OF EXPANSION (Complete after circulation)
 24a. Corrected A P I Gravity
 Observed A P I Gravity _____ 56.0
 Hydrometer employed _____ 6 H
 Observed Sample Temperature _____ 63 °F
 Corrected A P I Gravity @ 60°F. From Table A. _____ 55.6
 Coefficient of Expansion for Involved Product From Table B. _____ 1.0005336
 Transfer COE to Line 25b

21. VAPOR RECOVERY SYSTEM Stage I Stage II

24b. COEFFICIENT OF EXPANSION RECIPROCAL METHOD
 Type of Product _____
 Hydrometer Employed _____ H
 Temperature in Tank After Circulation _____ °F
 Temperature of Sample _____ °F
 Difference (+/-) _____ °F
 Observed A P.I. Gravity _____
 Reciprocal _____ Page # _____
 Total quantity in full tank (16 or 17) _____ Reciprocal _____ Volume change in this tank per °F _____
 Transfer to Line 26a

24c. FOR TESTING WITH WATER see Table C & D
 Water Temperature after Circulation Table C _____ °F
 Coefficient of Water Table D _____
 Added Surfactant? Yes No Transfer COE to Line 25b



The above calculations are to be used for dry soil conditions to establish a positive pressure advantage, or when using the four pound rule to compensate for the presence of subsurface water in the tank area
 Refer to NFPA 30 Sections 2-324 and 2-72 and the tank manufacturer regarding allowable system test pressures

25. (a) 11655 × (b) 1.0005336 = (c) 6.7374053 gallons
 Total quantity in full tank (16 or 17) Coefficient of expansion for involved product Volume change in this tank per °F
 26. (a) 6.7374053 = 0.7200
 Volume change per °F (25 or 24b) Digits per °F in test Range (23) Volume change per digit Compute to 4 decimal places This is test factor (a)

27. Sensor Calibration _____ / _____		30. HYDROSTATIC PRESSURE CONTROL		31. VOLUME MEASUREMENTS (V) RECORD TO .001 GAL.			34. TEMPERATURE COMPENSATION USE FACTOR (a)			38. NET VOLUME CHANGING EACH READING	39. ACCUMULATED CHANGE
LOG OF TEST PROCEDURES		29. Reading No.		32. Product in Graduate		33. Product Replaced (-)	35.	36.	37.	Temperature Adjustment	At Low Level compute Change per Hour (NFPA criteria)
28. DATE	Record details of setting up and running test. (Use full length of line if needed.)	Beginning of Reading	Level to which Restored	Before Reading	After Reading	Product Recovered (+)	Thermal Sensor Reading	Change Higher + Lower - (c)	Computation (c) * (a) = Expansion + Contraction -	Volume Minus Expansion (+) or Contraction (-) #33(V) - #37(T)	
TIME (24 hr.)											
920	TANKER TAPPED OFF										
930	SET UP TEST										
945	TESTING 2.175										
950	RAISE TO 12"								.0209		
1045	SEASONAL ADJUST	1	-2		.690		13220				
1100		2	41.9		.690	.670	-020	13228	+8	+1167	-.187
1115		3	42.1	-2	.670	.690	+020	13233	+5	+105	-.085
1130		4	42.4	12	.690	.740	+050	13240	+7	+146	-.096
1145		5	42.8	12	.740	.820	+080	13246	+6	+120	-.040
1200		6	42.9	42	.820	.920	+100	13254	+8	+167	-.067
1215		7	42.9	12	.190	.280	+090	13260	+6	+126	-.036
1230		8	43.1	42	.280	.400	+120	13266	+6	+126	-.006
1232	LOWERING TO 12"										
1245	READING AT 12"	9	13.2		.400	.560	+160	13272	+6	+126	+034
1300		10	13.2		.560	.690	+130	13279	+7	+146	-.016
1315			12.1		.690	.760	+070	13282	+3	+063	+007
1330			12.3		.760	.810	+050	13284	-2	+042	+008
1345			12.4		.140	.200	+060	13289	+4	+084	-.024
1350			12.6		.200	.250	+050	13289	+1	+021	+029
1325			12.3		.250	.280	+030	13291	+2	+042	-.012
1330			12.3		.290	.320	+030	13292			+019
1335			12.3		.320	.370	+050	13294	+3	+063	-.013
1340			12.3		.370	.420	+050	13297	+3	+063	-.025
1345			12.3		.420	.470	+050	13298	-2	+042	+008
1350			12.3		.470	.510	+040	13302	+3	+063	-.023
1355			12.3		.510	.550	+040	13304	-3	+042	-.022
1400			12.3		.550	.600	+050	13308	+2	+042	-.022
1405			12.3		.600	.640	+040	13309	-1	+021	+009

1	3.1	2.3	.640	.690	+0.050	13312	-2	-0.02	-0.02	
2		2.3	.720	.760	+0.040	13312	-2	-0.02	-0.02	
3		2.3	.720	.800	+0.080	13312	-2	-0.02	-0.02	
4		2.3	.800	.830	+0.030	13312	-2	-0.02	-0.02	
5		2.3	.830	.890	+0.060	13312	-2	-0.02	-0.02	
6		2.3	.890	.920	+0.030	13320	+2	+0.042	-0.022	
7		2.3	.920	.980	+0.060	13323	+3	-0.063	-0.033	
8		2.3	.980	1.030	+0.050	13326	+3	+0.063	-0.013	
9		2.3	1.030	1.080	+0.050	13328	+2	+0.042	-0.009	
10		2.3	1.080	1.130	+0.050	13330	+2	-0.042	+0.008	
11		2.3	1.130	1.170	+0.040	13333	+3	+0.063	-0.023	-0.0100
12		2.3	1.170	1.210	+0.040	13335	+2	-0.042	-0.002	-0.0145
13		2.3	1.210	1.250	+0.040					
14		2.3	1.250	1.290	+0.040					
15		2.3	1.290	1.330	+0.040					
16		2.3	1.330	1.370	+0.040					
17		2.3	1.370	1.410	+0.040					
18		2.3	1.410	1.450	+0.040					
19		2.3	1.450	1.490	+0.040					
20		2.3	1.490	1.530	+0.040					
21		2.3	1.530	1.570	+0.040					
22		2.3	1.570	1.610	+0.040					
23		2.3	1.610	1.650	+0.040					
24		2.3	1.650	1.690	+0.040					
25		2.3	1.690	1.730	+0.040					
26		2.3	1.730	1.770	+0.040					
27		2.3	1.770	1.810	+0.040					
28		2.3	1.810	1.850	+0.040					
29		2.3	1.850	1.890	+0.040					
30		2.3	1.890	1.930	+0.040					
31		2.3	1.930	1.970	+0.040					
32		2.3	1.970	2.010	+0.040					
33		2.3	2.010	2.050	+0.040					
34		2.3	2.050	2.090	+0.040					
35		2.3	2.090	2.130	+0.040					
36		2.3	2.130	2.170	+0.040					
37		2.3	2.170	2.210	+0.040					
38		2.3	2.210	2.250	+0.040					
39		2.3	2.250	2.290	+0.040					
40		2.3	2.290	2.330	+0.040					
41		2.3	2.330	2.370	+0.040					
42		2.3	2.370	2.410	+0.040					
43		2.3	2.410	2.450	+0.040					
44		2.3	2.450	2.490	+0.040					
45		2.3	2.490	2.530	+0.040					
46		2.3	2.530	2.570	+0.040					
47		2.3	2.570	2.610	+0.040					
48		2.3	2.610	2.650	+0.040					
49		2.3	2.650	2.690	+0.040					
50		2.3	2.690	2.730	+0.040					
51		2.3	2.730	2.770	+0.040					
52		2.3	2.770	2.810	+0.040					
53		2.3	2.810	2.850	+0.040					
54		2.3	2.850	2.890	+0.040					
55		2.3	2.890	2.930	+0.040					
56		2.3	2.930	2.970	+0.040					
57		2.3	2.970	3.010	+0.040					
58		2.3	3.010	3.050	+0.040					
59		2.3	3.050	3.090	+0.040					
60		2.3	3.090	3.130	+0.040					
61		2.3	3.130	3.170	+0.040					
62		2.3	3.170	3.210	+0.040					
63		2.3	3.210	3.250	+0.040					
64		2.3	3.250	3.290	+0.040					
65		2.3	3.290	3.330	+0.040					
66		2.3	3.330	3.370	+0.040					
67		2.3	3.370	3.410	+0.040					
68		2.3	3.410	3.450	+0.040					
69		2.3	3.450	3.490	+0.040					
70		2.3	3.490	3.530	+0.040					
71		2.3	3.530	3.570	+0.040					
72		2.3	3.570	3.610	+0.040					
73		2.3	3.610	3.650	+0.040					
74		2.3	3.650	3.690	+0.040					
75		2.3	3.690	3.730	+0.040					
76		2.3	3.730	3.770	+0.040					
77		2.3	3.770	3.810	+0.040					
78		2.3	3.810	3.850	+0.040					
79		2.3	3.850	3.890	+0.040					
80		2.3	3.890	3.930	+0.040					
81		2.3	3.930	3.970	+0.040					
82		2.3	3.970	4.010	+0.040					
83		2.3	4.010	4.050	+0.040					
84		2.3	4.050	4.090	+0.040					
85		2.3	4.090	4.130	+0.040					
86		2.3	4.130	4.170	+0.040					
87		2.3	4.170	4.210	+0.040					
88		2.3	4.210	4.250	+0.040					
89		2.3	4.250	4.290	+0.040					
90		2.3	4.290	4.330	+0.040					
91		2.3	4.330	4.370	+0.040					
92		2.3	4.370	4.410	+0.040					
93		2.3	4.410	4.450	+0.040					
94		2.3	4.450	4.490	+0.040					
95		2.3	4.490	4.530	+0.040					
96		2.3	4.530	4.570	+0.040					
97		2.3	4.570	4.610	+0.040					
98		2.3	4.610	4.650	+0.040					
99		2.3	4.650	4.690	+0.040					
100		2.3	4.690	4.730	+0.040					

* TANK TIGHT *
 LAST HOUR READING = 0.145

**P-T Tank Test Data Chart
 Additional Info**

1. Net Volume Change at Conclusion of Precision Test 0.145 gph
 Signature of Tester James P. Read
 Date 10/17/89

2 Statement:
 Tank and product handling system has been tested tight according to the Precision Test Criteria as established by N.F.P.A. publication 329. This is not intended to indicate permission of a leak.
 OR
 Tank and product handling system has failed the tank tightness test according to the Precision Test Criteria as established by N.F.P.A. publication 329.

It is the responsibility of the owner and/or operator of this system to immediately advise state and local authorities of any implied hazard and the possibility of any reportable pollution to the environment as a result of the indicated failure of this system. Heath Consultants Incorporated does not assume any responsibility or liability for any loss of product to the environment

Tank Owner/Operator _____
 Date _____

Data Chart for Tank System Tightness Test

Job # 1546

PLEASE PRINT

1. OWNER Property
 Tank(s)

ARCO Center St. / Grove NY, Castro Valley
Name Address Representative Telephone

2. OPERATOR

Name Address Telephone

3. REASON FOR TEST
(Explain Fully)

New installation TANKS, LINES, etc.

4. WHO REQUESTED TEST AND WHEN

Name Title Company or Affiliation Date

5. TANK INVOLVED

Use additional lines for manifolded tanks

Identify by Direction	Capacity	Brand/Supplier	Grade	Approx Age	Steel/Fiberglass
Tank closest to PARROT to garage way	12,000	ARCO	Unbonded Clear	NEW	Double wall Fiberglass

6. INSTALLATION DATA

Location	Cover	Fills	Vents	Siphones	Pumps
Northeast of lot - North inside driveway, Rear of station, etc	Concrete Asphalt	4"	2"	NONE	Remotes - Prod Jackhofs

7. UNDERGROUND WATER

Depth to the Water table 12/11 Is the water over the tank? Yes No

8. FILL-UP ARRANGEMENTS

Tanks to be filled 6:30 AM 10-17-89 Date Arranged by Paridesio
Extra product to "top off" and run tank tester How and who to provide? Consider NO Lead
Terminal or other contact for notice or inquiry

9. CONTRACTOR, MECHANICS, any other contractor involved

BETLER RYAN INC.
S. MOORE
J. REED

10. OTHER INFORMATION OR REMARKS

Full Systems Test - excluding product line.

11. TEST RESULTS

Tests were made on the above tank systems in accordance with test procedures prescribed for as detailed on attached test charts with results as follows:

Tank Identification	Tight	Leakage Indicated	Date Tested
#1 Unbonded Clear	✓ 02/16		10-17-89

12. SENSOR CERTIFICATION
10-17-89
Date


13. This is to certify that these tank systems were tested on the date(s) shown. Those indicated as "Tight" meet the criteria established by the National Fire Protection Association Pamphlet 329.

Technicians
1. S. MOORE

Testing Contractor or Company BETLER RYAN INC. By S. Moore Signature
1712 NATIONAL AVE. HAWARD, CA. Address

Certification # 414812279

15. TANK TO TEST
Closest to Grove way
 Identify by position
Areo - Unbleaded Clear
 Brand and Grade



16. CAPACITY
 Nominal Capacity 12,000 Gallons
 By most accurate capacity chart available _____ Gallons

From
 Station Chart
 Tank Manufacturer's Chart
 Company Engineering Data
 Charts supplied with
 Other _____

17. FILL-UP FOR TEST

Suck Water Bottom before Fill-up 0 in. to $\frac{1}{8}$ "
 Gallons _____
 Tank Diameter 92" in.
 Inventory _____

	Gallons	Total Gallons as Reading
<u>92"</u>	<u>11,627</u>	<u>11,627</u>
<u>Top off</u>	<u>23</u>	<u>+ 23</u>
		<u>11,650</u>

Transfer total to line 25a

18. SPECIAL CONDITIONS AND PROCEDURES TO TEST THIS TANK
 Water in tank Line(s) being tested with LVLLT
 High water table in tank excavation

See manual sections applicable Check below and record procedure in log (27)

Use maximum allowable test pressure for all tests
 Four pound rule does not apply to doublewalled tanks

Complete section below

- 1 Is four pound rule required? Yes No
- 2 Height to 12" mark from bottom of tank _____ in.
- 3 Pressure at bottom of tank _____ P.S.I.
- 4 Pressure at top of tank _____ P.S.I.

19. TANK MEASUREMENTS FOR TSTT ASSEMBLY

Bottom of tank to grade" 168 in
 Add 30" for "T" probe assy. 30 in.
 Total tubing to assemble - approximate _____ in

20. EXTENSION HOSE SETTING

Tank top to grade" 78 in
 Extend hose on suction tube 6" or more
 below tank top 82" + in.

*If fill pipe extends above grade, use top of fill

22. Thermal-Sensor reading after circulation 12882 digits
61-622 °F
 Between

23. Digits per °F in range of expected change 322 digits

COEFFICIENT OF EXPANSION (Complete after circulation)

24a. Corrected A P I Gravity 55.7
 Observed A P I Gravity _____
 Hydrometer employed 6 H
 Observed Sample Temperature 66 °F
 Corrected A P I Gravity @ 60°F. From Table A. 56.3 - 0.6 = 55.7
 Coefficient of Expansion for involved Product From Table B .00059230
 Transfer COE to Line 25b


21. VAPOR RECOVERY SYSTEM Stage I Stage II

24b. COEFFICIENT OF EXPANSION RECIPROCAL METHOD

Type of Product N/A
 Hydrometer Employed N/A H
 Temperature in Tank After Circulation N/A °F
 Temperature of Sample N/A °F
 Difference (+/-) N/A °F
 Observed A P I Gravity N/A
 Reciprocal _____ Page # _____
 Total quantity in full tank (16 or 17) _____ Reciprocal _____ Volume change in this tank per °F _____
 Transfer to Line 26a

24c. FOR TESTING WITH WATER see Table C & D

Water Temperature after Circulation Table C _____ °F
 Coefficient of Water Table D _____
 Added Surfactant? Yes No Transfer COE to Line 25b



The above calculations are to be used for dry soil conditions to establish a positive pressure advantage, or when using the four pound rule to compensate for the presence of subsurface water in the tank area.

Refer to NFPA 30, Sections 2-3.2.4 and 2-7.2 and the tank manufacturer regarding allowable system test pressures

25. (a) 11,650 Total quantity in full tank (16 or 17) × (b) .00059230 Coefficient of expansion for involved product = (c) 6.900295 gallons
 Volume change in this tank per °F

26. (a) 6.900295 Volume change per °F (25 or 24b) ÷ 322 Digits per °F in test Range (23) = 0.021429487 Volume change per digit Compute to 4 decimal places. This is test factor (a) .0214

27. Sensor Calibration <u>16600, 16600</u>			30. HYDROSTATIC PRESSURE CONTROL		31. VOLUME MEASUREMENTS (V) RECORD TO .001 GAL			34. TEMPERATURE COMPENSATION USE FACTOR (a)			38. NET VOLUME CHANGING EACH READING	39. ACCUMULATED CHANGE
LOG OF TEST PROCEDURES			29. Reading No		32. Product in Graduate		33. Product Replaced (-)	35. Thermal Sensor Reading	36. Change Higher + Lower - (c)	37. Computation (c) * (a) = Expansion + Contraction -	Temperature Adjustment	At Low Level compute Change per Hour (NFPA criteria)
DATE	Record details of setting up and running test. (Use full length of line if needed)	29. Reading No	Beginning of Reading	Level to which Restored	Before Reading	After Reading	Product Recovered (+)				Volume Minus Expansion (+) or Contraction (-) #33(V) - #37(T)	
TIME (24 hr)	<u>Unleaded Clear-</u>											
0925	Pump Primed + Running	All										
0930	Begin Circulation -									Factor A		
1025	Took API Sample									(.0214)		
1030	1st Sensor Reading	1	42	—	.895	1st Sensor -		12882				
1045	High level	2	40.6	42	.895	.790	.105	12891	+9	+1926	-.2976	
1100		3	40.8	42	.790	.690	.100	898	+7	+1498	-.2498	
1115		4	41.1	42	.690	.620	.070	905	+7	+1498	-.2198	
1130		5	41.3	42	.620	.570	.050	911	+6	+1284	-.1784	
1145		6	41.3	42	.570	.530	.040	920	+9	+1926	-.2326	
1200		7	41.4	42	.530	.490	.040	930	+10	+2140	-.2540	
1215		8	41.8	42	.490	.480	.010	938	+8	+1712	-.1812	
1220	Trap is low level	9	42	42	.480	1st Sensor		939				
1230		10	13.5	12	.480	.590	+110	943	+4	+0856	+0244	
1245		11	13.3	12	.590	.680	+090	953	+10	+2140	-.1240	
1250	Resin Low level	12	12.5	12	.680	.720	+040	955	+2	+0428	-.0028	
1255		13	12.4	12	.720	.755	+035	959	+4	+0856	-.0506	
1300		14	12.4	12	.755	.790	+035	963	+4	+0856	-.0506	
1305		15	12.4	12	.790	.820	+030	967	+4	+0856	-.0556	
1310		16	12.5	12	.820	.855	+035	972	+5	+1070	-.0720	
1315		17	12.5	12	.800	.035	+035	975	+3	+0642	-.0292	
1320		18	12.5	12	.035	.065	+030	976	+1	+0214	+0086	
1325		19	12.5	12	.065	.100	+035	978	+2	+0428	-.0078	
1330		20	12.5	12	.100	.130	+030	981	+3	+0642	-.0342	
1335		21	12.6	12	.130	.170	+040	983	+2	+0428	-.0028	
1340		22	12.5	12	.170	.205	+035	987	+4	+0856	-.0506	

1315	23	12.7	12	.205	.255	+0.050	991	+4	+0.0856	-0.0356	
1350	24	13.0	12	.255	.325	+0.070	993	+2	+0.0428	+0.0272	
1355	25	12.8	12	.325	.370	+0.045	997	+4	+0.0856	-0.0406	
1400	26	12.5	12	.370	.405	+0.035	13000	+3	+0.0642	-0.0292	
1405	27	12.8	12	.405	.455	+0.050	003	+3	+0.0642	-0.0142	
1410	28	12.9	12	.455	.510	+0.055	007	+4	+0.0856	-0.0306	
1415	29	12.7	12	.510	.555	+0.045	010	+3	+0.0642	-0.0192	
1420	30	12.9	12	.555	.610	+0.055	014	+4	+0.0856	-0.0306	
1425	31	12.8	12	.610	.660	+0.050	016	+2	+0.0428	+0.0072	
1430	32	12.9	12	.660	.720	+0.060	018	+2	+0.0428	+0.0172	
1435	33	12.9	12	.720	.780	+0.060	021	+3	+0.0642	-0.0042	
1440	34	12.7	12	.780	.820	+0.040	023	+2	+0.0428	-0.0028	
1445	35	12.8	12	.820	.870	+0.050	027	+4	+0.0856	-0.0356	-0.2693
1450	36	12.9	12	.870	.930	+0.060	030	+3	+0.0642	-0.0042	-0.2700
1455	37	12.9	12	.930	.995	+0.065	033	+3	+0.0642	+0.0008	-0.2443
1500	38	12.8	12	.160	.225	+0.065	034	+1	+0.0214	+0.0236	-0.1972
1505	39	12.5	12	.225	.260	+0.035	036	+2	+0.0428	-0.0078	-0.1733
1510	40	13.0	12	.260	.330	+0.070	040	+4	+0.0856	-0.0156	-0.1451
1515	41	12.8	12	.330	.380	+0.050	041	+1	+0.0214	+0.0286	-0.1162
1520	42	12.8	12	.380	.425	+0.045	042	+1	+0.0214	+0.0236	-0.1087
1525	43	12.9	12	.425	.490	+0.065	044	+2	+0.0428	+0.0222	-0.0937
1530	44	13.2	12	.490	.570	+0.080	046	+2	+0.0428	+0.0372	-0.0580
1535	45	12.6	12	.570	.600	+0.030	050	+4	+0.0856	-0.0556	-0.0844
1340	46	12.8	12	.600	.660	+0.060	052	+2	+0.0428	+0.0172	-0.0505
1345	47	13.0	12	.660	.725	+0.065	054	+2	+0.0428	+0.0222	-0.0216
1350											

**P-T Tank Test Data Chart
Additional Info**

1 Net Volume Change at Conclusion of Precision Test gph

Signature of Tester A. MADIE

Date 10-17-89

(-0.0216)

2 Statement:

Tank and product handling system has been tested tight according to the Precision Test Criteria as established by N.F.P.A. publication 329. This is not intended to indicate permission of a leak

OR

Tank and product handling system has failed the tank tightness test according to the Precision Test Criteria as established by N.F.P.A. publication 329.

It is the responsibility of the owner and/or operator of this system to immediately advise state and local authorities of any implied hazard and the possibility of any reportable pollution to the environment as a result of the indicated failure of this system. Heath Consultants Incorporated does not assume any responsibility or liability for any loss of product to the environment.

Tank Owner/Operator _____

Date _____

Data Chart for Tank System Tightness Test

-JCR
1546

PLEASE PRINT

1. OWNER Property Tank(s)

ARCO SU #2152 2214# CENTER ST / GREECE CITY 581-126

Name Address Representative Telephone

2. OPERATOR

Name Address Telephone

3. REASON FOR TEST
(Explain Fully)

NEW TANKS

4. WHO REQUESTED TEST AND WHEN

COURZANO HOLMAN ARCO 10/17/89

Name Title Company or Affiliation Date

Address Telephone

5. TANK INVOLVED
Use additional lines for manifolded tanks

Identify by Direction	Capacity	Brand/Supplier	Grade	Approx. Age	Steel/Fiberglass
<u>CLOSEST TO CENTER ST</u>	<u>12,000</u>	<u>ARCO</u>	<u>SEWAGE</u> <u>(MANHOLE)</u>	<u>NEW</u>	<u>POSSIBLY STEEL</u> <u>FIBERGLASS</u>

6. INSTALLATION DATA

Location	Cover	Fills	Vents	Siphones	Pumps
<u>NORTHEAST OF BUILDING</u> North inside driveway, Rear of station, etc.	<u>FULL SLAB</u> Concrete, Black Top, Earth, etc.	<u>4"</u> Size, Tilefill make, Drop tubes, Remote Fills	<u>2"</u> Size, Manifolded	<u>None</u> Which tanks?	<u>None</u> Suction, Remote, Make if known

7. UNDERGROUND WATER

Depth to the Water table ? Is the water over the tank? Yes No

8. FILL-UP ARRANGEMENTS

Tanks to be filled 630 hr. 10/17/89 Date Arranged by COURZANO HOLMAN

Extra product to "top off" and run tank tester. How and who to provide? Consider NO Lead

Terminal or other contact for notice or inquiry _____ Company Name Telephone

9. CONTRACTOR, MECHANICS, any other contractor involved

GETTNER PUGH INC
JIM REED

10. OTHER INFORMATION OR REMARKS

1) TESTED WITH ALL LINES PLUGGED AT TANK
2) VENT & VAPOR LINES TESTED WITH REDUCED TANK
3) TESTED WITH TWO CIRCULATING PUMPS

Additional information on any items above. Officials or others to be advised when testing is in progress or completed. Visitors or observers present during test, etc

11. TEST RESULTS

Tests were made on the above tank systems in accordance with test procedures prescribed for as detailed on attached test charts with results as follows:

Tank Identification	Tight	Leakage Indicated	Date Tested
<u>12,000 GALLON SUPERUNLOADED</u>	<u>YES</u>		<u>10/18/89</u>

12. SENSOR CERTIFICATION

10/18/89 Date

Serial No. of Thermal Sensor _____

13. This is to certify that these tank systems were tested on the date(s) shown. Those indicated as "Tight" meet the criteria established by the National Fire Protection Association Pamphlet 329.

Technicians

1. JIM REED GETTNER PUGH INC Testing Contractor or Company / By: Signature

Certification # 414813017 1992 Address

2. _____

Certification # _____

OKA
PM6827

Name of Supplier, Owner or Dealer

Address No. and Street(s)

City


State

Date of Test

15. TANK TO TEST

CLOSEST TO CENTER ST
Identify by position
ARCO SUPER UNLEADED
Brand and Grade

15a. BRIEF DIAGRAM OF TANK FIELD



16. CAPACITY

Nominal Capacity 12,000 Gallons
By most accurate capacity chart available 11630 Gallons

- From Station Chart, Tank Manufacturer's Chart, Company Engineering Data, Charts supplied with, Other

17. FILL-UP FOR TEST

Stick Water Bottom before Fill-up 0 to 1/4 in. Gallons Tank Diameter 92 in. Inventory 11630 Gallons Total Gallons ea. Reading 11655

18. SPECIAL CONDITIONS AND PROCEDURES TO TEST THIS TANK

- Water in tank, Line(s) being tested with LVLLT, High water table in tank excavation

See manual sections applicable. Check below and record procedure in log (27).

Use maximum allowable test pressure for all tests Four pound rule does not apply to doublewalled tanks.

Complete section below

- 1. Is four pound rule required? Yes No X
2. Height to 12" mark from bottom of tank
3. Pressure at bottom of tank P.S.I.
4. Pressure at top of tank P.S.I.

19. TANK MEASUREMENTS FOR TSTT ASSEMBLY

Bottom of tank to grade* 180 in. Add 30" for "T" probe assy 30 in. Total tubing to assemble - approximate 210 in.

20. EXTENSION HOSE SETTING

Tank top to grade* 88 in. Extend hose on suction tube 6" or more below tank top 98 in.

22. Thermal-Sensor reading after circulation 13240 digits 62/63/64 F Between 324 digits

COEFFICIENT OF EXPANSION (Complete after circulation)

24a. Corrected A.P.I. Gravity 56.0 Observed A.P.I. Gravity Hydrometer employed 2 H Observed Sample Temperature 212 F Corrected A.P.I. Gravity @ 60°F, From Table A 55.3

Coefficient of Expansion for Involved Product From Table B

Transfer COE to Line 25b

21. VAPOR RECOVERY SYSTEM

- Stage I, Stage II

24b. COEFFICIENT OF EXPANSION RECIPROCAL METHOD


Type of Product, Hydrometer Employed, Temperature in Tank After Circulation, Temperature of Sample, Difference (+/-), Observed A.P.I. Gravity, Reciprocal, Page #, Total quantity in full tank (16 or 17), Reciprocal, Volume change in this tank per °F, Transfer to Line 26a.

24c. FOR TESTING WITH WATER see Table C & D

Water Temperature after Circulation Table C, Coefficient of Water Table D, Added Surfactant? Yes No Transfer COE to Line 25b

25. (a) 11655 x (b) .00058023 = (c) 6.762530 gallons

26. (a) 6.762530 = (b) 324 = (c) .0209 This is test factor (a)



NOTES:

The above calculations are to be used for dry soil conditions to establish a positive pressure advantage, or when using the four pound rule to compensate for the presence of subsurface water in the tank area

Refer to NFPA 30 Sections 2-3.2.4 and 2-7.2 and the tank manufacturer regarding allowable system test pressures

27. Sensor Calibration _____ / _____		30. HYDROSTATIC PRESSURE CONTROL		31. VOLUME MEASUREMENTS (V) RECORD TO .001 GAL.			34. TEMPERATURE COMPENSATION USE FACTOR (a)			38. NET VOLUME CHANGING EACH READING		39. ACCUMULATED CHANGE
LOG OF TEST PROCEDURES												
28. DATE	Record details of setting up and running test. (Use full length of line if needed.)	29. Reading No.	32. Standpipe Level in Inches		32. Product in Graduate		33. Product Replaced (-)	35. Thermal Sensor Reading	36. Change Higher + Lower - (c)	37. Computation (c) x (a) = Expansion + Contraction -	38. Temperature Adjustment	At Low Level compute Change per Hour (NFPA criteria)
			Beginning of Reading	Level to which Restored	Before Reading	After Reading	Product Recovered (+)				Volume Minus Expansion (+) or Contraction (-) #33(V) - #37(T)	
9:00	SET UP TESTERS											
9:45	FLUED TESTERS & BLEW OFF AIR									.0209		
10:00	RAISED TO 42"											
11:00	READING @ 42"	1		42		.100		13260				
11:15	" " "	2	44.3	42	.100	.220	+ .120	13268	+8	+ .167	- .047	
11:30	" " "	3	44.8	42	.220	.370	+ .150	13276	+8	+ .167	- .017	
11:45	" " "	4	44.8	42	.370	.510	+ .140	13226	+10	+ .209	- .069	
12:00	" " "	5	45.0	42	.510	.660	+ .150	13295	+9	+ .183	- .038	
12:15	" " "	6	45.1	42	.660	.810	+ .150	13306	+11	+ .230	- .080	
12:30	" " "	7	45.4	42	.810	1.000	+ .190	13317	+11	+ .230	- .040	
12:45	" " "	8	45.4	42	.200	.390	+ .190	13329	+12	+ .251	- .061	
12:47	lowered to 12"			42								
1:00	READING TO 2"	9	16.0	12	.360	.620	+ .260	13335	+10	+ .269	+ .051	
1:15	" " "	10	15.7	12	.620	.850	.230	13350	+11	+ .230	± .000	
1:30	" " "	11	13.3	12	.060	.140	+ .080	13354	+4	+ .084	- .004	
1:45	" " "	12	13.3	12	.140	.220	+ .080	13359	+5	+ .105	- .025	
2:00	" " "	13	13.0	12	.220	.280	+ .060	13362	-2	+ .063	- .003	
2:15	" " "	14	13.0	12	.280	.340	+ .060	13364	-2	+ .042	+ .003	
2:30	" " "	15	13.0	12	.340	.400	+ .060	13366	-2	+ .042	+ .003	
2:45	" " "	16	13.2	12	.400	.470	+ .070	13367	+3	- .000	+ .000	
3:00	" " "	17	13.4	12	.470	.560	+ .090	13372	+3	+ .063	+ .027	
3:15	" " "	18	13.2	12	.560	.630	+ .070	13376	+4	+ .090	- .000	
3:30	" " "	19	13.3	12	.630	.710	+ .080	13380	+4	- .000	- .004	
3:45	" " "	20	13.3	12	.710	.790	+ .080	13383	+3	+ .063	+ .017	
4:00	" " "	21	13.2	12	.790	.870	+ .070	13388	+5	HOS	- .035	
4:15	" " "	22	13.3	12	.870	.950	+ .080	13392	+4	+ .034	- .004	
4:30	" " "	23	13.3	12	.950	1.00	+ .050	13396	+4	- .040	- .004	
4:45	" " "	24	13.2	12	1.00	1.190	+ .070	13399	-3	+ .063	+ .007	

DATA CHART
For Use With REGISTER

1 LOCATION: 7241 CENTER ST / 6 ROVE **CANTONMENT CA**

2 COMPANY: **ABCO**

3 TESTER: **NEW LINES**

4 TESTER'S NAME: **CAUTION HOLMAN**

5 SPECIAL INSTRUCTIONS:

6 CONTRACTOR OR COMPANY MAKING TEST MECHANIC(S) NAME: **GUTTER RYAN INC.**

7 IS A TANK TEST TO BE MADE WITH THIS LINE TEST? YES NO

8 MAKE AND TYPE OF PUMP OR DISPENSER:

9 WEATHER: **F 2/2** TEMPERATURE IN TANKS: **7** °C COVER OVER LINES: **0.01** APPROXIMATE BURIAL DEPTH:

11 IDENTITY AND LINE AS TESTED	12 TIME (MILITARY)	13 LOG OF TEST PROCEDURES, AMBIENT TEMPERATURE, WEATHER, ETC.	14 PRESSURE (PSI OR LPS)		15 VOLUME		16 TEST RESULTS
			BEFORE	AFTER	BEFORE	AFTER	
LINES (2/1)	1000	SET UP TESTER					
	1015	FLARED TESTER & PUMPED AIR					
	1030	PUMPED UP TO 50PSI					
	800	RESTORED TO 50PSI		50		073	
	815	↓ ↓ ↓	48	50	073	071	-002
	830	↓ ↓ ↓	47	50	071	068	-003
	845	↓ ↓ ↓	48	50	068	066	-002
	900	↓ ↓ ↓	48	50	066	064	-002
	915	↓ ↓ ↓	49	50	064	063	-001
							LINE TIGHT LAST HOUR READING: 002
SUPRA-VALVED	920	SET UP TESTER					
	930	FLARED TESTER & PUMPED AIR					
	940	PUMPED UP TO 50PSI					
	1000	RESTORED TO 50PSI		50		049	
	1015	↓ ↓ ↓	48	50	049	047	-002
	1030	↓ ↓ ↓	48	50	047	044	-003
	1045	↓ ↓ ↓	48	50	044	043	-001
	1100	↓ ↓ ↓	49	50	043	042	-001
	1115	↓ ↓ ↓	50	50	042	042	-000
							LINE TIGHT LAST HOUR READING: -005

[Handwritten signature]

11 IDENTIFY EACH LINE AS TESTED	12 TIME (MILITARY)	13 LOC. OF LEAKS, WELDS, ETC.	14 PRESSURE		15 VOLUME		16 TEST RESULTS
			BEFORE	AFTER	BEFORE	AFTER	
REGULAR	710	SURVEILLANCE					
	720	FINISH TESTER'S WORK	0.000				
	715	REMOVED UP TO 70 PSI					
	800	MARKED TO 50 PSI		50	.051		
	815		47	50	.081	.048	-003
	830		48	50	.048	.046	-002
	845		49	50	.045	.044	-001
	900		48	50	.044	.042	-002
	915	↓ ↓ ↓	49	50	.042	.041	-001

LINE TIGHT
LAST HOUR READING '007

SCALE: 1 PAGE = 9 FT. PER SQUARE—THIS SHEET = 168" x 114"
 3 PAGES = 9 FT. PER SQUARE—THIS SHEET = 336" x 336"

17 SKETCH OF LOCATION SHOW NORTH, STREETS, STATION BUILDING, TANKS, ISLANDS, PIPING (IF KNOWN OR BEST INFO), PUMPS OR DISPENSERS (USE NUMBERS ONLY IF PERMANENTLY MARKED).

