

ARCO Products Company

17315 Studebaker Road
Cerritos, California 90701-1488
Telephone 310 404 5300

Mailing Address: Box 6411
Artesia, California 90702-6411



92 MAY 13 11 1:59

5-8-92

Alameda County Health
Dept. of Env. Health
80 Swan Way Room 200
Oakland, Ca 94621

Amiv

Attn: Ravi Arulanantham

Re: Monitor and Leak Detector Test Results
ARCO #2152
22141 Center
Oakland, Ca. 94546

Contra Valley

Dear Sirs:

This letter is to notify you that the monitoring system and leak detectors at the above facility passed the intergity system test, as noted in the attached test results for the underground storage tank and line system on 12-6-91 and 7-3-91. Neither the tanks nor product lines require annual precision tests, to my knowledge.

ARCO is committed to the compliance of all environmental laws that govern the safe operation of underground storage tanks. Feel free to call me at 310-407-2610.

Sincerely,

ARCO Products Company
a division of Atlantic Richfield Company

C. A. Holman
Env. Compl. Engineer

ING



ARCO TANKS/LINE MONITORING SYSTEM CERTIFICATION

FOR POSITIVE SHUTDOWN

<u>Location</u>	<u>Service Company</u>	<u>Date</u>
<u>ARCO # 2152</u>	<u>API / RONAN</u>	<u>12-6-91</u>
<u>22141 Center</u>	<u>3031 Tischway</u>	
<u>Castro Valley, CA</u>	<u>San Jose, CA</u>	

Technician Performing Test B. THORNTON

TECH # 180

MANUFACTURER RONAN

PRODUCT LINE
TYPE DWF

TANK
TYPE DWF

WASTE OIL TANK
TYPE _____

MONITOR
____ Non Existing

MONITOR
____ Non Existing

MONITOR
____ Non Existing

API/PSD Operational

PSD Operational

____ Operational

____ Non Operational

____ Non Operational

____ Non Operational

DEAR SIR.

THIS IS TO CERTIFY THAT THE ANNUAL MONITORING SYSTEM TEST WERE PERFORMED AT THE ABOVE REFERENCED FACILITY, THE METHOD USED TO TEST THE MONITORING SYSTEM IS APPROVED BY, AND EXCEEDS THE SPECIFICATION ACCORDING TO THE MANUFACTURER.

SINCERELY

B. Thornton

Please leave one copy at the facility and send one copy to ARCO.



A dams Precision Instrumentation, Co.

A.P.I./RONAN LEAK DETECTION SYSTEMS
 2300 EAST ARTESIA BOULEVARD • LONG BEACH, CA 90805
 (213) 984-5380 • FAX (213) 984-5390

SERVICE ORDER NUMBER 00107	
DATE OF SERVICE 12-6-91	
TECHNICIAN B. THORNTON	
ARRIVED 3:00 pm	DEPARTED 5:15 p

1107

BILL TO		SITE ID NUMBER ARCO # 2152	
ADDRESS		ADDRESS AND CROSS STREET 22141 Center St. @ Grove	
CITY, STATE AND ZIP CODE		CITY, STATE AND ZIP CODE Castro Valley, CA 94546	
P.O. NUMBER 280587	MODEL NUMBER X765-A3-3x-35	SERIAL NUMBER 8-1112	SITE PHONE # (415) 581-1268
SERVICE REQUESTED BY/C.O. ARCO			
SERVICE REQUESTED Install KV-700			

DESCRIPTION OF WORK PERFORMED
Install 3 KV-700 interposing relays - RUN conduit & pull wire - Terminate wires for failsafe Positive shutdown. Test all 3 lines for shutdown - all pass - Label system & relays. cert & seal

SYSTEM CERTIFIED YES <input checked="" type="checkbox"/> NO <input type="checkbox"/> PSD	SYSTEM PSD YES <input checked="" type="checkbox"/> NO <input type="checkbox"/>	SYSTEM RUNNING YES <input checked="" type="checkbox"/> NO <input type="checkbox"/>	WASTE OIL YES <input type="checkbox"/> NO <input checked="" type="checkbox"/>	SYSTEM SEALED YES <input checked="" type="checkbox"/> NO <input type="checkbox"/>
--	---	---	--	--

DEMONSTRATED FOR:

QTY	MATERIALS USED MODEL #	DESCRIPTION	UNIT PRICE	TOTAL
3	KV-700	24VDC - N.O.		} 14.90
1	1/2" x 90"	LIT. Flex conn	3.90	
1	1/2" x 180"	LIT. Flex conn	2.35	
2	1/2" LIT. Flex		1.56	
15	Fork Lugs		20.50	
40	18g TFFN wire		1.46	
1	1/2" chase nipple		.05	
3	wire nuts		.05	

HOURS-MILEAGE	RATE	AMOUNT
LABOR	2.25	
TRAVEL	1	
MILES	44	

 CUSTOMER SIGNATURE	 DATE 12-6-91 TIME 5:15	SUB-TOTAL
		TAX
		TOTAL