

ALAMEDA COUNTY
HEALTH CARE SERVICES
AGENCY



DAVID J. KEARS, Agency Director

R0937

RAFAT A. SHAHID, ASST. AGENCY DIRECTOR

March 25, 1993
STID 2041

DEPARTMENT OF ENVIRONMENTAL HEALTH
State Water Resources Control Board
Division of Clean Water Programs
UST Local Oversight Program
80 Swan Way, Rm 200
Oakland, CA 94621
(510) 271-4530

Lynne Glassman
All Mercedes Dismantlers Inc.
1225-7th St.
Oakland CA 94607

Dear Mr. Glassman,

As you know, a 10,000-gallon underground storage tank (UST) was removed from your site on 10/22/92. According to the field inspection report, three soil samples were collected from below the tank. One sample had non-detectable concentrations of contaminants. One sample had 98 parts per million (ppm) TPH-gasoline and 0.220 ppm benzene. The results from the third sample are unknown. The stockpiled soil was sampled and found to contain 710 ppm gasoline, 0.210 ppm benzene, and 110 ppm lead. This information was provided by facsimile from your company.

A tank removal report was due to this office within 60 days of the tank removal, in this case by 12/22/92. This is stipulated on the Underground Tank Closure Plan, which you signed on 10/5/92 prior to tank removal. The tank removal report should contain all of the information outlined in item #22 of the Tank Closure Plan. We therefore request that you submit the tank removal report within 30 days or by April 25, 1993.

Please be advised that this is a formal request for technical reports pursuant to California Water Code Section 13267(b). Any extensions of the stated deadlines, or modifications of the required tasks, must be confirmed in writing by either this agency or the RWQCB.

If you have any questions, please contact me at 510-271-4530.

Sincerely,

A handwritten signature in cursive script, appearing to read "Jennifer Eberle".

Jennifer Eberle
Hazardous Materials Specialist

cc: Bob Mercado, Applied Environmental Solutions, 2530
Berryessa Rd., Suite 809, San Jose CA 95132
Rich Hiatt, RWQCB
Ed Howell/file

je