

ANALYSTS, INC.
2910 FORD STREET
OAKLAND, CALIFORNIA 94601

415-536-5914 TELEX 258039 OAKL
800-654-6696 INSIDE CALIFORNIA
800-332-0099 OUTSIDE CALIFORNIA

SEP 15 1988 14 SEPT, 1988

BERKELEY FARMS
ATTN: RONALD MADERO
4550 SAN PABLO AVE
EMERYVILLE, CA 94608

SAMPLE ID : RUSH SAMPLE FROM BERKELEY FARMS
DATE DRAWN:

PO#: N/R
LAB#: 31618

FOR THE TESTS PERFORMED, THE DATA INDICATES THE SAMPLE MEETS
ASTM D975 REQUIREMENTS FOR DIESEL NO. 2

PHYSICAL TEST RESULTS:	MEASURED	REQUIREMENTS DIESEL NO. 2	
		MIN	MAX
D93 - FLASH POINT (PMCC) - DEG F	205	125	
D287 - API GRAVITY AT 60 DEG F	33.3		
D1500 - ASTM COLOR - BEFORE	8.0		
D1500 - ASTM COLOR - AFTER	8.0		
F21-61 - ACCELERATED STABILITY	10		
D976 - CETANE NUMBER (CALCULATED)	46.3	39.5	
D86 - DISTILLATION DATA:			
- INIT TEMP - F	448		
- 5% TEMP - F	466		
- 10% TEMP - F	474		
- 20% TEMP - F	484		
- 30% TEMP - F	500		
- 40% TEMP - F	512		
- 50% TEMP - F	528		
- 60% TEMP - F	544		
- 70% TEMP - F	560		
- 80% TEMP - F	584		
- 90% TEMP - F	618	540	640
- 95% TEMP - F	648		
- END POINT - F	652		
RESIDUE - % VOL	1.0		
RECOVERY - % VOL	98.0		
LOSS - % VOL	1.0		

COMMENTS:

UNABLE TO DETERMINE AGE OF SAMPLE

REPORTED BY
ANALYSTS, INC.



BROWN AND CALDWELL LABORATORIES

1255 POWELL STREET EMERYVILLE, CA 94608 • (415) 428-2300

ANALYTICAL REPORT

LOG NO: E88-09-086

Received: 06 SEP 88

Reported: 12 SEP 88

SEP 15 1988

Mr. Ronald Madero
Berkeley Farms
4550 San Pablo Ave
Emeryville Ca. 94608

REPORT OF ANALYTICAL RESULTS

Page 1

LOG NO	SAMPLE DESCRIPTION, AQUEOUS SAMPLES				DATE SAMPLED
09-086-1	First Out of Tap				02 SEP 88
09-086-2	Second Out of Tap				02 SEP 88
09-086-3	Third Out of Tap				02 SEP 88
09-086-4	Fourth Out of Tap				02 SEP 88
PARAMETER	09-086-1	09-086-2	09-086-3	09-086-4	
Total Fuel Hydrocarbons					
Date Analyzed	09.08.88	09.08.88	09.08.88	09.08.88	
Total Fuel Hydrocarbons, mg/L	<1.0	<1.0	<1.0	<1.0	
Other Total Fuel Hydrocarbons	---	---	---	---	

Stacy J. Ficklin for
Sim D. Lessley, Ph.D., Laboratory Director