

ALAMEDA COUNTY
HEALTH CARE SERVICES



AGENCY

DAVID J. KEARS, Agency Director

August 26, 2003

RO 2555

Mr. Dan Koch
Olympian Oil
260 Michelle Court
So. San Francisco, CA 94080

ENVIRONMENTAL HEALTH SERVICES

ENVIRONMENTAL PROTECTION
1131 Harbor Bay Parkway, Suite 250
Alameda, CA 94502-6577
(510) 567-6700
FAX (510) 337-9335

RE: Olympian CFS, 2005 W. Winton Avenue, Hayward – Interim Free Product Remediation Work Plan

Dear Mr. Koch:

The August 13, 2003 TEC Accutite proposal for interim free-phase product (FP) removal has been reviewed to determine whether the proposed scope satisfies the continued requirement to remove FP to the extent practicable. The current scope proposes the use of a 4" GNE active skimmer to remove FP from the tank pit via a 12" extraction well, with extracted product routed to a 4000-gallon aboveground holding tank via belowground, secondarily contained PVC piping previously emplaced at the site during recent station upgrade construction. This proposed interim measure follows initial FP removal employing a vacuum truck that was successful at recovering a reported 1300 gallons of FP to date. However, the efficiency of this recovery method has reportedly diminished, hence the current proposal for use of an active skimmer and associated appurtenances.

The scope of the current proposal has been accepted.

Please be aware, however, that the City of Hayward Fire Department (HFD) may require additional permit, containment, signage, and other measures in order to construct and operate this interim FP recovery system. Please contact HFD's Mr. Danilo Galang at (510) 583-4925 for these additional requirements.

Please call me at (510) 567-6783 should you have any questions.

Sincerely,



Scott O. Seery, RG, CHMM
Hazardous Materials Specialist

cc: Betty Graham, RWQCB
Shari Knieriem, SWRCB UST Fund
Danilo Galang, Hayward Fire Dept., 777 B St., Hayward, CA 94541-5007
David Gregory, TEC Accutite, 35 So. Linden Ave., So. S.F., CA 94080-6407