

STID 798
Emergency 1500 Park Ave. Emeryville, 94608

my sister Mrs. Nestor (415) 896-6100
180 Bush St 26th Floor
SF 94104

2/10/98

Rec'd call from Susan Gunfish (PTSC) 540-3896
re: complaint leaking tank hauled at
Erickson on 12/31/97 while she was conducting
an inspection - The tank was removed on 1/22/98
per my inspection report. Why it arrived on
12/31/97?

Talked to Susan Gunfish - she faxed me copy of
her inspection/complaint report & copy of
manifest for UST.

Key Waste Hauler - regulated by state
Transportation unit (916) 324-2430
(510) 783-2881 Ed Nieto

Trident (Hayward) duty officer
info =

can they still waste hauled at their site - how long?
Julio Katter (916) 324-1818

Erickson - 255 PARK Blvd. Richmond CA 94801
Dave Sato (510) 235-1393

TRUMPP ROB. INC. (408) 292-0820
1540 Industrial Ave
San Jose CA 95122

2/11/98

Talked to Gary Thompson - he contracted
with Erickson for disposal / hauler for
UST.

Dave Sato ->
info on Trident

Talked to Ed Nieto -> (916) 324-2430
-> duty officer

Emergency
transport
8 days

2/11/98

Talked to ~~Bob [redacted]~~ Junk Lines
Manager = ~~[redacted]~~

~~(S) 782 2000~~ ~~Hayward~~ ~~Outlet~~ TSTID 2228

23000-23474
Clamier
L. [redacted]

He said that they are allowed to keep
the USTs at their yard for 10 days?

- = Was the tank monitored during storage @ their yard
- = tank was leaking - any secondary containment

2/11/98

Talked to ~~[redacted]~~ @ Hayward Fire Dept.
- they don't have any jurisdiction - work reported
Hayward but they filed complaints (same case)
for storing removed tanks at their facility
- he said he will send me info in their file.

Talked to Scott Selby = talked to

~~[redacted] (DTSC) - 546-3800~~
~~K [redacted] (DTSC) - 546-3824~~

2/11/98

Call for ~~[redacted]~~ Hayward Fire Dept
~~[redacted]~~ -> referred to Alameda Co. Fire

2/11/98

1:26 PM ~~[redacted]~~ (DTSC) ~~[redacted]~~
re: Incident

- Complaint (to) Patti Barni - Berkeley

2/11/98

Talked to ~~[redacted]~~ Alameda Co. Fire

~~[redacted]~~ ->
Fire Code violation - } need permit to store
Maybe zoning variance - } tanks
C/F / Alameda county fire

- Talked to Arica
- need to consult w/ P.A. Larry Blager

2/17/98

Met Julio Buitan Title 22

Talked to Julio Buitan
 - App 6/30/98 license
 ↳ H.P. →

- Transfer facility ^{for residential}
 ↳ can 144 hrs only if not permitted
 ↳ industrial

→ Amelia Rodriguez (916) 322-5308
 ↳ info

Talked to Amelia Rodriguez (916) 322-5308
 permit →

Assumption: transporter Title 22:

⇒ no open containers

⇒ industrial zone -10 hrs

⇒ permitted ⇒
 ↳