

## Drogos, Donna, Env. Health

---

**Subject:** RO2745 - 1601 Webster, Ala  
**Entry Type:** Phone call

**Start:** Mon 8/23/2004 2:00 PM  
**End:** Mon 8/23/2004 2:00 PM  
**Duration:** 0 hours

8/23/04, 152p, 559-645-9306, Karen Petryna, 1601 webster in Alameda, upgrade work at station on wed, ruptured UST w/turban too long, OES report made, URF in today, UST backfill well, dewater UST pit on thur realized he was pumping out FR, recovered 915 gal immed, loss of 2100 gal, , new CW?  
--> 1601 Webster, Alameda, Need to open new case

UST  
EVR upgrades, enhanced vapor recovery, connecting sumps to USTs,  
Cambria 75%, Delta, Toxicchem