

UNDERGROUND STORAGE TANK UNAUTHORIZED RELEASE (LEAK) / CONTAMINATION SITE REPORT			
EMERGENCY <input type="checkbox"/> YES <input checked="" type="checkbox"/> NO		HAS STATE OFFICE OF EMERGENCY SERVICES REPORT BEEN FILED? <input type="checkbox"/> YES <input checked="" type="checkbox"/> NO	
FOR LOCAL AGENCY USE ONLY I HEREBY CERTIFY THAT I HAVE DISTRIBUTED THE INFORMATION ACCORDING TO THE DISTRIBUTION SHOWN ON THE INSTRUCTION SHEET ON THE BACK PAGE OF THIS FORM			
REPORT DATE 08/12/04		CASE #	
REPORTED BY	NAME OF INDIVIDUAL FILING REPORT Karen Petryna		PHONE (559) 695-9306
	SIGNATURE <i>Karen Petryna</i>		
	REPRESENTING <input checked="" type="checkbox"/> OWNER/OPERATOR <input type="checkbox"/> REGIONAL BOARD <input type="checkbox"/> LOCAL AGENCY <input type="checkbox"/> OTHER		
COMPANY OR AGENCY NAME Shell Oil Products US			
ADDRESS 20945 S. Wilmington Avenue Carson CA 90810			
RESPONSIBLE PARTY	NAME Equilon Enterprises dba Shell Oil Products US <input type="checkbox"/> UNKNOWN		CONTACT PERSON Karen Petryna
	ADDRESS 20945 S. Wilmington Avenue Carson CA 90810		PHONE (559) 695-9306
SITE LOCATION	FACILITY NAME (IF APPLICABLE) Shell-branded Service Station		PHONE ()
	ADDRESS 1601 Webster Street Alameda CA 94501		
	CROSS STREET Lincoln Avenue		
IMPLEMENTING AGENCIES	LOCAL AGENCY AGENCY NAME Alameda County Health Agency		CONTACT PERSON Robert Weston
	REGIONAL BOARD San Francisco Bay		PHONE (510) 567-6781
	Regional Water Quality Control Board		Betty Graham PHONE (510) 622-2358
SUBSTANCES INVOLVED	(1) Gasoline Constituents		NAME TPH ₃ , Total xylenes
	(2)		QUANTITY LOST (GALLONS) <input checked="" type="checkbox"/> UNKNOWN <input type="checkbox"/> UNKNOWN
DISCOVERY/ABATEMENT	DATE DISCOVERED 08/11/04	HOW DISCOVERED <input type="checkbox"/> TANK TEST <input type="checkbox"/> INVENTORY CONTROL <input type="checkbox"/> TANK REMOVAL <input type="checkbox"/> SUBSURFACE MONITORING <input type="checkbox"/> MISPLACED CONDITIONS	<input checked="" type="checkbox"/> OTHER Analytical report - Reported soil sample results from status upgrade
	DATE DISCHARGE BEGAN u u d d v v v v	METHOD USED TO STOP DISCHARGE (CHECK ALL THAT APPLY)	<input type="checkbox"/> REMOVE CONTENTS <input type="checkbox"/> CLOSE TANK & REMOVE <input type="checkbox"/> REPAIR PIPING
	HAS DISCHARGE BEEN STOPPED? <input type="checkbox"/> YES <input type="checkbox"/> NO IF YES, DATE u u d d v v v v	<input checked="" type="checkbox"/> UNKNOWN	<input type="checkbox"/> REPAIR TANK <input type="checkbox"/> CLOSE TANK & FILL IN PLACE <input type="checkbox"/> CHANGE PROCEDURE
SOURCE/CAUSE	SOURCE OF DISCHARGE <input type="checkbox"/> TANK LEAK <input checked="" type="checkbox"/> UNKNOWN <input type="checkbox"/> PIPING LEAK <input type="checkbox"/> OTHER		CAUSE(S) <input type="checkbox"/> OVERFILL <input type="checkbox"/> RUPTURE/FAILURE <input type="checkbox"/> SPILL <input type="checkbox"/> CORROSION <input type="checkbox"/> UNKNOWN <input type="checkbox"/> OTHER
	CHECK ONE ONLY <input checked="" type="checkbox"/> UNDETERMINED <input type="checkbox"/> SOIL ONLY <input type="checkbox"/> GROUNDWATER <input type="checkbox"/> DRINKING WATER - (CHECK ONLY IF WATER WELLS HAVE ACTUALLY BEEN AFFECTED)		
CURRENT STATUS	CHECK ONE ONLY <input type="checkbox"/> NO ACTION TAKEN <input type="checkbox"/> PRELIMINARY SITE ASSESSMENT WORKPLAN SUBMITTED <input type="checkbox"/> POLLUTION CHARACTERIZATION		
	<input type="checkbox"/> LEAK BEING CONFIRMED <input type="checkbox"/> PRELIMINARY SITE ASSESSMENT UNDERWAY <input type="checkbox"/> POST CLEANUP MONITORING IN PROGRESS		
REMEDIAL ACTION	<input type="checkbox"/> REMEDIATION PLAN <input type="checkbox"/> CASE CLOSED (CLEANUP COMPLETED OR UNNECESSARY) <input type="checkbox"/> CLEANUP UNDERWAY		
	CHECK APPROPRIATE ACTION(S) <input type="checkbox"/> CAP SITE (CS) <input type="checkbox"/> EXCAVATE & DISPOSE (ED) <input type="checkbox"/> REMOVE FREE PRODUCT (FP) <input type="checkbox"/> ENHANCED BIO DEGRADATION (BT)		
COMMENTS	<input type="checkbox"/> CONTAINMENT BARRIER (CB) <input type="checkbox"/> EXCAVATE & TREAT (ET) <input type="checkbox"/> PUMP & TREAT GROUNDWATER (GT) <input type="checkbox"/> REPLACE SUPPLY (RS)		
	<input type="checkbox"/> VACUUM EXTRACT (VE) <input type="checkbox"/> NO ACTION REQUIRED (NA) <input type="checkbox"/> TREATMENT AT HOOKUP (HU) <input type="checkbox"/> VENT SOIL (VS) <input type="checkbox"/> OTHER (OT)		
Soil samples collected on 8/10/04 during fuel system upgrades. Laboratory analytical report dated 8/11/04 reported highest concentrations of 1,300 ppm TPH ₃ , 49 ppm total xylenes. There were no other analytes detected above laboratory's reporting limits.			