

ALAMEDA COUNTY
HEALTH CARE SERVICES

AGENCY

DAVID J. KEARS, Agency Director



CB-08-01

202760

March 6, 2001

ENVIRONMENTAL HEALTH SERVICES
ENVIRONMENTAL PROTECTION
1131 Harbor Bay Parkway, Suite 250
Alameda, CA 94502-6577
(510) 567-6700
FAX (510) 337-9335

Mr. Rod Freitag, PE
County of Alameda
General Services Agency
Technical Services Drive
1401 Lakeside Drive
Oakland, CA 94612

RE: Parcel 16A-Santa Rita Property, Hacienda Dr. & Dublin Blvd, Dublin, CA

Dear Mr. Freitag:

I have reviewed the Soil Sampling During Diesel UST Removal at Parcel 16A Santa Rita Property Report dated January 3, 2001 that was prepared by Gettler-Ryan Inc. Two confirmatory soil samples were taken during the UST removal on December 8, 2000 that contained 720 ppm and 1.5 ppm of TPH(diesel) and were non-detect for BTEX and MTBE. The concrete pad that the UST rested on located approximately 8 feet below ground surface was removed on December 21 & 22, 2000. This work was performed without the knowledge of this office. No soil samples were collected underneath the concrete pad after it was removed.

With the information that is currently available to this office, no further action is required at this time. In the future, if information becomes available to this office that the levels of contamination left in place poses a threat to the public health and environment, your Agency maybe require to perform a subsurface investigation.

If you have any questions, please contact me at (510) 567-6774.

Sincerely,


Larry Seto
Sr. Hazardous Materials Specialist

Cc: Ariu Levi, Chief Hazardous Materials, Alameda County Environmental Health
Susan Hugo, Acting Supervisor-Hazardous Materials, Alameda County
Environmental Health
Chuck Headlee, San Francisco Bay Region, RWQCB
Files