



ALAMEDA COUNTY FLOOD CONTROL AND WATER CONSERVATION DISTRICT

5897 PARKSIDE DRIVE PLEASANTON, CALIFORNIA 94686-5127 PHONE (510) 484-2600 FAX (510) 462-3914

TELEFAX TRANSMITTAL

DATE: 12 May 97

DELIVER TO: Frank Goldman

NAME OF FIRM: Deodor

FAX NUMBER: (707) 523-0852

FROM: Hayman Hong

NUMBER OF PAGES: 2
(Including transmittal)

FOR VOICE CONTACT CALL: (510) 484-2600
FOR RETURN FAX: (510) 462-3914

REMARKS: Drilling permit 97296 for a contamination
investigation at 1899 Denison St in Oakland
for Steam Valve Machine

SENT BY: DATE 12-31 1997 14:40

5-12-97 ; 4:08PM ; ZONE 7 WATER AGENCY WELL

KINKOS SANTA ROSA FAX NO. 510+462+3914

510 337 9335:# 2/ 3 P. 02

SENT BY: DATE 12-31 1997 10:35

5-12-97 ; 1:52PM ; ZONE 7 WATER AGENCY WELL

KINKOS SANTA ROSA FAX NO. 510+462+3914

510 462 3914:# 2/ 2 P. 02



ZONE 7 WATER AGENCY

8997 PARKSIDE DRIVE, PLEASANTON, CALIFORNIA 94588-8127 PHONE (510) 464-2800 X236 FAX (510) 462-3914

Attention: Wyman Hong

DRILLING PERMIT APPLICATION

FOR APPLICANT TO COMPLETE

FOR OFFICE USE

LOCATION OF PROJECT 1899 Dennis Street
Oakland CA 94611
@ former Cuyler Post Yard

PERMIT NUMBER 97296
WELL NUMBER _____
APN _____

California Coordinate Source _____ ft. Accuracy ± _____ ft.
CCM _____ ft. SCE _____ ft.
APN _____

PERMIT CONDITIONS

Circled Permit Requirements Apply

CLIENT Name Steve Cowley / Steam Valve Machine
Address 98 Heintzenberg Loop Phone 625-9091
City Oakland, CA Zip 94602
FAX: (510) 635-2227

- A. GENERAL
 - 1. A permit application should be submitted so as to arrive at the Zone 7 office five days prior to proposed starting date.
 - 2. Submit to Zone 7 within 60 days after completion of permit work the original Department of Water Resources Water Well Drillers Report or equivalent for well projects, or drilling log and location sketch for geotechnical projects.
 - 3. Permit is void if project not begun within 60 days of approval date.
- B. WATER SUPPLY WELLS
 - 1. Minimum surface seal thickness is two inches of cement grout placed by tremie.
 - 2. Minimum seal depth is 50 feet for municipal and industrial wells or 20 feet for domestic and irrigation wells unless lesser depth is specially approved.
- C. GROUNDWATER MONITORING WELLS INCLUDING PIEZOMETERS
 - 1. Minimum surface seal thickness is two inches of cement grout placed by tremie.
 - 2. Minimum seal depth for monitoring wells is the maximum depth practicable or 20 feet.
- D. GEOTECHNICAL Backfill bore hole with compacted cuttings heavy bentonite and upper two feet with compacted material, area of known or suspected contamination, tremie cement grout shall be used in place of compacted cuttings.
- E. CATHODIC. Fill hole above anode zone with concrete placed tremie.
- F. WELL DESTRUCTION. See attached.
- G. SPECIAL CONDITIONS

APPLICANT Name Frank Goldman, RG, ChG.
Cylo Solv, LLC Fax 707 996-7882
Address 434 Oregon St Phone 707 996-4227
City Sanoma, CA Zip 95476

TYPE OF PROJECT

Well Construction	Geotechnical Investigation
Cathodic Protection <input type="checkbox"/>	General <input type="checkbox"/>
Water Supply <input type="checkbox"/>	Contamination <input type="checkbox"/>
Monitoring (Borehole) <input checked="" type="checkbox"/>	Well Destruction <input type="checkbox"/>

PROPOSED WATER SUPPLY WELL USE

New Domestic <input type="checkbox"/>	Replacement Domestic <input type="checkbox"/>
Municipal <input type="checkbox"/>	Irrigation <input type="checkbox"/>
Industrial <input type="checkbox"/>	Other _____ <input type="checkbox"/>

DRILLING METHOD:

Mud Rotary <input type="checkbox"/>	Air Rotary <input type="checkbox"/>	Auger <input type="checkbox"/>
Cable <input type="checkbox"/>	Other <input checked="" type="checkbox"/>	Geoprobe <input type="checkbox"/>

DRILLER'S LICENSE NO. Vivonex
(510) 266-0966

WELL PROJECTS

Drill Hole Diameter _____ in.	Maximum _____
Casing Diameter _____ in.	Depth _____ ft.
Surface Seal Depth _____ ft.	Number _____

GEOTECHNICAL PROJECTS

Number of Boreholes <u>4</u>	Maximum _____
Hole Diameter <u>2</u> in.	Depth <u>15</u> ft.

ESTIMATED STARTING DATE 5/13/97 TUESDAY 10:00 AM
ESTIMATED COMPLETION DATE 5/12/97 2:00 PM

Approved: Wyman Hong Date 12 May 97

I hereby agree to comply with all requirements of this permit and Alameda County Ordinance No. 73-88.

APPLICANT'S SIGNATURE Frank Goldman Date 5/12/97