

ALAMEDA COUNTY
HEALTH CARE SERVICES

AGENCY
DAVID J. KEARS, Agency Director



PO2684

October 4, 2001

ENVIRONMENTAL HEALTH SERVICES
ENVIRONMENTAL PROTECTION
1131 Harbor Bay Parkway, Suite 250
Alameda, CA 94502-6577
(510) 567-6700
FAX (510) 337-9335

SR0000545

Mr. William Schwartz
Environmental Analyst
Lawrence Livermore National Laboratory
P.O. Box 808, L-627
7000 East Avenue
Livermore, California 94550

RE: Underground storage tank closure, 490-R3U1 and 490-R3U2

Dear Mr. Schwartz:

This office is in receipt of the August 24, 2001 staff report presenting documents associated with the June 26, 2001 closure of two - 180 gallon double wall stainless steel underground storage tanks (UST) at the subject site.

The subject USTs appear to have been closed in full compliance with provisions of Title 23, California Code of Regulations. Further, based upon information presented to this office, with the provision that such information is accurate and representative of site conditions, and in concert with observations made at the time of UST closure, no further action is required.

Please contact this office if you have any questions regarding this matter at (510) 567-6781.

Sincerely,

Robert Weston
Sr. Hazardous Materials Specialist

Cc: Susan Hugo, Manager, ACDEH

ALAMEDA COUNTY
HEALTH CARE SERVICES

AGENCY
DAVID J. KEARS, Agency Director



R02884

ENVIRONMENTAL HEALTH SERVICES
1131 Harbor Bay Parkway, Suite 250
Alameda, CA 94502-6577
(510) 567-6700
(510) 337-9335 (FAX)

May 13, 1998

ATTN: Sir Or Madam

Lawrence Livermore Natnl
P O Box 5001, L - 435
Livermore CA 94551

RE: Project # 2449A - Type R
at 7000 East Ave in Livermore 94550

Dear Property Owner/Designee:

Our records indicate the deposit/refund account for the above project has fallen below the minimum deposit amount. To replenish the account, please submit an additional deposit of \$344.00, payable to Alameda County, Environmental Health Services, within two weeks of receipt of this letter.

It is expected that the amount requested will allow the project to be completed with a zero balance. Otherwise, more money will be requested or any unused monies will be refunded to you or your designee.

The deposit refund mechanism is authorized in Section 6.92.040L of the Alameda County Ordinance Code. Work on this project will be debited at the Ordinance specified rate, currently \$94 per hour.

Please be sure to write the following identifying information on your check:

- project #
- type of project and
- site address

(see RE: line above).

If you have any questions, please contact Amir Gholami at (510) 567-6876.

Sincerely,

Tom Peacock, Manager
Environmental Protection

c: files

ALAMEDA COUNTY
HEALTH CARE SERVICES

AGENCY
DAVID J. KEARS, Agency Director



R02884

ENVIRONMENTAL HEALTH SERVICES
1131 Harbor Bay Parkway, Suite 250
Alameda, CA 94502-6577
(510) 567-6700
(510) 337-9335 (FAX)

May 12, 1998

ATTN: Sir Or Madam

Lawrence Livermore N. L.
7000 East Ave.
Livermore CA 94550

RE: Project # 1817A - Type R
at 7000 East Ave in Livermore 94550

Dear Property Owner/Designee:

Our records indicate the deposit/refund account for the above project has fallen below the minimum deposit amount. To replenish the account, please submit an additional deposit of \$445.75, payable to Alameda County, Environmental Health Services, within two weeks of receipt of this letter.

It is expected that the amount requested will allow the project to be completed with a zero balance. Otherwise, more money will be requested or any unused monies will be refunded to you or your designee.

The deposit refund mechanism is authorized in Section 6.92.040L of the Alameda County Ordinance Code. Work on this project will be debited at the Ordinance specified rate, currently \$94 per hour.

Please be sure to write the following identifying information on your check:

- project #
- type of project and
- site address

(see RE: line above).

If you have any questions, please contact Amir Gholami at (510) 567-6876.

Sincerely,

Tom Peacock, Manager
Environmental Protection

c: files

ALAMEDA COUNTY
HEALTH CARE SERVICES



AGENCY
DAVID J. KEARS, Agency Director

RO#2884

June 4, 1997

ENVIRONMENTAL HEALTH SERVICES

1131 Harbor Bay Parkway, Suite 250
Alameda, CA 94502-6577
(510) 567-6700
(510) 337-9335 (FAX)

STID 2306 6472

Mr. Bill Hoppes
Lawrence Livermore National Laboratory
P.O. Box 808, L-627
Livermore, CA 94550

RE: LLNL Subsite 511-D1U1, 7000 East Avenue, Livermore

Dear Mr. Hoppes:

This letter transmits the enclosed underground storage tank (UST) case closure letter in accordance with Chapter 6.75 (Article 4, Section 25299.37[h]) of the California Health and Safety Code. The State Water Resources Control Board (SWRCB) has required since March 1, 1997 that this agency use this case closure letter for all UST leak sites. We are also transmitting to you the enclosed case closure summary. These documents confirm the completion of the investigation and cleanup of the reported release at this site.

SITE INVESTIGATION AND CLEANUP SUMMARY

Please be advised that the following conditions exist at the site:

- o Up to 2300 parts per million (ppm) Total Petroleum Hydrocarbons as Diesel and 0.00073 ppm benzene, among other constituents, remain in native soil beneath the former UST at a depth of 20.5 - 20.8 feet below current grade.

If you have any questions, please contact the undersigned at (510) 567-6783.

Sincerely,


Scott O. Seery, CHMM
Senior Hazardous Materials Specialist

Enclosures:

1. Case Closure Letter
2. Case Closure Summary

cc: Robert Weston, ACDEH Environmental Protection Division