

1132 Beecher, SL

Phone call from Mr. Fiore

12/5/90, am

- ① Asked if OK to fill hole.
- ② Told him water sample was high (Benzene & TPH) and that if they filled hole we would add for g-water well & I'd be sampling.
- ③ He agreed to resample water in pit. Will call me so I can observe. W Faulhaber

November 26, 1990

Alameda County Health Dept.  
80 Swan Way Room 200  
Oakland, Ca. 94621

Attention: Bill Faulhaber

Re: Gas Tank Removal, 1132 Beecher Street, San Leandro

Dear Mr. Faulhaber:

As we discussed, I am sending you the test results regarding a gas tank that we removed at 1132 Beecher Street, San Leandro. We are anxious to complete the project and would appreciate your analysis on the test results. Thank you for your cooperation.

Sincerely,

Linda Marcheschi  
Linda Marcheschi

Fowell  
says  
go for  
closure

1132 Beecher, SL

F.M. CONSTRUCTION COMPANY

1118 SAN ANTONIO AVE

ALAMEDA, CA. 94501

(415) 523-6712

FAX: 523-4582

NOV 28 AM 11:44

November 26, 1990

Alameda County Health Dept.  
80 Swan Way Room 200  
Oakland, Ca. 94621

Attention: Bill Faulhaber

Re: Gas Tank Removal, 1132 Beecher Street, San Leandro

Dear Mr. Faulhaber:

As we discussed, I am sending you the test results regarding a gas tank that we removed at 1132 Beecher Street, San Leandro. We are anxious to complete the project and would appreciate your analysis on the test results. Thank you for your cooperation.

Sincerely,

*Linda Marcheschi*  
Linda Marcheschi

*Fowl  
says  
go for  
closure*



LOG NO.: 9243  
 DATE SAMPLED: 10/29/90  
 DATE RECEIVED: 10/29/90  
 DATE EXTRACTED: 11/01/90  
 DATE ANALYZED: 11/06/90  
 DATE REPORTED: 11/07/90

CUSTOMER: S & M Construction  
 REQUESTER: Freore Marcheschi  
 PROJECT: 1132 Beecher Street, San Leandro, CA

Sample Type: Soil

Method and Constituent	Units	1: Fill End 2000 Gallon Gasoline Tank (Wall)		2: Vent End 2000 Gallon Gasoline Tank (Wall)	
		Concen- tration	Reporting Limit	Concen- tration	Reporting Limit
DHS Method:					
Total Petroleum Hydro- carbons as Gasoline	ug/kg	ND	500	ND	500
Benzene	ug/kg	ND	5	ND	5
Toluene	ug/kg	ND	5	ND	5
Xylenes	ug/kg	ND	20	ND	20
Ethylbenzene	ug/kg	ND	5	ND	5

Concentrations reported as ND were not detected at or above the reporting limit.



LOG NO.: 9243  
DATE SAMPLED: 10/29/90  
DATE RECEIVED: 10/29/90  
DATE ANALYZED: 11/01/90  
DATE REPORTED: 11/01/90  
PAGE: Two

Sample Type: Water

3: Water From North  
End 2000 Gallon  
Gasoline Tank

Method and  
Constituent

Units                      Concen-  
tration                      Reporting  
Limit

DHS Method:

Total Petroleum Hydro-  
carbons as Gasoline

ug/l                              270                              50

Benzene

ug/l                              1.2                              0.5

Toluene

ug/l                              3.2                              0.5


Xylenes

ug/l                              3.6                              2


Ethylbenzene


ug/l                              0.97                              0.5

Louis W. DuPuis  
Quality Assurance/Quality Control Manager



1132 Beecher Street  
Alameda, CA 94501





CHAIN OF CUSTODY RECORD

Proj.No.		Project Name		No. of Containers	<div style="border: 1px solid black; padding: 5px; transform: rotate(-45deg); display: inline-block;">                 TPH+G/BTEX             </div>				9243	REMARKS
Samplers (signature)		1132 Beecher Street / San Leandro, CA								
L. Sean Norvian for TAL										
Sample ID	Date	Time	Site Location							
1	10/29/90	2:00PM	Fill End, 2,000 Gallon Gasoline Tank (Wall)	1 BT.	X				Depth At Water Level 6 1/2'	
2		2:05PM	Fill End, 2,000 Gallon Gasoline Tank (Wall)	1 BT	X				At Water Level 6 1/2'	
3		1:50PM	Water from North End 2,000 Gallon Gasoline Tank	2 pres VOAs	X				Water Level 6 1/2'	
									Normal TAT	
									BT, soil => 4-8	
									WATER = 240 ml / White with HCL	
Relinquished by: (signature)			Date/Time	Received by: (signature)			Date/Time			
							GWS			
Relinquished by: (signature)			Date/Time	Received by: (signature)			Date/Time			
Received for Laboratory by: (signature)							Date/Time			
REMARKS										
Call to confirm TAT <i>[Signature]</i>										