



RECEIVED

1:33 pm, Jul 23, 2010

Alameda County
Environmental Health

WALKER'S HYDRAULICS

250 KEATS CIRCLE / PLEASANT HILL, CA 94523 / 935-5518

July 3, 1985

Mr. Ken Beesen
Shattuck Import Service
6562 Shattuck Ave.
Oakland, Ca. 94609

Re: Removal of gasoline storage tanks.

Dear Mr. Beesen,

The following is a list of procedures we followed on removal of your gasoline storage tank as requested by the City of Oakland Fire Dept.:

- 1.. Notified city Fire Marshall and obtained permit.
2. At the time of excavation , we found several holes in the gasoline product lines allowing product to go into backfill area. We notified Mr. Gordon Gullett of Oakland Fire Dept and Mr. Dale Bowyer of the Regional Water Resources Board. They asked that soil samples be taken.
3. Tanks were removed and disposed of. Soil samples (see attached sampling sketch) were taken (see lab report).
4. During the 2 week wait for the lab report, we spread the excavated backfill around the lot to evaporate and dry. The soil was stirred every other day and spread at a depth of 12-16 in.
5. Lab report showed a max. of 42 P.P.M.
6. Upon receiving lab report, I contacted Mr. Peter Johnson of the Regional Water Board. He said that the above measures were adequate and to go ahead and fill the excavated site and pour a slab.

Thank you for your patience with us on this project.

Sincerely,

Raymond E. Walker