

ALAMEDA COUNTY  
HEALTH CARE SERVICES

AGENCY  
DAVID J. KEARS, Agency Director



December 31, 1990

Liddell Iron Craft  
Mr. Wingham Liddell  
1000 90th Ave.  
Oakland, CA 94603

DEPARTMENT OF ENVIRONMENTAL HEALTH  
Hazardous Materials Program  
80 Swan Way, Rm. 200  
Oakland, CA 94621  
(415)

Re: Underground Tank Removal at Lidell Iron Craft, 1000 90th Ave.  
Oakland CA, 94603

Dear Mr. Liddell:

Thank you for the submission of documents regarding the underground tank removal from the above referenced property. Alameda County Environmental Health, Hazardous Materials Division is in receipt of:

1. The certificate of tank disposal from H and H.
2. A copy of the Uniform Hazardous Waste Manifest from H and H.
3. A site map depicting the location of soil samplings.
4. The chain-of-custody form for the soil samples taken to TAL laboratory.
5. A copy of the analytical results from the two soil samples taken from the north and south sides of the pit floor.

Although the Total Petroleum Hydrocarbons as gasoline is 6.5 and 32 mg/kg for the north and south soil samples, detectable amounts of BTEX (Benzene, Toluene, Ethylbenzene and Xylenes) were found in both samples. The site may still be eligible for a "Case #2" closure ie No Further Action Required, but before we can make this determination you must provide the county with the information on the attachment. This attachment is from the Tri-Regional Board Staff Recommendations for Preliminary Evaluation and Investigation of Underground Tank Sites, 10 August 1990 version. Please provide this information so that we may proceed in reviewing your case.

Please contact the undersigned at 271-4320 if you have any questions regarding this letter.

Sincerely,

Barney M. Chan  
Hazardous Materials Specialist

enclosure

cc: Gil Jensen, Alameda County District Attorney Office,  
Consumer and Environmental Protection Div.  
Lester Feldman, RWQCB  
Edgar Howell, Chief Hazardous Materials Division

OR