

Detterman, Mark, Env. Health

From: dave@eras.biz
Sent: Thursday, September 15, 2016 9:12 AM
To: ahamersley@icsinc.tv
Cc: Clinton Stockton (clinton@johnmurray.com); Detterman, Mark, Env. Health; greg@eras.biz
Subject: FW: Footing along building
Attachments: IMG_20160914_152717736.jpg; IMG_20160914_152729141.jpg

Hi Ashley, I just talked to JR about the plan. We agreed that due to the location of a former building foundation found along the existing building side of the VMS trench, we will modify the trench design to be approximately 20" wide (not 36 inches) and 4 feet deep (not 3 feet).

We feel the trench operations will remove the contamination found along the base of the existing building and will still provide sufficient material to provide a barrier for vapors that will be vented.

Please contact me if you have any questions. Note I have copied the Client and Mark Detterman at Alameda County on this matter.

David Siegel
Senior Program Manager
ERAS Environmental, Inc.
1533 B Street
Hayward, CA 94546
(510) 247-9885 x 304
www.eras.biz

From: Ashley Hamersley [<mailto:ahamersley@icsinc.tv>]
Sent: Wednesday, September 14, 2016 4:00 PM
To: dave@eras.biz
Cc: JR Deperalta <jrdeperalta@icsinc.tv>
Subject: FW: Footing along building

Dave please see the attached pictures.
JR will call to discuss.
Thank you,

Ashley Hamersley
Project Coordinator

Innovative Construction Solutions
6639 Sierra Lane, Suite A, Dublin CA 94568
T: 925.574.2600 | F: 925.574.2601 | www.icsinc.tv
D: 925.574.2610 | C: 925.727.2849 | ahamersley@icsinc.tv

Stay in touch with us on [LinkedIn!](#)



*Technical Expertise,
Practical Experience*

From: JR Deperalta
Sent: Wednesday, September 14, 2016 3:51 PM
To: Ashley Hamersley <ahamersley@icsinc.tv>
Subject: Footing along building

Thanks,

JR Deperalta
Superintendent

Innovative Construction Solutions
6693 Sierra Lane, Suite A, Dublin, CA 94568

T: 925.574.2600 F: 925.574.2601

C: 925.557.5972

www.icsinc.tv

jrdeperalta@icsinc.tv



