


CITY OF OAKLAND



250 FRANK H. OGAWA PLAZA, SUITE 3341 • OAKLAND, CALIFORNIA 94612-2032

Fire Prevention Bureau

September 16, 2014

(510) 238-3851  
TDD (510) 238-6884

Mr. Bob Hung  
Hung Revocable Trust  
P.O. Box 616  
Berkeley, CA 94701

RE: Underground Storage Tank Referral

2823 Adeline Street  
Oakland, California

Mr. Hung::

This letter confirms the closure in place of one underground storage tanks (UST) at subject site. The UST was of single walled steel construction, previously contained gasoline and had a capacity of 1,000-gallon. Advanced Fuel Services performed and completed the UST closure in place and International Geologic LLC provided a report on this project.

The City Of Oakland Fire Department/Hazardous Material Management Program (OFD/HMMP) staff has reviewed the analytical results. Based on the available information, this site is considered contaminated and is being transferred to Alameda County Environmental Health for follow up. Attached is a copy of the transfer form.

Please note the following:

1. The final report should state the samples were analyzed for TPHg and not TVHg as indicated.
2. The City of Oakland Fire Department was not present for sampling of the down gradient ground water or soil sampling at the dispenser pad.

If you have any questions, please contact me at (510) 238-7253

Sincerely,

Sheryl Skillern,  
Senior Hazardous Materials Inspector

Cc: ~~Jerry Wickham, Alameda County Environmental Health~~  
Advanced Fuel Services  
Geologic LLC