


## UNDERGROUND STORAGE TANK (UST) SITE - UNAUTHORIZED RELEASE / CONTAMINATION REPORT

EMERGENCY <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No		HAS STATE OFFICE OF EMERGENCY SERVICES REPORT BEEN FILED? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No		<b>FOR LOCAL AGENCY USE ONLY</b>		
REPORT DATE 8-3-2017		CASE #		I HEREBY CERTIFY THAT I AM A DESIGNATED GOVERNMENT EMPLOYEE AND THAT I HAVE REPORTED THIS INFORMATION TO LOCAL OFFICIALS PURSUANT TO SECTION 25180.7 OF THE HEALTH AND SAFETY CODE.		
NAME OF INDIVIDUAL FILING REPORT Eric V. Montesano (Agent)		PHONE (510) 614-8390		SIGNATURE 		
REPORTED BY	REPRESENTING <input type="checkbox"/> LOCAL AGENCY <input type="checkbox"/> REGIONAL BOARD <input type="checkbox"/> OWNER/OPERATOR <input checked="" type="checkbox"/> OTHER <b>G.C. (Agent)</b>		COMPANY OR AGENCY NAME Armer/Norman and Associates			
	ADDRESS 2600 Williams Street STREET San Leandro CITY CA STATE 94577 ZIP					
RESPONSIBLE PARTY	NAME AK Services Inc. <input type="checkbox"/> Unknown		CONTACT PERSON Amin Sardar		PHONE (510) 386-3684	
	ADDRESS 821 Corporate Way STREET Fremont CITY CA STATE 94539 ZIP					
SITE LOCATION	FACILITY NAME (IF APPLICABLE) Chevron Gas Station		OPERATOR Amin Sardar		PHONE (510) 368-3684	
	ADDRESS 4707 First Street STREET Livermore CITY Alameda COUNTY 94551 ZIP					
	CROSS STREET Southfront Road					
IMPLEMENTING AGENCIES	LOCAL AGENCY AGENCY NAME Livermore-Pleasanton Fire Dept., Alameda County Environmental Health (LOP) <b>(CUPA)</b>				PHONE (925) 454-2362	
	REGIONAL BOARD State Water Resources Control Board				PHONE ( )	
SUBSTANCES INVOLVED	(1) NAME 7-20-17 Soil Sampling TPH-d P3 d3' 1800 ppm		QUANTITY LOST (GALLONS) <input checked="" type="checkbox"/> Unknown			
	(2) NAME 7-20-17 Soil Sampling TPH-g P3 d3' 950 ppm		<input checked="" type="checkbox"/> Unknown			
DISCOVERY/ABATEMENT	DATE DISCOVERED 7-20-17		HOW DISCOVERED <input type="checkbox"/> Soil Sample <input checked="" type="checkbox"/> Pipe Removal <input type="checkbox"/> Nuisance Conditions <input type="checkbox"/> Inventory Control <input type="checkbox"/> Subsurface Monitoring <input type="checkbox"/> Other			
	DATE DISCHARGE BEGAN <input checked="" type="checkbox"/> Unknown		METHOD USED TO STOP DISCHARGE (CHECK ALL THAT APPLY) <input checked="" type="checkbox"/> Remove Contents <input checked="" type="checkbox"/> Close Tank Pipe <input type="checkbox"/> Repair Tank <input type="checkbox"/> Change Procedure <input type="checkbox"/> Replace Tank <input checked="" type="checkbox"/> Other <input checked="" type="checkbox"/> unknown <input type="checkbox"/> Repair Piping			
	HAS DISCHARGE BEEN STOPPED? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No IF YES, DATE <input checked="" type="checkbox"/> Unknown					
SOURCE/ CAUSE	SOURCE OF DISCHARGE <input type="checkbox"/> Tank <input type="checkbox"/> Piping <input type="checkbox"/> Dispenser <input type="checkbox"/> Delivery Problem <input type="checkbox"/> Submersible Turbine Pump (STP) <input checked="" type="checkbox"/> Other - Unknown		CAUSE(S) <input type="checkbox"/> Spill <input type="checkbox"/> Overfill <input type="checkbox"/> Physical/Mechanical Damage <input type="checkbox"/> Corrosion <input type="checkbox"/> Installation Problem <input checked="" type="checkbox"/> Unknown <input type="checkbox"/> Other			
	CHECK ONE ONLY <input type="checkbox"/> Undetermined <input checked="" type="checkbox"/> Soil Only <input type="checkbox"/> Groundwater <input type="checkbox"/> Drinking Water – (CHECK ONLY IF WATER WELLS HAVE ACTUALLY BEEN AFFECTED)					
CURRENT STATUS	CHECK ONE ONLY <input checked="" type="checkbox"/> Open - Site Assessment <input type="checkbox"/> Open - Verification Monitoring <input type="checkbox"/> Open - Assessment & Interim Remedial Action <input type="checkbox"/> Open - Inactive <input type="checkbox"/> Open - Remediation <input type="checkbox"/> Closed – No Further Action Required					
	CHECK APPROPRIATE ACTION(S) Human health exposure control? <input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> Unknown Groundwater migration control? <input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> Unknown <input type="checkbox"/> No Action Required (NAR) <input type="checkbox"/> Excavate & Treat (ET) <input type="checkbox"/> Treatment at Hookup (TH) <input type="checkbox"/> Other <input type="checkbox"/> Excavate & Dispose (ED) <input type="checkbox"/> Free Product Removal (FPR) <input type="checkbox"/> Replace Supply (RS)					
COMMENTS	Based on onsite observations and with Isaac Mendel of Livermore Pleasanton fire witnessing, it appeared that the majority of the hydrocarbon impacted soil has been removed. From the construction management point of view, we would hope that at this point we could get approval to backfill this excavation with clean import (the excavated soil from this area will be profiled and disposed of offsite). Per GeoLogic Joel Greger C.E.G.					